


NOTES:

1. 3" COMPOUND METER (SUPPLIED BY CITY).
2. 3" FLG. D.I. SPOOL PIECE.
3. 3" DISMANTLING JOINT W/MECHANICAL RESTRAINT.
4. 3" FLG. RESILIENT SEATED GATE VALVE W/HANDWHEEL.
5. 3" FLG TEE & 3" BLIND FLANGE W/2" THREADED TAP (IP THREAD).
6. 2" BRASS ELBOW.
7. 2" BRASS PIPE
8. 2" BRASS F.I.P. X F.I.P. COUPLING AND 2" BRASS M.I.P. X 110 COMP. STRAIGHT COUPLING. MUELLER H-15428 OR FORD C847-Q.
9. 2" THREADED GATE VALVE W/HANDWHEEL. (IP THREAD).
10. 3 COATED "STAND-ON" PIPE SUPPORTS. SEE DETAIL NO. WT-3095.
11. OLD CASTLE 577LA (577-B BASE, 57-T-2-332P TOP, 352P FRAME AND DOOR). USE 352NS (NON-SLIP FINISH) FRAME AND DOOR IN AREAS WITH PEDESTRIAN OR BIKE FACILITIES.
12. 2" X 6" BRASS NIPPLE.
13. INSTALL STANDARD COMPOUND METER ASSEMBLY IN ACCORDANCE WITH DETAIL WT-3115.

3" Compound Meter			CITY OF WILSONVILLE  PUBLIC WORKS STANDARDS
DRAWING NUMBER: WT-3105	DRAWN BY: SR	SCALE: N.T.S.	
FILE NAME: WT-3105.DWG	APPROVED BY: NK	DATE: 6/4/14	