

ORDINANCE NO. 815

AN ORDINANCE OF THE CITY OF WILSONVILLE ADOPTING THE 2017 WATER TREATMENT PLANT MASTER PLAN UPDATE AS A SUB-ELEMENT OF THE CITY'S COMPREHENSIVE PLAN AND THE CAPITAL IMPROVEMENT PROJECT LIST FOR THE WATER TREATMENT PLANT.

WHEREAS, ORS 197.175 requires cities to prepare, adopt, and implement Comprehensive Plans consistent with statewide planning goals adopted by the Land Conservation and Development Commission; and

WHEREAS, ORS 197.712(2)(c) requires cities to develop and adopt a public facilities plan for areas with the Urban Growth Boundary containing a population greater than 2,500 people, including rough cost estimates for projects needed to provide sewer, water, and transportation uses contemplated in the Comprehensive Plan and Land Use Regulations; and

WHEREAS, the 2017 Water Treatment Plan Master Plan Update (2017 MPU) is needed to account for growth and plan for future development; and

WHEREAS, the newly formed Willamette Intake Facilities Commission will begin sharing Wilsonville's Willamette River Treatment Plant intake facility, once expansion of that intake facility is permitted and completed; and

WHEREAS, the 2017 MPU documents:

- Existing and future water demand, and the expected future Level of Service;
- Existing treatment technologies and associated operational performance in terms of water quality and regulatory compliance;
- The condition and reliability of the existing plant infrastructure with particular focus on life safety deficiencies, surge protection and seismic resiliency;
- Recommended short-term and long-term capital improvement plan needed to ensure continued reliability of the treatment plant as the plant capacity increases from the current 15 million gallons per day (mgd) to 30 mgd in year 2035 and beyond; and

- The cost estimates and recommended schedules for the design and construction of the recommended capital improvements.

WHEREAS, the 2017 MPU was prepared with the following key objectives:

- Define the steps for expanding the existing treatment plant infrastructure to maximize the return on previous investments;
- Optimize process selection and layout to meet capacity and water quality goals at the expanded treatment plant;
- Strategize near-term and long-term plant expansion for a 20-year planning horizon and cash-flow to guide future financial planning; and
- Ensure that Willamette Water Supply-related facilities, including raw water pumping, surge protection, and standby power infrastructure, do not prevent the cities of Wilsonville and Sherwood from meeting their ultimate build-out demands for the existing treatment plant on the current site; and

WHEREAS, in preparing the 2017 MPU, the City has sought to carry out federal, state, and regional mandates, provide for alternative improvement solutions to minimize public and private expense, avoid the creation of nuisances, and maintain the public's health; and

WHEREAS, the City sponsored a website and conducted work sessions with the Planning Commission and City Council to solicit citizen input addressing Statewide Planning Goal #1 – Citizen Involvement; and

WHEREAS, following the timely mailing and publication of the required Ballot Measure 56 notice, the Wilsonville Planning Commission conducted a public hearing on February 14, 2018 and adopted Resolution LP18-1002 recommending approval of the 2017 MPU to the City Council; and

WHEREAS, after providing due public notice as required by City Code and Oregon Law, a public hearing was held before the City Council on April 16, 2019, at which time the City Council considered the recommendation of the Planning Commission, gathered additional evidence and afforded all interested parties an opportunity to present oral and written testimony concerning the 2017 MPU; and

WHEREAS, the City Council carefully considered the public record, including all recommendations and testimony.

NOW, THEREFORE, THE CITY OF WILSONVILLE ORDAINS AS FOLLOWS:

1. The above findings are adopted and incorporated herein, including the findings and conclusions of Planning Commission Resolution LP18-1002, its staff report and public record attached hereto as **Exhibit 1** and incorporated herein.
2. The City Council finds and concludes that the 2017 MPU is necessary to protect the public health, safety, and welfare of the City of Wilsonville to help ensure adequate water capacity and quality for the City's municipal water system.
3. The City Council hereby adopts the 2017 MPU, attached hereto as **Exhibit 2** and incorporated herein.
4. This Ordinance shall be declared to be in full force and effect thirty (30) days from the date of final passage and approval on second reading.


SUBMITTED to the Wilsonville City Council and read for the first time at a regular meeting thereof on the 16th day of April, 2018, and scheduled for a second reading at a regular meeting of the Council on the 7th day of May, 2018, commencing at the hour of 7:00 P.M. at the Wilsonville City Hall.



Kimberly Veliz, City Recorder

ENACTED by the City Council on the 7th day of May, 2018 by the following votes:

Yes: 4 No: 0



Kimberly Veliz, City Recorder

DATED and signed by the Mayor this 7th day of May, 2018.



SCOTT STARR, Council President

SUMMARY OF VOTES:

Mayor Knapp	Excused
Council President Starr	Yes
Councilor Stevens	Yes
Councilor Lehan	Yes
Councilor Akervall	Yes

Attachments:

1. Exhibit 1 – Planning Commission Resolution LP18-1002, staff report, and record – can be accessed at this link:
<https://www.ci.wilsonville.or.us/DocumentCenter/View/13114>
2. Exhibit 2 – Willamette River Water Treatment Master Plan Update 2017 – can be accessed at this link:
<https://files.carollo.com/message/AXBna1dOIFAJMZPP5ycIp6>

**PLANNING COMMISSION
RESOLUTION NO. LP18-0002**

A RESOLUTION OF THE PLANNING COMMISSION OF THE CITY OF WILSONVILLE RECOMMENDING THE CITY COUNCIL ADOPT THE WILLAMETTE RIVER WATER TREATMENT PLANT 2017 MASTER PLAN UPDATE RELATING TO IMPROVEMENTS, EXPANSION, AND OPERATION OF THE EXISTING WATER TREATMENT PLANT

WHEREAS, the Planning Commission of the City of Wilsonville (“City”) has the authority to review and make recommendations to the City Council regarding changes to, or adoption of new elements and sub-elements of, the Comprehensive Plan pursuant to Sections 2.322 and 4.032 of the Wilsonville Code (“WC”); and

WHEREAS, the Willamette River Water Treatment Plant 2017 Master Plan Update is a support document to the City’s Comprehensive Plan, and the Update to the Water Treatment Plant Master Plan is subject to the same rules and regulations as an update to the City’s Comprehensive Plan; and

WHEREAS, the Planning Director submitted a proposed Ordinance to the Planning Commission, along with a Staff Report, in accordance with the public hearing and notice procedures that are set forth in WC 4.008, 4.011, 4.012, and 4.198; and

WHEREAS, the Planning Commission conducted a work session on December 13, 2017, and after providing the required public notice, held a public hearing on February 14, 2018 to review the proposed Update to the Water Treatment Plant Master Plan and to gather additional testimony and evidence regarding the Update to the Water Treatment Plant Master Plan; and

WHEREAS, the Planning Commission has afforded all interested parties an opportunity to be heard on this subject and has entered all available evidence and testimony into the public record of its proceeding; and


WHEREAS, the Planning Commission has duly considered the subject, including the staff recommendations and all the exhibits and testimony introduced and offered by all interested parties; and

NOW, THEREFORE, BE IT RESOLVED that the Wilsonville Planning Commission does hereby adopt the Staff Report and its attachments (attached hereto as Exhibit A), as presented at the February 14, 2018 public hearing, including the findings and recommendations contained

therein, and further recommends the Wilsonville City Council approve and adopt the Update to the Water Treatment Plant Master Plan relating to the improvements, expansion, and operation of the existing Water Treatment Plant facility as hereby approved by the Planning Commission; and

BE IT FURTHER RESOLVED that this Resolution shall be effective upon adoption.

ADOPTED by the Wilsonville Planning Commission at a regular meeting thereof this 14th day of February, 2018, and filed with the Wilsonville City Recorder this date.


Wilsonville Planning Commission

ATTEST:


Tami Bergeron, Planning Administrative Assistant

SUMMARY OF VOTES:

- Commissioner Greenfield: y
- Commissioner Postma: y
- Commissioner Hurley: y
- Commissioner Mesbah: y
- Commissioner Millan: y
- Commissioner Springall: y
- Commissioner Heberlein: y

Attachments:

Exhibit A – Staff Report



NOTICE OF DECISION

PLANNING COMMISSION

RECOMMENDATION OF APPROVAL TO CITY COUNCIL

FILE NO.: LP18-0002

APPLICANT: City of Wilsonville

REQUEST: A RESOLUTION OF THE PLANNING COMMISSION OF THE CITY OF WILSONVILLE RECOMMENDING THE CITY COUNCIL ADOPT THE WILLAMETTE RIVER WATER TREATMENT PLANT 2017 MASTER PLAN UPDATE RELATING TO IMPROVEMENTS, EXPANSION, AND OPERATION OF THE EXISTING WATER TREATMENT PLANT

After conducting a public hearing on February 14, 2018, the Planning Commission voted to recommend this action to the City Council by unanimously passing Resolution No. LP18-0002.

The City Council is scheduled to conduct a Public Hearing on this matter on **March 5, 2018, at 7:00 p.m., at the Wilsonville City Hall, 29799 SW Town Center Loop East.**

For further information, please contact the Wilsonville Planning Division, 29799 SW Town Center Loop East, or telephone (503) 682-4960.

**PLANNING COMMISSION
WEDNESDAY, FEBRUARY 14, 2018
6:00 P.M.**

**Wilsonville City Hall
29799 SW Town Center Loop East
Wilsonville, Oregon**

MOTIONS

ADMINISTRATIVE MATTERS

- A. Welcome New Planning Commissioner Ron Heberlein
- B. Planning Commission Chair & Vice-Chair Nomination

Simon Springall nominated Jerry Greenfield as the 2018 Planning Commission Chair.
Peter Hurley nominated Eric Postma as the 2018 Chair.

Following a ballot vote, Jerry Greenfield was elected 2018 Planning Commission Chair.

Phyllis Millan nominated Eric Postma.
There were no other nominations.

Eric Postma was elected 2018 Planning Commission Vice-Chair.

C. Consideration of the January 10, 2018 Planning Commission Minutes
The January 10, 2018 Planning Commission minutes were accepted as presented.

II. LEGISLATIVE HEARING

- A. Water Treatment Plant Master Plan Update (Kraushaar)

Commissioner Postma moved to approve Resolution No. LP18-0002 with the following additions to the Willamette River Water Treatment Plant 2017 Master Plan Update:

- **Include key assumptions used to develop the Master Plan, which would include growth projections used to forecast demand**
- **Include discussion of net present value**
- **Include Some treatment of cost sharing and processes to determine an equitable distribution of the costs**

Commissioner Heberlein seconded the motion, which passed unanimously.

**PLANNING COMMISSION
WEDNESDAY, FEBRUARY 14, 2018
6:00 P.M.**

**Wilsonville City Hall
29799 SW Town Center Loop East
Wilsonville, Oregon**

*Minutes approved as
presented at the March
14, 2018 PC Meeting*

Minutes

I. CALL TO ORDER - ROLL CALL

Chair Jerry Greenfield called the meeting to order at 6:06 p.m. Those present:

Planning Commission: Jerry Greenfield, Eric Postma, Peter Hurley, Simon Springall, Phyllis Millan, Kamran Mesbah, and Ron Heberlein.

City Staff: Chris Neamtzu, Amanda Guile-Hinman, Andrew Sheehan and Nancy Kraushaar

PLEDGE OF ALLEGIANCE

The Pledge of Allegiance was recited.

CITIZEN'S INPUT - This is an opportunity for visitors to address the Planning Commission on items not on the agenda. There was none.

ADMINISTRATIVE MATTERS

A. Welcome New Planning Commissioner Ron Heberlein

Chris Neamtzu, Planning Director, introduced Ron Heberlein and provided a brief background of his career and volunteer experience, which included the Development Review Board (DRB) and Frog Pond Technical Advisory Committee.

Commissioner Heberlein said he had been interested in the Planning Commission since he began volunteering for the City. His time on the DRB gave him a feel for how things operate and this would be a great fit. He was an engineer for 15 years before becoming a program manager. He has two kids enrolled in Boeckman Creek and is building a plane in his garage.

B. Planning Commission Chair & Vice-Chair Nomination

Simon Springall nominated Jerry Greenfield as the 2018 Planning Commission Chair.

Peter Hurley nominated Eric Postma as the 2018 Chair.

Following a ballot vote, Jerry Greenfield was elected 2018 Planning Commission Chair.

Phyllis Millan nominated Eric Postma as the 2018 Planning Commission Vice-Chair.

There were no other nominations.

Eric Postma was elected 2018 Planning Commission Vice-Chair.

C. Consideration of the January 10, 2018 Planning Commission Minutes

The January 10, 2018 Planning Commission minutes were accepted as presented.

II. LEGISLATIVE HEARING

A. Water Treatment Plant Master Plan Update (Kraushaar)

Chair Greenfield read the legislative hearing procedure into the record and opened the public hearing at 6:13 pm.

Chris Neamtzu, Planning Director, noted the Planning Commission had a work session on the Water Treatment Plant Master Plan Update a couple of months ago, so much of tonight's PowerPoint would look familiar. The proposed update came out of a larger master plan created by the water supply partners. The City initially had pieces of that larger plan and former Project Manager Eric Mende decided it would make more sense to create a mini master plan for the water treatment plant site that focused on the City's facility, which was the document being presented to the Commission tonight. He noted that Nancy Kraushaar was now the Project Manager and Jude Grounds of Carollo Engineers was the primary author of the master plan.

Nancy Kraushaar, Community Development Director, noted prior Project Manager Eric Mende had taken a job in Eugene and was no longer with the City of Wilsonville, so she had taken over as Project Manager. Jude Grounds was an expert and a great consultant that knew the ins and outs of the Master Plan. The purpose of the Master Plan Update was to ensure the City was keeping up with growth and changes to treatment processes. When the plant was originally built, the City knew expansion would be necessary over time, and many seismic and safety repairs were also necessary. Carollo Engineers was hired to help the City examine the entire plant and develop the latest list of projects, timing, and growth projections for the plant, so the City could keep up with demand.

Ms. Kraushaar and Jude Grounds of Carollo Engineers, Inc. presented the 2017 Water Treatment Plant Master Plan Update via PowerPoint, paper copies of which were provided at the dais. The purposes of the update and how the Master Plan's improvements would be implemented were reviewed with these key comments:

- The treatment plant was built in 2002 in partnership with the Tualatin Valley Water District (TVWD). The partnership made the treatment plant possible and the City has always valued that partnership.
 - The plant was designed for 70 million gallons per day (MGD) and with very conservative level of service (LOS) goals and operations. The community had been using wells for water prior to the treatment plant and the City planned to use the Willamette River as its water source. Some communities believed the river was too contaminated to use, so the City wanted to deliver the highest quality of water to its residents; therefore, the treatment plant was designed in a very superior way. The plant's current capacity was 15 MGD, of which 5 MGD was used by Sherwood following agreements between TVWD and Sherwood.
 - The plant was still state-of-the art, but improvements were needed to ensure it stayed that way.
- The existing treatment plant, with its Actiflo, intermediate ozone filters, and clear well, was becoming the gold standard for water treatment in the region because it provided multiple barriers for the types of contaminants that the City anticipated and wanted to plan for surface waters like the Willamette River. Lake Oswego and Tigard had already adopted the standard, as would the Willamette Water Supply Program.
- Incorporate Level of Service Goals from 2015 Master Plan. The LOS goals covered everything from the way the plant was currently operated, which was very conservatively, to meeting water quality goals that comply with Oregon's rules. The 2015 Master Plan update recommended middle ground would goals where the City could maintain water quality goals and push a bit more water through the plant.
 - LOS goals were also defined for seismic and non-seismic events, such as a Cascadia Subduction Zone event or a gasoline spill in the river.
- The 20 MGD and 30 MGD capacity expansions would occur within a 20-year planning window.
 - The 20 MGD expansion would incorporate life safety and seismic improvements the City was now aware of based on new seismic criteria. Additionally, the expansion would allow the facility to push more water through the existing concrete and included some mechanical improvements.

- The 30 MGD expansion would occur at the end of the planning horizon and was intended to provide additional capacity.
- Identify Lower Site Repairs/Replacements/Upgrades. Veolia Water North America has done an outstanding job operating the plant by performing high-quality maintenance on all of the equipment to ensure maximum useful life. Veolia's budgets had been incorporated into the Master Plan Update.
 - Seismic codes had changed requiring some seismic retrofits which include shoring up some of the deeper basins to ensure they would stay intact in a seismic event.
 - Life safety repairs included things like maintenance, fall protections, and handrails, as well as addressing changes in the building codes.
 - Equipment repairs and replacements were planned. Pumps, for example, have a useful life of about 30 years. Staff worked to align these repairs and replacements with other capacity expansions to make these capital improvement projects the most cost effective and efficient.
- Implementation Plan. Many of the plant upgrades would be coordinated with the Willamette Water Supply Program, which would expand the pump station, upgrade the generator, and install new seismic walls to protect the plant and their equipment from potential sliding in a big earthquake. Anytime Willamette Water Supply was on site, the City would do what it could to combine projects and coordinate as partners.
 - The items circled on Slide 20 indicated the work that would be done by Willamette Water Supply. Their new water pump station/electrical building would take up a large portion of the treatment plant's site, and the Secant Pile wall was for seismic protection.
 - Willamette Water Supply's new facilities would be very close to Wilsonville's water plant. As the City partners with Willamette Water Supply during the work, the City would ensure no impacts would deter from anything the City needed to do at the site.
 - The Master Plan also included a long list of smaller projects scheduled from 2022 to 2036, depending on what needed done. Some life safety repairs and smaller seismic projects would be done annually. Staff still needed to do more work on the Capital Improvement Program (CIP) to fit projects into the budget cycle.
- The CIP estimate included many big ticket items. (Slide 22) Currently, the City's water rates were balanced with project costs; however, another water rate review would be done later in the year, and the timing of the projects would be considered to make sure the City could meet its needs with the finances available at the time.
- Water demands were growing. According to demand forecasts, the City would need the 20 MGD capacity expansion completed by 2022 and the 30 MGD expansion by 2036. Because the estimates might change due to changes with water conservation, water use, and water reuse, Master Plan assumptions and growth projections would be reviewed every five to ten years.
- Next steps included a City Council work session and First Reading on March 5th; the Second Reading and adoption of the ordinance on March 19th; and the effective date 30 days later on April 19, 2018.

Commissioner Mesbah:

- Asked what the cost differences were between the three LOS in today's dollars.
 - Mr. Grounds explained the LOS dictated how the plant would be operated and expanded. The most conservative, which was the current operational parameters for the plant, the 30 MGD expansion would need to happen at the 20 MGD level, so, \$32 million would need to be implemented next year. (Slide 22).
 - The middle LOS criteria would allow the City to postpone the 30 MGD expansion simply by pushing more water through the plant. The plant was originally designed to accommodate that incremental capacity expansion, which would cost \$3 million.
- Noted that was the capital cost. He wanted net present worth for the different options, which included operations and maintenance. In looking at such facility plans, he was used to seeing present worth comparisons in order to make an apples-to-apples comparison.

- Mr. Grounds said he did not have those numbers with him, but the 2015 Master Plan, which was done as part of the Willamette Water Supply Program, included an incredible amount of present worth analysis associated with each criterion for operations.
- Said he did not see present worth cost comparisons in the 2015 Master Plan on the City's website, but he might have missed them in the 1,012 pages.
 - Mr. Grounds confirmed the present net worth numbers were in the materials on the City's website and summarized in a presentation. The numbers were summarized in the chapters and in a cost tech memorandum in an appendix. He did not know if that was presented to the Planning Commission, but he would provide that reference to the Commission.
- Stated he had missed the December presentation and would have asked Mr. Mende for the information. After Mr. Mende's first presentation in 2017, he told Mr. Mende that present worth values needed to be in his presentations, even if it was just three numbers because the presentations were for public information. Just picking the middle LOS would between two extremes did not tell anyone what the savings were or what cost calculations would be reflected in the fees people would be charged. The whole purpose of the public hearing was to inform the public.
- Noted he did not see population forecasts included in the water use projections. He saw several references in the facilities plan and assumed City Planning Staff considered potential population projections. The Environmental Protection Agency (EPA) did this work using authorized population projections. In many ways, plans are a dream. The history of growth needed to be seen, as well as the potential for future growth. Demographers were likely doing this work at the Metro Council level and allocating numbers to the different municipalities in the region. Those numbers should be clearly referred to in the Master Plan, so the projections did not come across as wishful thinking or guess work. He understood this Master Plan would be revisited every five years, but the numbers that get adopted would drive fee increases this year. If the numbers were off or the City was overbuilding, people could be charged unnecessary fees. The data becomes part of the information campaign for the users.
 - Mr. Grounds replied the projections and demands were provided to Carollo and he believed they were developed as part of the Water Distribution System Master Plan and Water Conservation Plan that were done separate from this Water Treatment Plant Facility Plan. His scope was focused on infrastructure inside the facility. He relied on the distribution system planning and forecasting engineers to develop those projections. He agreed including a cross reference from his work to that planning work would be good to make sure the integrity of the numbers was transparent.
 - Chair Greenfield recalled seeing a figure of 50,000 at midcentury for capacity. He asked if that was a based on a guess at population.
 - Mr. Grounds explained those projections came from the Master Plan work, but even though Carollo did not do that work for the City, the assumptions increase the farther out one went. The scope for water treatment plant facility plans was typically limited to 20 years, because that was where the industry felt comfortable planning. Plans were refined every five years to try to narrow the scope, but certainly the numbers that were 50 years out were a best guess at this point.
- Added that sometimes, 50-year projections were the only choice because the project involved putting pipes with a 50-year life expectancy in the ground. However, a 20-year projection should definitely be included. The official expected growth projections were updated every ten years.
 - Ms. Kraushaar offered to provide the numbers that were assumed in the Water Distribution System Master Plan. She suggested adding a paragraph in the Executive Summary to provide a backdrop for the growth assumptions.
- The Commission was asking the questions the constituents would be asking. If the information was missing, most people would not ask about population projections. Tonight's hearing was an opportunity to educate. The aspects of this facilities plan dealing with seismic and code upgrades were necessary, but the optional aspects of the plan must have justification and costs as well. He believed adding the numbers and references to other documents in clear ways in the Executive Summary would make this Master Plan useful to the average citizen.

Commissioner Postma confirmed the information was readily available and could be added prior to presenting the Master Plan Updates to City Council.

- Ms. Kraushaar clarified the added information would include the growth projections used in the Water Distribution Master Plan, which were used to forecast demand in 20 years, as well as the assumptions that were made.

Commissioner Heberlein added he wanted to identify the key assumptions used to develop the Master Plan. It was difficult to read a Master Plan from the beginning without having those assumptions defined.

- Mr. Grounds said he understood some net present values showing the impacts of each option should also be included.

Commissioner Mesbah:

- Noted if one of the options turned the 30 MGD expansion into the 20 MGD expansion, there would be a big capital cost difference.
 - Mr. Grounds agreed if a net present value of 10 years was considered, there would be a big difference because the numbers were incredibly skewed toward the trigger for capacity expansion, particularly the more concrete expansion. If a net present value of 50 or 100 years was considered, the difference began to attenuate. He asked what horizon should be used in the net present value.
- Replied the EPA documentation for present worth work was 20 years with the understanding that anything with a life longer than 20 years would be monetized and brought back to the present worth.
 - Mr. Grounds said the criteria, inflation and etc. used for the net present value analysis as part of the 2015 Master Plan Update was driven by the criteria submitted by TVWD. The Commission might want to look at those criteria to ensure it aligned with the City's expectations.
- Stated present worth calculations did not use inflation. It used authorized percentages given by the EPA for the discount rate. It was important to explain that the present worth number was not the amount that would be paid, but it put options on the same level so they could be compared.
 - Mr. Grounds confirmed he would share the information.

Commissioner Heberlein:

- Asked what percentage of each capacity expansion was allocated to Wilsonville versus other water users.
 - Mr. Grounds said Sherwood could use up to 9.7 MGD in the future. However, discussions were still ongoing between Wilsonville and Sherwood.
- Said it looked like the two expansions were only being funded by system development charges (SDCs), which were paid by new construction, not the rate payers. (Slide 22)
 - Ms. Kraushaar added the expansions were 100 percent eligible for SDC funding. However, it would be up to City Council to decide how much SDCs and rates to spend on the expansion after considering the Budget Committee's recommendations.
 - She confirmed the life safety, seismic, electrical, and operational upgrades would be paid for by the rate payers.

Commissioner Mesbah asked if Sherwood was an owner or client, and who owned the plant.

- Ms. Kraushaar explained that Sherwood had an agreement with TVWD, Wilsonville's contractual partner. The City of Wilsonville and TVWD both owned a share of the plant.

Chair Greenfield asked if Wilsonville's arrangement with Sherwood was an intergovernmental agreement (IGA).

Commissioner Postma stated the IGA was with TVWD, not Sherwood. Sherwood had its own IGA with TVWD.

- Ms. Kraushaar confirmed Commissioner Postma was correct.

Commissioner Heberlein:

- Understood that in theory, Sherwood would be paying their fair share of the costs for the expansion.
 - Ms. Kraushaar replied yes, as well as some of the maintenance costs. The current agreement was based on consumption. Wilsonville would need to work with Sherwood while developing the new CIP to determine the appropriate cost sharing. She would be working on the agreement during a meeting scheduled for next week.
- Confirmed the costs were not yet defined, so the costs on Slide 20 did not give the Commission any idea how much Wilsonville and Sherwood would pay.
 - Mr. Grounds stated that was correct. The final report would have the cost decisions memorialized in it.

Commissioner Postma:

- Confirmed that any portion paid through SDCs would also translate over to Sherwood.
 - Ms. Kraushaar added she was not familiar with Sherwood's SDCs, but if those charges were for growth, surely Sherwood would include that cost in its SDC methodology.
- Confirmed Wilsonville was not Sherwood's only source of water, which skewed the SDC analysis a bit. As some point, two jurisdictions would start pointing fingers at each other about paying after spending so much money.

Commissioner Mesbah suggested adding a paragraph to the Executive Summary explaining that Wilsonville was in the process of coming to an agreement with Sherwood or TVWD on cost sharing and how it would be allocated.

Chair Greenfield asked if this issue needed to be addressed in the resolution.

Commissioner Postma stated it could be done by simply asking for changes to the Executive Summary. The same applied for cost sharing and expenditures.

Ms. Kraushaar recommended adding a paragraph about the importance of cost sharing and making sure the costs were allocated fairly and equitably to those who benefit from the utility. The Master Plan was not the place to include concrete agreements on cost sharing, but it was definitely an important piece to planning the water system.

Commissioner Postma said he and Commissioner Mesbah had been advocating for using the Executive Summary as the way to inform the public. The public would not look any further than the Executive Summary, so the Executive Summaries of these documents needed to speak to the people in a manner they could be understood. With regard to cost sharing expenditures, the Commission wanted to ensure there was some understanding as to how those expenditures got paid. However, simply saying it was important to have an equitable cost sharing relationship might not be saying enough if there was no understanding or indication of what needed to be figured out. Transparency was all about making sure people understand the mechanism so they could feel confident about following the issues they cared about. He was concerned one sentence about the importance of an equitable cost sharing relationship with Sherwood and other jurisdictions would not be enough. He suggested the summary explain that the project could be paid for with SDCs and rate changes coordinated amongst multiple jurisdictions.

Commissioner Mesbah added it would not be wise to start upsetting other jurisdictions during negotiations by saying the City would work on an agreement until Wilsonville believed it was fair. However, he agreed with Commissioner Postma that the City needed to clearly indicate to the average citizen what the negotiation would be aimed at.

- Amanda Guile-Hinman, Assistant City Attorney, suggested making a recommendation rather than a dictation of the Commission wanted: note the importance of the agreement and recommend equitable distribution of the costs.

Commissioner Postma clarified that in addition to a recommendation for an equitable resolution, he wanted an explanation of the types of things that went into the analysis of how costs would be shared.

- Ms. Guile-Hinman explained that there were a variety of opportunities for getting funding and she did not want to foreclose on any possibilities.

Commissioner Heberlein said if this was just for Wilsonville's requirements, the 30 MGD expansion would not be necessary. The project costs were significantly different without any assumption of cost sharing with other partners. If the other jurisdictions asked Wilsonville to fund the entire project, he would say the Master Plan was invalid because Wilsonville did not need that much additional capacity.

- Ms. Kraushaar explained the Master Plan was a look to the future based on existing conditions and expected future conditions, which could change. That potential for change was the reason the master plans were updated regularly. Master plans evolve with time and this was the City's best guess for right now. She would be happy to make changes or additions that addressed the Commission's concerns.

Chair Greenfield asked what kind of input Sherwood made into the Master Plan.

- Mr. Grounds said the former project manager had kept Sherwood updated the Master Plan's development. Sherwood representatives would attend meetings and provide comments. Staff would meet with Sherwood representatives on Tuesday to begin discussing cost sharing. He believed the relationship between Wilsonville and Sherwood was strong and collaborative.
- Ms. Kraushaar added that Sherwood was limited and unable to grow the way Wilsonville had. Sherwood's usage was currently set at 5 MGD, but their maximum usage was 9.6 MGD, which helped Wilsonville estimate its share of the costs.

Commissioner Mesbah noted the future projections might change due to conservation. The 20 MGD threshold could be the difference between serving Sherwood or not. While 33 percent would be a lot of conservation, Wilsonville usually tried to achieve 20 or 25 percent with really good conservation. However, it was not possible to know what technology would do to conservation capabilities 20 years from now. That was a \$32 million prize, especially if Sherwood and Wilsonville were in that kind of collaborative, cooperative spirit. Both communities might want to do a conservation campaign that would delay the big jump. Now is the time to talk about conservation, not three years before upgrades were needed.

Chair Greenfield:

- Said the capacity variables for demand and delivery were obviously quantifiable, but the quality variable was less quantifiable. He asked Staff to comment on the middle range threshold for acceptable quality.
 - Mr. Grounds responded when the original water plant was built, the idea was to design it to address all future unknowns as best as possible. Those criteria were defined by Wilsonville's commitment to date to dose ozone at a concentration that allowed 90 percent in activation of cryptosporidium, which was not detected in the river at that time. It had been detected a few times since, but it had not been ubiquitous. The decision was to retain that criteria in the operational standards. If Wilsonville did not use ozone for cryptosporidium, even more water could be pushed through. However, as part of the 2015 Master Plan, the City, Sherwood, TVWD, Beaverton, and Hillsboro agreed that the criteria the plan had been operated at to date was criteria that should not be relaxed. Maintaining the water quality was the way to operate with integrity.
- Inquired if there were criterion other than the cryptosporidium that the City should be aware of.
 - Mr. Grounds said the adjacent processes were ballasted flocculation and granular activated carbon filtration. Increasing the overflow rate of ballasted flocculation would allow more water to be pushed through. The rate at the B criteria would still be relatively conservative. Lake Oswego's and Tigard's plants were designed at a rate higher than Wilsonville's rate at the B criteria. For the granular activated carbon filtration, the rates at which water would be filtered approach rates approved in Oregon and Washington. Wilsonville's filter was very robust and could increase loading rates, but

those loading rates were capped based on how much water was pushed through the filters at the B criteria. The B criteria would be adopted for the future expansion.

- Asked if chemical filtration was less sensitive to pushing water through.
 - Mr. Grounds explained that granular activated carbon removed organics and allowed some biological activity that also removed organics. The effectiveness of absorption and the biological activity was proportional to how much time the water spent in the column of media. As more water was pushed through the carbon, less organics could be absorbed. It would be difficult to determine if that would have an impact because the raw water quality was pristine. The filters were not being loaded with so much that removal of organics could be seen. The City also replaced the carbon proactively, keeping it very absorptive. Pushing more water through and increasing the filtration rate could increase the probability of a tricky contaminate getting through.
- Understood if that occurred, the contaminate would be discovered and filtration rates could be adjusted.
 - Mr. Grounds noted the policies were implemented to prevent water quality issues. That decision was made by a consensus of all the participants involved in the 2015 Master Plan Update.

Commissioner Heberlein said he preferred the plan represent the cost to Wilsonville and indicate that costs would be shared. If the costs were not yet known because there was not an agreement, maybe a range of estimated costs to each jurisdiction could be noted for the different projects. Seeing Wilsonville's cost instead of the total project cost would give a better indication of the impacts to the rate payers.

- Mr. Grounds added that Carollo tried to take extra steps by providing Staff with an electronic CIP, which was an interactive spreadsheet. As things were negotiated with Sherwood, and as true project costs come in, the CIP could be adjusted as the project moved forward. The spreadsheet also included parameters for the cost split between Wilsonville and Sherwood.

Commissioner Postma asked what assumptions the CIP spreadsheet was based on. He cautioned against displaying the spreadsheet, as it could be considered an exhibit and Staff might not want people to see it.

- Ms. Guile-Hinman recommended that the spreadsheet not be displayed.

Commissioner Millan commended that Wilsonville's water quality continued to exceed most other city water quality reports. She was happy to hear that would be continued. However, she was concerned about seismic activities and whether the projected LOS could actually be reached. She believed the projected LOS were purely speculative and that no one really knew what would happen. The forecast was that the land would almost be liquefied for a few minutes, which led her to doubt that the construction for all of the projections would be enough. Other things needed to be considered, like upgrading switch gears, which would be extremely important if more water was going to be pushed through. That LOS could not be maintained without that upgrade. Many considerations were highly technical. While her fellow Commissioners were concerned about cost sharing, she believed the foundations of operations were very solid.

- Mr. Grounds noted that the Secant Pile wall shown on Slide 20 was a monumental benefit to the city. The wall would hold the land back in a seismic event and help prevent a lateral spread while dealing with the differential total sediment that occurred as water escaped from the liquefied soils.

Chair Greenfield asked what authority approved the design of the wall.

- Mr. Grounds replied he would have to get back to the Commission on that. The design was currently being completed as part of the highly collaborative Willamette Water Supply Program, and Wilsonville had a representative and a review role in the Program's process.
- Ms. Kraushaar added the wall design would go beyond the Building Code. Structural engineers and geotechnical experts were working on the project, and there would also be plenty of peer reviews.
- Mr. Grounds explained that the premise of program was to create a seismically resilient water supply. The consultants working on the program were considering every detail, down to the welding on the pipe joints. The design would be held to a very high standard.

Commissioner Postma noted the Commission had been discussing potential additions to the Executive Summary. He did not want to tie Staff's hands and preferred to leave it to their discretion as to where to add the additional text. He confirmed the wording of the recommended revisions with the Commission as follows:

- Include key assumptions used to develop the Master Plan, which would include the growth projections used to forecast the demand.
- Discussion of net present value, as discussed by the Commission.
- Discussion about cost sharing and that a future process existed to determine the cost sharing in some equitable manner.

Commissioner Mesbah:

- Asked what fire demand assumptions were used.
 - Mr. Grounds explained that Building Codes did not consider water treatment plants to be critical facilities because reservoirs provide fire flow, not treatment plants. However, water treatment plants were still designed as critical facilities. The fire flow analysis was included in the Water Treatment Plant Distribution System Master Plan, and not considered for the Water Treatment Plant Master Plan. Treatment plants were designed to meet maximum daily demands, and reservoirs were used to handle peak day demands and fire flow.
- Added that was why he wanted to know the fire flow standard being used. In his experience, depending on the standard, the fire flow demand volumes added to peak hour usage were a whole unit above that.
 - Ms. Kraushaar said she did not know the exact number of hours, but agreed it was significant.
- Said it was two hours, 2,000 gallons per minute, which added up in a small community, and in his opinion, it would require a huge reservoir. He had not seen any elevated reservoirs in Wilsonville.
 - Ms. Kraushaar said elevated reservoirs were not typical in Oregon, but the large, round reservoirs about 30 feet tall were common.
- Stated it had impacts on insurance rates. The elements that benefit people in ways that have nothing to do with drinking water become educational pieces that should be meaningful to people because they save money. He confirmed his concern about fire flow and dealing with the entire distribution system did not need to be addressed in the Water Treatment Plant Master Plan.

Commissioner Springall confirmed the reservoir on Elligson Road was part of Wilsonville's water system, and that the reservoir in Charbonneau was a small tank.

- Ms. Kraushaar added there were several reservoirs. There were two tanks on Elligson Road and one higher up on the hill at the same elevation as Tualatin's tank. Another reservoir was planned for an area northwest of Villebois. The Water Distribution Master Plan gave that project a five to ten-year timeline.

Mr. Grounds confirmed the Executive Summary was a high-level summary of the entire Master Plan. Everything would be included in the body of the document, and the Commission could coach Staff on which elements of the Master Plan's body should be highlighted in the Executive Summary.

Commissioner Postma agreed some of the additions would be long enough that they would have to be included in the body, but the Executive Summary should include a sentence touching on those additions. He did not want the Executive Summary to be too technical.

Chair Greenfield noted the recommendations were issues the Commission wanted to call to Council's attention. He closed the public hearing at 7:15 pm.

Commissioner Postma moved to approve Resolution No. LP18-0002 with the following additions to the Willamette River Water Treatment Plant 2017 Master Plan Update:

- **Include key assumptions used to develop the Master Plan, which would include growth projections used to forecast demand;**
- **Include discussion of net present value as discussed on the record;**

- **Include some treatment of cost sharing and processes to determine an equitable distribution of the costs.**

Commissioner Heberlein seconded the motion, which passed unanimously.

III. INFORMATIONAL

A. City of Wilsonville Tree Inventory (Public Works)

Chris Neamtzu, Planning Director, overviewed the City's internship program and introduced Andrew Sheehan, the intern who worked with Public Works on the street tree inventory. He noted the last street tree inventory done in 1998 was just a rough survey, but it looked at the trees by neighborhood and the diversity of species. The City had always been concerned about the urban forest and damaging pests, and it was important to understand the age and distribution of the species. He thanked Commissioner Springall for notifying him of the newspaper article and suggesting tonight's work session.

Andrew Sheehan, Intern, presented the Street Tree Inventory via PowerPoint, paper copies of which were provided at the dais, describing the process used for the inventory and reviewing the number, species, tree health, and utility conflicts of street trees in Wilsonville overall, as well as in the Charbonneau and Villebois neighborhoods; however, data was provided for all nine neighborhood zones. (Slide 15)

Key comments and discussion items were as follows, including responses to Commissioner questions from Staff as noted:

- Trees in the parks had already been surveyed, however, some trees in parks located along the streets were included because they were considered both park and street trees.
- The roots of larger trees generally caused sidewalk damage. Villebois was a newer part of the city, but the southern portion, which was the older part of the neighborhood that contained a lot of mature oaks and maples, had some significant sidewalk damage. (Slide 10)
 - The results were surprising because all of Villebois was built with a root barrier, as required by Public Works, which should have prevented tree root from damaging the sidewalks. Perhaps the barrier was installed incorrectly or had become damaged. Mr. Neamtzu said he was compelled to do his own visual assessment of the damage.
 - The Planning Department needed to be aware of the tree health and the impacts to infrastructure, which was discussed at length in the newspaper article.
 - Villebois had worse sidewalk damage than expected for a new neighborhood built with the newest and best planning regulations and Code updates. The City needed to find out if the work was not done to the standard specified in the past, or if something could be done better in the Code going forward. The issues needed to be explored further, especially in the worst areas. The inventory was very informative.
- Mr. Neamtzu noted that an Urban Forestry Management Plan Project had emerged from the tree inventory. Staff would request budget funding to develop a plan that used the tree inventory data to provide recommendations after considering the community holistically and from an urban forestry perspective. The inventory's data would become stale in one to two years, so it was important to create an action plan quickly.
- The Code included a list of recommended tree species from the 1980s, but the list had not really been approved. The data from the tree inventory could help create an approved list of recommended trees.
 - Mr. Neamtzu hoped the Code could be overhauled, particularly the landscaping section. Because the evolution of cultivated tree varieties rapidly changed and larger cities do a great job of keeping up with those changes, the City did not keep its own list but deferred to Portland's or Seattle's tree list. The City was typically better than most communities at ensuring the right trees were planted in the right places.
- The City had an antiquated Public Works Standard for tree spacing and height. The challenges of planting trees near utilities and infrastructure were described. In more dense urban areas, like Villebois, utility and infrastructure requirements were often in conflict with tree planting (Slide 11), but it was the only way to

balance the livability of neighborhoods and still retain some urban forestry elements. There was certainly tension between those creating neighborhoods and those having to maintain them.

- The City was at a point where street tree installation must be inspected to ensure trees were planted in the right spot to protect the City's infrastructure.
- The City of Portland has banned all red maples from being planted as street trees due to concerns about the potential of pests or disease wiping out the existing red maples, which were so widely used in the city.
- Villebois received a low tree health rating compared other neighborhoods because many of the younger trees were dying due to incorrect planting.
- Quantifying damage to utilities and sidewalks caused by street trees was suggested. In the inventory, sidewalk damage was indicated whether there was a crack or a significantly raised portion of the sidewalk, resulting in lifted panels which created dangerous walking conditions. Intrusion of tree roots was another problem.
 - Mr. Neamtzu confirmed Public Works Staff presented repair program ideas to City Council. Council had established a goal to consider urban forestry and street tree issues in neighborhoods. The last sidewalk repair program failed to consider street trees, so a program update needed to be presented to Council.
 - Sherwood had a cost sharing program for sidewalk repairs. The City of Sherwood hires the contractor to do all the sidewalk repairs in the neighborhood. The City pays 50 percent of costs and the other half is charged to each resident on their utility bill. Residents can pay off that cost over the course of one year. Residents could opt out and hire their own contractor. However, Sherwood's program is very robust and comprehensive, and residents receive significant cost savings and detailed reports.
 - Mr. Neamtzu envisioned a comparable program in Wilsonville because currently, according to Code, all the responsibility was on the property owner. Residents were forced to keep trees doing damage, but were still responsible for that damage, which he agreed did not seem fair.
 - In some larger neighborhoods, homeowners associations were responsible for street trees in common areas. In older neighborhoods, where the trees were getting quite large, the homeowners were responsible. Mature trees were great for the urban canopy, but not for sidewalks.
- The dangerous conditions of the sidewalk along Wilsonville Rd were discussed. The rubber sidewalk installed in that location about eight years ago was already heaving, as seen in the bottom photo on Slide 10. A curb extension would be required to keep the tree in its current location. Hopefully, one individual homeowner would not be responsible for paying for that repair.
 - Many of the issues being discussed were wider concerns so distributing repair costs was supported.
 - While working on the tree inventory, the number one complaint from the public was tree root damage to sidewalks as well as comments that residents should not have to pay for all the repairs.
- While Villebois' trees should be healthiest, the overall health of street trees in Villebois was poor compared to the rest of the city due to improper planting. Many of the older trees were healthy, but while taking inventory, Staff saw new trees being planted as fast as possible; some with their root ball above ground.
- The interns started working on the inventory in July and finished in December, conducting field work 40 hours per week and walking every street in Wilsonville at least twice.
- The tree inventory would be useful to the Planning Department, Planning Commission, and city residents. Providing the information to the Development Review Boards (DRBs) was suggested because the data might inform decisions on new developments like Frog Pond.
- Administrative approvals for a Type B Tree Removal, which was for a street tree or for more than three trees, typically included an arborists report. Removing a street tree required notification and a reason, like a utility conflict, disease, or a dying tree. The City processed a lot of Type B permits. On private property, there was nothing to question so a citizen could take out more than four trees for any reason.
 - Staff offered the City's arborist to save citizens money; however, citizens could still hire their own arborist when applying for a tree removal permit. The City's arborist was just a first line of communication and could answer questions about overall tree health, but he would not climb into trees, analyze insects, or do a comprehensive analysis of the conditions.

- In Canyon Creek, two trees were planted on every lot to give the neighborhood an immediate effect. The lots were too small to accommodate two trees, so, a neighborhood-wide permit was issued to allow for a comprehensive neighborhood-wide removal of every other tree. The City had issued these permits in other neighborhoods as well. If there was a single species throughout an entire neighborhood, the City could do a district-wide tree removal program.
- Several conditions could make the Type B Tree Removal process cumbersome and complicated. For example, in Canyon Creek, the trees were in the front yards on private property, not in the public rights-of-way. However, the trees were still considered street trees because of their proximity to the curb.
- The separation issue regarding street trees had to be addressed, but it was difficult to know when the landscaping crew would be working. A process could be established with specific planting protocols for Frog Pond. The City could require an inspection at the time of planting to ensure planting was done correctly.
- Right now, so many homes were being built and Staff did not have the time or resources to pay a lot of attention to new street trees. Although the Building Department Staff already visited every home, their expertise regarded fire, life, and safety.
 - Trees impact fire, life, and safety, especially considering their impact on sidewalks. In the 1980s, too many communities decided to build urban forests by planting trees with 3-ft circumferences in 3-ft parking strips.
- The City should develop a strong, robust, city-wide street tree plan because it would positively impact residents and homeowners. Current practices created situations that practically guaranteed inflicting financial burdens on homeowners. Sidewalks were public utilities and better street tree mitigation processes were needed. Trees doing damage to sidewalks or utilities should be replaced with a new, different type of tree. What financial liabilities were being incurred across the city because of this issue?
 - Given the responses from the Commission about the tree inventory, the Commission should work on a new street tree document.
 - The City should require either a 5-ft or 6-ft parking strip or trees should be planted on the homeowner's side of the sidewalk. The trees would have a better chance of survival and the homeowners were already responsible for the trees anyway.
- There were two distinct issues: mitigating the existing problem and making the City's Code more explicit and prospective with regard to street tree planting for new neighborhoods. The Commission's role in planning community-wide mitigation was questioned.
- The Commission did not want what happened in Villebois to occur in Frog Pond. The neighborhood would end up full of dead trees and needing hundreds of thousands of dollars in sidewalk and water main replacements.
- Inspecting at the time of planting made sense. However, soil in the parkways of new developments was scrap soil, so unless it was replaced with good soil in the root zone, trees would become stressed even if the root ball was completely buried. The right tree species needed to be planted in the right places. The large oaks along French Prairie in Charbonneau were breaking up the walls. The trees were planted too close to each other and overwatered, causing them to shed branches.
 - Perhaps Staff should budget for an additional person to oversee tree planting.
 - Newly planted trees were often guaranteed for a year, so the HOAs would not have to pay to replace them.
 - Inspections would incur fees, which would increase costs.
 - Many cities did not allow private developers to install trees and the city was entirely responsible for planting the trees. However, it was uncertain whether those cities also took responsibility for the trees' maintenance after installation.
- The tree inventory was eye opening. The City had to do better and create a process to avoid repeating the same errors in Frog Pond. Staff would work on developing a cost sharing program as well.

- Seattle gave a credit on stormwater charges if a property had trees of a certain size, canopy, etc. The benefits of trees on infrastructure were tremendous and a true cost/benefit analysis would demonstrate that with properly planted and properly maintained trees, the City would come out ahead. Hopefully, this would be reflected in the Urban Forestry Plan.
- Property owners with giant trees in one Wilsonville neighborhood had discussed how the trees took care of their stormwater, but they did not receive any break on storm water bills or on the cost of repairing the damage done by the trees.
- Unfortunately, trees become part of selling a development. Developers try to protect huge trees on the land, but end up locating a house or sidewalk in close proximity. The developers could say they were not cutting down the trees, but in ten years, they would be dead.
- The discussion needed to center on trees being renewable, and if a tree was not a Champion Tree, it should be removed and replaced in a better location to have a development that made sense. The face of the proposed development was being protected in the proposals just for PR purposes.
- Trees were one of the few City assets that appreciated overtime, but not if they were destroying sidewalks and utilities.

Chair Greenfield called for a brief recess at 8:10 pm and reconvened the meeting at 8:15 pm.

B. Southbound I-5 Boone Bridge Auxiliary Lane Study (Kraushaar)

Nancy Kraushaar, Community Development Director, stated the PowerPoint was prepared in partnership with ODOT, and was slightly different from the version in the original packet. When she first prepared the Staff report, she planned to present just the existing conditions. However, the future conditions memorandum and the evaluation of three ramp-to-ramp lane alternatives had been completed. The presentation would also be presented to various organizations throughout the city including the French Prairie Forum, Chamber of Commerce, Charbonneau, and the Oregon Freight Association. She presented the Southbound I-5 Boone Bridge Congestion Study, a revised copy of which was provided at the dais, and addressed clarifying questions from the Commission.

Comments and key responses to Commissioner questions were as follows:

- The numbers shown along the left side of I-5 (Slide 5) represented the existing measured trips during the PM peak hour. The maximum number of trips allowed by the ramp meter to enter the freeway from the southbound ramp was 1200 vehicles per hour, and because demand exceeded that amount, traffic backed up on the ramps, Wilsonville Rd, Boones Ferry Rd, and Town Center Lp.
- Staff was not sure if ODOT used variable operations on this ramp meter because it was located at the end of the system. Meters in the middle of the system were very reactive to traffic conditions. Staff was looking into how the ramp meter operated; however, ODOT would not set the ramp meter limit any higher than 1200 vehicles per hour.
- All freeway ramps were the State's and completely controlled by ODOT. However, ODOT wanted local support for the proposed facility plan. The Planning Commission would provide input for City Council to consider when considering a resolution to support the facility plan, which would be adopted into the Oregon Transportation Plan by the Oregon Transportation Commission.
- The ramp meters were set by ODOT to control the flow of traffic onto the freeway to a maximum of 1200 vehicles per hour to prevent overloading the capacity of the freeway. Vehicles were counted with a traffic counter to determine the actual number of trips during the PM peak hour. Many large cities have ramp meters that limit traffic flow.
- ODOT's level of service (LOS) goal for I-5 was LOS D. Currently, the project area was LOS E, which was failing.
- A business owner recently shared that they could not conduct any business passed 2:30 pm because of the freeway issues were region wide. Traffic congestion had been decades in the making.

- Freight delays from the Willamette River to I-205 cost \$750,000 per mile annually for freight. Congestion in the bottleneck could be impacted for two to three hours, so drivers must plan a 300 percent buffer to arrive on time 19 out of 20 days. (Slide 8)
- The Congestion Study was done on southbound traffic only, but Staff would see if traffic figures were available for the northbound portion of I-5 between Charbonneau and Wilsonville Rd. Looking at northbound traffic before and after the proposed alternatives would also help inform the southbound project.
- There was no timeline yet for making seismic improvements to the Boone Bridge; however, the State was getting pressure to be more prepared for the big earthquake, but funding was an issue. The State and Metro region have prioritized funding for three other large freeway projects, but the potential for the Boone Bridge to be considered one of the next high priorities for the State was good. A reasonable timeline for this project was 10 to 25 years.
- ODOT would consider increasing the flow at the Wilsonville on the southbound ramp to 1400 vehicles. However, Staff did not know the current actual demand on the ramp.
- Adding an auxiliary lane would not require widening the Boone Bridge, but adding a driving lane would.
- Adding the second lane off the Canby/Hubbard exit now was suggested because there was room in the area and the exit already opened up to two lanes. This would provide some relief to congestion more immediately than the current 10 to 20 year timeline. Staff would have the project team consider adding the lane ahead of time. (Option C, Slide 10)
- The speeds have been dropping quickly, especially over the last two years due to population growth and possibly the economy.
- Determining what was causing the significantly drop in average PM speeds (Slide 6) might lead to some more immediate and entirely different solutions than just fixing the Boone Bridge.
 - ODOT needed to consider a new bridge within a few miles of the Boone Bridge because so much development was occurring south of the Willamette River. Adding one lane on I-5 would not make a huge difference.
 - The Dundee bypass bridge could be used as connection, but roads would need to be built on the other side to make the connection viable which would be extremely difficult.
- Another factor confirming the need for the facilities plan was the anticipated growth in the Coffee Creek and Basalt Creek areas, which could dump even more truck traffic onto Stafford Rd, contributing to even more congestion. Alternatively, businesses might question whether they want to site their businesses in Wilsonville if their trucks could not travel efficiently.
 - Washington County did identify I-5 as a critical need in its freight study last year, so perhaps the timeline for the project's completion might be less than 20 years.
 - The City would continue to encourage people to use other modes of transportation. The transit network was focused in the Portland/Beaverton areas, but growing that network toward the outskirts of town would provide other alternatives to using the freeway.
 - Transit ridership, however, was down significantly nationwide.
 - Wilsonville was trying to grow its industry to improve the housing and jobs balance. The City wanted to provide opportunities for people to live and work closer so they did not have to use the freeway as much.
- Widening the Wilsonville Rd on ramp to two lanes was considered; however, ODOT eliminated that option because it would cause too many safety issues.
 - ODOT had been asked to increase the ramp meter limit. City Council might not support the plan if more traffic was not taken off Wilsonville Rd.
- Traffic was one of the biggest issues in Wilsonville right now, so there might be a large attendance at the public hearing in May.
- Reconfiguring the pedestrian bridge with travel lanes would alleviate some of the traffic from Wilsonville Rd headed to the first two exits. Although this would increase costs, funding mechanisms would increase as

well. Expanding the pedestrian bridge could produce a significant improvement, and the City would not have to wait on ODOT for funding.

- Regional traffic should be kept on the freeway by improving the freeway itself. Local residents did not want regional traffic bypassing through their neighborhoods to get across the river because the Boone Bridge was under built.
- Sixty percent of the traffic was local traffic just crossing the river, not regional traffic. The travel lanes on the pedestrian could connect to Miley Rd, which went into Canby.

C. City Council Action Minutes: (Jan. 4 and Jan. 18, 2018)

Chris Neamtzu, Planning Director, announced the Form-based Code was adopted on first reading at the February 12th City Council meeting by a unanimous vote and with almost no discussion about the options the Commission contemplated. The Council appreciated the Commission's work. The second reading was scheduled for February 22, 2018.

Chair Greenfield noted he heard at a recent conference that Wilsonville's Form-based Code was cutting edge.

D. 2018 Planning Commission Work Program

Chris Neamtzu, Planning Director, noted some additional items ~~that~~ were added this week. SMART planned to propose amendments to the Transit Master Plan in order to capture a new opportunity for revenue. The amendments would be discussed during a work session in May.

- He explained that the Density Inconsistency Revisions were highly technical and he expected about three hours of discussion. Staff was currently working on the revisions as time allowed. He was considering pulling the project from the Work Program because Staff had other pressing items and summer scheduling was also a factor.

IV. ADJOURNMENT

Chair Greenfield adjourned the regular meeting of the Wilsonville Planning Commission at 9:15 pm.

Respectfully submitted,

By Paula Pinyerd of ABC Transcription Services, Inc. for
Tami Bergeron, Administrative Assistant-Planning



PLANNING COMMISSION
WEDNESDAY, FEBRUARY 14, 2018

II. LEGISLATIVE HEARING

A. Water Treatment Plant Master Plan (Kraushaar)

www.ci.wilsonville.or.us/WTPMPupdate

**PLANNING COMMISSION
RESOLUTION NO. LP18-0002**

A RESOLUTION OF THE PLANNING COMMISSION OF THE CITY OF WILSONVILLE RECOMMENDING THE CITY COUNCIL ADOPT THE WILLAMETTE RIVER WATER TREATMENT PLANT 2017 MASTER PLAN UPDATE RELATING TO IMPROVEMENTS, EXPANSION, AND OPERATION OF THE EXISTING WATER TREATMENT PLANT

WHEREAS, the Planning Commission of the City of Wilsonville (“City”) has the authority to review and make recommendations to the City Council regarding changes to, or adoption of new elements and sub-elements of, the Comprehensive Plan pursuant to Sections 2.322 and 4.032 of the Wilsonville Code (“WC”); and

WHEREAS, the Willamette River Water Treatment Plant 2017 Master Plan Update is a support document to the City’s Comprehensive Plan, and the Update to the Water Treatment Plant Master Plan is subject to the same rules and regulations as an update to the City’s Comprehensive Plan; and

WHEREAS, the Planning Director submitted a proposed Ordinance to the Planning Commission, along with a Staff Report, in accordance with the public hearing and notice procedures that are set forth in WC 4.008, 4.011, 4.012, and 4.198; and

WHEREAS, the Planning Commission conducted a work session on December 13, 2017, and after providing the required public notice, held a public hearing on February 14, 2018 to review the proposed Update to the Water Treatment Plant Master Plan and to gather additional testimony and evidence regarding the Update to the Water Treatment Plant Master Plan; and

WHEREAS, the Planning Commission has afforded all interested parties an opportunity to be heard on this subject and has entered all available evidence and testimony into the public record of its proceeding; and

WHEREAS, the Planning Commission has duly considered the subject, including the staff recommendations and all the exhibits and testimony introduced and offered by all interested parties; and

NOW, THEREFORE, BE IT RESOLVED that the Wilsonville Planning Commission does hereby adopt the Staff Report and its attachments (attached hereto as Exhibit A), as presented at the February 14, 2018 public hearing, including the findings and recommendations contained

therein, and further recommends the Wilsonville City Council approve and adopt the Update to the Water Treatment Plant Master Plan relating to the improvements, expansion, and operation of the existing Water Treatment Plant facility as hereby approved by the Planning Commission; and

BE IT FURTHER RESOLVED that this Resolution shall be effective upon adoption.

ADOPTED by the Wilsonville Planning Commission at a regular meeting thereof this 14th day of February, 2018, and filed with the Wilsonville City Recorder this date.

Wilsonville Planning Commission

ATTEST:

Tami Bergeron, Planning Administrative Assistant

SUMMARY OF VOTES:

Commissioner Greenfield: _____
Commissioner Postma: _____
Commissioner Hurley: _____
Commissioner Mesbah: _____
Commissioner Millan: _____
Commissioner Springall: _____
Commissioner Heberlein: _____

Attachments:

Exhibit A – Staff Report

**PLANNING COMMISSION HEARING
STAFF REPORT**



Meeting Date: 02/14/2018		Subject: Resolution LP18-0002: 2017 Water Treatment Plant Master Plan Update	
		Staff Member: Eric Mende, PE, Capital Projects Engineering Manager	
		Department: Community Development	
Action Required		Advisory Board/Commission Recommendation	
<input checked="" type="checkbox"/> Motion <input checked="" type="checkbox"/> Public Hearing Date:02/14/18 <input type="checkbox"/> Ordinance 1 st Reading Date: <input type="checkbox"/> Ordinance 2 nd Reading Date: <input checked="" type="checkbox"/> Resolution <input type="checkbox"/> Information or Direction <input type="checkbox"/> Information Only <input type="checkbox"/> Council Direction <input type="checkbox"/> Consent Agenda		<input type="checkbox"/> Approval <input type="checkbox"/> Denial <input type="checkbox"/> None Forwarded <input checked="" type="checkbox"/> Not Applicable	
		Comments:	
Staff Recommendation: Staff respectfully recommends that the Planning Commission conduct the public hearing on the proposed 2017 Water Treatment Plant Master Plan, and approve Resolution LP18-0002 recommending approval and adoption of the 2017 Master Plan Update by the City Council.			
Recommended Language for Motion: Move to approve Resolution LP18-0002, recommending approval and adoption of the 2017 Water System Master Plan (with or without specific changes).			
Project / Issue Relates To: <i>[Identify which goal(s), master plans(s) your issue relates to.]</i>			
<input checked="" type="checkbox"/> Council Goals/Priorities -Fiscal Discipline, Environmental Stewardship, Well Maintained Infrastructure		<input checked="" type="checkbox"/> Adopted Master Plan(s)	<input type="checkbox"/> Not Applicable

ISSUE BEFORE PLANNING COMMISSION:

The City of Wilsonville is completing a Master Plan Update for the Willamette River Water Treatment Plant (WTP). Master Plans, once adopted, become an amendment to the City's Comprehensive Plan, and as such, require a formal adoption process that includes a hearing

EXHIBIT A

before the Planning Commission, consideration of conclusionary findings for consistency with Statewide Planning Goals, a recommendation for adoption from Planning Commission to City Council, and hearing and adoption by ordinance by City Council.

Staff and Consultants will give a PowerPoint presentation on the 2017 Master Plan Update, and answer any questions from the Commission and the Public.

EXECUTIVE SUMMARY:

The 2017 Master Plan Update for consideration tonight specifically addresses the existing Willamette River Water Treatment Plant, operational since 2002, and currently providing treated water to the citizens of Wilsonville and Sherwood. The primary goals of the 2017 Master Plan Update are:

- 1) To confirm the quantity and timing of long range water delivery from the WTP over a 20 year planning horizon;
- 2) To identify and select appropriate treatment technologies and design criteria for future water treatment facilities;
- 3) To evaluate existing Water Treatment Plant facilities for upgrades and replacements; and
- 4) To identify the capital costs, timing, and funding strategy required to meet the future water supply and level of service goals.

All of these goals are accomplished in the 2017 Master Plan Update. Chapter 2 provides information on existing and future water demand, and the expected future Level of Service. Chapters 3 and 4 describes the existing treatment technologies and associated operational performance in terms of water quality and regulatory compliance. Chapter 5 evaluates the condition and reliability of the existing plant infrastructure with particular focus on life safety deficiencies, surge protection and seismic resiliency. Chapter 6 presents the recommended short term and long-term capital improvement strategy needed to ensure continued reliability of the treatment plant as the plant capacity increases from the current 15 mgd to 30 mgd in year 2035 and beyond. Lastly, Chapter 7 presents the capital cost estimates and recommended schedules for the design and construction of improvements identified in Chapter 6.

Conclusionary Findings demonstrating consistency with Statewide Planning Goals are included as Attachment B.

EXPECTED RESULTS:

Administratively, a recommendation to City Council for adoption of the 2017 Master Plan Update, and subsequent adoption by City Council, will make this Master Plan part of the City's Comprehensive Plan. Inclusion in the Comprehensive Plan allows identified capital and operational improvements to be planned and budgeted in future rate studies and capital spending plans. From a utility management standpoint, this Master Plan provides a 20-year planning tool to ensure reliable delivery of high quality drinking water to Wilsonville citizens and businesses.

TIMELINE:

Planning Commission Hearing: February 14, 2018

EXHIBIT A

City Council Hearing: March 05, 2018 (Approval of Ordinance on first reading)
City Council: March 19, 2018 - Second Reading of Ordinance
Effective Date: 30 Days after 2nd Reading

CURRENT YEAR BUDGET IMPACTS:

None. Consulting Services for the 2017 Master Plan Update are budgeted under CIP 1122

FINANCIAL REVIEW / COMMENTS:

Reviewed by: _____ Date: _____
n/a

LEGAL REVIEW / COMMENT:

Reviewed by: _____ Date: _____
n/a

COMMUNITY INVOLVEMENT PROCESS:

A web page and virtual open house have been set up at www.ci.wilsonville.or.us/WTPMPupdate where the entire document can be viewed, and public comment and questions can be submitted.

POTENTIAL IMPACTS or BENEFIT TO THE COMMUNITY (businesses, neighborhoods, protected and other groups):

A reliable source of properly treated domestic water is essential to the well-being of the community.

ALTERNATIVES:

None

CITY MANAGER COMMENT:

ATTACHMENTS:

Attachment A: Master Plan Executive Summary

Attachment B: Conclusionary Findings

Attachment C: Full version of the Water Treatment Plant 2017 Master Plan Update accessed:
www.ci.wilsonville.or.us/WTPMPupdate



City of Wilsonville

Willamette River Water Treatment Plant 2017 Master Plan Update

2017 MASTER PLAN UPDATE

FINAL DRAFT | February 2018





City of Wilsonville
Willamette River Water Treatment Plant

2017 MASTER PLAN UPDATE

Jude D. Grounds,
February 5, 2018,
State of Oregon,
P.E. No. 74678

ATTACHMENT A

Contents

EXECUTIVE SUMMARY

ES.1	Introduction	ES-1
ES.2	Plant Expansion and Level of Service Goals	ES-2
ES.3	Existing Facilities and Operational Performance	ES-2
ES.4	Historical Raw and Finished Water Quality	ES-3
ES.5	Existing Infrastructure	ES-3
ES.5.1	Electrical Supply and Distribution CIP	ES-3
ES.5.2	Seismic Evaluation CIP	ES-3
ES.5.3	Life-Safety Evaluation CIP	ES-3
ES.6	WRWTP Expansion CIP	ES-3
ES.6.1	20-MGD Expansion CIP	ES-4
ES.6.2	30-MGD Expansion CIP	ES-5
ES.6.3	Electrical Expansion CIP	ES-11
ES.6.4	Repair and Replacement CIP	ES-11
ES.7	CIP Approach and Schedule	ES-11

Chapter 1 - INTRODUCTION

1.1	WRWTP AND SOURCE BACKGROUND	1-1
1.2	MASTER PLAN UPDATE OBJECTIVES AND ORGANIZATION	1-3

Chapter 2 - PLANT EXPANSION AND LEVEL OF SERVICE GOALS

2.1	Introduction	2-1
2.2	Water Demands and Expansion Strategy	2-1
2.2.1	Demand Projections and Hydraulic Requirements	2-1
2.2.2	Capacity Expansion and Phasing Strategy	2-3
2.3	Hazard Analysis and Associated Level of Service Goals	2-4
2.3.1	LOS Goal Objective	2-4
2.3.2	Catastrophic Event	2-5
2.3.3	Regional Precedents	2-8
2.3.4	Recommended Preliminary LOS Goals for WRWTP Expansion	2-10

Chapter 3 - EXISTING FACILITIES AND OPERATIONAL PERFORMANCE

3.1 Introduction	3-1
3.2 Summary of Previous Studies	3-1
3.3 Major Plant Components	3-3
3.3.1 General	3-3
3.3.2 Raw Water Facilities	3-17
3.3.3 Chemical Injection Vault and Initial Mixing Facility	3-17
3.3.4 Ballasted Flocculation (Actiflo®) System	3-18
3.3.5 Ozonation System	3-19
3.3.6 Filtration System	3-20
3.3.7 Liquid Chemical Storage and Feed Facilities	3-21
3.3.8 Washwater Equalization Basin	3-22
3.3.9 Gravity Thickener	3-22
3.4 Historical Plant Performance	3-23
3.5 Conclusions	3-30

Chapter 4 - HISTORICAL WATER QUALITY AND REGULATORY COMPLIANCE

4.1 Introduction	4-1
4.2 Historical Water Quality	4-1
4.3 Regulatory Compliance	4-11
4.3.1 Existing Regulations	4-11
4.3.2 Unregulated Contaminant Monitoring	4-11
4.3.3 CT Compliance	4-13
4.3.4 Future Regulations	4-14
4.4 Emerging Contaminants	4-14
4.4.1 National Perspective and Literature Review	4-15
4.4.2 Regional Perspective	4-17
4.4.3 2015 MPU Participant Interviews	4-18
4.5 Conclusion	4-19

Chapter 5 - EXISTING INFRASTRUCTURE

5.1 Introduction	5-1
5.2 Site Mapping	5-1
5.3 Hydraulic Assessment	5-5

5.4 Equipment Assessment	5-8
5.5 Electrical Assessment	5-8
5.5.1 Evaluation Results	5-8
5.5.2 Recommendations	5-10
5.6 Seismic Evaluation and Mitigation Alternatives	5-15
5.6.1 Oregon Seismic Requirements	5-15
5.6.2 Geotechnical Investigation Summary	5-16
5.6.3 Seismic Evaluation of Existing Facilities	5-16
5.7 Life Safety Evaluation	5-17
5.8 Transient Surge Analysis	5-17
5.8.1 Evaluation Methodology	5-17
5.8.2 Evaluation Results	5-23
5.8.3 Recommendations	5-23
 Chapter 6 - EXPANSION ALTERNATIVES ANALYSIS	
6.1 Introduction	6-1
6.2 Treatment Technologies	6-1
6.3 Confirmation of Treatment Recommendation	6-1
6.4 20 mgd Expansion	6-2
6.4.1 Flow Projections	6-2
6.4.2 Raw Water Pumping	6-2
6.4.3 Flash Mix	6-7
6.4.4 Ballasted Flocculation (Actiflo®)	6-7
6.4.5 Ozonation and Ozone Generation	6-7
6.4.6 Filtration	6-8
6.4.7 Clearwell/Chlorine Disinfection	6-8
6.4.8 Finished Water Pumping	6-9
6.4.9 Waste Washwater Recovery	6-9
6.4.10 Mechanical Solids Dewatering	6-9
6.4.11 Chemical Storage and Metering	6-9
6.5 30-mgd Expansion	6-18
6.5.1 Expansion Alternatives	6-18
6.5.2 Flow Projections	6-23

6.5.3 Raw Water Pumping	6-23
6.5.4 Flash Mix	6-27
6.5.5 Ballasted Flocculation (Actiflo®)	6-27
6.5.6 Ozonation	6-27
6.5.7 Filtration	6-27
6.5.8 Clearwell/Chlorine Disinfection	6-27
6.5.9 Finished Water Pumping	6-27
6.5.10 Waste Washwater Recovery	6-28
6.5.11 Mechanical Solids Dewatering	6-28
6.5.12 Chemical Storage and Metering	6-28
6.6 Electrical Upgrades	6-37
6.7 Repair and Replace	6-38

Chapter 7 - CIP APPROACH AND SCHEDULE

7.1 Introduction	7-1
7.2 Capital Cost Assumptions	7-1
7.2.1 Cost Estimate Classification	7-1
7.2.2 Opinion-of-Probable Construction Cost Estimate	7-1
7.2.3 Cost Factoring Workbook	7-2
7.2.4 CIP Workbook	7-2
7.3 Design and Construction Schedule	7-3
7.4 Financial Summary	7-3

Appendices

Appendix A – Condition Assessment Calculations

Appendix B – Life Safety and Seismic Assessment Technical Memorandum

Appendix C – Surge Transient Analysis & Pre-Design Recommendations Technical Memorandum

Appendix D – Capital Cost Estimates

Appendix E – CIP Workbook

Tables

Table ES.1 Cities of Wilsonville and Sherwood Treatment LOS Goals	ES-2
Table ES.2 Estimated CIP Costs (2017 Dollars)	ES-11
Table ES.3 Operations – Repair and Replace Estimated CIP Cost (2017 Dollars)	ES-12
Table ES.4 WRWTP Expansion Design and Construction Schedule	ES-12
Table 2.1 Hydraulic and Capacity Requirements of the WRWTP Participants	2-3
Table 2.2 Catastrophic Hazards Events and Potential Impact on the WRWTP Lower Site	2-5
Table 2.3 Likelihood of Volcanic Ash Having Substantial Impact on Watersheds with a Southwest Wind	2-6
Table 2.4 Water Treatment Facility Recovery Levels for Various Earthquake Hazard Levels as Implied by Current Codes and Standards for New Construction	2-7
Table 2.5 East Bay Municipal Utility District Level of Service Goals	2-8
Table 2.6 Oregon Resilience Plan Recommended LOS Goals for Water Systems	2-9
Table 2.7 Joint Water Commission WTP LOS Goals	2-10
Table 2.8 Adopted LOS Goals for the WRWTP	2-11
Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures	3-3
Table 3.2 WRWTP Production (mgd)	3-28
Table 4.1 WRWTP Comparison of Regulatory and Contract Sampling Frequencies	4-2
Table 4.2 Comparison of Regulatory and Contract Finished Water Parameters	4-3
Table 4.3 WRWTP Summary of Raw Water Quality and Corresponding Finished Water MCL (May 2006 through 2014)	4-5
Table 4.4 WRWTP Summary of Finished Water Quality (May 2006 through 2014)	4-8
Table 4.5 Summary of Wilsonville Distribution System Water Quality Data	4-11
Table 4.6 Summary of UCMR 3 Finished and Distribution Water Quality	4-12
Table 4.7 Summary of Preliminary UCMR 3 Results	4-16
Table 4.8 Summary of CECs Interview Responses by Regional Surface Water Suppliers	4-17
Table 4.9 Summary of CECs Interview Responses by 2015 MPU Participant Water Suppliers	4-18
Table 5.1 WRWTP Caisson and Willamette River Elevations	5-5
Table 5.2 WRWTP Electrical Load Summary	5-9
Table 5.3 Summary of Seismic Vulnerabilities	5-18

ATTACHMENT A

Table 5.4 Summary of Life Safety Findings	5-20
Table 5.5 Hydraulic Transient Analysis Demand Scenarios	5-23
Table 5.6 Hydropneumatic Tank Sizing Recommendations	5-23
Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures	6-10
Table 6.2 WRWTP 30 mgd Expansion Alternatives	6-18
Table 6.3 WRWTP 30 mgd Expansion Alternatives – Design and Operating Criteria following a Catastrophic Seismic Event	6-21
Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures	6-29
Table 6.5 WRWTP Repair and Replace Projects	6-38
Table 7.1 Example of CIP Actual Construction Cost	7-2
Table 7.2 WRWTP Expansion Design and Construction Schedule	7-3
Table 7.3 WRWTP Near-Term CIP Costs (2017 Dollars)	7-4
Table 7.4 WRWTP Total CIP Costs (2017 Dollars)	7-6

Figures

Figure ES.1 WRWTP Capacity Projections and Recommended Expansion Phasing	ES-4
Figure ES.2 Site Plan – 20-MGD Capacity Expansion	ES-7
Figure ES.3 Site Plan – 30-MGD Capacity Expansion	ES-9
Figure ES.4 RWTP Near-Term CIP Costs by Project (2017 Dollars)	ES-14
Figure ES.5 WRWTP Total CIP Costs by Project (2017 Dollars)	ES-15
Figure 2.1 WRWTP Capacity Projections and Recommended Expansion Phasing	2-2
Figure 2.2 WRWTP and WWSP Water Demand Projections	2-3
Figure 3.1 WRWTP Existing Site Plan	3-11
Figure 3.2 WRWTP Process Flow Diagram	3-13
Figure 3.3 WRWTP Hydraulic Profile	3-15
Figure 3.4 WRWTP Process Performance Summary	3-25
Figure 3.5 WRWTP Raw Water Turbidity	3-29
Figure 3.6 WRWTP Raw Water and Finished Water	3-31
Figure 3.7 WRWTP Monthly Finished Water Production and Power Consumption	3-32
Figure 3.8 WRWTP Monthly Finished Water Production and Solids Production	3-33

Figure 5.1 Lower Site Survey	5-3
Figure 5.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity	5-7
Figure 5.3 Current Electrical Load Distribution Diagram	5-11
Figure 5.4 Existing Electrical System – 20 mgd Capacity	5-12
Figure 5.5 Upgraded Electrical System – 20 mgd Capacity	5-13
Figure 5.6 Upgraded Electrical System – 30 mgd Capacity	5-14
Figure 6.1 WRWTP Site Layout – 20 mgd Capacity	6-3
Figure 6.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity	6-5
Figure 6.3 WRWTP 30 mgd Expansion – LOS	6-19
Figure 6.4 WRWTP 30 mgd Expansion – LOS + Post Regional Seismic Event Resiliency	6-19
Figure 6.5 WRWTP Site Layout – 30 mgd Design Capacity	6-25
Figure 7.1 Example Assumptions in CIP Workbook	7-2
Figure 7.2 WRWTP Near-Term CIP Costs (2017 Dollars)	7-5
Figure 7.3 WRWTP Total CIP Costs (2017 Dollars)	7-7

Abbreviations

%	percent
2015 MPU	2015 WRWTP Master Plan Update
AACE	American Association of Cost Engineers
BRP	Blue Ribbon Panel
C	Celsius
Caisson	Raw Water Intake Pump Station Caisson
CECs	Contaminants of Emerging Concern
CECs	contaminants of emerging concern
CFD	computational fluid dynamic
City	City of Wilsonville
COW	cost of work
DBP	disinfection by-product
EBMUD	East Bay Municipal Utility District
ENR	Engineering News Record
EPA	Environmental Protection Agency
ESA	Endangered Species Act
EWEB	Eugene Water and Electric Board
FERC	Federal Energy Regulatory Commission
ft	feet
GAC	granular activated carbon
HABs	harmful algal blooms
IBC	International Building Code
JWC	Joint Water Commission
LOS	level of service
LOX	liquid oxygen
MCC	motor control centers
MCL	maximum contaminant level
mg/L	milligrams per liter
mgd	million gallons per day
MM	million
MPU	Master Plan Update
MWh	megawatt hours
NAVD	North American Vertical Datum
NCOD	National Contaminant Occurrence Database
nm	nanometers
NMFS	National Marine Fisheries Service

ATTACHMENT A

NTU	Nephelometric turbidity units
OAR	Oregon Administrative Rule
ODFW	Oregon Department of Fish and Wildlife
OHA	Oregon Health Authority
ORP	Oregon Resilience Plan
ORS	Oregon Revised Statutes
OPCC	opinion-of-probable construction-cost
OSSAC	Oregon Seismic Safety Advisory Committee
OSSC	State of Oregon Structural Specialty and Fire and Life Safety Code
OWUC	Oregon Water Utility Council
PGE	Portland General Electric
PNW	Pacific Northwest
PPCPs	pharmaceuticals and personal care products
ppd	pounds per day
PWB	Portland Water Bureau
RM	Richter scale magnitude
RWF	Raw Water Facility
SCADA	supervisory control and data acquisition
SCM	streaming current monitor
SDWA	Safe Drinking Water Act
the Act	Oregon Drinking Water Quality Act
TOC	total organic carbon
TVWD	Tualatin Valley Water District
UBC	Uniform Building Code
UCM	Unregulated Contaminant Monitoring
UCMR	Unregulated Contaminant Monitoring Rule
USGS	United States Geological Survey
WRWTP	Willamette River Water Treatment Plant
WWSA	Willamette River Water Supply Agency
WWSP	Willamette Water Supply Program
µg/L	micrograms per liter

ATTACHMENT A

EXECUTIVE SUMMARY

ES.1 Introduction

The 2017 Willamette River Water Treatment Plant Master Plan Update (2017 MPU) for the cities of Wilsonville and Sherwood defines the strategy to meet future demands, boost supply resiliency and reliability, and support responsible growth.

Commissioned in 2002, the Willamette River Water Treatment Plant (WRWTP) has a treatment capacity of 15 mgd. Of this capacity, Wilsonville owns 10 mgd, and the Tualatin Valley Water District (District) initially owned 5 mgd. The District invested in the plant's construction, oversizing many of its facilities to enable expansion for its own future water needs.

The existing property along the Willamette River in Wilsonville is irregularly shaped, creating two semi-contiguous parcels called the Lower Site and the Upper Site. During original design, the Lower Site, home to the existing treatment plant, would allow for an expansion of up to 60 mgd. The Upper Site was identified for future development in the *Willamette River Water Treatment Plant Master Plan* (MWH, 2006), which demonstrated enough space for at least 100 mgd additional capacity. Combined, both sites have a 160 mgd potential total capacity.

Since the 2006 Master Plan was published, several actions occurred that affect both construction and operational planning for expanding the WRWTP:

- In 2012, the District sold its 5 mgd of plant capacity to the City of Sherwood.
- In 2013, the District and the City of Hillsboro named the mid-Willamette supply alternative as their preferred supplemental supply, which laid the foundation for the Willamette Water Supply Program (WWSP).
- In 2014, the city of Wilsonville led a coalition of utilities that petitioned the Oregon Health Authority (OHA) for the right to recognize the disinfection benefits from intermediate ozonation.
- In 2015, the City and WWSP stakeholders updated the WRWTP Master Plan (MWH, 2006) in the 2015 MPU (Carollo, 2016) to outline how the existing plant could be expanded to meet future demand.
- As of 2017, the WRWTP is expected to supply Wilsonville and Sherwood exclusively. However, the oversized river intake and raw water pumping station will be expanded to supply raw water to both the WRWTP and the proposed WWSP treatment facilities.

The 2017 MPU updates the 2015 WRWTP MPU and addresses these changes. The 2017 MPU has the following key objectives.

1. To define the steps for expanding the existing WRWTP infrastructure to maximize the return on previous investments.
2. To optimize process selection and layout to meet capacity and water quality goals at the expanded WRWTP.
3. To strategize near- and long-term plant expansion for a 20-year planning horizon and cash-flow to guide future financial planning.
4. To ensure that WWSP-related facilities, including raw water pumping, surge protection, and standby power infrastructure, do not prevent the cities of Wilsonville and Sherwood from meeting their ultimate build-out demands for the existing WRWTP on the current site.

ES.2 Plant Expansion and Level of Service Goals

In addition to these objectives, levels of service (LOS) goals were used to plan the preliminary site and estimate its construction and operations costs.

Municipal utilities in the United States and elsewhere commonly use LOS goals to evaluate systems and operations. LOS goals can be defined in terms of the customer’s experience of utility service and/or technical standards based on professional expertise of utility staff.

LOS goals can guide investments in maintenance, repair, and replacement. For new assets, they can be used to set design criteria and prioritize needs. Using a structured decision-making process that incorporates LOS goals helps a utility reach desired service objectives and minimize life-cycle costs.

The LOS goals address only the facilities required to operate the expanded WRWTP and do not apply to City infrastructure outside of the WTP fence line. The goals were first developed with participants of the 2015 MPU during a project workshop and adopted by the participants’ governing bodies. These LOS goals, which were revisited and re-confirmed during a 2017 MPU workshop, are shown in Table ES.1.

Table ES.1 Cities of Wilsonville and Sherwood Treatment LOS Goals

LOS Goal	Regional Event (Seismic)	Local Event (Non-Seismic)
“Following a W catastrophic event ...	2,500 year	Per occurrence
...within X days/weeks of the event...	48 hours	14 days
...deliver Y % of average day demand...	50% of nameplate capacity	100% of nameplate capacity
...with Z water quality.”	Potable (at minimum regulatory requirement)	Potable (at plant's intended treatment processes and procedures)

As stated in Table ES.1, 48 hours after a 2,500-year regional (seismic) event, 50 percent of the nameplate treatment plant production capacity will be available, with potable water quality that meets minimum regulatory requirements. Within 14 days of a local (non-seismic) event, 100 percent of the nameplate production capacity will be available with potable water quality at the plant's intended treatment processes and procedures.

The costs for achieving these LOS goals were developed and confirmed to fall within the cities’ affordability and risk tolerances. We recommend these LOS goals continue to guide the WRWTP planning efforts.

ES.3 Existing Facilities and Operational Performance

When the 2006 WRWTP Master Plan was completed approximately four years after plant start-up, the City of Wilsonville was the only consumer of WRWTP finished water. In mid-2012, the City of Sherwood started using finished water from the WRWTP as its primary supply. To meet the demands of both cities, the plant went from operating on a daily start/stop basis for 8 to 16 hours per day depending on demand to operating 24 hours per day, year-round. Since the hours of operation impact plant operations and the expanded plant will continue to operate

continuously, the plant performance data evaluated for this Master Plan Update was limited to 2012 through 2014, as included in the 2015 MPU. No additional plant performance data was analyzed as part of this 2017 MPU.

The 2015 MPU review of plant performance data demonstrates exceptional operational performance for turbidity removal, disinfection levels, total organic carbon (TOC) removal, and low disinfection by-product (DBP) formation. The extremely narrow range between the 5 and 95 percentile value for key water quality parameters such as turbidity, pH, and chlorine residual is a testament to the plant's robust design and its operators' attention to continuous optimal performance.

ES.4 Historical Raw and Finished Water Quality

Raw water quality data from May 2006 through 2014 was collected, reviewed, and compared to the data in the 2006 Master Plan and 2015 MPU. The trace-level contaminants detected in the raw water have not been detected in the finished water and were therefore assumed to be removed through the treatment processes.

The historical finished water quality data confirms that the plant consistently surpasses existing finished water regulatory requirements. The high-quality source water and robust treatment process result in excellent finished water quality delivered to customers. With only minor modifications, the current treatment processes are expected to continue to meet future regulatory requirements.

ES.5 Existing Infrastructure

The 2017 MPU offers additional electrical, seismic, and life-safety assessment for the WRWTP.

ES.5.1 Electrical Supply and Distribution CIP

To meet the 2022 site capacity of nominally 20 mgd, the plant's electrical supply and distribution system will need significant upgrades. Preliminary engineering for the capacity expansion will require detailed analysis of electrical supply alternatives, including backup power requirements. Improving the "backbone" of electrical and standby power is recommended in parallel with the expansion project.

ES.5.2 Seismic Evaluation CIP

The preliminary structural analysis identified both structural and non-structural vulnerabilities that may affect plant performance in a regional catastrophic seismic event. This 2017 MPU recommends including seismic retrofits to minimize infrastructure downtime and ensure plant performance after a catastrophic event.

ES.5.3 Life-Safety Evaluation CIP

The preliminary life-safety analysis identified issues about building code compliance and structural improvements. This 2017 MPU recommends modifications to support worker safety after a catastrophic seismic event.

ES.6 WRWTP Expansion CIP

Projected demand was submitted by the cities of Wilsonville and Sherwood based on each city's planning studies. To meet the cities' combined day demand of 30 mgd by 2036 as shown in Figure ES.1, this 2017 MPU recommends the following expansion and phasing:

- Preliminary design of the near-term expansion will likely begin in 2019 to bring WRWTP capacity from 15 mgd to 20 mgd by 2022.
- Total raw water intake capacity for both WRWTP and WWSP will be between 80 mgd and 84 mgd by 2026.
- Preliminary design of the 30 mgd expansion will likely begin in 2032 to bring the nameplate capacity of the WRWTP from 20 mgd to 30 mgd by 2036.
- Capacity expansion projects should be completed two years before the capacity is needed to allow flexibility. The 20 mgd capacity expansion will be completed in 2022 and the 30 mgd capacity expansion in 2036.




Figure ES.1 WRWTP Capacity Projections and Recommended Expansion Phasing

ES.6.1 20-MGD Expansion CIP

As outlined in the 2015 MPU, rather than constructing additional basins, the existing treatment processes will be updated for the 20 mgd WRWTP expansion. For the primary treatment processes, the uprating will include the following.

- Increasing the Actiflo® flow rate from 7.5 mgd per basin to 10 mgd per basin.
- Increasing the ozonation basin flow rate from 7.5 mgd per basin to 10 mgd per basin. This will decrease the ozone contact time from 15 to 11 minutes, which still allows sufficient contact time for 1-log *Cryptosporidium* inactivation, provided increased levels of ozone can be dosed in the contactor.
- Increasing the filtration rate to a nominal rate of 5.7 gpm/sf and a maximum rate of 7.5 gpm/sf when one filter is off-line, and to a nominal rate of 7.5 gpm/sf and a maximum

rate of 10 gpm/sf when one basin is offline. This increased filtration rate will require approval from OHA prior to increasing plant capacity. To support OHA approval, a full-scale pilot study should be conducted in which the filtration rate is gradually increased and water quality is closely monitored.

Figure ES.2 depicts the site layout following completion of the 20-mgd capacity expansion.

ES.6.2 30-MGD Expansion CIP

The following two alternatives were considered for the 30 mgd expansion.

1. Install one additional process train: 1 Actiflo® basin, 1 ozone basin, and 2 filters.
2. Install two additional treatment process trains: 2 Actiflo® basins, 2 ozone basins, and 4 filters.

Both alternatives would need to meet the LOS goal after a regional seismic event. However, Alternative 1 would have limited treatment rates during equipment maintenance. For example, during filter backwash, the maximum filtration rate of 12 gpm/sf would limit finished water production to 8 mgd. Conversely, the capital and operating costs required for Alternative 2 make it undesirable because it raises rates for Wilsonville and Sherwood residents. Therefore, we recommend that the WRWTP construct Alternative 1 and identify an additional water supply to meet the LOS goal after a regional seismic event.

Using Alternative 1, the 30 mgd expansion requires the following major construction projects:

- One Actiflo® basin.
- One ozonation basin.
- Two filters.
- One 35-foot diameter gravity thickener.

Figure ES.3 depicts the site layout for the 30-mgd capacity expansion. As recommended in the 2015 MPU, space dedicated for future AOP processes (such as UV treatment) improves the ability of the expanded WRWTP to treat constituents of emerging concern.

ATTACHMENT A

-This Page Intentionally Left Blank-




Figure ES.2 Site Plan – 20-MGD Capacity Expansion

-This Page Intentionally Left Blank-




Figure ES.3 Site Plan – 30-MGD Capacity Expansion

-This Page Intentionally Left Blank-

ES.6.3 Electrical Expansion CIP

The electrical system is loaded above 80 percent of listed capacity and is considered overloaded. Additionally, the existing emergency generator is not connected to all WRWTP equipment; for example, it is wired only to Actiflo® Basin 2. Furthermore, its capacity is sufficient only to power the 4 mgd raw and finished water pumps.

We recommend that the plant upgrade its existing electrical equipment that as part of the 20 mgd expansion to ensure that service is not interrupted by electrical fault. The following upgrades are recommended:

- **Replace switchgear** with 15-KV metering switchgear and 5 KV transformer, which should be sufficient to power the WRWTP through 60 MGD
- **Replace emergency generator** with a 2-MW generator wired directly to the 15-KV metering switchgear. This will allow all plant equipment run on the emergency generator.
- **Rewire plant** to connect all finished water pumps to the 5-V transformer/switchgear. This will leave sufficient capacity on the remaining transformers to power the rest of the plant.

ES.6.4 Repair and Replacement CIP

In addition to the seismic and life-safety CIP, the WRWTP requires ongoing maintenance/repair and replacement (R&R) of its existing infrastructure to meet service goals. This 2017 MPU summarizes repair and replacement projects for the next 20 years.

ES.7 CIP Approach and Schedule

The existing WRWTP must be expanded to 20 mgd by 2022 and to 30 mgd by 2036.

Table ES.2 breaks down the capital costs for the two expansions and related repair and replace projects, electrical equipment upgrades, life safety repairs, and seismic retrofits necessary to maintain plant operation. Table ES.3 details repair and replace projects by year and dollar amount. The CIP cost estimates are classified as American Association of Cost Engineers (AACE) Class 4 or Class 5 estimates. The Class 4 estimates have an expected level of accuracy of +50% to -30%. The Class 5 estimates have an expected level of accuracy of +100% to -50%. Figures ES.4 and ES.5 depict the near term and total CIP costs, respectively, as broken down by project.

Table ES.2 Estimated CIP Costs (2017 Dollars)

Project	Cost ⁽¹⁾	% Water Operations	% SDCs
20 mgd Expansion	\$3,700,000	--	100%
30 mgd Expansion	\$38,640,000	--	100%
Life Safety Repairs	\$620,000	100%	--
Seismic Retrofits	\$1,160,000	100%	--
Electrical Upgrades	\$11,090,000	100%	--
Operations - Repair and Replace	\$19,180,000	100%	--

Notes:

(1) Includes 15% design fee and 10% administrative cost.

(2) All costs are rounded up to nearest \$10,000.

ATTACHMENT A

Table ES.3 Operations – Repair and Replace Estimated CIP Cost (2017 Dollars)

Repair and Replace Year	Cost ⁽¹⁾	% Water Operations	% SDCs
2019	\$2,030,000	100%	--
2020	\$1,430,000	100%	--
2021	\$20,000	100%	--
2022	\$4,490,000	100%	--
2023	\$20,000	100%	--
2024	\$20,000	100%	--
2025	\$20,000	100%	--
2026	\$20,000	100%	--
2027	\$5,220,000	100%	--
2028	\$20,000	100%	--
2029	\$20,000	100%	--
2030	\$20,000	100%	--
2031	\$20,000	100%	--
2032	\$2,480,000	100%	--
2033	\$20,000	100%	--
2034	\$20,000	100%	--
2035	\$20,000	100%	--
2036	\$3,400,000	100%	--

Notes:

(1) Includes 10% administrative cost.

To meet growing water demand from Wilsonville and Sherwood, the existing WRWTP will first be expanded to a capacity of 20 mgd, followed by an expansion to 30 mgd near the end of this planning horizon. Table ES.4 summarizes a preliminary and final design and construction schedule.

Table ES.4 WRWTP Expansion Design and Construction Schedule

Project	Approx. Service Year	Duration (Months)		Start Date
		Design	Construction	
20 MGD Capacity Expansion	2022	12	18	2019
Electrical Upgrades	2022	12	12	2019
Life Safety Repairs	2022	6	6	2020
Seismic Retrofits	2022	6	6	2020
30 MGD Capacity Expansion	2036	12	24	2033
Operations – Repair and Replace				
Year 1	2018	0	0	--
Year 2	2019	0	6	2018

ATTACHMENT A

Table ES.4 WRWTP Expansion Design and Construction Schedule (Continued)

Project	Approx. Service Year	Duration (Months)		Start Date
		Design	Construction	
Year 3	2020	0	6	2019
Year 4	2021	0	3	2021
Year 5	2022	6	9	2020
Year 6	2023	0	3	2023
Year 7	2024	0	3	2024
Year 8	2025	0	3	2025
Year 9	2026	0	3	2026
Year 10	2027	0	9	2026
Year 11	2028	0	3	2028
Year 12	2029	0	3	2029
Year 13	2030	0	3	2030
Year 14	2031	0	3	2031
Year 15	2032	0	9	2032
Year 16	2033	0	3	2033
Year 17	2034	0	3	2034
Year 18	2035	0	3	2035
Year 19	2036	0	12	2035

ATTACHMENT A




Figure ES.4 RWTP Near-Term CIP Costs by Project (2017 Dollars)

ATTACHMENT A




Figure ES.5 WRWTP Total CIP Costs by Project (2017 Dollars)

ATTACHMENT A

-This Page Intentionally Left Blank-

The final project document chapters and appendices in their entirety
are here:

www.ci.wilsonville.or.us/WTPMPupdate

CONCLUSIONARY FINDINGS

STATEWIDE PLANNING GOALS

Statewide Planning Goal #1 - Citizen Involvement (OAR 660-015-0000(1)): *To develop a citizen involvement program that insures the opportunity for citizens to be involved in all phases of the planning process.*

Response: A web page was created specifically to collect comments on the draft 2017 Willamette River Water Treatment Plant Master Plan (the Plan); no public comment was received via the project web page. City staff held a work session with the Planning Commission on December 13, 2017.

The City of Wilsonville has provided notice of public hearings before the Planning Commission consistent with the Planning and Land Development Ordinance requirements. Such notices were posted in the local newspaper, in three locations throughout the City and on the website. In addition, they were mailed to 115 property owners within the City limits and a list of interested agencies. The City has conducted a public involvement process and no major areas of controversy have been identified. At the upcoming public hearing, the public will be afforded an opportunity to provide public testimony to the Planning Commission as part of deliberations on this matter. The City Council will also hold a public hearing on this proposal. **This goal is met.**

Statewide Planning Goal #7 – Areas Subject to Natural Disasters and Hazards (OAR 660-015-0000(7)): *To protect people and property from natural hazards.*

Response: This Plan update includes technical analysis and alternative scenarios for impacts on the Willamette River Water Treatment Plant in a catastrophic seismic event. In addition, the Plan provides recommendations for seismic retrofits to minimize ‘down time’ of existing infrastructure and impact on water quality while ensuring treatment plant performance following a catastrophic seismic event. The adoption of this Plan will identify projects that will help minimize the risk of water treatment disruption and maintenance of safe water quality for the City of Wilsonville customers and its regional partners. **This goal is met.**

Statewide Planning Goal #11 – Public Facilities and Services (OAR 660-015-0000(11)): *It is the purpose of Goal 11 to plan and develop a timely, orderly and efficient arrangement of public facilities and services to serve as a framework for urban and rural development. Cities are required to develop public facilities plans for their UGBs.*

Response: This proposal will update the Willamette River Water Treatment Plant Master Plan, which documents the current condition of the water system, predicts future demand, and evaluates the cost and timing of necessary operational, maintenance, and capital improvements over the next 20 years. **This goal is met.**

COMPREHENSIVE PLAN

In recognition of Statewide Planning Goals and to provide a framework for development of water treatment facilities, the following policy and implementation measures have been established:

GOAL 1.1 To encourage and provide means for interested parties to be involved in land use planning processes, on individual cases and City-wide programs and policies.

Policy 1.1.1 The City of Wilsonville shall provide opportunities for a wide range of public involvement in City planning programs and processes.

Response: On December 13, 2017, the Planning Commission held a work session on the purpose and technical summary in the proposed update to the Willamette River Water Treatment Plant Master Plan. Public notice of the public hearings was mailed to all property owners within 250' of the site as well as to agencies and interested individuals. **The above criteria are supported by the Planning Commission process.**

Implementation Measure 1.1.1.a Provide for early public involvement to address neighborhood or community concerns regarding Comprehensive Plan and Development Code changes. Whenever practical to do so, City staff will provide information for public review while it is still in "draft" form, thereby allowing for community involvement before decisions have been made.

Response: The Planning Commission practice is to conduct a minimum of one work session per legislation agenda item allowing for early involvement into the proposed concepts. This item has had numerous work sessions. This item was last discussed at the Planning Commission meeting on December 13, 2017. Draft versions of the proposed Master Plan have been available in paper and digital form, as well as on the city web site. **This criterion is met.**

Implementation Measure 1.1.1.e Encourage the participation of individuals who meet any of the following criteria:

- 1. They reside within the City of Wilsonville.*
- 2. They are employers or employees within the City of Wilsonville.*
- 3. They own real property within the City of Wilsonville.*
- 4. They reside or own property within the City's planning area or Urban Growth Boundary adjacent to Wilsonville.*

Response: Through the work-sessions, public notification and public hearing schedule, the City has encouraged the participation of a wide variety of individuals addressing the groups listed above. **This criterion is met.**

Implementation Measure 1.1.1.f Establish and maintain procedures that will allow any interested parties to supply information.

ATTACHMENT B

Response: The established procedures, public notification process and enhanced city web site notifications all allow interested parties to supply information. The City's Citizen Request Module (CRM) provides another venue for citizens to comment on projects. **This criterion is satisfied.**

GOAL 1.2: For Wilsonville to have an interested, informed, and involved citizenry.

Policy 1.2.1 The City of Wilsonville shall provide user-friendly information to assist the public in participating in City planning programs and processes.

Response: Through the work session schedule, public hearing notices, available Planning Commission meeting minutes and project documents on the city web site, the City has informed and encouraged the participation of a wide variety of individuals. **This criterion is met.**

GOAL 3.1: To assure that good quality public facilities and services are available with adequate capacity to meet community needs, while also assuring that growth does not exceed the community's commitment to provide adequate facilities and services.

Policy 3.1.1 The City of Wilsonville shall provide public facilities to enhance the health, safety, educational, and recreational aspects of urban living.

Response: The purpose of this Master Plan update is to document existing conditions and demand of the Water System, incorporate Level of Service goals from the 2015 Willamette River Water Treatment Plant Master Plan, address capacity expansion strategies, identify repairs, replacements, and upgrades, and develop an implementation plan in order to provide for future growth. The Plan recommends improving electrical and power supply, seismic retrofits, phasing capacity expansion in 2022 and 2036, and upgrading equipment to accommodate capacity expansion. **This criterion is met.**

Implementation Measure 3.1.1.a The City will continue to prepare and implement master plans for facilities/services, as sub-elements of the City's Comprehensive Plan. Facilities/services will be designed and constructed to help implement the City's Comprehensive Plan.

Response: The City is proposing this Master Plan update in order to carry out and be consistent with the policies of the Comprehensive Plan. In order to keep up with growth and development, the plan recommends a two-phase capacity expansion by 2036 and upgrading/replacing aging equipment and infrastructure. **This criterion is satisfied.**

Policy 3.1.4 The City of Wilsonville shall continue to operate and maintain the wastewater treatment plant and system in conformance with federal, state, and regional water quality standards.

Response: The proposal will establish level of service goals to ensure the facility's equipment and operation conform to federal, state and regional water quality standards as more growth and development occur. **This criterion is satisfied.**

Implementation Measure 3.1.4.c Based on the service capacity and the permit monitoring

ATTACHMENT B

program, the City shall plan and appropriately schedule future expansions of the wastewater treatment plant

Response: The proposal includes the existing capacity and operational performance of the waste Water Treatment Plant, capacity and demand projections, and recommendations for future expansion phasing. The first phase of expansion is scheduled to be completed by 2022 and the second phase is scheduled to be completed by 2036. **This criterion is satisfied.**

Policy 3.1.5 The City shall continue to develop, operate and maintain a water system, including wells, pumps, reservoirs, transmission mains and a surface water treatment plant capable of serving all urban development within the incorporated City limits, in conformance with federal, state, and regional water quality standards. The City shall also continue to maintain the lines of the distribution system once they have been installed and accepted by the City.

Response: The City has continued to operate and maintain the existing water system consistent with Federal, State and Regional Water quality standards and is working on improving the system by updating the Willamette River Water Treatment Plant Master Plan. In general, the current condition of the Wilsonville distribution, treatment and storage infrastructure is very good. No major pressure or volume deficiencies were identified and there are currently no major facility deficiencies. However, a large excess capacity does not exist either, and increased capital, and operation and maintenance spending will be needed to keep pace with growth in order to avoid future deficiencies. **This criterion is met.**

Implementation Measure 3.1.5.a The City shall review and, where necessary, update the Water System Master Plan to conform to the planned land uses shown in the Comprehensive Plan and any subsequent amendments to the Plan.

Response: This purpose of this proposal is to update the Water Treatment Plant Master Plan. Therefore, **this criterion is met.**

GENERAL CONCLUSIONARY SUMMARY OF FINDINGS

- The Willamette River Water Treatment Plant Master Plan is consistent with the City's Comprehensive Plan goals and policies.
- In general, the current condition of the Water Treatment Plant distribution, treatment, and storage infrastructure is very good.
- Future demand and growth are based on analysis of the actual demand growth from 2000 to 2010.
- Approval of the Master Plan extends the planning period to 2036.
- The City has more than adequate water resources (e.g., water rights) to meet all estimated future demands for a build-out population of 52,400.
- The Capital Improvement Plan includes projects for two future expansions, electrical upgrades, repair and replacement.
- Biggest concerns are keeping up with growth, addressing aging infrastructure, and improvement seismic resiliency.

ATTACHMENT B

- Plan recommends improving electrical and power supply in parallel with the next expansion project.
- Plan recommends seismic retrofit to minimize impact on plant performance during following a catastrophic event.
- Plan recommends capacity expansion and phasing strategy to complete expansion by 2022 and 2036
- Plan recommends continuing to use Level of Service goals adopted in the 2015 Master Plan Update.
- Plan recommends addressing issues related to building code or structural improvement requirements to protect worker safety following a catastrophic seismic event.

As is evidenced by the staff report and findings contained herein, the proposal to update the City's Water System Master Plan is consistent with the applicable statewide planning goals and criteria contained in the Comprehensive Plan.

ATTACHMENT C

Attachment C: Full version of the Water Treatment Plant 2017 Master Plan Update access:

www.ci.wilsonville.or.us/WTPMUpdate

Planning Commission Briefing

February 14, 2018

2017 Water Treatment Plant Master Plan Update

Nancy Kraushaar, PE
Community Development Director

Jude Grounds, PE,
Carollo Engineers, Inc.



Purpose of 2017 Master Plan Update

- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades



Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, AeroGRID, IGN, SIA, User Contributed Data

A Brief History

- Built / Operational in 2002 (\$47M)
- Joint Ownership with TVWD
- 70 MGD Design*
- Conservative LOS goals/operations
- Current Capacity: 15 MGD (10 – WV, 5 – Sherwood)

Still state-of-the-art




Technical Summary:

Multi-barrier approach guides design and operational philosophy

- Turbidity / Particles
- Pathogens
- Tastes and Odors
- Trace Organics / CEC's

●		●	
	●		●
	●	●	
	●	●	



Purpose of 2017 Master Plan Update

- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades

Level of Service Goals (Water Quality)

	Water Quality Goals	Design / Operating Criteria
A	Keep current, very conservative water quality goals. Keep very conservative operational criteria (SF = 2)	Actiflo: 7.5 mgd (rated at 14 MGD) Filters: 5 mgd (rated at 10 MGD) Ozone/Chlorine: 1-log Crypto inactivation
B	Keep current, very conservative water quality goals. Modified operational criteria (SF= 1.5)	Actiflo: 10 mgd Filters: 6.7 mgd Ozone/Chlorine: 1-log Crypto inactivation
C	Lower WQ goals using aggressive operational criteria (SF = 1.0)	Actiflo: 14 mgd Filters: 7.9 mgd Ozone/Chlorine: 1-log Crypto inactivation

Level of Service Goals (Seismic)


LOS Goal	Regional Event (Seismic)	Local Event (Non-Seismic)
"Following a W catastrophic event ...	2,475 year	Per occurrence
...within X days/weeks of the event...	48 hours	14 days
...deliver Y % of average day demand...	50% of nameplate	100% of nameplate
...with Z water quality."	Potable (at minimum regulatory requirement)	Potable (at plant treatment processes and procedures)

Purpose of 2017 Master Plan Update

- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades


20 MGD Capacity Expansion

- Upgrading existing equipment
- Minor equipment upgrades to support upgrading
- Seismic / Life Safety Improvements
- Filtration pilot study or demonstration
- Recommend electrical upgrade



30 MGD Capacity Expansion

- Expand at updated design criteria
- Designed to new seismic code
- Reduces construction cost
- Conserve space for 60 MGD buildout at Lower Site





30 MGD WRWTP EXPANSION AND RWF LOWER SITE PLAN

Lower Site Repair and Replace

- Ongoing equipment repair and replacement schedule
 - Annual basis – Veolia

Seismic Retrofits

- Repairs to existing facilities to bring them to current seismic code
- Example: Addition of concrete braces to WWEQ Basin



Life Safety Repairs

- Tasks pertaining to building and hazard codes
- Projects include fall protection, hand railing, GFCIs, etc.



Equipment Repair & Replace

- Addresses equipment replacement due to service life
- Whenever possible ties in with capacity expansion

Purpose of 2017 Master Plan Update


- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades

Coordinated Facility Upgrades

Coordination with Willamette Water Supply

- Raw Water Pump Station Upgrade (24/25)
- Seismic Upgrade (Secant Pile Wall) (21/22)
- Generator Upgrade (18/19)**
- Electrical (Substation) Upgrades (18/19/20)
- Surge Tanks (18/19)**

** - WV Project




CIP Schedule

Project	Approx Service Year	Duration (Months)		Start Date
		Design	Construction	
20 MGD Capacity Expansion	2022	12	18	2019
Life Safety Repairs	2022	6	6	2021
Seismic Retrofits	2022	4	6	2021
Electrical Upgrades	2022	6	8	2020
30 MGD Capacity Expansion	2036	10	24	2033
Operations – Repair and Replace	Ongoing Annual Projects			

CIP Project Estimate

Project	Cost	% Water Operations	% SDCs
20 mgd Expansion	\$3,893,165	--	100%
30 mgd Expansion	\$32,518,600	--	100%
Life Safety Repairs	\$616,153	100%	--
Seismic Retrofits	\$1,151,866	100%	--
Electrical Upgrades	\$11,082,506	100%	--
Operations - Repair and Replace	\$19,045,704	100%	--

Implementation Plan/CIP



Master Plan - Next Steps

- MP Adoption Process
 - Planning Commission Work Session 12/13/17
 - Planning Commission Hearing 2/14/18
 - City Council Work Session (3/5/18)
 - City Council 1st Reading (3/5/18)
 - City Council 2nd Reading (3/19/18)
 - Effective Date 4/19/18

Questions?



From: plan.amendments@state.or.us
To: [Bergeron, Tami](#)
Subject: Confirmation of PAPA Online submittal to DLCD
Date: Wednesday, January 10, 2018 4:33:45 PM

Wilsonville

Your notice of a proposed change to a comprehensive plan or land use regulation has been received by the Oregon Department of Land Conservation and Development.

Local File #: LP18-0002

DLCD File #: [001-18](#)

Proposal Received: 1/10/2018

First Evidentiary Hearing: 2/14/2018

Final Hearing Date: 3/5/2018

Submitted by: bergeron@ci.wilsonville.or.us

If you have any questions about this notice, please reply or send an email to plan.amendments@state.or.us.

**NOTICE OF LEGISLATIVE PUBLIC HEARING
BEFORE THE PLANNING COMMISSION:
2017 WATER TREATMENT PLANT
MASTER PLAN UPDATE — LP18-0002**



Planning Commission:

On **Wednesday, February 14, 2018, beginning at 6:00 p.m.**, the Wilsonville Planning Commission will hold a public hearing regarding the following. The Planning Commission will consider whether to recommend adoption of the 2017 **Water Treatment Plant Master Plan Update LP18-0002** to the City Council. No additional mailed notice will be sent to you unless you either:

- Submit testimony or sign in at the Planning Commission hearing, or
- Submit a request, in writing or by telephone, to the Planning Division.

City Council:

The Wilsonville City Council is scheduled to hold a public hearing on the proposal on **Monday March 05, 2018 at 7:00 p.m.** after which it may make the final decision.

The hearings will take place at **Wilsonville City Hall, 29799 SW Town Center Loop East, Wilsonville, Oregon.**

A complete copy of the relevant file information, including the staff report, findings, and recommendations, will be available for viewing seven days prior to each public hearing at Wilsonville City Hall, at the Wilsonville Public Library and on the city's

Summary of Proposal:

The City of Wilsonville, is completing a master plan update for the Willamette River Water Treatment Plant. The master plan update identifies short term and long range water needs for the City, the treatment technologies to be used, and the capital improvements needed to meet these future goals.

The public is also invited to review and provide comments on the master plan update through an on-line open house located at www.ci.wilsonville.or.us/WTPMPupdate.

How to Comment: Oral or written testimony may be presented at the public hearing. Written comments on the proposal to be submitted into the public hearing record is welcome prior to the public hearing. To have your written comments or testimony distributed to the Planning Commission before the meeting, it must be received by 2 pm on **February 7, 2018**. Direct such written comments or testimony to:

Eric Mende, P.E. Engineering Division
29799 SW Town Center Loop East, Wilsonville, Oregon, 97070
mende@ci.wilsonville.or.us, (503) 682-4960

Copies of the full draft plan is available from the Wilsonville Planning Division at the above address and **at the project website: <http://www.ci.wilsonville.or.us/WTPMPupdate>**

Note: Assistive Listening Devices (ALD) are available for persons with impaired hearing and can be scheduled for this meeting. The City will also endeavor to provide qualified sign language interpreters and/or bilingual interpreters, without cost, if requested at least 48 hours prior to the meeting. To obtain such services, please call Tami Bergeron, Planning Administrative Assistant at (503) 682-4960.

**NOTICE OF A LEGISLATIVE PUBLIC HEARING
BEFORE THE WILSONVILLE PLANNING COMMISSION:
2017 WATER TREATMENT PLANT MASTER PLAN UPDATE
LP18-0002**

Planning Commission:

On **Wednesday, February 14, 2018, beginning at 6:00 p.m.**, the Wilsonville Planning Commission will hold a public hearing regarding adoption of the 2017 Water Treatment Plant Master Plan Update (Case File # LP18-0002). The Planning Commission will consider whether to recommend adoption of the amendment to the City Council. No additional mailed notice will be sent to you unless you either:

- Submit testimony or sign in at the Planning Commission hearing, or
- Submit a request, in writing or by telephone, to the Planning Division.

City Council:

The Wilsonville City Council is scheduled to hold a public hearing on the proposal on **Monday, March 05, 2018 at 7:00 p.m.** after which it may make the final decision.

The hearings will take place at **Wilsonville City Hall, 29799 SW Town Center Loop East, Wilsonville, Oregon**. A complete copy of the relevant file information, including the staff report, findings, and recommendations will be available for viewing seven days prior to each public hearing at Wilsonville City Hall, at the Wilsonville Public Library and on the city's web site.

Summary of Proposal: 2017 Water Treatment Plant Master Plan Update – LP18-0002

The City of Wilsonville is completing a Master Plan Update for the Willamette River Water Treatment Plant. The Master Plan Update identifies short and long range water needs for the City, the treatment technologies to be used, short term and long term repairs and replacements, and capital improvements needed to meet future goals. The Master Plan Update document can be viewed at www.ci.wilsonville.or.us/WTPMPupdate.

How to Comment

Comments may be submitted through a virtual open house forum accessed via the internet at www.ci.wilsonville.or.us/WTPMPupdate. Comments received through the virtual open house will be summarized by staff for the public hearing. Oral or written testimony may be presented at the public hearing. Written comment on the proposal to be submitted into the public hearing record is welcome prior to the public hearings. To have your written comments or testimony distributed to the Planning Commission before the meeting, it must be received by 2 pm on **Tuesday, February 7, 2018**. Direct such written comments or testimony to:

Eric Mende, P. E. Engineering Division
29799 SW Town Center Loop East,
Wilsonville, Oregon, 97070;
mende@ci.wilsonville.or.us
(503) 682-4960

A copy of the full draft plan is available from the Wilsonville Planning Division at the above address.

Note: Assistive Listening Devices (ALD) are available for persons with impaired hearing and can be scheduled for this meeting. The City will also endeavor to provide qualified sign language interpreters and/or bilingual interpreters, without cost, if requested at least 48 hours prior to the meeting. To obtain such services, please call Tami Bergeron, Planning Administrative Assistant at (503) 682-4960.

**PLANNING COMMISSION HEARING
STAFF REPORT**



Meeting Date: 02/14/2018		Subject: 2017 Water Treatment Plant Master Plan Update – LP18-0002	
		Staff Member: Eric Mende, PE, Capital Projects Engineering Manager Department: Community Development	
Action Required		Advisory Board/Commission Recommendation	
<input checked="" type="checkbox"/> Motion <input checked="" type="checkbox"/> Public Hearing Date:02/14/18 <input type="checkbox"/> Ordinance 1 st Reading Date: <input type="checkbox"/> Ordinance 2 nd Reading Date: <input type="checkbox"/> Resolution <input type="checkbox"/> Information or Direction <input type="checkbox"/> Information Only <input type="checkbox"/> Council Direction <input type="checkbox"/> Consent Agenda		<input type="checkbox"/> Approval <input type="checkbox"/> Denial <input type="checkbox"/> None Forwarded <input checked="" type="checkbox"/> Not Applicable	
		Comments:	
Staff Recommendation: N/A			
Recommended Language for Motion: Motion to Approve a Recommendation to City Council for Adoption of the 2017 Water Treatment Plant Master Plan Update.			
Project / Issue Relates To: <i>[Identify which goal(s), master plans(s) your issue relates to.]</i>			
<input checked="" type="checkbox"/> <u>Council Goals/Priorities</u> -Fiscal Discipline, Environmental Stewardship, Well Maintained Infrastructure		<input type="checkbox"/> Adopted Master Plan(s)	<input type="checkbox"/> Not Applicable

ISSUE BEFORE PLANNING COMMISSION:

The City of Wilsonville is completing a Master Plan Update for the Willamette River Water Treatment Plant (WTP). As with all Master Plans, this updated Master Plan requires a formal adoption process that includes a hearing before the Planning Commission, a recommendation from Planning Commission to City Council, and hearing and adoption by ordinance by City Council.

EXECUTIVE SUMMARY:

Planning Commissioners may recall that approximately one year ago, staff brought forward a different Master Plan (2015 Master Plan Update) which primarily addressed the potential addition of a second treatment plant to Wilsonville’s Water Treatment Plant site, to be owned and operated by Tualatin Valley Water District and other parties. Since that (2015) Master Plan primarily addressed facilities that would not be owned and maintained by Wilsonville, or provide water to Wilsonville residents, Planning Commission members questioned the appropriateness of conducting a hearing process for adoption of that 2015 Plan. The adoption process was therefore cancelled pending preparation of a Master Plan specifically targeted on the existing Wilsonville facility. The 2017 Master Plan Update for consideration tonight specifically addresses the existing Willamette River Water Treatment Plant, which currently provides treated water only to the citizens of Wilsonville and Sherwood. The primary goals of the 2017 Master Plan Update are:

- 1) To confirm the quantity and timing of long range water delivery from the WTP;
- 2) To identify and select appropriate treatment technologies and design criteria for future water treatment facilities;
- 3) To evaluate existing Water Treatment Plant facilities for upgrades and replacements; and
- 4) To identify the capital costs and timing required to meet the future water supply and level of service goals.

EXPECTED RESULTS:

A recommendation to City Council for adoption, by Ordinance, of the 2017 Water Treatment Plant Master Plan Update.

TIMELINE:

Planning Commission Hearing: February 14, 2018
City Council Hearing: March 05, 2018 (Approval of Ordinance on first reading)
City Council: March 19, 2018 - Second Reading of Ordinance
Effective Date: 30 Days after 2nd Reading

CURRENT YEAR BUDGET IMPACTS:

None. Consulting Services for the 2017 Master Plan Update are budgeted under CIP 1122

FINANCIAL REVIEW / COMMENTS:

Reviewed by: _____ Date: _____
n/a

LEGAL REVIEW / COMMENT:

Reviewed by: _____ Date: _____
n/a

COMMUNITY INVOLVEMENT PROCESS:

A web page and virtual open house have been set up at www.ci.wilsonville.or.us/WTPMPupdate where the entire document can be viewed, and public comment and questions can be submitted.

POTENTIAL IMPACTS or BENEFIT TO THE COMMUNITY (businesses, neighborhoods,

protected and other groups):

A reliable source of properly treated domestic water is essential to the well-being of the community.


ALTERNATIVES:

None

CITY MANAGER COMMENT:

ATTACHMENTS:

Due to the length of the document, only the Executive Summary of the Master Plan document is included/attached. The full document can be viewed at www.ci.wilsonville.or.us/WTPMPupdate. Findings are being drafted and will be available one week prior to the hearing.



The City of Wilsonville, Oregon
 Clackamas and Washington Counties

WTP Notice

FILE # LP18-0002

This product is for informational purposes and may not have been prepared for, or be suitable for legal, engineering, or surveying purposes. Users of this information should review or consult the primary data and information sources to ascertain the usability of the information.



12/13/2016



**AFFIDAVIT OF MAILING AND POSTING NOTICE OF
PUBLIC HEARING IN THE CITY OF WILSONVILLE**

STATE OF OREGON)

COUNTIES OF CLACKAMAS)
AND WASHINGTON)

CITY OF WILSONVILLE)

I, Tami Bergeron, do hereby certify that I am Administrative Assistant for the City of Wilsonville, Counties of Clackamas and Washington, State of Oregon, that the attached copy of Notice of Public Hearing is a true copy of the original notice; that on January 24, 2018, I did cause to be mailed copies of such notice of said public hearing in the exact form hereto attached to the following property owners:

MAILED TO: See Attached List

Also notice was posted at the following locations:

- City Hall, 29799 SW Town Center Loop, East, Wilsonville OR 97070
- Wilsonville Community Center, 7965 SW Wilsonville Road, Wilsonville, OR 97070
- Library, 8200 SW Wilsonville Road, Wilsonville OR 97070
- City of Wilsonville Web Site
- Wilsonville Spokesman Journal

Witness my hand this 15th day of February 2018



Tami Bergeron, Administrative Assistant

Acknowledged before me this 15th day of February 2018



NOTARY PUBLIC STATE OF OREGON



THE STATE OF TEXAS
COMMISSIONERS OF THE GENERAL LAND OFFICE
COUNTY OF [REDACTED]
[REDACTED]



Bergeron, Tami

From: Bergeron, Tami
Sent: Tuesday, September 19, 2017 2:43 PM
To: Bergeron, Tami
Subject: MASTER TIMELINE: WATER TREATMENT PLAN MASTER PLAN

Follow Up Flag: Follow up
Due By: Monday, December 4, 2017 9:00 AM
Flag Status: Completed

For my project tracking purposes:

12/2017 schedule update:

- Planning Commission Hearing (2/14/18)
- City Council Work Session (TBD)
- City Council 1st Reading (3/5/18)
- City Council 2nd Reading (3/19/18)

PC Hearing Timeline

Project: Water Treatment Plan Master Plan

Hearing Date: FEBRUARY 14, 2018 * REV.

Project Mgr.: Eric Mende

Task	Notes	Target Date/ Prompt	Completed Date
Draft Hearing & DLCD Notices for Chris 1 for publication 1 for mailing/posting (6-8 weeks prior to hearing)	DLCD NOTICE DUE Jan. 1 – 10, 2018 (35-40 DAYS PRIOR TO HEARING)	Jan 5 Jan. 10	01/10/2018
Check with Chris if Ballot Measure 56 Notice required If yes, see instructions (20-40 days prior to hearing)			01/08/2018
Spokesman publication (10-21 days prior to hearing)		JANUARY 24, 2018	01/24/2018
To Spokesman Publisher (Thursday prior to Wednesday publication date – above)		JANUARY 18, 2018	01/11/2018
Publish information on Web calendar		JANUARY 24, 2018	01/24/2018
Social Media – check with Mark Ottenad/Angela Handran	1/11/18 prompted Eric	JANUARY 24, 2018	01/10/2018 (E Mende)
Boones Ferry Messenger – check with Mark Ottenad/Angela Handran	Did Eric communicate with Mark O? REMINDED HIM 1/4/18	DECEMBER 10, 2017	YES 1/9/2018
Announcement/Placeholder on project Web page		JANUARY 24, 2018	
Mail / Email to: -property owners -PHN agencies -interested people -project manager -Planning Director (10-21 days prior to hearing)		JANUARY 24, 2018	01/24/2018
Public Place Notice Posting: -City Hall		February 7, 2018	01/24/2018

-Library -Com Center (week prior)			
Website Hearing Notice & Flash Posting (same as public place posting)		February 7, 2018	01/08/2018
Complete Affidavit N:\planning\Forms\PC Forms.			

ADAMS MATTHEW TRUSTEE
10511 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

ALVERSON CHRISTINA A & JEFFREY N
10530 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6586

ANGELL STEVE & GEORGIA
30828 SW ORCHARD DR
WILSONVILLE OR 97070-7535

ARABIA JOE
10601 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

ARNOLDY MARTY M & JUNE
28579 SW CASCADE LOOP
WILSONVILLE OR 97070-8747

BAKER LINDA & PATRICK
10598 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

BERRY MICHAEL D & KATRINA M
31460 SW ORCHARD DR
WILSONVILLE OR 97070-5537

BLOHN DAVID G & SUSAN M
10754 SW PARKVIEW DR
WILSONVILLE OR 97070-6534

BUCK ROBERT H
31445 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

BUSSEMEIER FRANKLIN E & JUDY D
31432 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

CAMERON JEFFERY
10541 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

CARSKADON BRIAN & ARLENE H
31401 SW OLYMPIC DR
WILSONVILLE OR 97070-5534

CARUSO SAMUEL J A
31394 SW OLYMPIC DR
WILSONVILLE OR 97070-5533

CROSBY STEVEN SCOTT & LEIGH ANN
30872 SW ORCHARD DR
WILSONVILLE OR 97070-7535

DEAN RONALD E JR & TRACY L
31413 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

DEATON JARVIS R TRUSTEE
31429 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

DENNIS BRETT T & KRISTIN A
31398 SW OLYMPIC DR
WILSONVILLE OR 97070-5533

DIEHL ROBERT & ALICE ANNE
31424 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

DUCK COUNTRY APARTMENTS LLC
PO BOX 490
ENTERPRISE OR 97828-0490

DYER DEANN M
10759 SW PARKVIEW DR
WILSONVILLE OR 97070-6534

DYKZEUL MICHAEL J & CARIN D
10753 SW PARKVIEW DR
WILSONVILLE OR 97070-6534

EAVE SCOTT S & MICHELE L
31433 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

ENSIGN-LEWIS DAVID & MARY K
31417 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

FAMILIA PROPERTIES
PO BOX 145
WILSONVILLE OR 97070-0145

FLORES MERCED
31432 SW ORCHARD DR
WILSONVILLE OR 97070-6589

FRITSCHI DAVID R JR TRUSTEE
PO BOX 694
GLEN ELLEN CA 95442-0694

GARCIA FRANK JR & LESLIE D
10576 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

GEARHART ROLF E & LAUREN M
10673 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

GODFREY DAWN M & KURT J
10502 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6586

GREENHALGH JAMES MALCOLM
31120 SW ORCHARD DR
WILSONVILLE OR 97070-7533

GREENLEY RONALD ALLEN TRUSTEE
10516 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6586

GREGORY DAVID T & DIANE L
10621 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

GUNNELL REID W & DIANE
31428 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

HANCOCK BILL A
31196 SW ORCHARD DR
WILSONVILLE OR 97070-7533

HARRIS BRADLEY & SHAWNA SAWYER
31254 SW ORCHARD DR
WILSONVILLE OR 97070-7533

HARTMAN WILLIAM & MAUREEN
31421 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

HAYES LIAM & ARMIDA
31393 SW OLYMPIC DR
WILSONVILLE OR 97070-5533

HELFIG SAUL
31050 SW ORCHARD DR
WILSONVILLE OR 97070-7533

HENDRICKS BRIAN F
31437 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

HIX SCOTT P & CONNIE L
10669 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

HOLBROOK RONALD C & GINA C
10532 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

HOLSEY DARREN P
31385 SW OLYMPIC DR
WILSONVILLE OR 97070-5533

HUMMELT HAROLD B TRUSTEE
10836 SW MOREY LN
WILSONVILLE OR 97070-9503

JOE BERNERT TOWING CO INC
PO BOX 37
WILSONVILLE OR 97070-0037

JOHNSON REED A & KIMBERLY S
31440 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

JONES STEVE & JO ANN
31397 SW OLYMPIC DR
WILSONVILLE OR 97070-5533

KISLYAK MAKSIM L & ANTONINA
10525 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6586

KJD PROPERTIES LLC
4131 IMPERIAL DR
WEST LINN OR 97068-3655

KLIESE GUENTER H & WALTRAUD
10650 SW WILSONVILLE RD
WILSONVILLE OR 97070-7504

KRECKLOW MICHAEL & LISA
10562 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

KRUEGER MICHAEL R & MARY
10671 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

LAM WAYNE KAM W & AMANDA
SEUNG S
31441 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

LARSEN BARRY A & LAURA E
10677 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

LEWIS JEFFREY A
10501 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

LOOD PETER TRUSTEE
31444 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

LUETH JOHN C & RHONDA M CAPRI
30936 SW ORCHARD DR
WILSONVILLE OR 97070-7535

MADDOX LEWIS J & MARLENE L
10615 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

MARTIN CRAIG A
10577 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

MATSON BENJAMIN T
31402 SW OLYMPIC DR
WILSONVILLE OR 97070-5534

MCDONALD GEORGE DUNCAN TRUSTEE
10616 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

MCKILLIP TERRY L
10594 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

MEISNER ADAM & KRISTEL
30762 SW ORCHARD DR
WILSONVILLE OR 97070-7535

MERMIS JEFF T & JESSICA L
10680 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

MESSMAN CYNTHIA J
31428 SW ORCHARD DR
WILSONVILLE OR 97070-6589

MOORE ERIC J & LAURA A
10525 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

MOORE JAMES D & TINA L
31409 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

MOREYS LANDING HOMEOWNERS ASSN
PO BOX 23099
TIGARD OR 97281-3099

NIETING JENNIFER D
10642 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

NOVITSKY DAVID & SALLY
31389 SW OLYMPIC DR
WILSONVILLE OR 97070-5533

OCHS NEIL JON & DINA A
10665 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

OSTOJA NICHOLAS J CO-TRSTE
28655 SW SANDALWOOD DR
WILSONVILLE OR 97070-8775

OSTOJA NICHOLAS J SR TRUSTEE
30683 SW PEACH COVE RD
WEST LINN OR 97068-9415

PACIFIC NW PROPERTIES LP
6600 SW 105TH AVE STE 175
BEAVERTON OR 97008-8834

PAYNE BRIAN & ALLIE
10668 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

PETERSON KEVIN J & SUSAN HOLMES
31312 SW ORCHARD DR
WILSONVILLE OR 97070-7534

PITTS CARROLL A
30748 SW ORCHARD DR
WILSONVILLE OR 97070-7525

QUENZER ROSS D & ANGELA B
10585 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

REBERS ROBYN M
10581 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

REED LINDA J
30500 SW KENSINGTON PL
WILSONVILLE OR 97070-7500

RICH CYNTHIA M & RICK F
10510 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

RUTTANAPAIBOONCHAROEN SURIN
10554 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

SAHLI MARK A & PATRICIA A
31388 SW ORCHARD DR
WILSONVILLE OR 97070-7534

SARIN BARRY STEVEN & ANNE MARIE
30612 SW ORCHARD DR
WILSONVILLE OR 97070-7525

SCHAEFER DAVID B CO-TRUSTEE
30678 SW ORCHARD DR
WILSONVILLE OR 97070-7525

SCHAUR VICKI L TRUSTEE
31464 SW ORCHARD DR
WILSONVILLE OR 97070-5537

SCHMIDT JORDAN T & KELSEY R
30722 SW ORCHARD DR
WILSONVILLE OR 97070-7525

SCHULDT BRADLEY P
10580 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

SCHULTE RICHARD W II
10681 SW EDGEWOOD CT
WILSONVILLE OR 97070-5512

SHANK JACOB L
9337 SW 171ST AVE
BEAVERTON OR 97007-6101

SPEAR THOMAS TRUSTEE
31406 SW ORCHARD DR
WILSONVILLE OR 97070-8656

STONE JOSHUA I & MILDRED J
10558 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

STOREY DOUGLAS E & CYNTHIA M
30998 SW ORCHARD DR
WILSONVILLE OR 97070-7535

STREET GREG & DEBBIE
31425 SW OLYMPIC DR
WILSONVILLE OR 97070-5535

PROPERTY OWNER
10544 SW SUNNYSIDE DR
WILSONVILLE OR 97070-6587

PROPERTY OWNER
31424 SW ORCHARD DR
WILSONVILLE OR 97070-6589

TABER CHARLES & CAROLYN
31406 SW OLYMPIC DR
WILSONVILLE OR 97070-5534

TUALATIN VALLEY WATER DISTRICT
1850 SW 170TH
BEAVERTON OR 97003-4211

VANLOON MARTIN GLASTRA & ANGIE
10635 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

WADDELL MARK & RICHELLE
10505 SW BROCKWAY DR
WILSONVILLE OR 97070-6588

WEISS JULIE A
30566 SW KENSINGTON PL
WILSONVILLE OR 97070-7500

WENDLER BRIAN TRUSTEE
3871 MOOSE RUN DR SW
ALBANY OR 97321-5101

WEST COAST REAL ESTATE HOLDINGS
PO BOX 1969
LAKE OSWEGO OR 97035-0059

WIRFS JOHN W & CYNTHIA L
31468 SW ORCHARD DR
WILSONVILLE OR 97070-5537

WOOLWORTH SHEILA M TRUSTEE
5020 SW EASTGATE DR
WILSONVILLE OR 97070-6831

WORTH CARL D
31405 SW OLYMPIC DR
WILSONVILLE OR 97070-5534

YAMAYEE ZIA A & MARLENE MOORE
10641 SW EDGEWOOD CT
WILSONVILLE OR 97070-5532

YOUNG DAVID S
PO BOX 7
WILSONVILLE OR 97070

PROP. MGR - TIMBER CREEK
APARTMENTS
30195 SW BROWN RD UNIT 37
WILSONVILLE OR 97070

PROP. MGR - WILSONVILLE HEIGHTS
29796 SW MONTEBELLO DR
WILSONVILLE OR 97070

PROP. MGR - OAK LEAF MOBILE PARK
10660 SW WILSONVILLE RD., UNIT 58
WILSONVILLE OR 97070

**AFFECTED AGENCIES
MAILING OF HEARING 02.14.2018
MAILED 1/24/18**

James Clark
BPA, Realty Department
2715 Tepper Lane
Keizer OR 97303

Chamber of Commerce
8565 SW Salish Lane
Wilsonville OR 97070

City Planner
City of Canby
182 N. Holly
Canby OR 97013

Planning Director
City of Sherwood
22560 SW Pine Street
Sherwood OR 97140

Aquilla Hurd-Ravich
City of Tualatin
18880 SW Martinazzi Avenue
Tualatin OR 97062

Mike McCallister
Clackamas Co. Trans. & Development
150 Beaver Creek Road
Oregon City OR 97045

Diane Taniguchi-Dennis
Clean Water Services
2550 SW Hillsboro Hwy.
Hillsboro OR 97123

Columbia Cable of Oregon
14200 SW Brigadoon Ct.
Beaverton OR 97005

Bobbi Burton
Com. Coord., Facilities Division
2575 Center Street, NE
Salem OR 97310

Doug Young
Department of Corrections
2575 Center Street NE
Salem OR 97310

John Lilly
Department of State Lands
775 Summer Street, NE
Salem OR 97301-1279

Justin Wood, Assoc. Dir. of Gov-Bdr Rel
Home Bdls Associations
15555 SW Bangy Road, Suite 301
Lake Oswego OR 97035

Jon Kloor, Gov. & Political Rel. Coord.
Home Bdls Associations
15555 SW Bangy Road, Suite 301
Lake Oswego OR 97035

Paulette Copperstone
Metro
600 NE Grand Avenue
Portland OR 97233

Brian Harper
Metro
600 NE Grand Avenue
Portland OR 97233

Anthony Buczek
Metro
600 NE Grand Avenue
Portland OR 97233

Nina Carlson
NW Natural Gas
220 NW 2nd Avenue
Portland OR 97209

Attn: Development Review
ODOT Region 1
123 NW Flanders Street
Portland OR 97209

District Manager
ODOT Region 2A
9200 SE Lawnfield Road
Clackamas OR 97015

Gail Curtis
ODOT Region 1
123 NW Flanders Street
Portland OR 97209

Seth Brumley
ODOT Region 1
123 NW Flanders Street
Portland OR 97209

Oregon Dept of Environ Quality
700 NE Multnomah Street, Suite 600
Portland OR 97232

Bill Ferber, Region Manager
Oregon Water Resources Department
725 Summer Street, NE, Suite A
Salem OR 97301

Brian Buswell
Portland General Electric
9480 SW Boeckman Road
Wilsonville OR 97070

Sherwood School Dist Admin Office
23295 SW Main Street
Sherwood OR 97140

Ben Baldwin
Tri-Met Project Planning Dept
4012 SE 17th Avenue
Portland OR 97202

Tualatin Valley Fire and Rescue
29875 SW Kinsman Road
Wilsonville OR 97070

Tualatin Valley Fire and Rescue
8445 SW Elligsen Road
Wilsonville OR 97070

Tualatin Valley Water District
1850 SW 170th Ave.
Beaverton OR 97005-4211

Frank Lonergan
United Disposal Services
10295 SW Ridder Road
Wilsonville OR 97070

Andy Back
Wash. County Long Range Planning
155 N. First Avenue
Hillsboro OR 97124

Dr. Kathy Ludwig
West Linn/Wilsonville School District 3JT
22210 SW Stafford Rd.
Tualatin OR 97062

Tim Woodley
West Linn/Wilsonville School District 3JT
22210 SW Stafford Rd.
Tualatin OR 97062

Pamplin MediaGroup


6605 SE Lake Road, Portland, OR 97222
PO Box 22109 Portland, OR 97269-2169
Phone: 503-684-0360 Fax: 503-620-3433
E-mail: legals@commnewsletters.com

AFFIDAVIT OF PUBLICATION

State of Oregon, County of Clackamas, SS I, Charlotte Allsop, being the first duly sworn, depose and say that I am the Accounting Manager of the **Wilsonville Spokesman**, a newspaper of general circulation, published at Wilsonville, in the aforesaid county and state, as defined by ORS 193.010 and 193.020, that


**CITY OF WILSONVILLE
NOTICE OF A LEGISLATIVE PUBLIC HEARING - Water Treatment Plant; ko18-0002
Ad#: 25879**

A copy of which is hereto annexed, was published in the entire issue of said newspaper(s) for 1 week(s) in the following issue(s):
01/24/2018



Charlotte Allsop (Accounting Manager)

Subscribed and sworn to before me this
01/24/2018.


NOTARY PUBLIC FOR OREGON

Acct #: 108863

Attn: TAMI BERGERON
WILSONVILLE, CITY OF
29799 SW TOWN CENTER LOOP E
WILSONVILLE, OR 97070

NOTICE OF A LEGISLATIVE PUBLIC HEARING BEFORE THE WILSONVILLE PLANNING COMMISSION: 2017 WATER TREATMENT PLANT MASTER PLAN UPDATE LP18-0002

Planning Commission:

On **Wednesday, February 14, 2018, beginning at 6:00 p.m.**, the Wilsonville Planning Commission will hold a public hearing regarding adoption of the 2017 Water Treatment Plant Master Plan Update (Case File # LP18-0002). The Planning Commission will consider whether to recommend adoption of the amendment to the City Council. No additional mailed notice will be sent to you unless you either:

- Submit testimony or sign in at the Planning Commission hearing, or
- Submit a request, in writing or by telephone, to the Planning Division.

City Council:

The Wilsonville City Council is scheduled to hold a public hearing on the proposal on **Monday, March 05, 2018 at 7:00 p.m.** after which it may make the final decision.

The hearings will take place at **Wilsonville City Hall, 29799 SW Town Center Loop East, Wilsonville, Oregon**. A complete copy of the relevant file information, including the staff report, findings, and recommendations will be available for viewing seven days prior to each public hearing at Wilsonville City Hall, at the Wilsonville Public Library and on the city's web site.

Summary of Proposal: 2017 Water Treatment Plant Master Plan Update – LP18-0002

The City of Wilsonville is completing a Master Plan Update for the Willamete River Water Treatment Plant. The Master Plan Update identifies short and long range water needs for the City, the treatment technologies to be used, short term and long term repairs and replacements, and capital improvements needed to meet future goals. The Master Plan Update document can be viewed at www.ci.wilsonville.or.us/WTPMPupdate.

How to Comment

Comments may be submitted through a virtual open house forum accessed via the internet at www.ci.wilsonville.or.us/WTPMPupdate. Comments received through the virtual open house will be summarized by staff for the public hearing. Oral or written testimony may be presented at the public hearing. Written comment on the proposal to be submitted into the public hearing record is welcome prior to the public hearings. To have your written comments or testimony distributed to the Planning Commission before the meeting, it must be received by 2 pm on **Tuesday, February 7, 2018**. Direct such written comments or testimony to:

Eric Mende, P. E. Engineering Division
29799 SW Town Center Loop East,
Wilsonville, Oregon, 97070;
mende@ci.wilsonville.or.us
(503) 682-4960

A copy of the full draft plan is available from the Wilsonville Planning Division at the above address.

Note: Assistive Listening Devices (ALD) are available for persons with impaired hearing and can be scheduled for this meeting. The City will also endeavor to provide qualified sign language interpreters and/or bilingual interpreters, without cost, if requested at least 48 hours prior to the meeting. To obtain such services, please call Tami Bergeron, Planning Administrative Assistant at (503) 682-4960.

Publish 01/24/2018.

WS25879

Bergeron, Tami

From: Bergeron, Tami
Sent: Wednesday, January 24, 2018 11:10 AM
Subject: Wilsonville Planning Commission Hearing Notice
Attachments: PC PHN WATER TREATMENT 2018.pdf

Planning Commission Public Hearing Notice (see attached) - PC on February 14, 2018 & CC on Monday, March 5, 2018

The proposal **Water Treatment Plant Master Plan Update LP18-0002** will be heard by the City of Wilsonville Planning Commission on February 14, 2018 at 6 pm. The Planning Commission will consider whether to recommend adoption of the revisions (Case File #LP18-0002) to the City Council.

Please note that no additional mailed notice will be sent to you unless you either:

- Submit testimony or sign in at the Planning Commission hearing, or
- Submit a request, in writing or by telephone, to the Planning Division.

Tami Bergeron

Administrative Assistant
City of Wilsonville

503.570.1571

bergeron@ci.wilsonville.or.us

www.ci.wilsonville.or.us

[Facebook.com/CityofWilsonville](https://www.facebook.com/CityofWilsonville)



29799 SW Town Center Loop East, Wilsonville, OR 97070

Disclosure Notice: Messages to and from this e-mail address may be subject to the Oregon Public Records Law.

**NOTICE OF LEGISLATIVE PUBLIC HEARING
BEFORE THE PLANNING COMMISSION:
2017 WATER TREATMENT PLANT
MASTER PLAN UPDATE — LP18-0002**



Planning Commission:

On **Wednesday, February 14, 2018, beginning at 6:00 p.m.**, the Wilsonville Planning Commission will hold a public hearing regarding the following. The Planning Commission will consider whether to recommend adoption of the **2017 Water Treatment Plant Master Plan Update LP18-0002** to the City Council. No additional mailed notice will be sent to you unless you either:

- Submit testimony or sign in at the Planning Commission hearing, or
- Submit a request, in writing or by telephone, to the Planning Division.

City Council:

The Wilsonville City Council is scheduled to hold a public hearing on the proposal on **Monday March 05, 2018 at 7:00 p.m.** after which it may make the final decision.

The hearings will take place at **Wilsonville City Hall, 29799 SW Town Center Loop East, Wilsonville, Oregon.**

A complete copy of the relevant file information, including the staff report, findings, and recommendations, will be available for viewing seven days prior to each public hearing at Wilsonville City Hall, at the Wilsonville Public Library and on the city's

Summary of Proposal:

The City of Wilsonville, is completing a master plan update for the Willamette River Water Treatment Plant. The master plan update identifies short term and long range water needs for the City, the treatment technologies to be used, and the capital improvements needed to meet these future goals.

The public is also invited to review and provide comments on the master plan update through an on-line open house located at www.ci.wilsonville.or.us/WTPMPupdate.

How to Comment: Oral or written testimony may be presented at the public hearing. Written comments on the proposal to be submitted into the public hearing record is welcome prior to the public hearing. To have your written comments or testimony distributed to the Planning Commission before the meeting, it must be received by 2 pm on **February 7, 2018**. Direct such written comments or testimony to:

Eric Mende, P.E. Engineering Division
29799 SW Town Center Loop East, Wilsonville, Oregon, 97070
mende@ci.wilsonville.or.us, (503) 682-4960

Copies of the full draft plan is available from the Wilsonville Planning Division at the above address and **at the project website: <http://www.ci.wilsonville.or.us/WTPMPupdate>**

Note: Assistive Listening Devices (ALD) are available for persons with impaired hearing and can be scheduled for this meeting. The City will also endeavor to provide qualified sign language interpreters and/or bilingual interpreters, without cost, if requested at least 48 hours prior to the meeting. To obtain such services, please call Tami Bergeron, Planning Administrative Assistant at (503) 682-4960.

Date of Planning Commission Meeting: **February 14, 2018**

Date Notice was posted: **January 24, 2018**

Bergeron, Tami

From: Bergeron, Tami
Sent: Wednesday, January 24, 2018 11:07 AM
To: Clark, Brad; Howe, Brenda; ComCenter Temp
Subject: to post: hearing notice
Attachments: PC PHN WATER TREATMENT 2018.pdf

Please find the attached Planning Commission Hearing Notice for the upcoming hearing on February 14, 2018. Please post in a public location within your building.

Also know that this information will also be available on our website later today.



Tami Bergeron

Administrative Assistant

503.570.1571 • bergeron@ci.wilsonville.or.us

29799 SW Town Center Loop East, Wilsonville, OR 97070

www.ci.wilsonville.or.us

[Facebook.com/CityofWilsonville](https://www.facebook.com/CityofWilsonville)

Disclosure Notice: Messages to and from this e-mail address may be subject to the Oregon Public Records Law.

**NOTICE OF LEGISLATIVE PUBLIC HEARING
BEFORE THE PLANNING COMMISSION:
2017 WATER TREATMENT PLANT
MASTER PLAN UPDATE — LP18-0002**



Planning Commission:

On **Wednesday, February 14, 2018, beginning at 6:00 p.m.**, the Wilsonville Planning Commission will hold a public hearing regarding the following. The Planning Commission will consider whether to recommend adoption of the **2017 Water Treatment Plant Master Plan Update LP18-0002** to the City Council. No additional mailed notice will be sent to you unless you either:

- Submit testimony or sign in at the Planning Commission hearing, or
- Submit a request, in writing or by telephone, to the Planning Division.

City Council:

The Wilsonville City Council is scheduled to hold a public hearing on the proposal on **Monday March 05, 2018 at 7:00 p.m.** after which it may make the final decision.

The hearings will take place at **Wilsonville City Hall, 29799 SW Town Center Loop East, Wilsonville, Oregon.**

A complete copy of the relevant file information, including the staff report, findings, and recommendations, will be available for viewing seven days prior to each public hearing at Wilsonville City Hall, at the Wilsonville Public Library and on the city's

Summary of Proposal:

The City of Wilsonville, is completing a master plan update for the Willamette River Water Treatment Plant. The master plan update identifies short term and long range water needs for the City, the treatment technologies to be used, and the capital improvements needed to meet these future goals.

The public is also invited to review and provide comments on the master plan update through an on-line open house located at www.ci.wilsonville.or.us/WTPMPupdate.

How to Comment: Oral or written testimony may be presented at the public hearing. Written comments on the proposal to be submitted into the public hearing record is welcome prior to the public hearing. To have your written comments or testimony distributed to the Planning Commission before the meeting, it must be received by 2 pm on **February 7, 2018**. Direct such written comments or testimony to:

Eric Mende, P.E. Engineering Division
29799 SW Town Center Loop East, Wilsonville, Oregon, 97070
mende@ci.wilsonville.or.us, (503) 682-4960

Copies of the full draft plan is available from the Wilsonville Planning Division at the above address and **at the project website:** <http://www.ci.wilsonville.or.us/WTPMPupdate>

Note: Assistive Listening Devices (ALD) are available for persons with impaired hearing and can be scheduled for this meeting. The City will also endeavor to provide qualified sign language interpreters and/or bilingual interpreters, without cost, if requested at least 48 hours prior to the meeting. To obtain such services, please call Tami Bergeron, Planning Administrative Assistant at (503) 682-4960.



PLANNING COMMISSION

WEDNESDAY, DECEMBER 13, 2017

II. WORK SESSION

A. Water Treatment Plant Master Plan (Mende) (45 minutes)

**PLANNING COMMISSION
WEDNESDAY, DECEMBER 13, 2017
6:00 P.M.**

**Wilsonville City Hall
29799 SW Town Center Loop East
Wilsonville, Oregon**

*Minutes approved as
presented at the
01.10.2018 PC
Meeting*

Minutes

I. CALL TO ORDER - ROLL CALL

Chair Jerry Greenfield called the meeting to order at 6:06 p.m. Those present:

Planning Commission: Jerry Greenfield, Peter Hurley, Al Levit, Simon Springall, and Phyllis Millan. Eric Postma arrived at 6:46 pm. Kamran Mesbah was absent.

City Staff: Chris Neamtzu, Amanda Guile-Hinman, Miranda Bateschell, Nancy Kraushaar, Eric Mende, Kimberly Rybold, and Jordan Vance.

PLEDGE OF ALLEGIANCE

The Pledge of Allegiance was recited.

CITIZEN'S INPUT - This is an opportunity for visitors to address the Planning Commission on items not on the agenda. There was none.

CONSIDERATION OF THE MINUTES

A. Consideration of the November 8, 2017 Planning Commission minutes
The November 8, 2017 Planning Commission minutes were accepted as presented.

II. WORK SESSION

A. Water Treatment Plant Master Plan

Chris Neamtzu, Planning Director, explained that the proposed Water Treatment Plant Master Plan used components from the larger 2015 Master Plan that applied to the Tualatin water supply system to develop a plan specifically for Wilsonville.

Jude Grounds, Assoc. Vice President at Carollo Engineers, and Mr. Mende presented the 2017 Water Treatment Plant Master Plan Update via PowerPoint. A brief history and purpose of the Master Plan Update and reviewing key elements of the Master Plan was provided, including the project's purpose, level of service goals, and plans for 20 and 30 MGD capacity expansions. Also shared was the Implementation Plan with regard to the CIP and schedule.

Discussion and feedback from the Planning Commission was as follows with responses to Commissioner questions as noted:

- The life expectancy for seismic upgrades was based on rates of return, not anticipated time periods for seismic events. The worst-case scenario was used to develop the level of service goals.
- Current capacities would remain the same for Wilsonville and Sherwood after the 20 million gallons per day (MGD) capacity upgrades. However, after the 30 MGD capacity upgrades, Wilsonville would receive 20 MGD and Sherwood would receive 10 MGD. Growth rate models show water usage would plateau at times due to economic downturns and other conditions, so usage would vary over the years.

- A lot of sediment was found in the raw water intake pipe during a recent cleaning. Willamette Water Supply (WWS) was considering doing sedimentation on the raw water received from the water system, but currently the design did not call for any prefiltration before the raw water was pumped through the pipeline. WWS would need to consider how the sediment would impact their capacity.
 - Many facilities in the region pump raw water, so provisions for cleaning the pipelines had been implemented. Additionally, screens filter out most of the large debris. The pumps were able to handle the smaller material that got through. The intake pipe was sized for 120 to 150 MGD, but only 15 MGD was being pumped through it; therefore, sediment was expected.
 - Many clams were found in the sediment during the cleaning; however, none were invasive species.
- The water system's entire infrastructure was built outside the 100-year flood plain, including the lower plant, so a major flood event was not a concern.
- The raw water intake pipeline was sized for 150 MGD, but the screens on top were only sized for 70 MGD. The cities that use this water system would simply need to replace the screens as part of their regular maintenance, which would not require any in-water work permitting. The pipeline, screens, and raw water facilities were all shared facilities. The pumps owned by individual jurisdictions would be co-located and would accommodate up to 10 pumps.
 - Wilsonville, Tualatin Valley, and WWS had entered into agreements that cover all aspects of the financials. The Master Plan would not reference those agreements, but Staff could provide more details about which entities would be financially responsible for improvements to the shared facilities and the legal basis behind the agreements.

B. Coffee Creek Industrial Form-Based Code

Chris Neamtzu, Planning Director, introduced the project team, including Consultant Marcy McInnelly of Urbsworks and noted their most recent efforts to engage the City's boards and commissions as well as the input received that influenced the updated Form-based Code. The team was preparing for the public hearing in January and the Commission would see a lot of Code edits in next month's hearing packet due to the cascading effect that Code changes typically had throughout the Code.

Kimberly Rybold, Associate Planner, presented a brief update on the Coffee Creek Industrial Form-based Code (FBC) via PowerPoint, highlighting the project's background; the feedback from the Planning Commission, and Joint DRB and City Council work sessions; the resulting modifications made to the FBC; and the recommended pilot parameters for determining the success of the Code amendments.

Mr. Neamtzu clarified that currently, application approvals could take from 60 to 120 days, depending on the project and if City Council was involved, which pushed approvals up against the maximum 120-day statutory requirement. He was uncertain how this compared to other cities, but many in the development community believed Wilsonville had one of the most efficient development review processes in the area. However, this had not always been the case. City Manager Cosgrove's leadership and using a customer service driven approach in the City's review of applications had enhanced the City's processes, which involved providing a balance between a good, efficient review process and affording the opportunity for citizen input. He suggested getting input from Commissioner Postma, who has done work in other communities.

Commissioner Postma stated Mr. Neamtzu's comments were accurate and he agreed the City had made vast improvements. He believed Wilsonville was probably faster than most jurisdictions without sacrificing thoroughness, but how did that translate to dollars, as it could still be expensive.

- He said he was disappointed because the Commission endeavored to make Code modifications to lower developers' costs, and yet they would still incur an expense. Additionally, developers would still go into the review process with cost and development uncertainties, despite having a new pattern book type of process. When speaking with the City, developers tend to indicate their acceptance of new processes because they believe their responses or preferences could impact the approval of future applications. However, he believed developers would be bothered that the City has back tracked to create a public hearing process.

The goal from the beginning, about 7 or 8 years ago, was to create a less expensive and more efficient process by putting the public hearing on the front end. If the City cared about small businesses, property values, and creating efficiencies for developers, he was disappointed to see the City backtracking from that goal and he could be a no vote on the FBC.

- When interacting with multiple people from the Development Review Board (DRB), he heard they were a bit bothered by the fact that the public hearing would go away. The public would still have the opportunity to speak on applications seeking waivers; but then to see it go to Council with that as the critical issue was disappointing.
- If a project met the guidelines and requirements of the pattern book, the application should be exempt from part of the process and expense, but now the City was backtracking from that which bothered him.

Comments from the Planning Commission and responses to Commissioner questions from Staff continued as follows:

- Language stating “shall be approved” should not be considered equal to “must be approved.” It seemed disingenuous that some of the language seemed to imply that an application would essentially be pre-approved if clear and objective standards were met, but then an approval process would also be required.
 - Ms. Rybold confirmed City Council requested the Code modifications be reviewed after a pilot review period and that an administrative review be implemented if the Code modifications were successful.
- Triggers for any future area-wide traffic studies would be determined during the initial traffic study. Staff had a good sense of the improvements already planned for the area and how those improvements would impact future capacity. Some minimums or maximums would be established for individual sites from the initial traffic study. Similar to the process in Villebois, Staff would keep track of the trips with regard to the traffic trip cap. If the trips allocated were exceeded, either by an individual project or toward build out, traffic would need to be studied further. The traffic impacts could depend on the type of industry and their specific traffic needs.
- Pilot parameters recommended that a review should be done after three applications or five years. Staff believed they would have a good sense of how things were going after processing three applications. Additionally, if the City only receives one application in five years, the Code modifications should be revisited. An urban renewal district was in place in the area and it would take time to build up urban renewal funds. It would take the City several years to realize meaningful infrastructure construction in the area that would incentivize development.
 - As an additional parameter, the DRB could propose changes to applications, which the City could track to determine how much change was implemented during the DRB review. However, Staff believed the type of feedback given by the DRB would be related more to aesthetics rather than the success of the Code modifications.
- Public input about this new process would be taken at the City Council hearing. However, in order to be really targeted, the City needed to see if the public was using the DRB forum.
 - Commissioners expressed concern about the public input that would be received after the Code modifications were implemented. Historically, commercial projects not near residential areas have not typically received much public input. Instead of waiting five years to hear from the public, Staff could just look back on the records of projects that were already approved.
 - The number of waivers requested would be very informative and instructive about changes that should be made to the Code. Many waivers would indicate where the Code was weak and patterns revealed by the details of the waivers would indicate what needed to be changed within the Code.
- Areas that prosper with new development have processes that allow developers to get approval in one to three days, not one to three months like here in Wilsonville. This was rare, but the Code modification project was an opportunity for Wilsonville to move in the same direction in a world that was edging toward on-demand development permits. However, the proposed recommendations seemed to be stepping backwards.
 - Wilsonville was not the only place to build, and other jurisdictions would be watching to see how these Code modifications work for Wilsonville.

- The Commission generally agreed the FBC review process should be put in place after a period of time and without the DRB review. The FBC process should be reviewed after a pilot time period, to consider such metrics like the number of requested waivers, time of approval, concerns from the public, etc. The City might determine FBC was not working after analyzing the metrics.
 - Other jurisdictions would want to know about any improvements or concerns regarding the FBC. If there were any cost savings experienced by developers? It was important that the Code modifications made sense, especially if the FBC was extended into Basalt Creek.
 - After several years, the Commission would also have actual buildings to see whether the FBC was achieving on the ground what was desired.
- Mr. Neamtzu confirmed that with or without DRB review, Staff's general level of effort would be similar; however, no DRB review would mean fewer night meetings and less Staff overtime. Fees were generally lower for an administrative review process than a public hearing.
 - The higher level of administrative authority would be new to Staff, but it would still allow Staff to hear from the community about issues, external impacts, and other performance related things that were beyond what the Code addressed.
 - The eventual turnover of Staff personnel was also a consideration with regard to increased administrative authority.
 - Coffee Creek still had neighbors close to the industrial area; residents that lived there a long time. The DRB wanted to hear from people about issues beyond what the FBC addressed or things that might not be captured in Staff's review.
 - Subsequently, he gravitated back to liking the pilot project and continuing to provide that venue for neighbors to provide input.
 - With clear and objective standards being created, like the Old Town Architectural Pattern Book and the FBC, to provide more certainty, the DRB's concerns about their role in the future were legitimate because the City had a legacy of generations of citizens owning and driving the way the community looks and feels. From that viewpoint, he believed both Council and the DRB were keyed in on the issues and took a respectful, conservative approach to give the bold, new FBC a chance via the pilot time period before taking next steps.

Commissioner Postma understood Mr. Neamtzu's comments, but noted the Planning Commission had been working on the Code modifications for several years within a citizen driven process. Now the City was backtracking. He recounted the number of public hearing opportunities available as land was annexed and developed, as well as the number of public meetings held regarding the FBC, so it had been vetted like crazy.

- He understood the apprehension about shifting from a more citizen-driven process and that the DRB was being removed from the process, but he wanted to give Economic Development Manager, Jordan Vance, something to sell. He wanted buildings going up faster in Wilsonville than anywhere else because the City was bold enough to step out and make a process that the development community was excited about, but the City had stepped away from that in the last couple of months.
- Residents in Coffee Creek have been watching this FBC process and some were excited because if the City could save developers money that would result in a slightly higher property value for those selling to the developers.
- The City had spent years developing the FBC and everyone needed to step away from their trepidations about the way things were done before, so Wilsonville could be the first to have this advantage over other jurisdictions in the area.
- He was excited about the City moving forward with FBC and the Code modifications; they could review their success in a few years.

Mr. Neamtzu noted the Commission would make a recommendation to Council next month at the public hearing when the public would be invited to give feedback on the recommended FBC process and the Code modifications. He would like see the recommendation include the option of a DRB review pilot.

- He confirmed administrative review would still involve noticing adjacent property owners and offering the option for a public hearing if Staff did not believe an application should be approved administratively.

Commissioner Postma noted it also incentivized developers to address any issues before submitting an application to Staff.

Commissioner Millan said she would be fine with the pilot process, but wanted to clean up the pilot parameters.

Chair Greenfield called for a brief recess and reconvened the meeting at 7:54 pm.

III. LEGISLATIVE HEARING

A. Year 2000 URA – Boeckman Creek Bridge

Chair Greenfield read the legislative hearing procedure into the record and opened the public hearing at 7:56 pm.

Chris Neamtzu, Planning Director, explained the proposed amendment would add the Boeckman Creek Bridge to the Year 2000 Urban Renewal Plan. The transportation facility did not meet minimum street standards as it lacked on-street bicycle facilities, sidewalks, and safe grades. This specific project and how it should be funded was discussed during the Frog Pond Plan and subsequent Infrastructure Funding Plan. Staff provided recommendations to City Council, which directed Staff to determine whether a substantial amendment to the Year 2000 Plan would be an acceptable way to fund and build this project. The project team would share their findings and ask for the Planning Commission's specific recommendation on whether the amendment was in compliance with the Comprehensive Plan, which was the scope of the Commission's review in this meeting.

Jordan Vance, Economic Development Manager, stated Staff had drafted the amendment and were working to obtain concurrence from the various taxing jurisdictions. The proposed amendment would increase the maximum indebtedness (MI) by approximately \$14 million to pay for the Boeckman Creek Bridge. The purpose of the hearing was to determine whether the Year 2000 Plan Amendment was in conformance with the Comprehensive Plan.

Scott Vanden Bos, Elaine Howard Consulting, LLC., noted details regarding the conformance of the amendment to the Comprehensive Plan were included in the meeting packet. He presented the Wilsonville Urban Renewal Amendment via PowerPoint, highlighting the background and bridge project details and reviewing the financial implications and the amendment's approval process with these key additional comments:

- The Wilsonville Urban Renewal Task Force unanimously supported the Plan Amendment.
- The Year 2000 urban renewal boundary included some unincorporated properties from Clackamas County, which was why the County had to improve the entirety of the proposed Plan amendment.
- The amendment would increase the Year 2000 Plan's MI and extend tax increment financing by three years. The Plan's original closure date was 2020.
- Concurrence was needed by the other taxing districts because the MI would be increased by more than 20 percent of the original MI as indexed for inflation. And, since the current MI already exceeded the 20 percent threshold, any further MI increase required concurrence.
 - Concurrence was also advised by Council because the Year 2000 Plan was in an alternative, not the statutory, review sharing program.
- Approval from Clackamas County was needed due to the unincorporated properties in the Year 2000 Plan Area.
- He offered to review the Comprehensive Plan Findings included in the meeting packet, and noted the suggested motion included very specific language required by statute. (Page 38 of 38 of the Staff report)

Commissioner Postma:

- Noted the proposed motion language stated that the Planning Commission was recommending that City Council adopt the proposed Year 2000 Urban Renewal Plan Amendment, but the resolution did not indicate the Commission was recommending anything. It provided the findings, but not a recommendation.
 - Mr. Vanden Bos responded that the Commission could strike the language from the motion that did not match the resolution. ORS Chapter 457 did not require that the language be in the motion.
- Confirmed that City Council could move on the issue without a recommendation preceding it and that only the findings were required. The motion could be revised and the resolution unchanged.

Chair Greenfield stated he had read the entire report with the references to the Comprehensive Plan as well as the responses, and he believed the amendment was in order.

Commissioner Springall:

- Asked how the Boeckman Bridge Project related to the Boeckman Creek Trail that ran underneath the bridge. Noting that Section 5 on Page 15 of the Staff report referenced the Bicycle and Pedestrian Master Plan and Frog Pond West Master Plan, he asked if the bridge project included development of the trail in that area or if it was entirely separate.
 - Nancy Kraushaar, Community Development Manager, replied the project would include construction of the trail immediately underneath the bridge, but not beyond reasonable limits of the bridge because that work would increase the budget and could extend outside the urban renewal boundary.
- Commented that since the trail was part the Comprehensive Plan, he wanted to ensure the Commission was moving forward on the trail as well as the bridge itself.
 - Ms. Kraushaar noted the Sanitary Sewer Master Plan included a sanitary sewer project linked to development of Frog Pond East that involved upsizing a gravity sewer line that went down Boeckman Creek, and pieces of the trail going to the south would be worked on during that project. The sewer line replacement was in the Capital Improvement Program (CIP), somewhere in the 4 to 7 year range. As Frog Pond developed, the focus would be on the trail north of Boeckman Rd.

Chair Greenfield:

- Asked when the Commission would see more details about the construction and design of the bridge, assuming the proposed Comprehensive Plan amendment was approved.
 - Ms. Kraushaar replied some preliminary conceptual planning had been done which developed some baseline footprint schematics of the bridge's cross section. Once the amendment was approved, the bridge project needed to be included in the budget, hopefully in 2018-2019 in order to start doing the design work. The City also wanted to coordinate the project with the Boeckman Rd improvements. The Boeckman Bridge Project would take quite a bit of time due to environmental permitting and working to find a way to build it with as little inconvenience to the public as possible. Boeckman Rd could be closed for two years to build the bridge, but the City preferred finding contractors with ideas about how to construct the bridge with limited road closures, which could get complicated. When choosing the consultant and contracting teams, the City would look for experience with more creative design and construction options.
- Confirmed the Comprehensive Plan required the Commission to move ahead on this project and how that would be done was yet to be determined. The decision tonight regarded whether the amendment conformed to the Comprehensive Plan.
 - Ms. Kraushaar added the project was in the Transportation System Plan, as well as the Frog Pond Master Plan. In terms of community connections, the project would play a big role in improving what was currently a barrier for pedestrians, bicyclists, and trucks, especially in winter weather. The bridge project would greatly increase the ability to connect the east and west sides of Canyon Creek Rd.

Commissioner Postma moved that the Wilsonville Planning Commission finds, based upon the information provided in the staff report, that the Year 2000 Urban Renewal Plan Amendment conforms to

the Wilsonville Comprehensive Plan and adopts Resolution No. LP17-0005. Commissioner Millan seconded the motion, which passed unanimously.

Chair Greenfield closed the public hearing at 8:18 pm.

Ms. Kraushaar said she was honored that Commissioner Levit's last vote was on the Boeckman Bridge Project.

IV. INFORMATIONAL

A. City Council Action Minutes 11-06-17 & 11/20/17

There were no comments.

B. 2018 Planning Commission Work Program

Chris Neamtzu, Planning Director, explained the geographical boundaries of the Arrowhead Creek Planning Area, which was a man-made small drainage area. City Council had identified working in this area as a goal to consider some land uses, potential riverfront access, and the transportation network building off of the road the City would be constructing soon. Once done, it would look like a mini master plan for that vacant land area south of Wilsonville Rd. Funding for the master plan was anticipated next year.

- He confirmed the City would run into environmental issues given the water in the area.
- He confirmed Phase I of the road project was from Kinsman Rd east and would start next year. The design phase was more than 50 percent complete. He highlighted some elements of the project. He was not certain about the timing for Phase II.
- He described the Density Inconsistency Revisions Project, which was intended to synchronize the Development Code and the Comprehensive Plan to provide increased clarity for anyone applying the development standards. Senior Planner Daniel Pauly would be the project manager.
- The City hoped to have a preferred alternative for the French Prairie Bridge site by July and then discussions would commence about the preferred bridge alignment and a bridge type. The planning process for funding the project was ongoing during each budget cycle as Community Development projects were prioritized. Once the location selection and design were far enough along, then a meaningful approach could be made about the funding. No cost estimate was yet available.

Miranda Bateschell, Planning Manager, clarified that the Town Center Master Plan should be adopted in or by October. The majority of the planning process would be complete by next summer and then it was just a matter of scheduling between the Planning Commission and City Council.

Mr. Neamtzu clarified the public hearing for the Town Center Master Plan was inadvertently placed in the work session column of the Work Program.

Mr. Neamtzu recognized Commissioner Levit for his 14 years of public service, which included two terms on the DRB and two terms on Planning Commission, in addition to his service on other committees. He commended the wonderful legacy and significant imprint he had left on the Wilsonville community and shared how proud he was of the work they had been able to do together. He looked forward to engaging Mr. Levit in some activities in the future.

Commissioner Levit noted one of the weirdest corrections he ever found was when he served on the DRB and he noticed an expired engineer stamp. He recounted his beginnings on the DRB which was only working on Villebois at the time. He clarified that he did not finish his 2nd term on the DRB and acknowledged how great the Staff is to work with and how hard they work. He commended the other Commissioners, noting how much he had enjoyed working with them.

Mr. Neamtzu presented Commissioner Levit with plaque of recognition and a card from the Planning Commission and Planning Staff, thanking him for his years of service.

V. ADJOURNMENT

Chair Greenfield adjourned the regular meeting of the Wilsonville Planning Commission at 8:27 pm.

Respectfully submitted,

By Paula Pinyerd of ABC Transcription Services, Inc. for
Tami Bergeron, Administrative Assistant-Planning



PLANNING COMMISSION WORKSESSION MEETING STAFF REPORT

Meeting Date: December 13, 2017		Subject: 2017 Water Treatment Plant Master Plan Update	
		Staff Member: Eric Mende, PE, Capital Projects Engineering Manager	
		Department: Community Development	
Action Required		Advisory Board/Commission Recommendation	
<input type="checkbox"/> Motion <input type="checkbox"/> Public Hearing Date: <input type="checkbox"/> Ordinance 1 st Reading Date: <input type="checkbox"/> Ordinance 2 nd Reading Date: <input type="checkbox"/> Resolution <input checked="" type="checkbox"/> Information or Direction <input type="checkbox"/> Information Only <input type="checkbox"/> Council Direction <input type="checkbox"/> Consent Agenda		<input type="checkbox"/> Approval <input type="checkbox"/> Denial <input type="checkbox"/> None Forwarded <input checked="" type="checkbox"/> Not Applicable	
		Comments:	
Staff Recommendation: n/a			
Recommended Language for Motion: n/a			
Project / Issue Relates To: <i>[Identify which goal(s), master plans(s) your issue relates to.]</i>			
<input type="checkbox"/> Council Goals/Priorities	<input type="checkbox"/> Adopted Master Plan(s)	<input type="checkbox"/> Not Applicable	

ISSUE BEFORE PC: Initial review of the Draft 2017 Water Treatment Plant Master Plan Update. Staff and Consultants will provide a short briefing and powerpoint, with most of the time reserved for questions from the Commission.

EXECUTIVE SUMMARY: The 2017 Willamette River Water Treatment Plant Master Plan Update (2017 Update) supplements and expands upon a more intensive and detailed 2015 Willamette River Water Treatment Plant Master Plan Update (2015 Plan) performed by Tualatin Valley Water District (TVWD), and completed in December 2016. The 2015 Plan focused primarily on long range regional water supply issues, with particular attention given to the

feasibility of constructing a second, independent water treatment facility on the upper portion of the treatment plant site to provide service to Hillsboro, Beaverton and the TVWD. At the time of it's completion in December 2016, it was felt that the non-Wilsonville focus of the 2015 Plan did not warrant consideration by the Wilsonville Planning Commission, and subsequent adoption into Wilsonville's Comprehensive Plan.

The current 2017 Update before Planning Commission focusses directly on the existing water treatment plant, and considers near term and longer term expansion of the plant driven by growth, as well as the associated repairs, replacements and operational improvements needed to ensure a high quality and reliable source of water for the City. Where appropriate, such as for seismic retrofits to protect the raw water intake, elements of the 2015 Plan are incorporated into the 2017 Update.

EXPECTED RESULTS:

The 2017 Update is intended to be adopted by City Council and become part of the City's Comprehensive Plan.

TIMELINE:

Planning Commission Hearing in February.
City Council Hearing in March.

CURRENT YEAR BUDGET IMPACTS: None. The 2017 Update is budget, and will be completed this fiscal year.

FINANCIAL REVIEW / COMMENTS:

Reviewed by: Date:

LEGAL REVIEW / COMMENT:

Reviewed by: Date:

COMMUNITY INVOLVEMENT PROCESS: Planning Commission and City Council Hearings. No city-wide open houses are being conducted.

POTENTIAL IMPACTS or BENEFIT TO THE COMMUNITY (businesses, neighborhoods, protected and other groups): Continued reliable and clean drinking water supply.

ALTERNATIVES:

CITY MANAGER COMMENT:

ATTACHMENTS:

Attachment A: Executive Summary of Draft 2017 Master Plan Update.

(Full Draft Document is available via electronic PC Packet

<https://or-wilsonville.civicplus.com/AgendaCenter>)



City of Wilsonville

Willamette River Water Treatment Plant

2017 MASTER PLAN UPDATE

DRAFT | December 2017



This page left blank intentionally

ATTACHMENT A



City of Wilsonville Willamette River Water Treatment Plant

2017 MASTER PLAN UPDATE

Jude D. Grounds,
December 6, 2017,
State of Oregon,
P.E. No. 74678

This page left blank intentionally

ATTACHMENT A

Contents

EXECUTIVE SUMMARY	ES-1
ES.1 Introduction	ES-1
ES.2 Plant Expansion and Level of Service Goals	ES-2
ES.3 Existing Facilities and Operational Performance	ES-3
ES.4 Historical Raw and Finished Water Quality	ES-3
ES.5 Existing Infrastructure	ES-3
ES.5.1 Electrical Supply and Distribution CIP	ES-3
ES.5.2 Seismic Evaluation CIP	ES-3
ES.5.3 Life-Safety Evaluation CIP	ES-4
ES.6 WRWTP Expansion CIP	ES-4
ES.6.1 20-MGD Expansion CIP	ES-5
ES.6.2 30-MGD Expansion CIP	ES-5
ES.6.3 Electrical Expansion CIP	ES-11
ES.6.4 Repair and Replacement CIP	ES-11
ES.6.5 CIP Cost Estimates Summary	ES-11
ES.7 Implementation Plan	ES-12
CHAPTER 1 - INTRODUCTION	1-1
1.1 WRWTP AND SOURCE BACKGROUND	1-1
1.2 MASTER PLAN UPDATE OBJECTIVES AND ORGANIZATION	1-3
CHAPTER 2 - PLANT EXPANSION AND LEVEL OF SERVICE GOALS	2-1
2.1 Introduction	2-1
2.2 Water Demands and Expansion Strategy	2-1
2.2.1 Demand Projections and Hydraulic Requirements	2-1
2.2.2 Capacity Expansion and Phasing Strategy	2-3
2.3 Hazard Analysis and Associated Level of Service Goals	2-4
2.3.1 LOS Goal Objective	2-4

ATTACHMENT A

2.3.2 Catastrophic Event	2-5
2.3.3 Regional Precedents	2-8
2.3.4 Recommended Preliminary LOS Goals for WRWTP Expansion	2-10
CHAPTER 3 - EXISTING FACILITIES AND OPERATIONAL PERFORMANCE	3-1
3.1 Introduction	3-1
3.2 Summary of Previous Studies	3-1
3.3 Major Plant Components	3-2
3.3.1 General	3-2
3.3.2 Raw Water Facilities	3-17
3.3.3 Chemical Injection Vault and Initial Mixing Facility	3-17
3.3.4 Ballasted Flocculation (Actiflo®) System	3-18
3.3.5 Ozonation System	3-19
3.3.6 Filtration System	3-20
3.3.7 Liquid Chemical Storage and Feed Facilities	3-20
3.3.8 Washwater Equalization Basin	3-22
3.3.9 Gravity Thickener	3-22
3.4 Historical Plant Performance	3-23
3.5 Conclusions	3-30
CHAPTER 4 - HISTORICAL WATER QUALITY AND REGULATORY COMPLIANCE	4-1
4.1 Introduction	4-1
4.2 Historical Water Quality	4-1
4.3 Regulatory Compliance	4-11
4.3.1 Existing Regulations	4-11
4.3.2 Unregulated Contaminant Monitoring	4-11
4.3.3 CT Compliance	4-13
4.3.4 Future Regulations	4-14
4.4 Emerging Contaminants	4-14
4.4.1 National Perspective and Literature Review	4-15
4.4.2 Regional Perspective	4-17
4.4.3 2015 MPU Participant Interviews	4-18

ATTACHMENT A

4.5 Conclusion	4-19
CHAPTER 5 - EXISTING INFRASTRUCTURE	5-1
5.1 Introduction	5-1
5.2 Site Mapping	5-1
5.3 Electrical Evaluation	5-5
5.4 Seismic Evaluation and Mitigation Alternatives	5-7
5.4.1 Oregon Seismic Requirements	5-7
5.4.2 Geotechnical Investigation Summary	5-9
5.4.3 Seismic Evaluation of Existing Facilities	5-9
5.5 Life Safety Evaluation	5-12
5.6 Transient Surge Analysis	5-12
5.6.1 Evaluation Methodology	5-12
5.6.2 Evaluation Results	5-16
5.6.3 Recommendations	5-16
CHAPTER 6 - WRWTP Expansion CIP	6-1
6.1 Introduction	6-1
6.2 Treatment Technologies	6-1
6.3 Confirmation of Treatment Recommendation	6-1
6.4 20 MGD Expansion	6-2
6.4.1 Flow Projections	6-2
6.4.2 Raw Water Pumping	6-2
6.4.3 Flash Mix	6-7
6.4.4 Ballasted Flocculation (Actiflo®)	6-7
6.4.5 Ozonation and Ozone Generation	6-7
6.4.6 Filtration	6-8
6.4.7 Clearwell/Chlorine Disinfection	6-8
6.4.8 Finished Water Pumping	6-9
6.4.9 Waste Washwater Recovery	6-9
6.4.10 Mechanical Solids Dewatering	6-9
6.4.11 Chemical Storage and Metering	6-9

ATTACHMENT A

6.5 30 MGD Expansion	6-18
6.5.1 Expansion Alternatives	6-18
6.5.2 Flow Projections	6-23
6.5.3 Raw Water Pumping	6-23
6.5.4 Flash Mix	6-27
6.5.5 Ballasted Flocculation (Actiflo®)	6-27
6.5.6 Ozonation	6-27
6.5.7 Filtration	6-27
6.5.8 Clearwell/Chlorine Disinfection	6-27
6.5.9 Finished Water Pumping	6-27
6.5.10 Waste Washwater Recovery	6-28
6.5.11 Mechanical Solids Dewatering	6-28
6.5.12 Chemical Storage and Metering	6-28
6.6 Electrical Upgrades	6-37
6.7 Repair and Replace	6-41

Appendices

To be added at a later date

Tables

Table ES.1 City of Wilsonville and Sherwood Treatment LOS Goals	ES-2
Table ES.2 Estimated CIP Costs (2017 Dollars)	ES-11
Table ES.3 Operations – Repair and Replace Estimated CIP Cost (2017 Dollars)	ES-12
Table ES.4 WRWTP Expansion Design and Construction Schedule	ES-12
Table 2.1 Hydraulic and Capacity Requirements of the WRWTP Participants	2-3
Table 2.2 Catastrophic Hazards Events and Potential Impact on the WRWTP	2-5
Table 2.3 Likelihood of Volcanic Ash Having Substantial Impact on Watersheds with a Southwest Wind	2-6
Table 2.4 Water Treatment Facility Recovery Levels for Various Earthquake Hazard Levels as Implied by Current Codes and Standards for New Construction	2-7
Table 2.5 East Bay Municipal Utility District Level of Service Goals	2-8
Table 2.5 East Bay Municipal Utility District Level of Service Goals (Continued)	2-9
Table 2.6 Oregon Resilience Plan Recommended LOS Goals for Water Systems	2-9

ATTACHMENT A

Table 2.7 Joint Water Commission WTP LOS Goals	2-10
Table 2.8 Adopted LOS Goals for the WRWTP	2-11
Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures	3-3
Table 3.2 WRWTP Production (mgd)	3-28
Table 4.1 WRWTP Comparison of Regulatory and Contract Sampling Frequencies	4-2
Table 4.2 Comparison of Regulatory and Contract Finished Water Parameters	4-3
Table 4.3 WRWTP Summary of Raw Water Quality and Corresponding Finished Water MCL (May 2006 through 2014)	4-5
Table 4.4 WRWTP Summary of Finished Water Quality (May 2006 through 2014)	4-8
Table 4.5 Summary of Wilsonville Distribution System Water Quality Data	4-11
Table 4.6 Summary of UCMR 3 Finished and Distribution Water Quality	4-12
Table 4.7 Summary of Preliminary UCMR 3 Results	4-16
Table 4.8 Summary of CECs Interview Responses by Regional Surface Water Suppliers	4-17
Table 4.9 Summary of CECs Interview Responses by 2015 MPU Participant Water Suppliers	4-18
Table 5.1 WRWTP Caisson and Willamette River Elevations	5-5
Table 5.2 WRWTP Electrical Load Summary	5-6
Table 5.3 Summary of Seismic Vulnerabilities	5-10
Table 5.4 Summary of Life Safety Findings	5-13
Table 5.5 Hydraulic Transient Analysis Demand Scenarios	5-16
Table 5.6 Hydropneumatic Tank Sizing Recommendations	5-16
Table 6.1 WRWTP 20 MGD Expansion Processes and Procedures	6-10
Table 6.2 WRWTP 30 MGD Expansion Alternatives	6-18
Table 6.3 WRWTP 30 MGD Expansion Alternatives – Design and Operating Criteria following a Catastrophic Seismic Event	6-21
Table 6.4 WRWTP 30 MGD Expansion Processes and Procedures	6-29
Table 6.5 WRWTP Repair and Replace Projects	6-41

ATTACHMENT A

Figures

Figure ES.1 WRWTP Capacity Projections and Recommended Expansion Phasing	ES-4
Figure ES.2 Site Plan – 20-MGD Capacity Expansion	ES-7
Figure ES.3 Site Plan – 30-MGD Capacity Expansion	ES-9
Figure 2.1 WRWTP Capacity Projections and Recommended Expansion Phasing	2-2
Figure 2.2 WRWTP and WWSP Water Demand Projections	2-3
Figure 3.1 WRWTP Existing Site Plan	3-11
Figure 3.2 WRWTP Process Flow Diagram	3-13
Figure 3.3 WRWTP Hydraulic Profile	3-15
Figure 3.4 WRWTP Process Performance Summary	3-25
Figure 3.5 WRWTP Raw Water Turbidity	3-29
Figure 3.6 WRWTP Raw Water and Finished Water	3-31
Figure 3.7 WRWTP Monthly Finished Water Production and Power Consumption	3-32
Figure 3.8 WRWTP Monthly Finished Water Production and Solids Production	3-33
Figure 5.1 Lower Site Survey	5-3
Figure 5.2 Current Electrical Load Diagram	5-7
Figure 6.1 WRWTP Site Layout – 20 mgd Capacity	6-3
Figure 6.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity	6-5
Figure 6.3 WRWTP 30 MGD Expansion – LOS	6-19
Figure 6.4 WRWTP 30 MGD Expansion – LOS + Post Regional Seismic Event Resiliency	6-19
Figure 6.5 WRWTP Site Layout – 30 mgd Design Capacity	6-25
Figure 6.6 Existing Electrical System – 20 MGD Capacity	6-38
Figure 6.7 Upgraded Electrical System – 20 MGD Capacity	6-39
Figure 6.8 Upgraded Electrical System – 30 MGD Capacity	6-40

ATTACHMENT A

Abbreviations

2015 MPU	2015 WRWTP Master Plan Update
BRP	Blue Ribbon Panel
C	Celsius
Caisson	Raw Water Intake Pump Station Caisson
CECs	Contaminants of Emerging Concern
CECs	contaminants of emerging concern
CFD	computational fluid dynamic
City	City of Wilsonville
DPB	disinfection by-product
EBMUD	East Bay Municipal Utility District
EPA	Environmental Protection Agency
ESA	Endangered Species Act
EWEB	Eugene Water and Electric Board
FERC	Federal Energy Regulatory Commission
ft	Feet
GAC	granular activated carbon
HABs	harmful algal blooms
IBC	International Building Code
JWC	Joint Water Commission
LOS	level of service
LOX	liquid oxygen
MCC	motor control centers
MCL	maximum contaminant level
mg/L	milligrams per liter
mgd	million gallons per day
MPU	Master Plan Update
mWh	megawatt hours
NAVD	North American Vertical Datum
NCOD	National Contaminant Occurrence Database
nm	nanometers
NMFS	National Marine and Fisheries Service
NTU	Nephelometric Turbidity Units
OAR	Oregon Administrative Rule
ODFW	Oregon Department of Fisheries and Wildlife
OHA	Oregon Health Authority
ORP	Oregon Resilience Plan

ATTACHMENT A

ORS	Oregon Revised Statutes
OSSAC	Oregon Seismic Safety Advisory Committee
OSSC	State of Oregon Structural Specialty and Fire and Life Safety Code
OWUC	Oregon Water Utility Council
PGE	Portland General Electric
PNW	Pacific Northwest
PPCPs	personal care products
ppd	pounds per day
PWB	Portland Water Bureau
RM	Richter Scale Magnitude
RWF	Raw Water Facility
SCADA	Supervisory Control and Data Acquisition
SCM	Streaming Current Monitor
SDWA	Safe Drinking Water Act
the Act	Oregon Drinking Water Quality Act
TOC	total organic carbon
TVWD	Tualatin Valley Water District
TVWD	Tualatin Valley Water District
UBC	Uniform Building Code
UCM	Unregulated Contaminant Monitoring
UCMR	Unregulated Contaminant Monitoring Rule
USGS	United States Geological Survey
WRWTP	Willamette River Water Treatment Plant
WRWTP	Willamette River Water Treatment Plant
WWSA	Willamette River Water Supply Agency
WWSP	Willamette Water Supply Program
µg/L	micrograms per liter

EXECUTIVE SUMMARY

ES.1 Introduction

The 2017 Willamette River Water Treatment Plant (WRWTP) Master Plan Update (2017 MPU) is presented herein for the cities of Wilsonville and Sherwood. The 2017 MPU defines the strategy to meet future demands, increase supply resiliency/reliability, and facilitate responsible growth.

The WRWTP was commissioned in 2002 for a treatment capacity of 15 mgd. To accommodate future drinking water needs of their own, the Tualatin Valley Water District (District) invested in the original construction of the WRWTP, oversizing many of the plant's facilities beyond the original capacity needs to more easily enable future expansion. Initially, both the District and the City of Wilsonville owned the WRWTP, owning 5 mgd and 10 mgd of the capacity, respectively. In 2012, the City of Sherwood purchased the District's 5 mgd capacity of the existing water treatment plant.

The existing property, located in Wilsonville along the Willamette River, is irregularly shaped, essentially creating two semi-contiguous parcels referred to as the Lower Site and an Upper Site. During original design, the Lower Site, home to the existing treatment plant, was planned to facilitate a future expansion of up to 70 mgd. The Upper Site plan was originally identified for future development in the *Willamette River Water Treatment Plant Master Plan* (MWH, 2006). That Master Plan demonstrated enough space for at least 100 mgd in additional capacity at the Upper Site. Combined, both sites have a 170 mgd potential total capacity.

Since the 2006 Master Plan, several events have occurred that changed planning-level construction and operational decisions for expanding the WRWTP. These include:

- In 2012, the District sold 5 mgd of the plant's capacity to the City of Sherwood.
- In 2013, the District and the City of Hillsboro identified the mid-Willamette supply alternative as its preferred supplemental supply option, which laid the foundation for the Willamette Water Supply Program (WWSP).
- In 2014, the City of Wilsonville led a coalition of utilities that petitioned the Oregon Health Authority (OHA) for the right to recognize the disinfection benefits intermediate ozonation.
- In 2015, the City and WWSP stakeholders updated the WRWTP Master Plan (MWH, 2006) to determine how the existing plant could be expanded to meet future demands.
- As of 2017, the WRWTP is expected to exclusively supply Wilsonville and Sherwood. However, the oversized river intake and raw water pumping station will be expanded to provide raw water to both the WRWTP and the proposed WWSP treatment facilities.

The 2015 WRWTP MPU is updated herein to address these changes.

The 2017 MPU has the following key planning objectives:

1. Outline steps needed to expand the existing WRWTP infrastructure to maximize the return on previous investments.
2. Optimize process selection and layout to meet capacity and water quality goals at the expanded WRWTP.

ATTACHMENT A

3. Establish the near- and long-term plant expansion strategy for the 20-year planning horizon; establish a cash-flow strategy to guide future financial planning.
4. Ensure WWSP-related facilities, including raw water pumping, surge and standby power infrastructure, do not prevent the cities of Wilsonville and Sherwood from meeting their ultimate/build-out demands via expansion of the existing WRWTP on the current site.

ES.2 Plant Expansion and Level of Service Goals

In addition to these objectives, the levels of service (LOS) goals were used to establish the preliminary site plans and associated construction and operations cost estimates.

Municipal utilities in the United States and elsewhere commonly use LOS standards to evaluate whether the physical system and operations are functioning to an adequate level. LOS can be defined in terms of the customer’s experience of utility service and/or technical standards based on professional expertise of utility staff.

LOS standards can help guide investments in maintenance, repair, and replacement; and for new assets can be used to establish design criteria and prioritize needs. Using a structured decision process that incorporates LOS can help a utility achieve desired service outcomes while minimizing life-cycle costs.

The LOS goals are intended to address only the facilities required to operate the expanded WRWTP and do not apply to City infrastructure outside of the WTP fence line. The goals, first developed with the Participants of the **2015 MPU** during a project workshop, and adopted by the Participants’ governing bodies. These goals, which were revisited and re-confirmed during a **2017 MPU** workshop, are shown in Table ES.1.

Table ES.1 City of Wilsonville and Sherwood Treatment LOS Goals

LOS Goal	Regional Event (Seismic)	Local Event (Non-Seismic)
“Following a W catastrophic event ...	2,500 year	Per occurrence
...within X days/weeks of the event...	48 hours	14 days
...deliver Y % of average day demand...	50% of nameplate capacity	100% of nameplate capacity
...with Z water quality.”	Potable (at minimum regulatory requirement)	Potable (at plant's intended treatment processes and procedures)

An example LOS goal from Table ES.1 is that 48 hours after a 2,500-year regional (seismic) event, 50 percent of the nameplate treatment plant production capacity will be available with potable water quality that meets minimum regulatory requirements. Within 14 days after a local (non-seismic) event, 100 percent of the nameplate production capacity will be available with potable water quality (at plant's intended treatment processes and procedures).

The costs associated with achieving these LOS goals were developed and confirmed to fall within the Cities’ affordability and risk tolerances. As such, it is recommended these LOS goals continue to guide the WRWTP planning efforts.

ES.3 Existing Facilities and Operational Performance

When the 2006 WRWTP Master Plan was completed (approximately four years after plant start-up), the City of Wilsonville was the only consumer of WRWTP finished water. In mid-2012, the City of Sherwood started using finished water from the WRWTP as its primary supply. With demand from both cities, the plant moved from operating on a daily start/stop basis for 8 to 16 hours per day, depending on demand, to operating 24 hours per day, year-round. Because hours of operation impact plant operations and the expanded plant will continue to operate continuously, the plant performance data evaluated for this Master Plan Update was limited to 2012 through 2014, as included in the 2015 MPU; no additional plant performance data was analyzed as part of this 2017 MPU.

2015 MPU review of the plant performance data demonstrates exceptional operational plant performance for turbidity removal, disinfection levels, TOC removal, and low disinfection by-product (DBP) formation potential. The extremely narrow range between the 5 and 95 percentile value for key water quality parameters such as turbidity, pH, and chlorine residual is a testament to the plant's robust design and its operators' attention to continuous optimal performance.

ES.4 Historical Raw and Finished Water Quality

Raw water quality data from May 2006 through 2014 was collected, reviewed and compared to the data collected and presented in the 2006 Master Plan and 2015 MPU. The few contaminants detected in the raw water at trace levels have not been measured in the finished water.

The historical finished water quality data confirms that the plant consistently surpasses existing finished water regulatory requirements. The high-quality source water, coupled with the robust treatment process result in excellent finished water quality delivered to the customers. The current treatment steps are expected to continue to meet anticipated future regulatory requirements with minor modifications to the treatment process procedures.

ES.5 Existing Infrastructure

To supplement previous efforts and help continue to lay the groundwork for future expansions, additional electrical, seismic, life-safety, and electrical survey of the WRWTP was completed as part of the **2017 MPU**.

ES.5.1 Electrical Supply and Distribution CIP

To meet the 2022 site capacity of nominally 20 mgd, the plant's electrical supply and distribution system will need significant upgrades. Preliminary engineering for the 20 mgd capacity expansion at the WRWTP will require a detailed analysis of electrical supply alternatives, including backup power requirements. Improving the overall 'backbone' of electrical and standby power supply is recommended to occur in parallel with the upcoming 20 mgd capacity expansion project.

ES.5.2 Seismic Evaluation CIP

The preliminary structural analysis identified both structural and non-structural vulnerabilities that may impact plant performance in a regional catastrophic seismic event. Preliminary engineering analysis at the WTWTP results in recommendations of inclusion of seismic retrofits to minimize 'down time' of existing infrastructure, and ensure plant performance following a catastrophic event.

ATTACHMENT A

ES.5.3 Life-Safety Evaluation CIP

The preliminary life-safety analysis identified issues related to building code or structural improvement requirements. Recommendations to implement these modifications to protect worker safety following a catastrophic seismic event are included in this 2017 MPU.

ES.6 WRWTP Expansion CIP

Projected demands were submitted by the Cities of Wilsonville and Sherwood based on each city's individual planning studies. To meet the ultimate combined maximum day demand of both cities of 30 mgd by 2036 as shown in Figure ES.1, the recommended plant capacity expansion, and phasing strategy is as follows:

- Preliminary design of the near-term expansion will likely begin in 2019 to bring the plant capacity of the WRWTP from 15 mgd to 20 mgd by 2022.
- Total raw water intake capacity for both WRWTP and WWSP will be between 80 mgd and 84 mgd by 2026.
- Preliminary design of the 30 mgd expansion will likely begin in 2032 to bring the nameplate capacity of the WRWTP from 20 mgd to 30 mgd by 2035.
- Capacity expansion projects are assumed to be completed two years before the capacity is needed to allow flexibility – the 20 mgd capacity expansion will be completed in 2022, and the 30 mgd capacity expansion will be completed in 2036.




Figure ES.1 WRWTP Capacity Projections and Recommended Expansion Phasing

ES.6.1 20-MGD Expansion CIP

As outlined in the 2015 MPU, the 20 mgd WRWTP expansion will be accomplished by uprating the existing treatment processes rather than constructing additional basins. For the primary treatment processes, the uprating will include the following:

- Increasing the Actiflo® flow rate from 7.5 mgd per basin to 10 mgd per basin
- Increasing the ozonation basin flow rate from 7.5 mgd per basin to 10 mgd per basin. This will decrease the ozone contact time from 15 minutes to 11 minutes, which still allows sufficient contact time for 1-log *Cryptosporidium* inactivation, provided increased levels of ozone can be dosed in the contactor.
- Increasing the filtration rate to a nominal rate of 5.7 gpm/sf and a maximum rate of 7.5 gpm/sf with one filter off-line to a nominal rate of 7.5 gpm/sf and a maximum rate of 10 gpm/sf when one basin is offline. This increased filtration rate will require approval from OHA prior to increasing plant capacity. To support OHA approval, a full-scale pilot study should be conducted in which the filtration rate is gradually increased and water quality is closely monitored.

Figure ES.2 depicts the site layout following completion of the 20-mgd capacity expansion.

ES.6.2 30-MGD Expansion CIP

Two alternatives were considered for the 30 mgd expansion:

1. Installation of one additional process train (i.e., 1 Actiflo® basin, 1 ozone basin, and 2 filters)
2. Installation of two additional treatment process trains (i.e., 2 Actiflo® basins, 2 ozone basins, and 4 filters)

Both alternatives would need the LOS goal in the event of a regional seismic event, but Alternative 1 would have limited treatment rates during equipment maintenance. For example, during filter backwash, the maximum filtration rate of 12 gpm/sf would limit finished water production to 8 mgd. However, the capital and operating costs required for Alternative 2 make it undesirable as it would result in higher rates for residents of Wilsonville and Sherwood. Therefore, it is recommended that the WRWTP construct Alternative 1 and identify an additional water supply that may be used to help meet the LOS goal after a regional seismic event.

Based on the selection of Alternative 1, the 30 md expansion includes the following major construction projects:

- Construction of one Actiflo® basin.
- Construction of one ozonation basin.
- Construction of two filters.
- Construction of one 35-foot diameter gravity thickener.

Figure ES.3 depicts the site layout following completion of the 30-mgd capacity expansion. As recommended in the 2015 MPU, space is dedicated for future AOP process (e.g., UV treatment, etc.) for these steps improves the ability of the future expanded WRWTP to be able to treat constituents of emerging concern.

ATTACHMENT A

-This Page Intentionally Left Blank-




Figure ES.2 Site Plan – 20-MGD Capacity Expansion

ATTACHMENT A

-This Page Intentionally Left Blank-




Figure ES.3 Site Plan – 30-MGD Capacity Expansion

ATTACHMENT A

-This Page Intentionally Left Blank-

ES.6.3 Electrical Expansion CIP

The electrical system is loaded above 80% of listed capacity and is considered overloaded. Additionally, the existing emergency generator is not connected to all WRWTP equipment (for example, it is only wired to Actiflo® Basin 2) and only has sufficient capacity to power the 4 mgd raw and finished water pumps.

Based on these evaluations, it is recommended that the plant upgrade its existing electrical equipment as part of the 20 mgd expansion to ensure service is not interrupted due to electrical fault. The following upgrades are recommended:

- **Switchgear Replacement:** Recommend replacement with a 15 KV metering switchgear and 5 KV transformer, which should be sufficient to power the WRWTP through 60 MGD
- **Emergency Generator Replacement:** Recommend replacement with a 2 MW generator wired directly to the 15 KV metering switchgear. This replacement will allow all plant equipment to be run on the emergency generator.
- **Plant Rewiring:** Recommend connection of all finished water pumps to the 5 KV transformer/switchgear, which will leave sufficient capacity on the remaining transformers to provide power to the rest of the plant.

ES.6.4 Repair and Replacement CIP

In addition to the seismic and life-safety CIP, the WRWTP requires on-going maintenance/repair and replacement (R&R) of its existing infrastructure to ensure normal operations level of service goals. This **2017 MPU** presents a summary of repair and replacement projects for the WRWTP across a 20-year planning horizon.

ES.6.5 CIP Cost Estimates Summary

The existing WRWTP will require an interim expansion to 20 mgd by 2022 and a second expansion to 30 mgd by 2036.

Table ES.2 breaks down the capital costs the two expansions as well as related repair and replace projects, electrical equipment upgrades, life safety repairs, and seismic retrofits necessary to maintain plant operation. Table ES.3 provides additional detail for the repair and replace projects by year and dollar amount. The construction cost estimate presented herein is an American Association of Cost Engineers (AACE) Class 4 estimate, which is considered a concept/feasibility level estimate with approximately 5 percent of the design defined with an expected accuracy range of +50 percent to -30 percent.

Table ES.2 Estimated CIP Costs (2017 Dollars)

Project	Cost ⁽¹⁾	% Water Operations	% SDCs
20 mgd Expansion	\$3,893,165	--	100%
30 mgd Expansion	\$32,518,600	--	100%
Life Safety Repairs	\$616,153	100%	--
Seismic Retrofits	\$1,151,866	100%	--
Electrical Upgrades	\$11,082,506	100%	--
Operations - Repair and Replace	\$19,045,704	100%	--

Notes:

(1) Includes 15% design fee and 10% administrative cost.

ATTACHMENT A

Table ES.3 Operations – Repair and Replace Estimated CIP Cost (2017 Dollars)

Repair and Replace Year	Cost ⁽¹⁾	% Water Operations	% SDCs
2019	\$2,035,169	100%	--
2020	\$2,135,061	100%	--
2021	\$12,513	100%	--
2022	\$4,384,143	100%	--
2023	\$12,513	100%	--
2024	\$12,513	100%	--
2025	\$12,513	100%	--
2026	\$12,513	100%	--
2027	\$5,213,450	100%	--
2028	\$12,513	100%	--
2029	\$12,513	100%	--
2030	\$12,513	100%	--
2031	\$12,513	100%	--
2032	\$2,476,513	100%	--
2033	\$12,513	100%	--
2034	\$12,513	100%	--
2035	\$12,513	100%	--
2036	\$2,651,218	100%	--

Notes:

(1) Includes 10% administrative cost.

ES.7 Implementation Plan

To meet the growing water demands from Wilsonville and Sherwood, the existing WRWTP will first be expanded to a capacity of 20 mgd, followed by a 30 mgd expansion near the end of this planning horizon. A preliminary and final design and construction schedule is summarized in Table ES.4.

Table ES.4 WRWTP Expansion Design and Construction Schedule

Project	Approx Service Year	Duration (Months)		Start Date
		Design	Construction	
Operations - Repair and Replace	2020	8	8	2018
20 MGD Capacity Expansion	2022	12	18	2019
Life Safety Repairs	2022	6	6	2021
Repair and Replace	2022	6	8	2020
Seismic Retrofits	2022	4	6	2021
Repair and Replace	2027	4	6	2026
Repair and Replace	2032	4	6	2031
Repair and Replace	2036	4	6	2035

ATTACHMENT A

30 MGD Capacity Expansion	2036	10	24	2033
20 MGD Capacity Expansion	2022	12	18	2019
Life Safety Repairs	2022	6	6	2021
Seismic Retrofits	2022	4	6	2021
Electrical Upgrades	2022	6	8	2020
30 MGD Capacity Expansion	2036	10	24	2033
Operations – Repair and Replace				
Year I	2018	0	0	--
Year II	2019	0	6	2018
Year III	2020	0	6	2019
Year IV	2021	0	3	2021
Year V	2022	6	9	2020
Year VI	2023	0	3	2023
Year VII	2024	0	3	2024
Year VIII	2025	0	3	2025
Year IX	2026	0	3	2026
Year X	2027	0	9	2026
Year XI	2028	0	3	2028
Year XII	2029	0	3	2029
Year XIII	2030	0	3	2030
Year XV	2031	0	3	2031
Year XVI	2032	0	9	2031
Year XVII	2033	0	3	2033
Year XVIII	2034	0	3	2034
Year XIV	2035	0	3	2035
Year XX	2036	0	12	2035

ATTACHMENT A

-This Page Intentionally Left Blank-



Planning Commission Briefing

December 13, 2017

2017 Water Treatment Plant Master Plan Update

Eric Mende, PE
Capital Projects Engineering Manager

Jude Grounds, PE,
Carollo Engineers

Purpose of 2017 Master Plan Update

- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades



Sludge Thickener SB-3
 Waste Washwater Equalization SB-4
 Filtration SB-7
 High Service Pump Station (Finish Water)
 Raw Water Pump Station
 Clearwell (Buried) SB-2
 Ozonation
 Ballasted Coagulation
 Administrative Building and Chemical Storage SB-4

225' from top of Slope to Limit of Block Failure at Base of Clearwell

100meters
 300feet

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, AeroGRID, IGN, SITA, Swire

A Brief History

- Built / Operational in 2002 (\$47M)
- Joint Ownership with TVWD
- 70 MGD Design*
- Conservative LOS goals/operations
- Current Capacity: 15 MGD (10 – WV, 5 – Sherwood)

Still state-of-the-art




Technical Summary:

Multi-barrier approach guides design and operational philosophy

- Turbidity / Particles
- Pathogens
- Tastes and Odors
- Trace Organics / CEC's

●		●	
	●		●
	●	●	
	●	●	



Purpose of 2017 Master Plan Update

- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades

Level of Service Goals (Water Quality)

	Water Quality Goals	Design / Operating Criteria
A	Keep current, very conservative water quality goals. Keep very conservative operational criteria (SF = 2)	Actiflo: 7.5 mgd (rated at 14 MGD) Filters: 5 mgd (rated at 10 MGD) Ozone/Chlorine: 1-log Crypto inactivation
B	Keep current, very conservative water quality goals. Modified operational criteria (SF= 1.5)	Actiflo: 10 mgd Filters: 6.7 mgd Ozone/Chlorine: 1-log Crypto inactivation
C	Lower WQ goals using aggressive operational criteria (SF = 1.0)	Actiflo: 14 mgd Filters: 7.9 mgd Ozone/Chlorine: 1-log Crypto inactivation

Level of Service Goals (Seismic)


LOS Goal	Regional Event (Seismic)	Local Event (Non-Seismic)
"Following a W catastrophic event ...	2,475 year	Per occurrence
...within X days/weeks of the event...	48 hours	14 days
...deliver Y % of average day demand...	50% of nameplate	100% of nameplate
...with Z water quality."	Potable (at minimum regulatory requirement)	Potable (at plant treatment processes and procedures)

Purpose of 2017 Master Plan Update

- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades


20 MGD Capacity Expansion

- Upgrading existing equipment
- Minor equipment upgrades to support upgrading
- Seismic / Life Safety Improvements
- Filtration pilot study or demonstration
- Recommend electrical upgrade



30 MGD Capacity Expansion

- Expand at updated design criteria
- Designed to new seismic code
- Reduces construction cost
- Conserve space for 60 MGD buildout at Lower Site





Lower Site Repair and Replace

- Ongoing equipment repair and replacement schedule
 - Annual basis – Veolia

Seismic Retrofits

- Repairs to existing facilities to bring them to current seismic code
- Example: Addition of concrete braces to WWEQ Basin



Life Safety Repairs

- Tasks pertaining to building and hazard codes
- Projects include fall protection, hand railing, GFCIs, etc.



Equipment Repair & Replace

- Addresses equipment replacement due to service life
- Whenever possible ties in with capacity expansion

Purpose of 2017 Master Plan Update


- Incorporate Level of Service Goals from 2015 MP
- Address 20 and 30 MGD Capacity Expansions
- Identify Lower Site Repairs/Replacements/Upgrades
- Implementation Plan (CIP, schedule)
 - Coordinate with WWSP Raw Water Facility Upgrades

Coordinated Facility Upgrades

Coordination with Willamette Water Supply

- Raw Water Pump Station Upgrade (24/25)
- Seismic Upgrade (Secant Pile Wall) (21/22)
- Generator Upgrade (18/19)**
- Electrical (Substation) Upgrades (18/19/20)
- Surge Tanks (18/19)**

** - WV Project



OZONE CONTACTOR

BALLASTED FLOUCLATION

GRAVITY THICKENER

GENERATOR FUEL STORAGE

ELECTRICAL BUILDING

HVAC AREA

HYDROPNEUMATIC SURGE TANKS



10' DIAMETER DRILLED SHAFT (TYP)

LIQUID OXYGEN STORAGE AND VAPORIZERS

TRANSFORMER AREA

EXISTING LOWER SITE INFRASTRUCTURE (TYP)

FILTERS

PLANT STANDBY GENERATOR (2MW)

HYDROPNEUMATIC SURGE TANK

NEW SWITCHGEAR BUILDING (12KV & 5KV)

EXISTING RAW WATER PUMP STATION

JET GROUT BLOCK

STORMWATER FACILITY

- WRWTP EXPANSION TO 20 MGD
- WRWTP EXPANSION TO 30 MGD
- EXISTING INFRASTRUCTURE
- NEW RWF INFRASTRUCTURE
- NEW PAVING


CIP Schedule

Project	Approx Service Year	Duration (Months)		Start Date
		Design	Construction	
20 MGD Capacity Expansion	2022	12	18	2019
Life Safety Repairs	2022	6	6	2021
Seismic Retrofits	2022	4	6	2021
Electrical Upgrades	2022	6	8	2020
30 MGD Capacity Expansion	2036	10	24	2033
Operations – Repair and Replace	Ongoing Annual Projects			

CIP Project Estimate

Project	Cost	% Water Operations	% SDCs
20 mgd Expansion	\$3,893,165	--	100%
30 mgd Expansion	\$32,518,600	--	100%
Life Safety Repairs	\$616,153	100%	--
Seismic Retrofits	\$1,151,866	100%	--
Electrical Upgrades	\$11,082,506	100%	--
Operations - Repair and Replace	\$19,045,704	100%	--

Implementation Plan/CIP



Master Plan - Next Steps

- MP Adoption Process
 - Planning Commission Work Session (12/13/17)
 - Planning Commission Hearing (2/14/18)
 - City Council Work Session (3/5/18)
 - City Council 1st Reading (3/5/18)
 - City Council 2nd Reading (3/19/18)
 - Effective Date 4/19/18



Questions?



Willamette River Water Treatment Plant MASTER PLAN UPDATE 2017

Project No. 1122



FINAL | March 2018





City of Wilsonville
Willamette River Water Treatment Plant

2017 MASTER PLAN UPDATE



EXPIRES: 06/30/19



EXPIRES: 12/31/19

Contents

EXECUTIVE SUMMARY

ES.1	Introduction	ES-1
ES.2	Plant Expansion and Level of Service Goals	ES-2
ES.2.1	Demand Projections	ES-2
ES.2.2	Level of Service Goals	ES-2
ES.2.3	Net Present Value	ES-3
ES.3	Existing Facilities and Operational Performance	ES-4
ES.4	Historical Raw and Finished Water Quality	ES-5
ES.5	Existing Infrastructure	ES-5
ES.5.1	Hydraulic Assessment	ES-5
ES.5.2	Equipment Assessment	ES-5
ES.5.3	Electrical Supply and Distribution	ES-5
ES.5.4	Seismic Evaluation	ES-6
ES.5.5	Life-Safety Evaluation	ES-6
ES.5.6	Transient Surge Analysis	ES-6
ES.6	WRWTP Expansion	ES-6
ES.6.1	20-MGD Expansion CIP	ES-6
ES.6.2	30-MGD Expansion CIP	ES-7
ES.6.3	Repair and Replacement CIP	ES-13
ES.7	CIP Approach and Schedule	ES-13

CHAPTER 1 - INTRODUCTION

1.1	WRWTP and Source Background	1-1
1.2	Master Plan Update Objectives and Organization	1-3

CHAPTER 2 - PLANT EXPANSION AND LEVEL OF SERVICE GOALS

2.1	Introduction	2-1
2.2	Water Demands and Expansion Strategy	2-1
2.2.1	Demand Projections and Hydraulic Requirements	2-1
2.2.2	Capacity Expansion and Phasing Strategy	2-3
2.2.3	Net Present Value	2-4

2.3 Hazard Analysis and Associated Level of Service Goals	2-5
2.3.1 LOS Goal Objective	2-6
2.3.2 Catastrophic Event	2-6
2.3.3 Regional Precedents	2-9
2.3.4 Recommended Preliminary LOS Goals for WRWTP Expansion	2-12

CHAPTER 3 - EXISTING FACILITIES AND OPERATIONAL PERFORMANCE

3.1 Introduction	3-1
3.2 Summary of Previous Studies	3-1
3.3 Major Plant Components	3-3
3.3.1 General	3-3
3.3.2 Raw Water Facilities	3-17
3.3.3 Chemical Injection Vault and Initial Mixing Facility	3-17
3.3.4 Ballasted Flocculation (Actiflo®) System	3-18
3.3.5 Ozonation System	3-19
3.3.6 Filtration System	3-20
3.3.7 Liquid Chemical Storage and Feed Facilities	3-21
3.3.8 Washwater Equalization Basin	3-22
3.3.9 Gravity Thickener	3-22
3.4 Historical Plant Performance	3-23
3.5 Conclusions	3-30

CHAPTER 4 - HISTORICAL WATER QUALITY AND REGULATORY COMPLIANCE

4.1 Introduction	4-1
4.2 Historical Water Quality	4-1
4.3 Regulatory Compliance	4-11
4.3.1 Existing Regulations	4-11
4.3.2 Unregulated Contaminant Monitoring	4-11
4.3.3 Contact Time Compliance	4-13
4.3.4 Future Regulations	4-14
4.4 Emerging Contaminants	4-14
4.4.1 National Perspective and Literature Review	4-15
4.4.2 Regional Perspective	4-17
4.4.3 2015 MPU Participant Interviews	4-18

4.5 Conclusion	4-19
CHAPTER 5 - EXISTING INFRASTRUCTURE	
5.1 Introduction	5-1
5.2 Site Mapping	5-1
5.3 Hydraulic Assessment	5-5
5.4 Equipment Assessment	5-9
5.5 Electrical Assessment	5-9
5.5.1 Evaluation Results	5-9
5.5.2 Recommendations	5-11
5.6 Seismic Evaluation and Mitigation Alternatives	5-16
5.6.1 Oregon Seismic Requirements	5-16
5.6.2 Geotechnical Investigation Summary	5-17
5.6.3 Seismic Evaluation of Existing Facilities	5-17
5.7 Life Safety Evaluation	5-18
5.8 Transient Surge Analysis	5-18
5.8.1 Evaluation Methodology	5-18
5.8.2 Evaluation Results	5-24
5.8.3 Recommendations	5-24
CHAPTER 6 - EXPANSION ALTERNATIVES ANALYSIS	
6.1 Introduction	6-1
6.2 Treatment Technologies	6-1
6.3 Confirmation of Treatment Recommendation	6-1
6.4 20 mgd Expansion	6-2
6.4.1 Flow Projections	6-2
6.4.2 Raw Water Pumping	6-2
6.4.3 Flash Mix	6-7
6.4.4 Ballasted Flocculation (Actiflo®)	6-7
6.4.5 Ozonation and Ozone Generation	6-7
6.4.6 Filtration	6-8
6.4.7 Clearwell/Chlorine Disinfection	6-8
6.4.8 Finished Water Pumping	6-9
6.4.9 Waste Washwater Recovery	6-9

6.4.10 Mechanical Solids Dewatering	6-9
6.4.11 Chemical Storage and Metering	6-9
6.4.12 Electrical Upgrades	6-10
6.5 30-mgd Expansion	6-18
6.5.1 Expansion Alternatives	6-19
6.5.2 Flow Projections	6-23
6.5.3 Raw Water Pumping	6-23
6.5.4 Flash Mix	6-27
6.5.5 Ballasted Flocculation (Actiflo®)	6-27
6.5.6 Ozonation	6-27
6.5.7 Filtration	6-27
6.5.8 Clearwell/Chlorine Disinfection	6-27
6.5.9 Finished Water Pumping	6-27
6.5.10 Waste Washwater Recovery	6-28
6.5.11 Mechanical Solids Dewatering	6-28
6.5.12 Chemical Storage and Metering	6-28
6.6 Repair and Replace	6-37
CHAPTER 7 - CIP APPROACH AND SCHEDULE	
7.1 Introduction	7-1
7.2 Capital Cost Assumptions	7-1
7.2.1 Cost Estimate Classification	7-1
7.2.2 Opinion-of-Probable Construction Cost Estimate	7-1
7.2.3 Cost Factoring Workbook	7-2
7.2.4 CIP Workbook	7-2
7.3 Design and Construction Schedule	7-3
7.4 Financial Summary	7-3

Appendices

Appendix A – Condition Assessment Calculations

Appendix B – Life Safety and Seismic Assessment Technical Memorandum

Appendix C – Surge Transient Analysis & Pre-Design Recommendations Technical Memorandum

Appendix D – Capital Cost Estimates

Appendix E – CIP Workbook

Tables

Table ES.1 Cities of Wilsonville and Sherwood Treatment LOS Goals	ES-3
Table ES.2 20-Year NPV for WRWTP Potential Treatment Alternatives	ES-4
Table ES.3 Estimated CIP Costs (2017 Dollars)	ES-13
Table ES.4 Operations – Repair and Replace Estimated CIP Cost (2017 Dollars)	ES-14
Table ES.5 WRWTP Expansion Design and Construction Schedule	ES-14
Table ES.6 WRWTP 2017 MPU Stakeholder Responsibility	ES-15
Table 2.1 Hydraulic and Capacity Requirements of the WRWTP Participants	2-3
Table 2.2 20-Year NPV for WRWTP Potential Treatment Alternatives	2-5
Table 2.3 Catastrophic Hazards Events and Potential Impact on the WRWTP Lower Site	2-6
Table 2.4 Likelihood of Volcanic Ash Having Substantial Impact on Watersheds with a Southwest Wind	2-7
Table 2.5 Water Treatment Facility Recovery Levels for Various Earthquake Hazard Levels as Implied by Current Codes and Standards for New Construction	2-8
Table 2.6 East Bay Municipal Utility District Level of Service Goals	2-10
Table 2.7 Oregon Resilience Plan Recommended LOS Goals for Water Systems	2-11
Table 2.8 Joint Water Commission WTP LOS Goals	2-11
Table 2.9 Adopted LOS Goals for the WRWTP	2-13
Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures	3-3
Table 3.2 WRWTP Production (mgd)	3-28
Table 4.1 WRWTP Comparison of Regulatory and Contract Sampling Frequencies	4-2
Table 4.2 Comparison of Regulatory and Contract Finished Water Parameters	4-3
Table 4.3 WRWTP Summary of Raw Water Quality and Corresponding Finished Water MCL (May 2006 through 2014)	4-5
Table 4.4 WRWTP Summary of Finished Water Quality (May 2006 through 2014)	4-8

Table 4.5 Summary of Wilsonville Distribution System Water Quality Data	4-11
Table 4.6 Summary of UCMR 3 Finished and Distribution Water Quality	4-12
Table 4.7 Summary of Preliminary UCMR 3 Results ⁽¹⁾	4-16
Table 4.8 Summary of CECs Interview Responses by Regional Surface Water Suppliers	4-17
Table 4.9 Summary of CECs Interview Responses by 2015 MPU Participant Water Suppliers	4-18
Table 5.1 WRWTP Caisson and Willamette River Elevations	5-5
Table 5.2 WRWTP Electrical Load Summary	5-10
Table 5.3 Summary of Seismic Vulnerabilities	5-19
Table 5.4 Summary of Life Safety Findings	5-21
Table 5.5 Hydraulic Transient Analysis Demand Scenarios	5-24
Table 5.6 Hydropneumatic Tank Sizing Recommendations	5-24
Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures	6-11
Table 6.2 WRWTP 30 mgd Expansion Alternatives	6-19
Table 6.3 WRWTP 30 mgd Expansion Alternatives – Design and Operating Criteria following a Catastrophic Seismic Event	6-22
Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures	6-29
Table 6.5 WRWTP Repair and Replace Projects	6-37
Table 7.1 Example of CIP Actual Construction Cost	7-2
Table 7.2 WRWTP Expansion Design and Construction Schedule	7-3
Table 7.3 WRWTP Near-Term CIP Costs (2017 Dollars)	7-4
Table 7.4 WRWTP Total CIP Costs (2017 Dollars)	7-7
Table 7.5 WRWTP 2017 MPU Stakeholder Responsibility	7-10

Figures

Figure ES.1 WRWTP Capacity Projections and Recommended Expansion Phasing	ES-2
Figure ES.2 Site Plan – 20-MGD Capacity Expansion	ES-9
Figure ES.3 Site Plan – 30-MGD Capacity Expansion	ES-11
Figure ES.4 RWTP Near-Term CIP Costs by Project (2017 Dollars)	ES-16
Figure ES.5 WRWTP Total CIP Costs by Project (2017 Dollars)	ES-17

Figure 2.1 WRWTP Capacity Projections and Recommended Expansion Phasing	2-2
Figure 2.2 WRWTP and WWSP Water Demand Projections	2-3
Figure 3.1 WRWTP Existing Site Plan	3-11
Figure 3.2 WRWTP Process Flow Diagram	3-13
Figure 3.3 WRWTP Hydraulic Profile	3-15
Figure 3.4 WRWTP Process Performance Summary	3-25
Figure 3.5 WRWTP Raw Water Turbidity	3-29
Figure 3.6 WRWTP Raw Water and Finished Water	3-31
Figure 3.7 WRWTP Monthly Finished Water Production and Power Consumption	3-32
Figure 3.8 WRWTP Monthly Finished Water Production and Solids Production	3-33
Figure 5.1 Lower Site Survey	5-3
Figure 5.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity	5-7
Figure 5.3 Current Electrical Load Distribution Diagram	5-12
Figure 5.4 Existing Electrical System – 20 mgd Capacity	5-13
Figure 5.5 Upgraded Electrical System – 20 mgd Capacity	5-14
Figure 5.6 Upgraded Electrical System – 30 mgd Capacity	5-15
Figure 6.1 WRWTP Site Layout – 20 mgd Capacity	6-3
Figure 6.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity	6-5
Figure 6.3 WRWTP 30 mgd Expansion – LOS	6-19
Figure 6.4 WRWTP 30 mgd Expansion – LOS + Post Regional Seismic Event (PRSE) Resiliency	6-20
Figure 6.5 WRWTP Site Layout – 30 mgd Design Capacity	6-25
Figure 7.1 Example Assumptions in CIP Workbook	7-2
Figure 7.2 WRWTP Near-Term CIP Costs (2017 Dollars)	7-5
Figure 7.3 WRWTP Total CIP Costs (2017 Dollars)	7-9

Abbreviations

%	percent
#	number
@	at
2015 MPU	2015 WRWTP Master Plan Update
AACE	American Association of Cost Engineers
ACFM	actual cubic feet per minute Ag silver
Al	aluminum
ASCE	American Society of Civil Engineers
ASR	aquifer storage and recovery
B	boron
BRP	Blue Ribbon Panel
C	Celsius
CaCO ₃	calcium carbonate
Caisson	Raw Water Intake Pump Station Caisson
CECs	contaminants of emerging concern
CF	cubic foot/feet
Cr+6	hexavalent chromium
CFD	computational fluid dynamic
CFM	cubic feet per minute
CIP	capital improvement plan
City	City of Wilsonville
COW	cost of work
CT	contact time
DCR	demand to capacity ratio
DBP	disinfection by-product
EBCT	empty bed contact time
EBMUD	East Bay Municipal Utility District
ENR	Engineering News Record
EPA	Environmental Protection Agency
ESA	Endangered Species Act
EWEB	Eugene Water and Electric Board
FEMA	Federal Emergency Management Agency
FERC	Federal Energy Regulatory Commission
FFA	future forced air cooled rating
fps	feet per second
ft	foot/feet GAC granular activated carbon

gpd	gallons per day
gpm	gallons per minute
gpm/sf	gallons per minute per square-foot
HAB	harmful algal bloom
HP	horse power
HR	hour(s)
HRT	hydraulic retention time
IBC	International Building Code
in	inches
IOC	inorganic contaminant
JWC	Joint Water Commission
KV	kilovolt
lb	pound(s)
LCR	Lead and Copper Rule
LOS	level of service
LOTWTP	Lake Oswego-Tigard Water Treatment Partnership
LOX	liquid oxygen
M.M.	Modified Mercalli Scale
MCC	motor control center
MCL	maximum contaminant level
MG	million gallon(s)
mg/L	milligrams per liter
mgd	million gallons per day
min	minute(s)
mL	milliliter
\$MM	million dollars
mm	millimeter
Mn	manganese
MPN	most probable number
MPU	Master Plan Update
MS	main switchgear
MWh	megawatt hours
NAVD	North American Vertical Datum
NCOD	National Contaminant Occurrence Database
nm	nanometers
NMFS	National Marine Fisheries Service
NPV	net present value

NTU	Nephelometric turbidity units
OA	oil-cooled rating
OAR	Oregon Administrative Rule
ODFW	Oregon Department of Fish and Wildlife
OHA	Oregon Health Authority
ORP	Oregon Resilience Plan
ORS	Oregon Revised Statutes
OPCC	opinion-of-probable construction-cost
OSSAC	Oregon Seismic Safety Advisory Committee
OSSC	State of Oregon Structural Specialty and Fire and Life Safety Code
OWUC	Oregon Water Utility Council
PGE	Portland General Electric
PNW	Pacific Northwest
PPCPs	pharmaceuticals and personal care products
ppd	pounds per day
PRSE	post-regional seismic event
PWB	Portland Water Bureau
RM	Richter scale magnitude
RWF	Raw Water Facility
s ⁻¹	per second
SCADA	supervisory control and data acquisition
SCM	streaming current monitor
SDC	system development charge
SDWA	Safe Drinking Water Act
SF	square feet
SOC	synthetic organic contaminant
TDH	total dynamic head
TDS	total dissolved solids
the Act	Oregon Drinking Water Quality Act
TOC	total organic carbon
TON	threshold odor number
TVWD	Tualatin Valley Water District
UBC	Uniform Building Code
UCM	Unregulated Contaminant Monitoring
UCMR	Unregulated Contaminant Monitoring Rule
USGS	United States Geological Survey
UV	ultraviolet

V	volt
V	vanadium
VFD	variable frequency drive
VOC	volatile organic compound
WRWTP	Willamette River Water Treatment Plant
WWSA	Willamette River Water Supply Agency
WWSP	Willamette Water Supply Program
Zn	zinc
µg/L	micrograms per liter
µm	micrometer

EXECUTIVE SUMMARY

ES.1 Introduction

The 2017 Willamette River Water Treatment Plant Master Plan Update (2017 MPU) for the Cities of Wilsonville and Sherwood defines the strategy to meet future demands, boost supply resiliency and reliability, and support responsible growth.

Commissioned in 2002, the Willamette River Water Treatment Plant (WRWTP) has a treatment capacity of 15 million gallons per day (mgd). Of this capacity, Wilsonville owns 10 mgd, and the Tualatin Valley Water District (TVWD) initially owned 5 mgd. The District invested in the plant's construction, oversizing many of its facilities to enable expansion for its own future water needs.

The existing property along the Willamette River in Wilsonville is irregularly shaped, creating two semi-contiguous parcels called the Lower Site and the Upper Site. During original design, the Lower Site, home to the existing treatment plant, would allow for an expansion of up to 60 mgd. The Upper Site was identified for future development in the *Willamette River Water Treatment Plant Master Plan* (MWH, 2006), which demonstrated enough space for at least 100 mgd additional capacity. Combined, both sites have a 160 mgd potential total capacity.

Since the 2006 Master Plan was published, several actions occurred that affect both construction and operational planning for expanding the WRWTP:

- In 2012, the TVWD sold its 5 mgd of plant capacity to the City of Sherwood.
- In 2013, the TVWD and the City of Hillsboro named the mid-Willamette supply alternative as their preferred supplemental supply, which laid the foundation for the Willamette Water Supply Program (WWSP).
- In 2014, the city of Wilsonville led a coalition of utilities that petitioned the Oregon Health Authority (OHA) for the right to recognize the disinfection benefits from intermediate ozonation.
- In 2015, the City and WWSP stakeholders updated the WRWTP Master Plan (MWH, 2006) in the 2015 MPU (Carollo, 2016) to outline how the existing plant could be expanded to meet future demand.
- As of 2017, the WRWTP is expected to supply Wilsonville and Sherwood exclusively. However, the oversized river intake and raw water pumping station will be expanded to supply raw water to both the WRWTP and the proposed WWSP treatment facilities.

The 2017 MPU updates the 2015 WRWTP MPU and addresses these changes. The 2017 MPU has the following key objectives.

1. To define the steps for expanding the existing WRWTP infrastructure to maximize the return on previous investments.
2. To optimize process selection and layout to meet capacity and water quality goals at the expanded WRWTP.
3. To strategize near- and long-term plant expansion for a 20-year planning horizon and cash-flow to guide future financial planning.
4. To ensure that WWSP-related facilities, including raw water pumping, surge protection, and standby power infrastructure, do not impact operation or prevent the Cities of Wilsonville and Sherwood from meeting their ultimate build-out demands for the existing WRWTP on the current site.

ES.2 Plant Expansion and Level of Service Goals

ES.2.1 Demand Projections

Two water agencies will continue using the expanded WRWTP as their primary source of drinking water supply: the City of Wilsonville and the City of Sherwood.

Figure 2.1 presents the two cities’ respective projected annual peak daily demands through 2050 as well as the combined ultimate build-out demand projection for 2050. It also shows a phased expansion strategy, which is detailed in the following subsections. The demand projection was published in the Wilsonville Water Master System Plan, adopted September 2012, and is based on the following assumptions:

- Annual residential growth of 2.9%.
- Annual non-residential growth of 3.5%.
- Industrial demand of increase 0.25 mgd every five years to a total of 1 mgd by 2025.
- City of Sherwood demand to increase from 5 mgd to approximately 10 mgd by 2025.

Figure ES.1 presents the two cities’ respective projected annual peak daily demands through 2050 as well as the combined ultimate build-out demand projection for 2050.




Figure ES.1 WRWTP Capacity Projections and Recommended Expansion Phasing

ES.2.2 Level of Service Goals

Level of service (LOS) goals were used to plan the preliminary site and estimate its construction and operations costs.

Municipal utilities in the United States and elsewhere commonly use LOS goals to evaluate systems and operations. LOS goals can be defined in terms of the customer’s experience of utility service and/or technical standards based on professional expertise of utility staff.

LOS goals can guide investments in maintenance, repair, and replacement. For new assets, they can be used to set design criteria and prioritize needs. Using a structured decision-making process that incorporates LOS goals helps a utility reach desired service objectives and minimize life-cycle costs.

The LOS goals address only the facilities required to operate the expanded WRWTP and do not apply to City infrastructure outside of the WTP fence line. The goals were first developed with participants of the 2015 MPU during a project workshop and adopted by the participants’ governing bodies. These LOS goals, which were revisited and re-confirmed during a 2017 MPU workshop, are shown in Table ES.1.

Table ES.1 **Cities of Wilsonville and Sherwood Treatment LOS Goals**

LOS Goal	Regional Event (Seismic)	Local Event (Non-Seismic)
“Following a W catastrophic event ...	2,500 year	Per occurrence
...within X days/weeks of the event...	48 hours	14 days
...deliver Y % of average day demand...	50% of nameplate capacity	100% of nameplate capacity
...with Z water quality.”	Potable (at minimum regulatory requirement)	Potable (at plant's intended treatment processes and procedures)

As stated in Table ES.1, 48 hours after a 2,500-year regional (seismic) event, 50 percent of the nameplate treatment plant production capacity will be available, with potable water quality that meets minimum regulatory requirements. Within 14 days of a local (non-seismic) event, 100 percent of the nameplate production capacity will be available with potable water quality at the plant's intended treatment processes and procedures.

The costs for achieving these LOS goals were developed and confirmed to fall within the cities’ affordability and risk tolerances. We recommend these LOS goals continue to guide the WRWTP planning efforts.

ES.2.3 Net Present Value

The 2015 MPU included a net present value (NPV) evaluation of three potential treatment alternatives for the WRWTP (which would also be design criteria for the WWSP treatment plant). The alternatives evaluated in Chapter 6 and Appendices I and J were the following:

- **Alternative A – Baseline Procedures:** The existing plant infrastructure would be maintained as-is, with additional capacity being gained by adding new concrete treatment basins and associated supporting mechanical equipment. This is the most conservative option but also had highest capital and operating costs.
- **Alternative B – OHA Modified Procedures:** Moderately increasing the treatment rate of select processes to realize available operational efficiencies and reduce the number or size of the process trains/basins compared to Alternative A. This the recommended option that utilized existing treatment steps with modified operational procedures to

achieve higher capacities in a smaller footprint while still meeting the existing WRWTP treated water quality goals.

- **Alternative C – OHA Compliance:** Aggressive increase in treatment rates compared to Alternative B and requires modifying the existing WRWTP treated water goals. This was the most aggressive with the lowest capital and operating costs. However, this alternative was not considered viable since it had the lowest potential to respond to future regulatory changes and would require changes to water treatment goals.

An NPV was developed as part of the 2015 MPU to determine the potential financial benefits of each alternative on a 36-year term with 4% interest rate. A version of the 2015 MPU NPV calculation (modified for 20-year and limited to the WRWTP expansions) is included in Appendix A. The relative cost differences for potential treatment alternatives are listed in Table ES.2. For a full list of the NPV criteria and assumptions, refer to Chapter 6 and Appendices I and J in the 2015 MPU.

Table ES.2 20-Year NPV for WRWTP Potential Treatment Alternatives

	Alternative A Baseline Procedures	Alternative B Modified Procedures	Alternative C OHA Compliance
NPV ⁽¹⁾	\$88,400,000	\$81,200,000	\$76,700,000
Cost Comparison (\$)			
Alternative A	--	\$(7,200,000)	\$(11,700,000)
Alternative B	\$7,200,000	--	\$(4,500,000)
Alternative C	\$11,700,000	\$4,500,000	--
Cost Comparison (%)			
Alternative A	--	-9%	-15%
Alternative B	8%	--	-6%
Alternative C	13%	6%	--

Notes:

(1) NPV amounts rounded up to the nearest \$100,000.

ES.3 Existing Facilities and Operational Performance

When the 2006 WRWTP Master Plan was completed approximately four years after plant start-up, the City of Wilsonville was the only consumer of WRWTP finished water. In mid-2012, the City of Sherwood started using finished water from the WRWTP as its primary supply. To meet the demands of both cities, the plant went from operating on a daily start/stop basis for 8 to 16 hours per day depending on demand to operating 24 hours per day, year-round. Since the hours of operation impact plant operations and the expanded plant will continue to operate continuously, the plant performance data evaluated for this Master Plan Update was limited to 2012 through 2014, as included in the 2015 MPU. No additional plant performance data was analyzed as part of this 2017 MPU.

The 2015 MPU review of plant performance data demonstrates exceptional operational performance for turbidity removal, disinfection levels, total organic carbon (TOC) removal, and low disinfection by-product (DBP) formation. The extremely narrow range between the 5 and 95 percentile value for key water quality parameters such as turbidity, pH, and chlorine residual is a testament to the plant’s robust design and its operators’ attention to continuous optimal performance.

ES.4 Historical Raw and Finished Water Quality

Raw water quality data from May 2006 through 2014 was collected, reviewed, and compared to the data in the 2006 Master Plan and 2015 MPU. The trace-level contaminants detected in the raw water have not been detected in the finished water and were therefore assumed to be removed through the treatment processes.

The historical finished water quality data confirms that the plant consistently surpasses existing finished water regulatory requirements. The high-quality source water and robust treatment process result in excellent finished water quality delivered to customers. With only minor modifications, the current treatment processes are expected to continue to meet future regulatory requirements.

ES.5 Existing Infrastructure

The 2017 MPU offers additional electrical, seismic, and life-safety assessment for the WRWTP.

ES.5.1 Hydraulic Assessment

A hydraulic model of the WRWTP was developed in Carollo's Hydraulix® software to compare water surface elevations in the treatment train at 15 mgd and 20 mgd to determine the feasibility of an interim expansion using the existing WRWTP infrastructure. The model also includes 10 percent internal recycle flow through the Actiflo®, Ozonation, and filter systems. Results of the hydraulics assessment included:

- Increasing the maximum flow of each Actiflo® basin from 7.5 to 10 mgd raised the water level elevation by approximately 0.5 feet (ft), but head losses in the system will not increase substantially.
- Increasing the maximum flow rate of each ozone basin from 7.5 to 10 mgd resulted in head loss increase of less than 1 inch.
- Increasing the maximum filtration rate of each deep-bed filter from 7.5 gallons per minute per square-foot (gpm/sf) to 10 gpm/sf reduced the head available for solids collection by approximately 1.5 ft. This decrease in solids accumulation capacity is not expected to impact plant operations since the filter backwash is conducted based on schedule rather than solids accumulation.

ES.5.2 Equipment Assessment

An assessment of the existing plant facilities was included to determine how equipment replacement would be included in the 20-year planning horizon. This evaluation was used to identify likely equipment replacement periods in order to ensure continued successful operation. The equipment assessment was performed using Veolia's equipment database management system and operations staff input. This was then compared to the planned capacity expansions to identify when service life expiration would coincide with capacity increases requiring equipment upgrades. Equipment with a service life expiration that did not coincide with a capacity expansion were identified for replacement (either "in-kind" or upgraded) during an interim project.

ES.5.3 Electrical Supply and Distribution

To meet the 2020 site capacity of nominally 20 mgd, the plant's electrical supply and distribution system will need significant upgrades. Preliminary engineering for the capacity expansion will require detailed analysis of electrical supply alternatives, including backup power requirements.

Improving the "backbone" of electrical and standby power is recommended as part of the 20 mgd expansion project.

ES.5.4 Seismic Evaluation

The preliminary structural analysis identified both structural and non-structural vulnerabilities that may affect plant performance in a regional catastrophic seismic event. This 2017 MPU includes seismic retrofits as a CIP project to minimize infrastructure downtime and ensure plant performance after a catastrophic event.

ES.5.5 Life-Safety Evaluation

The preliminary life-safety analysis identified issues about building code compliance and structural improvements. This 2017 MPU includes life safety repairs as a CIP project to support continued safe plant operations.

ES.5.6 Transient Surge Analysis

A transient analysis was performed on the finished water pumping and delivery system to confirm the findings of *Hydraulic Transient Analysis – City of Wilsonville* (MWH, 2011). This analysis confirmed that a hydropneumatic tank is recommended when the demand approaches 15 mgd. A 1,500 cubic-foot (CF) surge tank is recommended for the current installation to enhance near-term surge protection and eliminate the need for additional construction during the 20 and 30 mgd capacity expansions. Note that the surge tank project is being pursued as a separate construction project outside of the 2017 MPU and therefore is not included in the CIP.

ES.6 WRWTP Expansion

Projected demand was submitted by the cities of Wilsonville and Sherwood based on each city's planning studies. To meet the cities' combined day demand of 30 mgd by 2036 as shown in Figure ES.1, this 2017 MPU recommends the following expansion and phasing:

- Preliminary design of the near-term expansion will likely begin in 2018 to bring WRWTP capacity from 15 mgd to 20 mgd by 2020.
- Total raw water intake capacity for both WRWTP and WWSP will be between 80 mgd and 84 mgd by 2026.
- Preliminary design of the 30 mgd expansion will likely begin in 2032 to bring the nameplate capacity of the WRWTP from 20 mgd to 30 mgd by 2034.
- Capacity expansion projects should be completed two years before the capacity is needed to allow flexibility. The 20 mgd capacity expansion will be completed in 2020 and the 30 mgd capacity expansion in 2034.

ES.6.1 20-MGD Expansion CIP

As outlined in the 2015 MPU, rather than constructing additional basins, the existing treatment processes will be uprated for the 20 mgd WRWTP expansion. For the primary treatment processes, the uprating will include the following.

- Increasing the Actiflo® flow rate from 7.5 mgd per basin to 10 mgd per basin.
- Increasing the ozonation basin flow rate from 7.5 mgd per basin to 10 mgd per basin. This will decrease the ozone contact time from 15 to 11 minutes, which still allows sufficient contact time for 1-log *Cryptosporidium* inactivation, provided increased levels of ozone can be dosed in the contactor.

- Increasing the filtration rate to a nominal rate of 5.7 gpm/sf and a maximum rate of 7.5 gpm/sf when one filter is off-line, and to a nominal rate of 7.5 gpm/sf and a maximum rate of 10 gpm/sf when one basin is offline. This increased filtration rate will require approval from OHA prior to increasing plant capacity. To support OHA approval, a full-scale pilot study should be conducted in which the filtration rate is gradually increased and water quality is closely monitored.
- Upgrade the existing electrical equipment to ensure that service is not interrupted by electrical fault. The following upgrades are recommended:
 - Replace switchgear with 15-KV metering switchgear and 5 KV transformer, which should be sufficient to power the WRWTP through 60 MGD.
 - Replace emergency generator with a 2-MW generator wired directly to the 15-KV metering switchgear. This will allow all plant equipment run on the emergency generator.
 - Rewire plant to connect all finished water pumps to the 5-V transformer/switchgear. This will leave sufficient capacity on the remaining transformers to power the rest of the plant.

Figure ES.2 depicts the site layout following completion of the 20-mgd capacity expansion.

ES.6.2 30-MGD Expansion CIP

The following two alternatives were considered for the 30 mgd expansion.

1. Install one additional process train: One Actiflo® basin, one ozone basin, and two filters.
2. Install two additional treatment process trains: Two Actiflo® basins, two ozone basins, and four filters.

Both alternatives would need to meet the LOS goal after a regional seismic event. However, Alternative 1 would have limited treatment rates during equipment maintenance. For example, during filter backwash, the maximum filtration rate of 12 gpm/sf would limit finished water production to 8 mgd. Conversely, the capital and operating costs required for Alternative 2 make it undesirable because it raises rates for Wilsonville and Sherwood residents. Therefore, we recommend that the WRWTP construct Alternative 1 and identify an additional water supply to meet the LOS goal after a regional seismic event.

Using Alternative 1, the 30 mgd expansion requires the following major construction projects:

- One Actiflo® basin.
- One ozonation basin.
- Two filters.
- One 35-foot diameter gravity thickener.

Figure ES.3 depicts the site layout for the 30-mgd capacity expansion. As recommended in the 2015 MPU, space dedicated for future AOP processes (such as UV treatment) improves the ability of the expanded WRWTP to treat constituents of emerging concern.

-This Page Intentionally Left Blank-




Figure ES.2 Site Plan – 20-MGD Capacity Expansion

-This Page Intentionally Left Blank-




Figure ES.3 Site Plan – 30-MGD Capacity Expansion

-This Page Intentionally Left Blank-

ES.6.3 Repair and Replacement CIP

In addition to the seismic and life-safety CIP, the WRWTP requires ongoing maintenance/repair and replacement (R&R) of its existing infrastructure to meet service goals. This 2017 MPU summarizes repair and replacement projects for the next 20 years.

ES.7 CIP Approach and Schedule

The existing WRWTP must be expanded to 20 mgd by 2020 and to 30 mgd by 2034.

Table ES.3 breaks down the capital costs for the two expansions and related repair and replace projects, electrical equipment upgrades, life safety repairs, and seismic retrofits necessary to maintain plant operation. Table ES.4 details repair and replace projects by year and dollar amount. Table ES.6 details the stakeholder financial responsibility and fee structure for each CIP project.

The CIP cost estimates are classified as American Association of Cost Engineers (AACE) Class 4 or Class 5 estimates. The Class 4 estimates have an expected level of accuracy of +50% to -30%. The Class 5 estimates have an expected level of accuracy of +100% to -50%. Figures ES.4 and ES.5 depict the near term and total CIP costs, respectively, as broken down by project.

Table ES.3 Estimated CIP Costs (2017 Dollars)

Project	Cost ⁽¹⁾	%City of Wilsonville	%City of Sherwood	% Water Operations	% SDCs
20 mgd Expansion	\$15,730,000	66.7	33.3	37	63
30 mgd Expansion	\$38,650,000	67.7	32.2	37	63
Life Safety Repairs	\$630,000	66.7	33.3	100%	--
Seismic Retrofits	\$1,170,000	66.7	33.3	100%	--
Operations - Repair and Replace	\$17,740,000	66.7	33.3	100%	--

Notes:

(1) Includes 15% design fee and 10% administrative cost.

(2) All costs are rounded up to nearest \$10,000.

Table ES.4 Operations – Repair and Replace Estimated CIP Cost (2017 Dollars)

Repair and Replace Year	Cost ⁽¹⁾	% Water Operations	% SDCs
2019	\$1,360,000	100%	--
2020	\$1,450,000	100%	--
2021	\$20,000	100%	--
2022	\$3,110,000	100%	--
2023	\$20,000	100%	--
2024	\$20,000	100%	--
2025	\$20,000	100%	--
2026	\$20,000	100%	--
2027	\$4,740,000	100%	--
2028	\$20,000	100%	--
2029	\$20,000	100%	--
2030	\$20,000	100%	--
2031	\$20,000	100%	--
2032	\$2,260,000	100%	--
2033	\$20,000	100%	--
2034	\$20,000	100%	--
2035	\$20,000	100%	--
2036	\$3,090,000	100%	--

Notes:

(1) Includes 10% administrative cost.

To meet growing water demand from Wilsonville and Sherwood, the existing WRWTP will first be expanded to a capacity of 20 mgd, followed by an expansion to 30 mgd near the end of this planning horizon. Table ES.5 summarizes a preliminary and final design and construction schedule.

Table ES.5 WRWTP Expansion Design and Construction Schedule

Project	Approx. Service Year	Duration (Months)			Start Date
		Design	Construction	Float	
20 MGD Capacity Expansion	2020	12	18	6	2018
Life Safety Repairs	2022	6	6	3	2020
Seismic Retrofits	2022	6	6	3	2020
30 MGD Capacity Expansion	2036	12	24	6	2033
Operations – Repair and Replace					
Year 1	2019	0	6	6	2018
Year 2	2020	0	6	6	2019
Year 3	2021	0	6	6	2020

Table ES.5 WRWTP Expansion Design and Construction Schedule (Continued)

Project	Approx. Service Year	Duration (Months)			Start Date
		Design	Construction	Float	
Year 4	2022	0	6	6	2021
Year 5	2023	0	6	6	2022
Year 6	2024	0	6	6	2023
Year 7	2025	0	6	6	2024
Year 8	2026	0	6	6	2025
Year 9	2027	0	6	6	2026
Year 10	2028	0	6	6	2027
Year 11	2029	0	6	6	2028
Year 12	2030	0	6	6	2029
Year 13	2031	0	6	6	2030
Year 14	2032	0	6	6	2031
Year 15	2033	0	6	6	2032
Year 16	2034	0	6	6	2033
Year 17	2035	0	6	6	2034
Year 18	2036	0	6	6	2035

Table ES.6 WRWTP 2017 MPU Stakeholder Responsibility

CIP Project	%City of Wilsonville	%City of Sherwood	%Water Operations	%SDCs
20 mgd Expansion	66.7	33.3	37	63
Life Safety Repairs	66.7	33.3	100	--
Seismic Retrofits	66.7	33.3	100	--
30 mgd Expansion	68	32	37	63
Operations – Repair and Replace	66.7	33.3	85	15




Figure ES.4 RWTP Near-Term CIP Costs by Project (2017 Dollars)




Figure ES.5 WRWTP Total CIP Costs by Project (2017 Dollars)

-This Page Intentionally Left Blank-

Chapter 1

INTRODUCTION

The Willamette River is a source of high-quality and plentiful drinking water. In 1997, several Portland area agencies formed the Willamette River Water Supply Agency (WWSA) to assess the feasibility of using the Willamette River as a regional source. Extensive pilot testing and water quality sampling verified the supply's quality and treatability. The WWSA developed preliminary engineering plans for facilities, estimated associated costs, and identified potential governance and financing options to fund and manage the system. Members of the WWSA compared this information to other options for regional water supply and developed long-term strategic plans to best meet the region's needs.

At about the same time, the City of Wilsonville (City) placed a city-wide moratorium on new construction. The City's groundwater supply was over-drafted and an additional drinking water supply was needed. Working with the Tualatin Valley Water District (TVWD), the City built a new drinking water treatment plant on the Willamette River.

The resulting Willamette River Water Treatment Plant (WRWTP), commissioned in 2002, has a treatment capacity of 15 mgd. The City contracted with Veolia to operate the plant. Of the 15 mgd original capacity, the City owns 10 mgd. TVWD owned 5 mgd of plant capacity. With an eye to accommodating future drinking water needs of its own, TVWD had invested in the plant's construction, oversizing many plant facilities to enable expansion. In 2012, TVWD sold its 5 mgd capacity to the City of Sherwood, but the agency retains an ownership interest at the WRWTP.

In 2017, the WRWTP users (the Cities of Wilsonville and Sherwood) collaborated to update the 2015 WRWTP Master Plan Update (2015 MPU). This 2017 Update describes the strategy for the following:

- Meeting future demands.
- Increasing supply resiliency and reliability.
- Coordinating with the upcoming requirement to pump raw water to the Willamette Water Supply Program (WWSP) treatment plant in Washington County.
- Facilitating responsible growth within existing urban growth boundaries.

1.1 WRWTP and Source Background

The original plant's key objectives were to:

1. Produce consistently high-quality drinking water using a multi-barrier treatment process.
2. Exceed 2002 regulatory treatment and water quality standards to enhance consumer confidence.
3. Minimize the plant footprint, thereby providing space for public amenities.
4. Incorporate flexibility for cost-effective future plant capacity expansions.
5. Operate quietly, respectfully, and without negative impact on the neighborhood.

6. Complete design and construction in less than three years to meet the City's 2002 startup target.
7. Meet "critical facility" seismic and structural criteria.

The plant employed four innovative and robust treatment technologies: 1) high-rate clarification (ballasted flocculation); 2) intermediate ozonation; 3) deep-bed granular activated carbon (GAC)/sand filtration, and; 4) mechanical dewatering (centrifuges). When it was commissioned in 2002, the WRWTP was the first plant in the Pacific Northwest to use all four advanced technologies for drinking water treatment.

The existing WRWTP property along the river is irregularly shaped, creating Lower and Upper Sites, depicted on Figure 1.1. Home to the existing treatment plant, the Lower Site was designed for future expansion of up to 60 mgd of total capacity. The Upper Site, owned by TVWD, was not master-planned until after the District-led WRWTP Master Plan (MWH, 2006) was completed. The 2006 Master Plan showed the Upper Site could accommodate at least 100 mgd in additional capacity. Therefore, the combined WRWTP production capacity that could be constructed on the Upper and Lower sites is as high as 160 mgd.

Since then, several events have unfolded that affect construction and operational decision-making for expanding the plant, requiring an update to the 2006 Master Plan:

- In 2012, the City of Sherwood began purchasing WRWTP finished water. The plant, which had historically been operated in "start/stop" mode to meet Wilsonville's daily demands alone, is now operated 24 hours per day, seven days a week.
- In 2013, TVWD and the City of Hillsboro identified the mid-Willamette Supply alternative as its preferred supplemental supply option, which laid the foundation for the WWSP.
- Because of the WRWTP Tracer Study (MWH, 2014), the City led a coalition of Oregon's current and potential ozone users to petition the Oregon Health Authority (OHA) to give disinfection credit for intermediate ozonation. This credit would eliminate the requirement for costly chlorine contact basins or ultraviolet (UV) treatment for WRWTP expansions, a possibility considered when plant expansion scenarios were developed. At the time of this publication, the OHA had not yet issued a decision.
- In 2015, the City and WWSP stakeholders updated the WRWTP Master Plan (MWH, 2006) to explore expanding the plant to meet future demands of all stakeholders. Although the WRWTP Master Plan 2015 Update (Carollo, 2016) succeeded in evaluating these possibilities, it was later decided that the WWSP treatment facilities would be optimized at an alternative location in Sherwood, several miles north of the WRWTP. The WRWTP is now expected to supply Wilsonville and Sherwood exclusively. However, the oversized river intake and raw water pumping station will be expanded to supply raw water to both the WRWTP and the proposed WWSP treatment facility.

The 2015 Master Plan Update (2015 MPU) documented future water needs, level of service (LOS) goals, regulatory requirements, reliability and resiliency of the distribution system, and preliminary seismic evaluation of shared WRWTP and WWSP facilities. The goal of the 2017 Master Plan Update (2017 MPU) is to supplement and expand on the parts of the 2015 MPU that apply to the WRWTP facilities. The resulting stand-alone document details how increased water demand in the Cities of Wilsonville and Sherwood can be accommodated in coordination with the future WWSP treatment facility.

1.2 Master Plan Update Objectives and Organization

This 2017 MPU describes the WRWTP expansion to meet long-term water supply needs of Wilsonville, Sherwood, and potential future partners. It gives options for expanding the facilities and recommends a treatment and implementation plan to meet Wilsonville's and Sherwood's planning objectives:

- Objective #1: Maintain water supply by completing the WRWTP 20 mgd and 30 mgd expansion projects by 2020 and 2034, respectively.
- Objective #2: Define process selection and layout to meet capacity and water quality goals at the expanded WRWTP.
- Objective #3: Chart the course for expanding existing WRWTP infrastructure to make the most of previous investments.

The primary purposes for this 2017 MPU are to:

- Develop treated water quality goals.
- Evaluate preliminary process requirements to meet water quality goals.
- Identify preliminary capacity requirements to meet long-term water supply needs.
- Verify space requirements at site facilities.
- Develop planning-level cost estimates.
- Develop preliminary implementation schedule.

The 2017 MPU is organized into the following chapters.

- Chapter 1 – Introduction
- Chapter 2 – Plant Expansion and Level of Service Goals
- Chapter 3 – Existing Facilities and Operational Performance
- Chapter 4 – Historical Water Quality and Regulatory Compliance
- Chapter 5 – Existing Infrastructure
- Chapter 6 – Expansion Alternatives Analysis
- Chapter 7 – CIP Approach and Schedule

-This Page Intentionally Left Blank-

Chapter 2

PLANT EXPANSION AND LEVEL OF SERVICE GOALS

2.1 Introduction

This Chapter establishes the guiding principles for developing, evaluating, and comparing alternatives throughout the 2017 MPU and summarizes the current water supply demands and strategies for expansion phasing. This Chapter also reviews three alternative treatment procedures developed from workshops with the Participants for the 2015 MPU. With this review, the Chapter describes the methodology for evaluating the alternatives and summarizes the level of service (LOS) goals for the plant's expansion.

2.2 Water Demands and Expansion Strategy

Prepared in 1999, the Willamette River Water Supply System (WRWSS) Plan identified the potential need to withdraw up to 120 mgd from the existing Willamette River Water Treatment Plant (WRWTP) site based on combined projected demands from potential member agencies. The WRWSS Plan was updated in 2004, increasing the ultimate demand projection to 158 mgd. Following this, the 2006 WRWTP Master Plan bracketed the ultimate demand projection between 103 mgd and 156 mgd.

Under the original project, Wilsonville partnered with the Tualatin Valley Water District (TVWD) to fund oversized infrastructure that would better accommodate future WRWTP plant expansion(s) and meet the needs of the combined communities. In 2015, Wilsonville, along with other stakeholders, updated the WRWTP Master Plan (MWH, 2006) to determine how the existing plant could be expanded to meet future demands of the emerging Willamette Water Supply Program (WWSP); this effort culminated in the WRWTP 2015 Master Plan Update (2015 MPU) (Carollo, 2016).

However, after completing the 2015 MPU, the decision was made to construct the WWSP treatment facilities at an alternate site located several miles north of the existing WRWTP in unincorporated Washington County. The raw water intake and pump station for this alternate WWSS WTP will be co-located/shared with the existing WRWTP, which requires careful coordination between both sites.

Adjustments to the 2015 MPU's projected demand/capacity requirements and the timing of the capacity needs affect the planning of the expanded WRWTP site. This 2017 MPU summarizes these efforts in subsequent subsections.

2.2.1 Demand Projections and Hydraulic Requirements

Two water agencies will continue using the expanded WRWTP as their primary source of drinking water supply: the City of Wilsonville and the City of Sherwood.

Figure 2.1 presents the two cities’ respective projected annual peak daily demands through 2050 as well as the combined ultimate build-out demand projection for 2050. It also shows a phased expansion strategy, which is detailed in the following subsections. The demand projection was published in the Wilsonville Water Master System Plan, adopted September 2012, and is based on the following assumptions:

- Annual residential growth of 2.9%.
- Annual non-residential growth of 3.5%.
- Industrial demand of increase 0.25 mgd every five years to a total of 1 mgd by 2025.
- City of Sherwood demand to increase from 5 mgd to approximately 10 mgd by 2025.

Figure 2.2 presents the projected annual peak demand for the WRWTP and the proposed WWSP treatment facility. Projected WWSP demands were developed based on the agency's planning project and are separate from this 2017 MPU. However, as described in subsequent sections, the demands are relevant to upgrading some shared WRWTP facilities.




Figure 2.1 WRWTP Capacity Projections and Recommended Expansion Phasing




Figure 2.2 WRWTP and WWSP Water Demand Projections

Table 2.1 summarizes the anticipated demands and the hydraulic elevation that each City will likely require to serve its respective system.

Table 2.1 Hydraulic and Capacity Requirements of the WRWTP Participants

Participant	Hydraulic Elevation (ft)	2026 Max Day Demand (mgd)	2036 Max Day Demand (mgd)	2046 Max Day Demand (mgd)	Future Max Day Demand (mgd)
Wilsonville	400	12	14	17	30
Sherwood	380	5	6	7	13
Total		17	20	24	43

Notes:

(1) Projected demands obtained from independent City planning exercises.

2.2.2 Capacity Expansion and Phasing Strategy

Figures 2.1 and 2.2 present the projected WRWTP plant production capacity and total raw water withdrawals, respectively. Highlights of these projections are as follows:

- An initial expansion of the existing WRWTP required to meet combined demands for the Cities of Wilsonville and Sherwood: this expansion will increase WRWTP capacity to 20 mgd in 2020, two years before the capacity is required in 2022.

- Construction to support the WWSP Raw Water Facility (RWF) connection to the WRWTP intake structure and Raw Water Pump Station: this modification is expected to be completed by 2024, two years before the capacity is required in 2026.
- A subsequent expansion of the existing WRWTP to meet combined demands from the Cities of Wilsonville and Sherwood: this expansion will increase WRWTP capacity to 30 mgd in 2034, two years before the capacity is required in 2036.
- Capacity expansion projects: these projects are expected to be completed two years before the capacity is required, allowing flexibility for future unknowns.
- Ongoing repair and replacement projects: These R&R projects address aging infrastructure that has exceeded its service life or has become unreliable, but remain crucial to operations and must be integrated into the overall expansion plan.
- Seismic retrofits: These additions reflect changes in the seismic design criteria since the WRWTP was constructed in 2002. Given the changes in the USGS data between 2002 and 2008, projected ground accelerations in the region have increased up to 28 percent, significantly adding to the structural design requirements.
- Life safety upgrades: These improvements are necessary to protect the operations staff and maintain compliance with safety and building code requirements.

Based on capital, operational, and technical evaluations performed during the 2015 MPU, the WRWTP 20 mgd capacity expansion will be achieved by uprating major process trains and by providing installed redundancy wherever feasible. No additional basins will be constructed under this expansion. The details of this evaluation are summarized in Chapters 2 and 6 of the 2015 MPU.

Furthermore, evaluations of the 30 mgd capacity expansion include a discussion of pre- and post-regional seismic event resiliency to determine the scope of the expansion. Chapter 6 of this 2017 MPU describes the WRWTP expansions falling within the 20-year planning horizon and summarizes an evaluation of them.

2.2.3 Net Present Value

The 2015 MPU included a net present value (NPV) evaluation of three potential treatment alternatives for the WRWTP (which would also be design criteria for the WWSP treatment plant). The alternatives evaluated in Chapter 6 and Appendices I and J were the following:

- Alternative A – Baseline Procedures: The existing plant infrastructure would be maintained as-is, with additional capacity being gained by adding new concrete treatment basins and associated supporting mechanical equipment.
- Alternative B – OHA Modified Procedures: Moderately increasing the treatment rate of select processes to realize available operational efficiencies and reduce the number or size of the process trains/basins compared to Alternative A. Alternative B will use existing treatment steps but would modify operational procedures to achieve higher capacities in a smaller footprint while still meeting the existing WRWTP treated water quality goals
- Alternative C – OHA Compliance: Aggressive increase in treatment rates compared to Alternative B and requires modifying the existing WRWTP treated water goals

Of these three options, Alternative A was the most conservative but also had the highest capital and operating costs. Alternative C was the most aggressive and had the lowest capital and

operating costs, but was also determined to have the lowest potential to respond to future regulatory changes and would require changes to water treatment goals. Alternative B was a balanced approach, as it reduced capital and operating costs but maintained the same water quality goals. Therefore only Alternatives A and B were viable options to maintain the same water treatment goals.

An NPV was developed as part of the 2015 MPU to determine the potential financial benefits of each alternative on a 36-year term with 4% interest rate. Though the NPV evaluation was not performed for the 20 mgd expansion individually, the scale of the results are representative of the interim expansion costs for each alternative. The 2015 MPU recommended adopting Alternative B as the preferred alternative that provides a balanced approach where water quality goals expected by the community are maintained while allowing operational efficiencies that will limit the cost impacts of the interim and future expansions.

A version of the 2015 MPU NPV calculation (modified for 20-year and limited to the WRWTP expansions) is included in Appendix A. The relative cost differences for potential treatment alternatives are listed in Table 2.2. For a full list of the NPV criteria and assumptions, refer to Chapter 6 and Appendices I and J in the 2015 MPU.

Table 2.2 20-Year NPV for WRWTP Potential Treatment Alternatives

	Alternative A Baseline Procedures	Alternative B Modified Procedures	Alternative C OHA Compliance
NPV ⁽¹⁾	\$88,400,000	\$81,200,000	\$76,700,000
Cost Comparison (\$)			
Alternative A	--	\$(7,200,000)	\$(11,700,000)
Alternative B	\$7,200,000	--	\$(4,500,000)
Alternative C	\$11,700,000	\$4,500,000	--
Cost Comparison (%)			
Alternative A	--	-9%	-15%
Alternative B	8%	--	-6%
Alternative C	13%	6%	--

Notes:

(1) NPV amounts rounded up to the nearest \$100,000.

2.3 Hazard Analysis and Associated Level of Service Goals

This section describes the methodology used to identify hazards and to develop corresponding LOS goal recommendations for the WRWTP expansion. For the 2015 MPU planning process, preliminary LOS goals were used to establish the preliminary site plans and associated construction and operations cost estimates. After confirming that these preliminary results were consistent with those of the Cities of Wilsonville and Sherwood, this 2017 MPU adopts these LOS goals.

LOS goals address only the facilities required to operate the WRWTP and do not apply to facilities outside of the WTP fence line, such as the piping for the transmission and distribution systems. The goals herein were developed during the 2015 MPU and confirmed with the Cities during a 2017 MPU project workshop.

2.3.1 LOS Goal Objective

LOS goals are typically stated as follows:

"Following a W catastrophic event, within X days/weeks of the event, the WTP will deliver Y percent of average day demand with Z water quality."

This policy-level statement addresses how facilities will be recovered after a catastrophic event, in terms of water quality, quantity, and recovery time. Thus, the goal of this section is to first identify the various types of catastrophic events that may occur and then develop LOS goals that correspond to each event.

2.3.2 Catastrophic Event

To guide the selection of LOS goals after a catastrophic event, the Clackamas County Natural Hazards Mitigation Plan (December 2012) was reviewed for hazards of concern to the County. Additional hazards were also identified based on similar work performed by Ballantyne Consulting LLC. Potential WTP impacts were also considered for the 2015 MPU, although they may differ from those that could affect the County overall. Table 2.3 presents the identified hazards and the potential impacts on the Lower Site, which includes the WRWTP and WWSP raw water intake and pumping facilities.

Table 2.3 Catastrophic Hazards Events and Potential Impact on the WRWTP Lower Site

Hazard	Potential WTP Impacts
Seismic – Geotechnical	<ul style="list-style-type: none"> • Liquefaction at site causes differential settlement that compromises facilities. • Lateral spreading/landslide at river bank compromises slope stability and RW Intake.
Seismic – Structural	<ul style="list-style-type: none"> • Causes raw Water Pump Station structural damage. • Leads to High Service Pump Station / Clearwell structural damage. • Compromises connections of process piping and electrical duct banks at process facilities due to shearing.
Flood	<ul style="list-style-type: none"> • Erodes river bank. • Plugs or damages raw water intake.
Volcano	<ul style="list-style-type: none"> • Ash fall or water-transported debris compromises ability of plant to treat water.
Spills/Contaminants in River	<ul style="list-style-type: none"> • Raw sewage discharge from upstream communities compromises ability of plant to treat water. • Oil spill compromises ability of plant to treat water. • Other chemical spill compromises ability of plant to treat water.
Wild Fire	<ul style="list-style-type: none"> • Decreases water quality of Willamette River watershed. • Impact on river bank compromises raw water pump station.
Wind, Ice, Snow	<ul style="list-style-type: none"> • Local or regional power outage compromises plants' abilities to treat water. • Reduces staff availability.
Terrorism/Cyber Attack	<ul style="list-style-type: none"> • Reduces IT security and operational control. • Compromises control over finished-water quality.

Of these hazards, seismic hazards (geotechnical and structural) are expected to also affect other water supply facilities serving the region. The remaining hazards are expected to affect only the WRWTP, with exception of two possibly far-reaching hazards: volcanic ash and regional power disruption.

Volcanic ash fall could affect the City of Portland, City of Lake Oswego/Tigard, and Joint Water Commission (JWC) surface water supplies, depending on which volcano erupts and the wind direction at the time surrounding the eruption(s). Table 24 shows the relative likelihood of volcanic ash from an eruption of Three Sisters, Mount Hood, or Mount St. Helens, which would affect the surrounding four regional supply watersheds with the predominant southwest prevailing wind. As Table 2.4 shows, a volcanic event would likely not affect all four regional supplies.

Table 2.4 Likelihood of Volcanic Ash Having Substantial Impact on Watersheds with a Southwest Wind

River/Volcano	Three Sisters	Mount Hood	Mount St. Helens
Willamette River	High	Low	Low
Clackamas River	Moderate	High	Moderate
Bull Run River	Moderate	High	Moderate
Tualatin River	Low	Low	Low

A wind or ice storm could affect the regional power supply if it downs multiple high-voltage circuits crossing the Cascades. This hazard would be categorized as similar to seismic hazards. Based on this understanding, seismic hazards affecting all the regional water supply facilities shall be addressed separately from local hazards that would only affect the WRWTP Lower Site.

2.3.2.1 Hazards Affecting All Regional Facilities

A seismic hazard is typically discussed in terms of its likelihood of occurring in a 50-year period as well as its associated return period. This timeframe is used because it represents a building's typical life expectancy. Equipment has a life expectancy of approximately 20 years, and buried pipelines have a life expectancy of 100 years. For example, an earthquake with a 10 percent chance of occurring in 50 years has an approximately 500-year return period; one with a 5 percent chance has an approximately 1,000-year return period; and one with a 2 percent chance has an approximately 2,500-year return period.

On average, the Cascadia Subduction Zone earthquake occurs every 500 years. However, other earthquake sources also contribute to and heighten the probability of 500-year-return ground motions.

The Minimum Design Loads for Buildings and Other Structures (ASCE, 2010), which is a consensus-based standard, is used in conjunction with the International Building Code (IBC) to guide structural designs. Both start with a 2,500-year probabilistic ground motion, which are then multiplied by two-thirds. The resulting ground motion estimate is used to design most facilities and to achieve life safety for Category II facilities, such as residential and commercial structures.

ASCE 2010 assigns a risk category to various types of structures ranging from I to IV. Specifically, Risk Category II has an Importance Factor of 1.0, Risk Category III has an Importance Factor of 1.25, and Risk Category IV has an Importance Factor of 1.5. These factors are applied to the

ground motion. With the Importance Factor applied, the IBC ensures that structures designed to Risk Categories III and IV will only require minor repairs before returning to operation (Category III) or remain operational after a 500-year return event. The IBC requires "qualifying" equipment used in Category IV to demonstrate their ability to remain operable after an earthquake.

The Importance Factors are based on building observations and engineering judgment. Water facilities, particularly water treatment plants, are complicated systems made up of many geotechnical considerations, structural and non-structural components, and systems that may be vulnerable to earthquakes. Applying an Importance Factor of 1.5 does not necessarily address all of these various elements and does not guarantee post-earthquake operation after a 500-year return earthquake. To increase the likelihood of post-earthquake operation, a detailed facility system seismic vulnerability analysis is recommended. At a minimum, it is recommended that this vulnerability analysis include unit processes, communications, staffing, supply logistics, inventory maintenance, and staff accommodations. This analysis should be relevant to all facilities on the WRWTP Lower Site and will need to include coordination with the WWSP.

To be more conservative, the owner may request to design for 2,500-year return ground motions. These are 1.5 times the ground motions used for most structures, the same as the Category IV 1.5 Importance Factor. Applying the same methodology as used for a base-level earthquake, 2,500-year ground motions should be used in conjunction with an Importance Factor of 1.5. Adding these factors of safety would result in a ground motion design of $1 + 0.5 + 0.5 = 2.0$ multiplied by the base ground motion.

Because it only addresses the facilities' structural elements, this increase may not be enough to achieve post-earthquake facility functionality. To return to operations within days of a 2,500-year return event, a detailed facility system seismic vulnerability assessment is recommended. Furthermore, applying one 0.5 factor of safety (Importance Factor = 1.5), instead of applying both 0.5 factors of safety (Importance Factor = 2.0), is recommended.

The ground motion design, Importance Factor, and Facility System Seismic Analysis drive the Recovery Level, which represents the time it takes to get back in operation. The Recovery Level is the key parameter in determining a catastrophe's impact on a community. Table 2.5 shows the expected recovery level for combinations of ground motion design level, the Importance Factor, and a Facility System Seismic Analysis.

Table 2.5 Water Treatment Facility Recovery Levels for Various Earthquake Hazard Levels as Implied by Current Codes and Standards for New Construction

	Ground Motion Design Level					
	500-year	500-year	500-year	2,500-year	2,500-year	2,500-year
Importance Factor	1	1.5	1.5	1	1.5	1.5
Facility System Seismic Analysis	No	No	Yes	No	No	Yes
Subjected to:	Resume Service in:					
500-Year Return Period Earthquake	Months to Years	Days to Weeks	Days	Days to Weeks	Days	Days
2,500-Year Return Period Earthquake	Years	Months to Years	Months to Years	Months to Years	Days to Weeks	Days

In terms of the overall cost for the project, the difference of building new structures for Risk Category IV versus Risk Category III is nominal (estimated at 2 to 3 percent of total project cost to achieve Category IV for just the structures). The cost to conduct a detailed facility seismic vulnerability analysis is less than \$100,000, plus mitigation of identified deficiencies. As a result, this 2017 MPU recommend designing the future expanded WRWTP facilities to Category IV seismic design loading for a 500-year return event with no additional increase for 2,500-year ground motions. Chapter 5 of this 2017 MPU provides a detailed facility seismic vulnerability analysis of the existing facilities and summarizes Oregon's seismic requirements and standards put in place while the WRWTP was constructed.

As mentioned earlier, the IBC requires "qualifying" equipment in facilities designed to Risk Category IV. This means that the equipment used must be tested to ensure that it remains functional after the prescribed earthquake loading. Some standard WTP equipment and systems, such as motor control centers, were previously qualified. This equipment must be identified and located in the facilities.

In case of earthquakes and potential wind and ice events, loss of regional power is expected to affect all the regional supplies. Although some of the other regional supply facilities have backup power, these may be damaged in an earthquake. Therefore, the existing backup power facilities at the WRWTP must be expanded to meet the desired LOS goals.

2.3.2.2 Hazards Only Affecting the WRWTP

As discussed briefly in 2.3.2, flood, volcanic debris flow, water quality events, wild fire, wind/ice/snow storms (excluding regional power outage), and terrorism/cyber-attacks are expected to affect only the WRWTP. These local hazards have the largest impact on the intake (raw water quality) and finished water quality.

Unlike seismic events, where the shaking intensity increases for an event with a longer return period (lower probability), local hazards such as chemical spills or terrorist attacks do not have different intensities depending on different return periods. Therefore, we recommend not attaching a return period to this group of hazards. These events do, however, have a reasonable likelihood of occurring during the life of the WRWTP.

2.3.3 Regional Precedents

This section reviews the regional precedence for large regional water supply systems, which guides the selection of seismic LOS goals.

2.3.3.1 East Bay Municipal Utility District (Oakland, California)

A thought leader in seismic reliability, the East Bay Municipal Utility District (EBMUD) in Oakland, California, established LOS goals for a probable and maximum earthquake event. These goals apply to an existing system that includes supply, treatment, and distribution. Table 2.6 presents these LOS goals.

Table 2.6 East Bay Municipal Utility District Level of Service Goals

Category	Probable Earthquake	Maximum Earthquake
General	<ul style="list-style-type: none"> All water introduced into the distribution system are fully treated, but minimally disinfected. 	<ul style="list-style-type: none"> All water introduced into the distribution system are fully treated, but minimally disinfected.
Fire Service	<ul style="list-style-type: none"> Service to all hydrants within 20 days. 	<ul style="list-style-type: none"> Service to all hydrants within 100 days.
Hospitals and Disaster Collection Centers	<ul style="list-style-type: none"> Minimum service to affected area within 1 day (water available via backbone distribution system near each facility). 	<ul style="list-style-type: none"> Minimum service via distribution system or truck within 3 days.
Domestic Users	<ul style="list-style-type: none"> Potable water via distribution system or truck within 1 day. 	<ul style="list-style-type: none"> Impaired service within 30 days (water available via distribution system to each facility, possibly at reduced pressures).
Commercial, Industrial, and Other Users	<ul style="list-style-type: none"> Impaired service to affected area within 3 days (water available via distribution system to each commercial or industrial user, possibly at reduced pressures). 	<ul style="list-style-type: none"> Potable water at central locations for pick up within 1 week. Minimum service to 70% of customers within 10 days. Impaired service to 90% of customers within 30 days.

2.3.3.2 Oregon Resiliency Plan

The Oregon Seismic Safety Advisory Committee (OSSAC) developed the Oregon Resilience Plan (ORP) per the Oregon State Legislature's request. The ORP includes goals for specific functions of water systems, as shown in Table 2. 7. For WTPs, the ORP recommends that 20 to 30 percent of the potable supply be available within 24 hours of the event and be at near-full restoration within 1 to 2 weeks.

Table 2.7 Oregon Resilience Plan Recommended LOS Goals for Water Systems

System Function	Event Occurs							
	0-24 hours	1-3 days	3-7 days	1-2 weeks	2-4 weeks	1-3 months	3-6 months	6-12 months
Potable water available at supply source								
Main transmission facilities, pipes, pump stations, and reservoirs operational								
Water supply to critical facilities available								
Water for fire suppression at key supply points								
Water for fire suppression at fire hydrants								
Water available at community distribution centers/points								
Distribution system operational								

Notes:

- (1) Desired time to restore component to 80-90% operational.
- (2) Desired time to restore component to 50-60% operational.
- (3) Desired time to restore component to 20-30% operational.
- (4) Current state (90% operational).

2.3.3.3 Joint Water Commission (JWC) (Hillsboro, Oregon)

The JWC developed LOS goals for its existing WTP (originally constructed in 1976) for three earthquake return periods (72, 475, and 2,475 years) with goals for immediate and short-term capacity, as well as short-term restoration. In all cases, the water quality produced was intended to be potable. For the JWC WTP, the expected performance of various unit processes during a seismic event governed the capacities. Table 2.8 shows the JWC's LOS goals.

Table 2.8 Joint Water Commission WTP LOS Goals

Seismic Events	Immediate Capacity mgd	Short-Term Capacity mgd	Short-Term Restoration Time days	Water Quality
72 Year Event	42 ⁽¹⁾	42 ⁽¹⁾	0	Potable
475 Year Event	0	24	1	Potable
2,475 Year Event	0	12	3	Potable
		28 ⁽²⁾	7 to 14	
		42 ⁽¹⁾	60 to 90	

Notes:

- (1) Average Day Demand is 42 mgd.
- (2) Average Winter Demand is 28 mgd.

2.3.4 Recommended Preliminary LOS Goals for WRWTP Expansion

Two categories of preliminary LOS goals are recommended for the expanded WRWTP: 1) a regional seismic event that potentially affects all regional supplies where Participants rely on the WRWTP and 2) local events that affect only the WRWTP supply (i.e., other regional supplies remain on-line) and allow Participants to rely on other regional supplies.

Recommended LOS goals in this section were developed in a workshop setting that included the technical advisory committee (TAC). Because the expansion is for a regional facility, LOS goals must be verified with each agency during the design phase for compatibility with their own distribution and storage LOS goals. LOS goals developed as part of the 2015 MPU were adopted by the governing bodies of both Wilsonville and Sherwood.

Note that the WRWTP was designed and constructed in 2002, prior to Oregon's adoption of International Building Code (IBC) in 2004. Because of this, the WRWTP was built to withstand a reduced earthquake threshold (i.e., 500-year return period rather than 2,500-year return period specified in the IBC). For this reason, the WRWTP will not be able to meet their LOS goals until they construct additional infrastructure at the increased seismic requirement.

2.3.4.1 Hazard Return Period

To prepare for a regional event, new facilities should be designed and upgraded for 2,500-year return period ground motions, in accordance with the IBC Risk Category IV. When available, pre-qualified equipment should also be specified.

To prepare for local hazard events, no return periods should be attached to them, but scenarios for each event type should be considered.

2.3.4.2 WTP Outage Time

For the regional event, the region will depend on the WRWTP. The plant should be operable within 48 hours after the event.

For local hazard events, the Cities of Wilsonville and Sherwood will rely on their existing groundwater supplies for short-term use, while potential interties with other regional water purveyors will be considered for long-term use. The WRWTP should be returned to operation within 14 days of the event.

2.3.4.3 Delivery Capacity Percentage

For a regional event, the WTP should be able to deliver 50 percent of its full capacity. This number controls the amount of backup power required and the size of chemical storage facilities.

For a local hazard event, the WTP should be at full capacity when service resumes.

2.3.4.4 Water Quality

Whenever operational, the WTP should produce potable water for both the regional and local hazard events.

Table 2.9 summarizes the final LOS goals recommended for the expanded WRWTP facilities.

Table 2.9 Adopted LOS Goals for the WRWTP

LOS Goal	Regional Event (Seismic)	Local Event (Non-Seismic)
"Following a W catastrophic event ...	2,500 year	Per occurrence
...within X days/weeks of the event...	48 hours	14 days
...deliver Y % of average day demand...	50% of nameplate	100% of nameplate
...with Z water quality."	Potable (at minimum regulatory requirement)	Potable (at plant treatment processes and procedures)

-This Page Intentionally Left Blank-

Chapter 3

EXISTING FACILITIES AND OPERATIONAL PERFORMANCE

3.1 Introduction

The 2006 Willamette River Water Treatment Plant (WRWTP) Master Plan was completed approximately four years after initial plant start-up in 2002. At that time, the City of Wilsonville was the only consumer of WRWTP water.

In mid-2012, the City of Sherwood purchased 5 mgd of capacity from the Tualatin Valley Water District (TVWD) and started using water from the WRWTP as its primary supply. With this additional demand, the WRWTP moved from operating on a daily start/stop basis for 8 to 16 hours per day, depending on demand, to operating 24 hours per day.

This Chapter describes each major plant component and summarizes the existing WRWTP treatment facilities, previous studies, and historical operating performance. Because hours of operation affect plant operations and the expanded plant will operate continuously, the plant performance data considered for the 2015 MPU was limited to 2012 through 2014; no additional water quality data was analyzed as part of this 2017 MPU. Discussion on the existing facility infrastructure, including seismic and life-safety analysis, is presented in Chapter 5.

3.2 Summary of Previous Studies

WRWTP planning began in the early 1990s with preliminary raw water quality sampling. About ten years later, between 2000 and 2002, the existing 15-mgd WRWTP facility was constructed. The studies reviewed for the 2015 MPU are as follows:

- WWSA – Raw Water Quality Monitoring Program (WRWSA/MWH, 1994-2002).
- Willamette River Pilot Plant Study (MWH, 1994) – Summarizes bench- and pilot-scale studies verifying the treatability of the Willamette River.
- Willamette River Water Supply System, Preliminary Engineering Report (MSA/MWH, 1998) – Summarizes and consolidates several planning-level documents for the WRWTP, including water user permits and intergovernmental agreements, intake and river hydraulics, alternative RWPS layouts, preliminary geotechnical work, and water treatment plant schematic designs. Evaluates the treatment needs, treatment processes and procedures, and project and O&M costs for an initial 35 mgd WTP, ultimately expanding to 120 mgd. Findings enabled the project participants to determine how to meet future drinking water needs.
- Actiflo® Pilot Study Report (MWH, April 2000) - To evaluate performance of the combined Actiflo® and filtration treatment trains on the Willamette River, Actiflo® was piloted from February 24 through March 10, 2000, at the WRWTP site, in conjunction with a filter column modeling the proposed full-scale filter beds.

- *Source Water Assessment Report of Surface Water Supply* (MWH, September 2002) – Assesses the surface water source area upstream of the proposed WTP intake. Primary objectives are to delineate sensitive areas requiring special consideration to protect water quality, record potential contaminant sources, and assess the susceptibility of the supply to contamination.
- *Wilsonville Water Treatment Plant, Geotechnical Analysis* (Squire Associates, 2000) – Presents the results of a third-party geotechnical analysis and recommendations to support the WRWTP 30 percent level design-build documents.
- *Water Treatment Plant 3rd Party Peer Review* (Degenkolb, 2000) – Presents the findings and records the resulting design changes of a third-party peer review of the structural design.
- *WRWTP Record Drawings and O&M Manual* (MWH, 2002) – Offers the final record drawings and Operations and Maintenance Manual from the design-build contractor after start-up and commissioning of the original plant facilities.
- *WRWTP Tracer Study* (CH2MHill, 2002) – Summarizes the results of the original tracer study of the WRWTP clearwell to obtain OHA approval for finished water flows up to 10 mgd.
- *WRWTP Master Plan* (MWH, 2006) – Planning-level document to help the District select long-term water supply needs. The report recommends treatment technologies, provides treatment procedures, construction and O&M cost estimates, and offers an implementation plan for expanding the WRWTP.
- *WRWTP Surge Analysis* (MWH, 2009) – Shows the results of preliminary hydraulic calculations to determine the WRWTP finished water flow rates that would trigger the need for surge protection at the plant.
- *Water Treatment Plant CT Model* (MWH, 2011) - A disinfection calculation tool for performing real-time CT calculations at the WRWTP.
- *Willamette River WTP Disinfection (CT) Analysis* (MWH, 2011) - Updates and further defines the CT capacity of the existing WRWTP.
- *Hydraulic Transient Analysis* (MWH, 2011) - Updated modeling efforts focused on surge analysis at the existing WRWTP.
- *City of Wilsonville Water Master Plan* (Keller & Associates, 2012) – In part, this report summarizes finished water quality and disinfection strategies for the WRWTP, Wilsonville’s primary water supply. This document focuses on the distribution system, but also summarizes WQ issues.
- *WRWTP Tracer Study* (MWH, 2014) – Summarizes the results of the second tracer study of the WRWTP clearwell, which was used to obtain OHA approval for finished water flows up to 15 mgd.
- *WRWTP 2015 Master Plan Update* (Carollo, 2016) – Summarizes the planning efforts for incorporating the WWSP WTP at the existing site of the WRWTP: develop LOS goals for the plant, update raw water and finished water quality and plant performance, select structural and life-safety analysis, and complete an implementation plan/schedule.

3.3 Major Plant Components

3.3.1 General

The WRWTP site on the Willamette River in Wilsonville at approximately River Mile 39 is irregularly shaped and includes a narrow bottleneck separating the site into Upper and Lower Sites (see Site Plan presented in Figure 1-1). The existing treatment plant and Willamette River Water Treatment Plant Park are on the Lower Site.

When the plant was designed in 1999-2000, the WRWTP was master-planned for an ultimate capacity of 60 mgd, with features and infrastructure in the plant design and construction to facilitate expansion. The intake pipeline, which was tunneled from the raw water caisson to the river, and the 81-foot-deep circular caisson were designed and sized to accommodate approximately 100 mgd, estimated to be the ultimate capacity of the WWSP treatment plant at build-out.

Primary water treatment processes for the WRWTP effectively treat the raw Willamette River water and comply with existing and anticipated future drinking water regulations. A multi-barrier approach currently addresses these key “contaminants of concern”:

- Turbidity.
- Pathogenic microorganisms.
- T&O.
- Trace organics.

The WRWTP intake has two cylindrical tee-shaped screens, a raw water intake pipe and caisson, a raw water pump station and flow metering, flash mixing, a ballasted flocculation (Actiflo®) system, ozonation, filtration using deep-bed GAC/sand media, a 2.9-million-gallon (MG) clearwell, a high-service pump station and flow metering, backwash equalization, solids thickening, and a centrifuge solids dewatering facility. Table 3.1 summarizes plant treatment processes and procedures. Figures 3.1 through 3.3 give an overview of existing facilities.

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures

Description	Units	Value
Plant Design Flow	mgd	15
Willamette River		
Minimum River Level	FT	52.5
100 Year Flood Elevation	FT	91.1
500 Year Flood Elevation	FT	102.3
Intake Screens		
Type: Horizontal Cylindrical		
Number	#	2
Capacity, total	mgd	70
Diameter	IN	66

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Screen Opening Size	mm	1.75
Maximum Face Velocity	FPS	0.4
Top of Screen Elevation	FT	42.75
Screen Cleaning		
Cleaning Method: Air Burst		
Number of Compressors	#	2
Compressor Capacity	CFM	200
Air Receiver Volume	CF	2,200
Motor Size per Compressor	HP	50
Raw Water Pumps		
Type: Vertical Turbine, Single-Stage		
Number	#	4
Total Capacity with Standby	mgd	26.5
Capacity (each)		
1 VFD-Driven Pump (on backup power)	mgd	4
2 VFD-Driven Pumps	mgd	7.5
1 Constant-Speed Pump	mgd	7.5
Total Dynamic Head (15 mgd)	FT	107
Total Motor Horsepower	HP	1@100, 3@200
Initial Flash Mix		
Type: Pumped		
Number (Installed)	#	1
Mixing Energy	s ⁻¹	1,000
Pump Capacity	gpm	1,000
Total Dynamic Head	FT	16
Total Motor Horsepower	HP	7.5
Clarification Process		
Type: Ballasted Flocculation (Actiflo®)		
Number of Basins	#	2
Design Flow (per basin)	mgd	7.5
Maximum Process Hydraulic Flow (per basin)	mgd	15
Mixing/Flocculation		
Coagulation Chamber Volume	CF	2,000

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Coagulation Chamber HRT	MIN	2.9
Injection Chamber Volume	CF	2,165
Injection Chamber HRT	MIN	3.1
Maturation Chamber Volume	CF	6,330
Maturation Chamber HRT	MIN	9.1
Clarification		
Settling Chamber Volume	CF	7,570
Settling Chamber HRT	MIN	9.6
Lamella Tube Settlers, surface area	SF	520
Design Surface Loading Rate	GPM/SF	20
Maximum Surface Loading Rate	GPM/SF	40
Sand Slurry Recirculation System		
Number of Sludge Recirculation Pumps per Basin	#	2
Sludge Recirculation Rate	%	3
Capacity per Pump	GPM	165
Total Design Head	FT	75
Pump Horsepower	HP	10
Number of Sand Hydrocyclones (per basin)	#	2
Manufacturer's Maximum Anticipated Sand Loss	LB/MG	25
Ozone Contact Basins		
Type: 8-Stage Counter-Co-Counter with Fine-Bubble Diffusers		
Number of Basins	#	2
Detention Time at 15 mgd with Both Basins in Service	MIN	14.9
Average Water Depth	FT	21
Inside Dimensions (each basin)	FT x FT	6 x 10
Volume (total)	CF	20,800
Ozone Generators		
Number	#	2
Feed Gas Vaporized From LOX	-	GOX
Capacity (each)	ppd	300
% Ozone by Weight (maximum)	%	10
Design Ozone Dose at 15 mgd	mg/L	2.5
Filters		
Type: Deep Bed, Dual Granular Media with Influent Flow Splitting		

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Number of Filters	#	4
Number of Bays/Filter	#	1
Filter Bay Dimensions	FT x FT	20 x 23
Filter Area (each filter)	SF	460
Total Filter Area	SF	1,840
Maximum Filtration Rate (Q/A)		
All Filters On-Line at 15 mgd	GPM/SF	5.7
One Filter Off-Line at 15 mgd	GPM/SF	7.5
Hydraulic Maximum	GPM/SF	12
Filter Media		
GAC		
Depth	IN	72
Effective Size	MM	1.4
Uniformity Coefficient		<1.4
Depth: Diameter (L:D)		1,306
Minimum Empty Bed Contact Time (EBCT)		
All Filters On-Line at 15 mgd	MIN	7.9
One Filter Off-Line at 15 mgd	MIN	5.9
Sand		
Depth	IN	12
Effective Size	MM	0.45
Uniformity Coefficient		<1.4
Depth: Diameter (L:D)	MM:MM	677
Total Media		
Depth (maximum)	IN	84
Depth: Diameter (L:D)	MM:MM	1,984
Filter Wash System		
Air Scour Blowers		
Number	#	2
Air Scour Rate	CFM/SF	3.2
Blower Capacity (each)	SCFM	2,000
Blower Horsepower (each)	HP	100
Backwash Pumps		
Number	#	2
Maximum Backwash Rate	GPM/SF	20

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Pump Capacity (each)	GPM	9,200
Pump Horsepower (each) – constant speed	HP	150
Clearwell		
Type: Buried, Reinforced Concrete		
Active Volume	MG	2.9
Max Operating Side Water Depth	FT	21.5
Dimensions	FT x FT	135 x 135
Detention Time (HRT) at 15 mgd When Full	HOURS.	4.6
Hydraulic Efficiency up to 9.6 mgd	T10:HRT	0.16
Hydraulic Efficiency 9.6-15.0 mgd	T10:HRT	0.11
Treated Water Pumps		
Type: Vertical Turbine, Two-Stage		
Number	#	4
Total Capacity with Standby	mgd	26.5
Capacity (each)		
1 VFD-Driven Pump (on backup power)	mgd	4
2 VFD-Driven Pumps	mgd	7.5
1 Constant-Speed Pump	mgd	7.5
Total Dynamic Head	FT	312
Motor Size	HP	3@500, 1@300
Waste Washwater Equalization and Pump Station		
Equalization Basins		
Type: Concrete		
Number of Basins	#	1
Volume/# of Backwashes	GAL/#	244,000/2
Washwater Recycle Pumps		
Type: Vertical Turbine		
Number	#	3
Total Capacity with Standby	GPM	1,500
Capacity (each)		
2 VFD-Driven Pumps	GPM	500
1 Constant-Speed Pump	GPM	500
Total Dynamic Head	FT	25
Motor Horsepower	HP	3 @ 5

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Solids Treatment		
Type: Gravity Thickener and Centrifuges		
Estimated Maximum Solids Production (dry) at 15 mgd	LB/DAY	2,000
Gravity Thickener (circular)		
Number of Units	#	1
Side Water Depth	FT	12
Diameter	FT	35
Maximum Solids Loading Rate	PPD/SF	8
Maximum Hydraulic Loading Rate	GPM/SF	1
Solids Mixing		
Type: Vertical Non-Clog		
Number of Pumps	#	1
Pumping Capacity	GPM	600
Pump Horsepower	HP	5
Total Dynamic Head	FT	12
Solids Pump Station		
Type: Progressive Cavity		
Number of Pumps	#	2
Pumping Capacity (each)	GPM	60
Motor Size (each)	HP	5
Total Dynamic Head	FT	60
Centrifuges		
Type	-	Horz. Scroll
Number of Units	#	2
Minimum Solids Cake Concentration	%	18
Capacity (each)	GPM	60
Maximum Solids Loading (each)	LB/HR	750
Motor Horsepower-Scroll (each)	HP	40
Motor Horsepower-Back Drive (each)	HP	15
Chemical Storage		
Primary Coagulant (49% alum solution)		
Number of Tanks	#	2
Storage Capacity, total	GAL	13,000
Storage (average dose x maximum flow)	DAYS	40
Average Dosage	mg/L	15

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Solution Strength (alum)	LB/GAL	5.4
Cationic Polymer (dry polymer)		
Type	-	Dry Feeder
Feed Capacity	LB/HR	17.6
% solution	%	1
Mixing Time	min	30
Sodium Hypochlorite (12.5% NaOCl solution)		
Number of Tanks	#	2
Storage Capacity, total	GAL	10,000
Storage (average dose x maximum flow)	DAYS	80
Average Dosage	mg/L	10
Solution Strength	LB/GAL	1.0
Caustic Soda (25% NaOH solution)		
Number of Tanks	#	1
Storage Capacity, total	GAL	6,500
Storage (average dose x maximum flow)	DAYS	20
Average Dosage	mg/L	5
Solution Strength	LB/GAL	2.65
Liquid Oxygen (100% LOX)		
Number of Tanks (with vaporizers)	#	1
Storage Capacity, total	GAL	6,000
Storage (average dose x maximum flow)	DAYS	17
Average Dosage	mg/L	26
Aqueous Ammonia (19% NH ₄ OH solution) NOT USED		
Number of Tanks	#	1
Storage Capacity, total	GAL	1,400
Anionic Polymer		
Number of Drums	#	1
Storage Capacity, total	GAL	55
Storage (average dose x maximum flow)	DAYS	> 1 year
Average Dosage	mg/L	0.4
Non-Ionic Polymer		
Number of Drums	#	1
Storage Capacity, total	GAL	55
Storage (average dose x maximum flow)	DAYS	> 1 year
Average Dosage	mg/L	-

Table 3.1 WRWTP Existing Facilities Treatment Processes and Procedures (Continued)

Description	Units	Value
Calcium Thiosulfate		
Number of Totes	#	2
Storage Capacity, total	GAL	440
Storage (average dose x maximum flow)	DAYS	20
Average Dosage	mg/L	0.6
Solution Strength	LB/GAL	3.6




Figure 3.1 WRWTP Existing Site Plan

-This Page Intentionally Left Blank-




Figure 3.2 WRWTP Process Flow Diagram

-This Page Intentionally Left Blank-




Figure 3.3 WRWTP Hydraulic Profile

-This Page Intentionally Left Blank-

3.3.2 Raw Water Facilities

At the river end of the intake pipeline, cylindrical tee-shaped screens prevent debris and aquatic species from being drawn into the treatment plant. The screen system protects anadromous juvenile fish in flows up to 70 mgd, using Oregon Department of Fish and Wildlife (ODFW) and National Marine and Fisheries Service (NMFS) standards to meet Endangered Species Act (ESA) requirements.

The screens are cleaned with an airburst system, which releases pressurized air into the screen interior. Two compressors and an air receiver tank in the raw water pump station deliver air to the screens via two 12-inch air pipelines. Plant staff determines the frequency of screen cleaning according to intake flow, debris in the river, and the season of the year.

The raw water pump station consists of an 85-foot-deep circular caisson wet well below a pump station superstructure. All raw water pumps are vertical turbines. Pump columns extend to within a few feet of the bottom of the caisson.

The wet well and pump station were designed for an ultimate flow of approximately 120 mgd; the initial installed firm capacity was 19 mgd (with the largest pump out of service); and the total raw water pumping capacity is 26.5 mgd. Three of the pumps have variable frequency drives (VFDs), allowing for a wide range of pumping rates. The backup power generator can serve one 4-mgd pump.

To recycle flows within the plant and avoid surface discharge, an 8-inch plant drain pipe to empty water-retaining process basins, a 36-inch plant overflow pipe, and a 48-inch clearwell overflow pipe penetrate the raw water caisson.

The raw water pumps discharge to two separate manifolds that connect to the main 54-inch raw water pipeline to the treatment facility. The 54-inch pipeline is sized to deliver 70 mgd. A 24-inch magnetic flowmeter measures raw water flow rate, and the flow signal is transmitted to the Supervisory Control and Data Acquisition (SCADA) system to control downstream plant operations.

A sample tap on the raw water pipeline discharge header monitors raw water continuously at the raw water pump station. Turbidity, particle counts, pH, temperature, and hydrocarbon concentrations are monitored with on-line analyzers, and results are transmitted to SCADA.

3.3.3 Chemical Injection Vault and Initial Mixing Facility

A chemical injection vault upstream of the ballasted flocculation system is a point for adding the following chemicals:

- Alum or ferric chloride (not used) for primary coagulant.
- Sodium hydroxide for pH adjustment, if needed for optimized coagulation.
- Cationic polymer for the Actiflo® process.
- Sodium hypochlorite (for disinfection residual).

In addition, while not used currently, the chemical injection vault can add the following in the future:

- Aqueous ammonia if chloramines are used in lieu of free chlorine.
- Carbon dioxide for pH adjustment, if needed for optimized coagulation.

Alum, the primary coagulant, is added at the initial mixing vault upstream of the Actiflo® process. In the vault, raw water is suctioned from the raw water pipeline upstream of chemical injection and pumped back to the pipeline through a 90-degree spray nozzle. Primary coagulant is added at the "eye" of the spray cone to instantly mix coagulant into the raw water flow stream.

As a backup, primary coagulant can also be added at the coagulation chamber of the Actiflo® basin where the 36-inch raw water pipeline penetrates the structure. Coagulant addition is flow-paced using data from the raw water flowmeter. It can also be paced based on a signal from the Streaming Current Monitor (SCM), located in the Sludge Thickener Building.

Sampling for the SCM from the raw water pipeline occurs just downstream of the Initial Mix Vault, with alum being the only chemical typically added. The other chemical injection points in the injection vault are used seasonally.

3.3.4 Ballasted Flocculation (Actiflo®) System

Coagulated water flows into the Actiflo® inlet channel and is distributed to the two Actiflo® basins via 36-inch diameter inlet isolation valves. Designed for 7.5 mgd (at 20 gm/sf surface loading rate), each Actiflo® basin consists of four separate chambers: coagulation, injection, maturation, and settling.

The first three chambers contain vertical shaft mechanical mixers. The coagulation chamber provides intense mixing and is an alternate feed point for primary coagulant addition (as described in Section 3.3.3). The injection chamber also provides intense mixing for adding coagulant-aid polymer and microsand, which is critical to ensure that the floc and microsand adhere to each other.

Microsand added to the injection chamber is separated from the sludge via the hydrocyclones in a building above the injection chamber. The maturation chamber allows for slower mixing of the coagulated water for floc formation and attachment of the microsand to the floc. Enmeshment of the microsand in the floc creates a high-density material known as "ballasted floc".

The ballasted, or weighted, floc is then settled out in the settling chamber, which contains plastic lamella tube settlers to enhance settling and a rotating scraper arm to collect settled sludge. The sludge/microsand mixture collected in the settling chamber is pumped back to the head of the process where the microsand is separated in the hydrocyclones and returned to the injection chamber. The separated sludge is discharged to the gravity thickener. The hydrocyclones are housed inside of the Sand Storage Building on top of the Actiflo® coagulation and injection chambers.

Settled water from the Actiflo® process collects in rectangular weir troughs and flows into an effluent channel. The channel has a slide gate to isolate the effluent of each of the Actiflo® basins. Flow from the effluent channel is diverted to the ozone contact basins via a 30-inch diameter pipeline with an isolation butterfly valve.

Sample taps are located on each of the effluent pipelines, which route water through a turbidimeter and a pH/temperature probe. A settled water sample is also pumped to the laboratory sample sink.

The slide gate and isolation valves allow for operational flexibility. If one of the two ozone contact basins is out of service, settled water from both Actiflo® basins can flow to either ozone contact basin. If an Actiflo® basin is out of service, settled water can flow from one Actiflo® basin

to both ozone contact basins. The slide gate also allows the operator to bring one basin on-line and to overflow to waste while the other is in operation.

The Actiflo® process also contains an overflow weir and channel, which can divert flow back to the raw water caisson during initial start-up of the Actiflo® process or if the quality of the clarified water exceeds an operator setpoint. To dewater the basins, mud valves are located in each coagulation and maturation chamber to drain the basins while the recirculation pumps deliver flow back to the injection chamber.

3.3.5 Ozonation System

Ozonation following clarification (termed "intermediate ozonation") disinfects and inactivates *Giardia*, viruses, and *Cryptosporidium* (though not currently recognized by the State of Oregon from a regulatory compliance perspective). Ozonation also oxidizes the mild T&O compounds that occur nearly year-round in Willamette River water and oxidizes trace organic compounds that may occasionally be present. Ozone also improves the downstream filtration process by altering the surface charge of particles and making them more filterable. While not required by OHA, Wilsonville has operated the ozonation system since the plant's start-up in 2002 to achieve a minimum of 1.0-log of *Cryptosporidium* inactivation based on the United States Environmental Protection Agency (EPA) CT (product of concentration [C] and contact time [T]) tables.

Clarified water is conveyed from the Actiflo® process to the two ozone contact basins through individual pipes from the Actiflo® effluent channel. The individual pipes have motorized valves that can isolate each ozone contact basin if necessary. The ozonation system operates with both basins in service for a total treatment capacity of 15 mgd, or 7.5 mgd per basin. The nominal ozone contact time is 15 minutes at 15 mgd.

Multiple sample ports connected to on-line ozone residual monitors detect the dissolved ozone concentration throughout the contact basin. Each of the three residual ozone monitors connects to two to four sample locations. The ozone contactor gallery contains ambient air/oxygen and ozone monitors to detect any gas release into the gallery area.

In addition to local visual and audio alarms, each unit is alarmed to the SCADA system to notify operators. Ozone off-gas in the contactor headspace is conveyed to one of two ozone destruct units in the Ozone Contactor Gallery. There, the ozone is destroyed prior to venting to the atmosphere.

At the ozone effluent channel, calcium thiosulfate is added to the process stream to reduce any dissolved ozone residual in the settled water prior to entering the filters. This prevents ozone off-gassing at the filters and protects the piping, valves, and GAC filter media from ozone's potentially degrading effects. A sample line connected to an ozone residual monitor in the filter influent channel to detect any residual ozone in the filter influent water.

Non-ionic filter aid polymer can also be added to the ozone effluent to reduce filter-to-waste durations and improve filtration/solids capture. Filter aid polymer is not currently used, since the filtration process has historically performed well without it.

The Ozone Generation Room in the Administration Building complex contains two ozone generators, each rated at 300 pounds per day (ppd) with sufficient capacity to treat 15 mgd. The ozone generators are cooled using utility water from the treatment plant. Also in this room are the nitrogen boost system, ambient air oxygen and ozone monitors that detect any release of

gas into the area, and heating and ventilation equipment. Each monitor is alarmed to the SCADA system for operator notification and to local visual and audio alarms. A 6,000-gallon liquid oxygen (LOX) tank is located outdoors just south of this room.

3.3.6 Filtration System

The filters are located downstream of the Ozone Contact Basins. Filtration through a deep-bed dual media (GAC over sand) removes any material carried over from the Actiflo® basin and allows time for adsorbing dissolved organic material, such as SOCs, onto the GAC.

The GAC media is an optimal surface for growing bio-organisms for biofiltration, which also removes trace organic compounds. An inlet weir at each filter allows uniform distribution of flow to each of the four filter cells. At the current 15-mgd plant capacity, the filters are rated at 7.5 gpm/sf with one filter out of service for backwashing, and a nominal filtration rate of 5.7 gpm/sf when all four filters are in service.

The GAC filter media depth provides an EBCT of 7.5 minutes when all filters are on-line and 5.6 minutes with one filter out of service. The GAC filters adsorb trace organic compounds, which may occur infrequently at trace concentrations in the raw water supply, and act as another barrier against T&O. To maintain optimal adsorption capacity, the GAC and sand media are replaced approximately every four years; media change-outs are performed on two filters at a time, resulting in change-outs every two years.

The treated water exits the filters through the underdrain system and ultimately flows into a common filter effluent pipeline under the filter gallery slab. Filter-to-waste is provided by diverting filtered water back through the backwash header and over to the washwater equalization basin. A filter control weir structure is located between the filters and the clearwell to control the downstream hydraulic gradeline of the filters.

At the combined filter effluent pipeline, sodium hypochlorite is added to provide free chlorine residual for disinfection. Sodium hydroxide is also added to adjust the pH for corrosion control.

Space and hydraulic head were allocated in the original 1999-2000 designs and 2002 construction between the filters and clearwell to accommodate a potential future UV disinfection system.

Filters are backwashed based on an operator set time, effluent turbidity, or maximum head loss, as measured by filter differential pressure. Analytical instruments monitor the filtered water turbidity and particle counts on each filter effluent and a turbidity of the combined filtered effluent.

The cleaning cycle for each filter includes air scour and water backwash. When a wash cycle starts, the water level is drained to a few inches above the media, and air scour begins. After an operator-adjustable time, the backwash pump is activated at a low flow for concurrent air scour and wash water. When the water level rises to an operator-set level below the lip of the washwater troughs, the air scour is terminated, and the backwash rate is increased to an operator-adjustable high rate level.

3.3.7 Liquid Chemical Storage and Feed Facilities

The treatment plant has bulk storage space allocated for the following liquid treatment chemicals. The Chemical Storage Room in the Administration Building complex contains the following chemical storage facilities:

- Two 6,500-gallon tanks for liquid alum (or ferric chloride).
- One 4,400-gallon tank and one 3,900-gallon tank for liquid sodium hypochlorite.
- One 6,500-gallon tank for sodium hydroxide.
- One 1,400-gallon tank for aqueous ammonia (not used).
- Two 55-gallon drums for sludge conditioning polymer.
- Two 220-gallon totes for calcium thiosulfate.
- Two 55-gallon drums for filter aid polymer.
- One dry feeder and mixing tank for Actiflo® polymer.

Primary coagulant (alum) is used to coagulate the suspended solids and dissolved organic carbon in the raw water. The coagulant is added at the initial mix vault for efficient contact with the raw water. A secondary addition point in the Actiflo® basin's coagulation chamber is typically not used but is available as a back-up for the initial mix vault.

Liquid alum is stored as a 49 percent solution. The tanks are piped to the diaphragm metering pumps, which transfer the alum solution to the dosing location. The metering pumps have manual stroke adjustments and automatic speed control for flow-pacing based on the raw water flowmeter signal. All chemical systems share this common feature for chemical feed rate control.

A coagulant aid polymer used in the coagulation process is vital to the proper function of the Actiflo® process because it creates a floc that adheres to the microsand. High-molecular-weight cationic polymer is added at both the Hydrocyclone Collection Box and the effluent of the injection chamber. In case of a mechanical failure, another application point for temporary use is located upstream of the Actiflo® process at the chemical vault. Dry polymer is automatically batched into a dilute solution using the dry chemical feed system, which includes a dry hopper, mixing tank, and aging tank. The resulting solution is pumped to the appropriate location with chemical metering pumps. Each Actiflo® basin has a separate feed point.

Sodium hypochlorite, delivered in bulk as a 12.5 percent liquid solution, is provided for free chlorine disinfection following filtration and for residual disinfection in the distribution system. It can also be added for intermittent chlorination at other locations in the plant to keep various basins clean. The storage tanks are piped to the metering pumps, which transfer the solution to the dosing location. The primary application point is at the filter effluent, while additional "booster" chlorine can be added to the finished water.

Sodium hydroxide, delivered and stored as a 25 percent liquid solution, is used for pH adjustment and is delivered to the application location by metering pumps. The water's pH can be adjusted at three locations in the plant: raw water (chemical vault), filter influent, and filter effluent. The typical chemical feed point is at the filter effluent. Seasonally, sodium hydroxide is added to the raw water to optimize coagulation.

Although not currently used at the plant, nonionic polymer can be used as a filter aid. The primary point of chemical addition is at the Ozone Contact Basin effluent channel. The polymer

can also be added to the backwash water based on a flow signal from the backwash water flowmeter.

Calcium thiosulfate is used to quench any ozone residual in the ozonation system effluent prior to filtration. Liquid calcium thiosulfate is stored in 220-gallon totes. The active tote is connected to metering pumps that deliver the chemical to the ozone effluent channel. An ozone residual monitor in the filter gallery detects any ozone residual in the filter inlet channel.

Space in the Chemical Storage Room is allotted for storage and metering of polyphosphate, a corrosion inhibitor. However, this chemical has never been used at the WRWTP.

Space, chemical storage, and feed facilities were provided for aqueous ammonia. Aqueous ammonia reacts with sodium hypochlorite to form chloramines for residual disinfection of treated water. The chemical can be added downstream of the Filter Control Weir or at the High Service Pump Station. This system was added in case additional DBP control is needed to meet more stringent future regulations, or if the plant water were to be blended with another chloraminated water supply in the region, such as the Portland Water Bureau (PWB). To date, this chemical has not been used at the WRWTP.

Anionic polymer can be added to the thickener influent or the centrifuge inlet for sludge processing. It is stored as a liquid (emulsion) in 55-gallon drums housed in the Chemical Building. Polymer is pumped to the point of addition with PolyBlend® units, which combine polymer mixing with utility water and chemical delivery to the application points.

A truck fill station is located at the southeast corner of the Chemical Storage Room for bulk delivery of chemicals stored in tanks. At the fill station, the operator must select the chemical tank to fill on a local control panel, which displays the level in the tank to verify that it requires filling. When the operator selects start, the inlet valve will open and the delivery driver can connect the hose to the proper fill station and open the manual isolation valve. An alarm will sound at the station's tank HIGH level to warn that the tank has been filled.

3.3.8 Washwater Equalization Basin

The washwater equalization basin provides equalization for recycling the filter backwash water, filter-to-waste water, sludge thickener decant water, and the dewatering facility centrate water. The basin is sized to store approximately two backwash volumes, including filter-to-waste. Flow collected in the basin is pumped back to the raw water pipeline just downstream of the chemical injection vault.

The recycle pump station contains three variable-speed vertical turbine pumps, each rated at 500 gpm, which are controlled according to the desired recycle rate. The basin contains an overflow weir box and pipe to divert overflows back to the raw water pump station caisson.

3.3.9 Gravity Thickener

Sludge, containing suspended solids and chemical floc, is physically removed from the treatment plant in the settling basins of the Actiflo® process. The solids are separated from the microsand at the hydrocyclones and conveyed by gravity to the gravity thickener. While the Actiflo® process is operating, sludge flow to the thickener is continuous. Sludge is thickened from approximately 0.05 percent to 0.5 percent solids (in the Actiflo® waste stream) to 2.5 percent average solids concentration in the thickener.

Thickened sludge flows by gravity from the thickener to the sludge equalization and mixing tank, where sludge quality and quantity are equalized prior to pumping to the centrifuges. The pipeline between the thickener and mixing tank contains a motorized valve that controls sludge transfer based on an operator-set timer. The mixing tank contents are mixed with a constant-speed solids mixing pump.

A PVC standpipe is located adjacent to the mixing tank. In an emergency, the standpipe can be used to divert sludge from the mixing tank to the Irrigation Waste Pump Station. The pump station discharges to the sewer system. While this system has not been needed to date, it can be used for short-term removal of solids from the treatment plant.

Thickened sludge transfer pumps, monitored by a magnetic flowmeter, convey contents of the sludge mixing tank to the centrifuges for dewatering in conjunction with the centrifuges. Polymer is added to the thickened sludge before the centrifuges to help with dewatering.

The centrifuges are located in the two-story Solids Handling Building. The upper floor contains the mechanical equipment, and the lower floor is a pass-through for the sludge-hauling trucks. A diverter gate is located on the solids discharge chute of the centrifuges. Once the solids have reached a specified percent solid concentration, or an operator set time has elapsed, the diverter gate opens and dewatered sludge drops down into a screw conveyor trough on the underside of the upper story floor slab. The conveyor must be operating when the centrifuge is in operation to collect sludge and divert it to the conveyor chutes and into sludge collection bins (or a hauling truck in the future). Liquid recovered from the centrifuge operation (called "centrate") is conveyed by gravity to the washwater equalization basin.

3.4 Historical Plant Performance

In March 2015, plant staff provided historical operating and plant performance data. Figure 3.4 summarizes key operational and water quality performance parameters as a process flow diagram of the overall plant.

-This Page Intentionally Left Blank-




Figure 3.4 WRWTP Process Performance Summary

-This Page Intentionally Left Blank-

Plant performance data was limited to a three-year period (2012 to 2014) due to the significant increase in plant production and change from batch to continuous operation once the WRWTP started serving the City of Sherwood. Parameters in the figure include monthly finished water production, electrical usage, chemical usage, sand loss, settled water, filtered water and finished water turbidity, ozone disinfection performance, filter production efficiency, and clearwell disinfection performance.

Before Sherwood took water in early 2012, the plant was operated on a daily on/off cycle for 8 to 16 hours per day to meet Wilsonville's water demands. The average annual production ranged from 2.8 to 3.2 mgd, with a peak day demand of 6.6 mgd. Since early 2012, the plant has operated continuously to meet water demand for both Wilsonville and Sherwood. During 2012 to 2014, the annual average plant production ranged from 4.5 to 4.9 mgd, with a peak day demand of 12.5 mgd. Table 3.2 shows the WRWTP production data from 2006 to 2014. Figure 3.5 shows raw water turbidity levels from January 2006 to June 2015, which have ranged from approximately 1 to 147 Nephelometric Turbidity Units (NTU).

The Actiflo® process has performed well, consistently producing clarified water with less than 0.95 NTU. Sand loss through the Actiflo® system has been relatively low (2.8 pounds per million gallons [lbs/mg]) during the evaluation period, well below the manufacturer's maximum anticipated loss of 25 lbs/mg at other Actiflo® plants on the West Coast.

The ozonation process has achieved a minimum of 1.0-log *Cryptosporidium* inactivation and greater than 3.0-log inactivation of *Giardia*, meeting the stringent requirements of the operations contract, though OHA does not grant any disinfection credit for ozonation. A minimum of 0.5-log *Giardia* inactivation is also achieved after filtration in the clearwell using free chlorine. Using the ozone system CT values and the EPA ozone disinfection tables, the plant consistently achieves greater than 8.0-log of *Giardia* removal or inactivation; OHA only requires 3.0-log of *Giardia* removal or inactivation.

Table 3.2 WRWTP Production (mgd)

Year	Annual Average	Peak Season Average ⁽¹⁾	Low Season Average ⁽²⁾	Minimum Monthly Average		Maximum Monthly Average		Maximum Weekly Average		Maximum Daily	
				Month	Value	Month	Value	Dates	Value	Date	Value
2006	3.1	4.7	2	Feb	1.9	Jul	5.4	07/20 - 07/26	6	07/22	6.3
2007	3.2	4.8	2.2	Dec	2.1	Jul	5.3	07/10 - 07/16	5.9	07/12	6.3
2008	3.1	4.7	2.1	Jan	2.1	Jul	5.5	08/11 - 08/17	6.2	08/15	6.5
2009	3.1	4.7	2.1	Feb	2.1	Jul	5.3	07/27 - 08/02	6	08/01	6.9
2010	2.8	4.1	2.1	Jan	2	Aug	5.2	07/22 - 07/28	5.6	07/25	6.2
2011	2.8	4.2	2	Jan	2	Aug	4.9	09/02 - 09/08	5.7	08/29	6.0
2012	4.5	6.9	2.5	Jan	2.1	Aug	8.4	08/15 - 08/21	8.7	08/17	9
2013	4.8	6.9	3.3	Jan	3.2	Jul	8	08/06 - 08/12	8.4	08/06	8.8
2014	4.9	7.8	3.2	Dec	3.2	Aug	8.9	08/04 - 08/10	9.2	07/11	10.2
										07/31	12.5
										08/24	11.4

Notes:

- (1) Peak season is defined as June through September.
- (2) Low season is defined as December through February.




Figure 3.5 WRWTP Raw Water Turbidity

Average monthly raw water total organic carbon (TOC) levels ranged from 1.1 milligrams per liter (mg/L) to 1.8 mg/L. As shown in Figure 3.6, TOC removal is excellent, resulting in a low chlorine demand in the finished water and in the distribution systems, and low disinfection by-product (DBP) formation (based on evaluation of total trihalomethanes [TTHMs] and haloacetic acid 5 [HAA5, the sum of 5 HAA compound concentrations]). Average TOC percent removal between raw and finished water has ranged seasonally between 46 percent and 77 percent, with an average of 60 percent.

Various filter performance indicators were reviewed and analyzed, including filtered water turbidity and filter run times. Filtered water turbidities have always been less than 0.10 NTU, well below both regulatory standards and the stringent performance requirements in the operations contract. Since the plant started operating continuously in early 2012, the filtration production efficiency has been very high (>98 percent), resulting in low backwash water usage.

During 2012 to 2014, the plant used between 225 and 637 megawatt hours (mWh) per month. More power is used during the peak plant production months of June through September due to the increased pumping capacity at the raw water and finished water pump stations. The average unit power usage has been 2.7 mWh per MG produced. Figure 3.7 summarizes electrical power usage as a function of monthly finished water production.

During 2012 to 2014, the plant produced between 14 and 69 wet tons per month of dewatered alum solids (sludge). More solids are generally produced during the fall and winter months when the raw water turbidity is elevated. A single centrifuge operates 10 to 20 hours per week, typically producing dewatered solids at a concentration of greater than 25 percent. The dewatered solids are hauled to a landfill (currently Coffin Butte Landfill located north of Corvallis) via a waste management contract. The average unit solids production has been 0.2 wet tons per MG produced, or approximately 0.05 dry tons/MG assuming 25-percent solids concentration. Figure 3.8 summarizes solids production as a function of monthly finished water production.

3.5 Conclusions

The data demonstrate exceptional operational plant performance for turbidity removal, disinfection levels, TOC removal, and low DBP formation potential. The extremely narrow range between the 5 and 95 percentile value for key water quality parameters such as turbidity, pH, and chlorine residual is a testament to the plant's robust design and the operator's attention to continuous optimal performance.




Figure 3.6 WRWTP Raw Water and Finished Water




Figure 3.7 WRWTP Monthly Finished Water Production and Power Consumption




Figure 3.8 WRWTP Monthly Finished Water Production and Solids Production

-This Page Intentionally Left Blank-

Chapter 4

HISTORICAL WATER QUALITY AND REGULATORY COMPLIANCE

4.1 Introduction

This Chapter summarizes Willamette River raw water quality, Willamette River Water Treatment Plant (WRWTP) finished water quality, and current and anticipated water quality regulations, including Contaminants of Emerging Concern (CECs). It also compares contractual and regulatory requirements. The Chapter shows raw and finished water quality data from May 2006 through December 2014; no additional water quality analysis was done for this master plan update. The 2006 Master Plan supplied data from April 2002 through April 2006.

The WRWTP was commissioned in 2002 and is operated by Veolia through an agreement with the City. For some contaminants, water quality and operational contractual requirements are more stringent than regulations require.

4.2 Historical Water Quality

The Oregon Drinking Water Quality Act (the Act) includes the Oregon Revised Statutes (ORS), with periodic amendments. Per the OHA, the Act:

- Ensures that all Oregonians have safe drinking water.
- Is a simple and effective regulatory program for drinking water systems.
- Recommends ways to improve inadequate drinking water systems.

ORS 448.131 authorizes the OHA to adopt administrative rules that ensure safe drinking water. Oregon Administrative Rule (OAR) Chapter 333 Division 061 regulates public water systems.

Table 4.1 compares the sampling frequency of finished and raw water quality to comply with OAR requirements and the Veolia operating contract.

Table 4.1 WRWTP Comparison of Regulatory and Contract Sampling Frequencies

Contaminant	OAR Requirement	Contract Requirement
Physical Chemical Inorganic Parameters		
Conductivity	-	Weekly
Temperature	-	Continuous
Total Alkalinity	-	Weekly (Daily in the winter)
Total Hardness	-	Weekly
Calcium Hardness	-	Weekly
TON	-	Weekly
Iron	-	Monthly
Turbidity	Continuous	Continuous
Particles		Continuous
Color	-	Weekly
Physical Chemical Inorganic Parameters		
Chlorine Residual	Continuous	Continuous
Total Dissolved Solids (TDS)	-	Weekly
Microbiological and Organic Parameters		
Total Coliform	40/month in Dist. Sys.	n/a
<i>E. coli</i>	If TC Positive	n/a
Viruses	-	Quarterly
<i>Giardia</i>	-	Monthly
<i>Cryptosporidium</i>	-	Monthly
Total Trihalomethanes	Quarterly	Monthly
Haloacetic Acids	Quarterly	Monthly
Bromate	Quarterly	Monthly
Regulated VOCs/SOCs (+dioxin)	Varies (Annually/ 3 Years)	Quarterly
Regulated IOCs	Varies (Annually/3 Years/ 9 Years)	Quarterly
Unregulated IOCs (Al, B, Cr-6, Mn, Ag, V, Zn)	-	Quarterly
TOC	Monthly	Weekly
Geosmin	-	Monthly

Table 4.1 contains the contractual requirements for finished and raw water sampling. During the project's planning stages, the City set WRWTP treated water quality goals, which have been slightly modified since the plant was commissioned.

Table 4.2 compares the contractual treated water quality goals with existing regulations from the OAR. The contractual finished water quality goal meets or exceeds regulatory requirements for all water quality parameters.

Table 4.2 Comparison of Regulatory and Contract Finished Water Parameters

Water Quality Parameter	Unit	Existing Regulations	Contract Requirement
Total/fecal coliform	MPN/100 mL	<5% positive in system	0% positive leaving plant
Turbidity	NTU	≤0.3 95% of time; Always <1.0	<0.1 each filter 95% of filter run time ⁽¹⁾ ; Always <0.3
Particles (>2 μm)	Count/mL	None	<50 95% of filter run time ⁽¹⁾
Pathogen Removal/Inactivation			
Viruses		4-log inactivation	Provide multi-barrier 2-log removal and 2-log inactivation
<i>Giardia</i>		2.5-log removal and 0.5-log inactivation (post filtration)	Provide multi-barrier 3-log removal and 1-log inactivation
<i>Cryptosporidium</i>		2-log removal	Provide multi-barrier 3-log removal and 1-log inactivation
Disinfection By-Products⁽²⁾			
TTHMs	μg/L	80	<40
HAA5	μg/L	60	<30
Bromate	μg/L	10	<5
Synthetic Organic Chemicals (including dioxins ⁽³⁾)	μg/L	Varies	<detection limit
Volatile Organic Chemicals	μg/L	Varies	<detection limit
Unregulated IOCs (Al, B, Cr-6, Mn, Ag, V Zn) ⁽³⁾	μg/L	Varies	<50% MCL
Alkalinity	mg/L as CaCO ₃	None	≥=20
pH		None	≥=7.5 95% of time ⁽¹⁾ ; Always ≥7.0
Arsenic	μg/L	2 to 10	≤2
Sulfate	mg/L	250	<MCL
TOC	mg/L	35% reduction in TOC if raw water in TOC is from 2-4 mg/L. 45% reduction if raw water TOC is from 4-8 mg/L	Same as OAR
T&O Compounds			
Geosmin	ng/L	None	<7
Odors	TON	3	<3

Notes:

- (1) Within a 24-hour period from midnight to midnight.
- (2) Data presented is from the finished water at the WTP effluent and not from the distribution system.
- (3) Added analyses per Owner's request.

Veolia staff and the Cities of Wilsonville and Sherwood personnel helped obtain raw and finished water quality information. Along with regularly calibrating field instruments, operations staff continually monitors raw and finished water quality, the data for which is summarized in Table 4.3. The multi-barrier treatment approach at the WRWTP continues to produce finished water quality that meets or surpasses state and federal regulatory requirements. The tables show finished water quality maximum contaminant level (MCL) along with number of samples, value range, average, and median data.

The 2006–2015 raw water quality data was compared to that in the 2006 Master Plan. The few raw water contaminants detected at trace levels were not found in the finished water, meaning they were removed in the treatment process. Table 4.4 summarizes the WRWTP's finished water quality.

Table 4.3 WRWTP Summary of Raw Water Quality and Corresponding Finished Water MCL (May 2006 through 2014)

Contaminant	Unit	Finished Water MCL	No. of Samples	Value Range	Average	Median
General						
Turbidity	NTU	TT ⁽²⁾ : ≤0.3 95% of time; Always <1.0	3,167	1-147	9	5.2
TOC	mg/L	35% reduction in TOC if raw water in TOC is from 2-4 mg/L. 45% reduction if raw water TOC is from 4-8 mg/L	104	0.9 - 2.4	1.3	1.2
Alkalinity	mg/L as CaCO ₃	None	1,000	0 - 31.3	22.9	22.9
Secondary Contaminants						
Color	-	15 color units	457	0 - 75	12.6	10
Corrosivity ⁽¹⁾	-	Non-corrosive				
Foaming Agents ⁽¹⁾	mg/L	0.5	n/a	n/a	n/a	n/a
pH	-	6.5-8.5	3,152	6.47-7.75	7.24	7.25
Hardness	mg/L as CaCO ₃	-	463	0 - 38.1	23.5	23.2
Odor	-	3 TON	457	0 - 12	4.1	4.7
Total Dissolved Solids (TDS) ⁽¹⁾	mg/L	500	n/a	n/a	n/a	n/a
Aluminum	mg/L	0.05-2	35	0 - 3.76	0.46	0.24
Chloride ⁽¹⁾	mg/L	250	n/a	n/a	n/a	n/a
Copper	mg/L	1 (MCL TT ⁽²⁾)	35	0.0052 - 0.0435	0.02	0.02
Fluoride	mg/L	2 (MCL 4.0)	35	0 - 0	0	0
Iron	mg/L	0.3	106	0 - 49.6	1.0	0.3
Manganese	mg/L	0.05	35	0.0035 - 0.169	0.02	0.01
Silver	mg/L	0.10	35	0 - 0	0	0
Sulfate	mg/L	250	35	2.5 - 9.46	4.3	3.9
Zinc	mg/L	5	35	0 - 0.0136	0.001	0
Contaminant	Unit	Finished Water MCL	No. of Samples	No. of Detects	Value Range	Median
Inorganic Contaminants (IOCs)						
Antimony	mg/L	0.006	35	1	0 - 0.00128	-
Arsenic	mg/L	0.010	35	1	0 - 0.0008	-
Barium	mg/L	2	35	35	0.00371 - 0.0268	0.0057
Beryllium	mg/L	0.004	35	1	0 - 0.00008	-
Boron	mg/L	Non-regulated	35	1	0 - 0.0543	-
Cadmium	mg/L	0.005	35	0	ND	ND
Chromium (total)	mg/L	0.1	35	6	0 - 0.00309	-
Cyanide (as free cyanide)	mg/L	0.2	35	1	0 - 0.0446	-
Lead	mg/L	TT ⁽²⁾	35	2	0 - 0.00103	0
Mercury	mg/L	0.002	35	0	ND	ND
Nickel	mg/L	Non-Regulated	35	0	ND	ND
Nitrate-N	mg/L	10	35	35	0.17 - 0.74	0.37
Nitrite-N	mg/L	1	35	0	ND	ND
Selenium	mg/L	0.05	35	0	ND	ND
Sodium	mg/L	Non-regulated	35	35	3.16 - 8	4.6
Thallium	mg/L	0.002	35	0	ND	ND
Vanadium	mg/L	Non-regulated	35	23	0 - 0.0103	0.0023
Synthetic Organic Contaminants (SOCs)						
2,4-D	mg/L	0.07	35	0	ND	ND
2,4,5-TP Silvex	mg/L	0.05	35	1	0 - 0.00029	-
Bis (2ethylhexyl)adipate	mg/L	0.4	35	0	ND	ND
Alachlor	mg/L	0.002	35	0	ND	ND
Atrazine	mg/L	0.003	35	0	ND	ND
Benzo(a)pyrene	mg/L	0.0002	35	0	ND	ND
Lindane ⁽¹⁾	mg/L	0.0002	n/a	n/a	n/a	n/a
Carbofuran	mg/L	0.04	35	0	ND	ND
Chlordane	mg/L	0.002	35	0	ND	ND
Dalapon	mg/L	0.2	35	0	ND	ND
Dibromochloropropane (DB CP)	mg/L	0.0002	35	0	ND	ND

Table 4.3 WRWTP Summary of Raw Water Quality and Corresponding Finished Water MCL (May 2006 through 2014) – (Continued)

Contaminant	Unit	Finished Water MCL	No. of Samples	No. of Detects	Value Range	Median
Dinoseb	mg/L	0.007	35	0	ND	ND
Dioxin (2,3,7,8-TCDD)	mg/L	0.00000003	35	0	ND	ND
Diquat	mg/L	0.02	35	0	ND	ND
Endothall	mg/L	0.1	35	0	ND	ND
Endrin	mg/L	0.002	35	0	ND	ND
Ethylene Dibromide	mg/L	0.00005	35	0	ND	ND
Heptachlor	mg/L	0.0004	35	0	ND	ND
Heptachlor epoxide	mg/L	0.0002	35	0	ND	ND
Hexachlorobenzene	mg/L	0.001	35	0	ND	ND
Hexachlorocyclopentadiene	mg/L	0.05	35	0	ND	ND
Methoxychlor	mg/L	0.04	35	0	ND	ND
Pentachlorophenol	mg/L	0.001	35	0	ND	ND
Bis(2-ethylhexyl)phthalate	mg/L	0.006	35	1	0 - 0.0013	-
Picloram	mg/L	0.5	35	0	ND	ND
Polychlorinated Biphenyls	mg/L	0.0005	35	0	ND	ND
Simazine	mg/L	0.004	35	0	ND	ND
Toxaphene	mg/L	0.003	35	0	ND	ND
Oxamyl(Vydate)	mg/L	0.2	35	0	ND	ND
Volatile Organic Contaminants (VOCs)						
Benzene	mg/L	0.005	35	0	ND	ND
Bromobenzene	mg/L	Non-regulated	35	0	ND	ND
Bromochloromethane	mg/L	Non-regulated	35	0	ND	ND
Bromodichloromethane	mg/L	Non-regulated	35	0	ND	ND
Bromoform	ug/L	10	35	0	ND	ND
Bromomethane	mg/L	Non-regulated	35	0	ND	ND
n-Butylbenzene	mg/L	Non-regulated	35	0	ND	ND
sec-Butylbenzene	mg/L	Non-regulated	35	0	ND	ND
tert-Butylbenzene	mg/L	Non-regulated	35	0	ND	ND
Chlorobenzene	mg/L	0.1	35	0	ND	ND
Carbon Tetrachloride	mg/L	0.005	35	0	ND	ND
Chloroethane	mg/L	Non-regulated	35	0	ND	ND
Chloroform	mg/L	Non-regulated	35	3	0 - 0.00138	-
Chloromethane	ug/L	10	35	0	ND	ND
2-Chlorotoluene	mg/L	Non-regulated	35	0	ND	ND
1,2-Dibromo- 3Chloropropane	mg/L	Non-regulated	35	0	ND	ND
Dibromochloromethane	ug/L	10	35	0	ND	ND
1,2-Dibromoethane	mg/L	Non-regulated	35	0	ND	ND
Dibromomethane	mg/L	Non-regulated	35	0	ND	ND
1,2-Dichlorobenzene	mg/L	0.6	35	0	ND	ND
1,3-Dichlorobenzene	mg/L	Non-regulated	35	0	ND	ND
1,4-Dichlorobenzene	mg/L	0.075	35	0	ND	ND
Dichlorodifluoromethane	mg/L	Non-regulated	35	0	ND	ND
1,1-Dichloroethane	mg/L	Non-regulated	35	0	ND	ND
1,2-Dichloroethane	mg/L	0.005	35	0	ND	ND
1,1-Dichloroethylene	mg/L	0.007	35	0	ND	ND
cis-1,2-Dichloroethylene	mg/L	0.07	35	0	ND	ND
trans-1,2-Dichloroethylene	mg/L	0.1	35	0	ND	ND
1,2-Dichloropropane	mg/L	0.005	35	0	ND	ND
1,3-Dichloropropane	mg/L	Non-regulated	35	0	ND	ND
2,2-Dichloropropane	mg/L	Non-regulated	35	0	ND	ND
1,1-Dichloropropene	mg/L	Non-regulated	35	0	ND	ND
cis-1,3-Dichloropropane	mg/L	Non-regulated	35	0	ND	ND
trans-1,3-Dichloropropene	mg/L	Non-regulated	35	0	ND	ND
Ethylbenzene	mg/L	0.7	35	0	ND	ND
Hexachlorobutadiene	mg/L	Non-regulated	35	0	ND	ND
Isopropylbenzene	mg/L	Non-regulated	35	0	ND	ND
p-Isopropylbenzene	mg/L	Non-regulated	35	0	ND	ND

Table 4.3 WRWTP Summary of Raw Water Quality and Corresponding Finished Water MCL (May 2006 through 2014) – (Continued)

Contaminant	Unit	Finished Water MCL	No. of Samples	No. of Detects	Value Range	Median
Methylene Chloride	mg/L	Non-regulated	35	0	ND	ND
Napthalene	mg/L	Non-regulated	35	0	ND	ND
n-Propylbenzene	mg/L	Non-regulated	35	0	ND	ND
Styrene	mg/L	0.1	35	0	ND	ND
1,1,1,2-Tetrachloroethane	mg/L	Non-regulated	35	0	ND	ND
1,1,2,2-Tetrachloroethane	mg/L	Non-regulated	35	0	ND	ND
Tetrachloroethylene	mg/L	0.005	35	0	ND	ND
Toluene	mg/L	1	35	0	ND	ND
1,2,3-Trichlorobenzene	mg/L	Non-regulated	35	0	ND	ND
1,2,4-Trichlorobenzene	mg/L	0.07	35	0	ND	ND
1,1,1-Trichloroethane	mg/L	0.2	35	0	ND	ND
1,1,2-Trichloroethane	mg/L	0.005	35	0	ND	ND
Trichloroethylene	mg/L	0.005	35	0	ND	ND
Trichloroflouromethane	mg/L	Non-regulated	35	0	ND	ND
1,2,3-Trichloropropane	mg/L	Non-regulated	35	0	ND	ND
1,2,4-Trimethylbenzene	mg/L	Non-regulated	35	0	ND	ND
1,3,5-Trimethylbenzene	mg/L	Non-regulated	35	0	ND	ND
Vinyl Chloride	mg/L	0.002	35	0	ND	ND
Xylenes (total)	mg/L	10	35	0	ND	ND
Dichloromethane	mg/L	0.0005	35	0	ND	ND
Contaminant	Unit	Finished Water MCL	No. of Samples	% Detected	Value Range	Median
Microbial Contaminants						
Total Coliform	MPN/100 mL	<5% positive in system	1,000	100%	1 - 11200	301
<i>E. Coli</i>	MPN/100 mL		1,000	98%	0 - 866	6
Viruses	MPN/100 L	4-log	35	63%	0 - 78.8	3.36
<i>Giardia</i>	MPN/100 L	3-log	105	13%	0 - 93.2	0
<i>Cryptosporidium</i>	MPN/100 L	2-log removal	105	2%	0 - 10	0

Notes:
 (1) Parameter not actively sampled.
 (2) TT: Treatment Technique.

Table 4.4 WRWTP Summary of Finished Water Quality (May 2006 through 2014)

Contaminant	Unit	Finished Water MCL	No. of Samples	Value Range	Average	Median
General						
Turbidity	NTU	TT ⁽²⁾ : ≤0.3 95% of time; Always <1.0	3,167	0.02-0.06	0.04	0.04
TOC	mg/L	Non-regulated	104	0.29 - 0.82	0.51	0.54
Alkalinity	mg/L as CaCO ₃	None	942	19 - 33.	25	25
Taste and Odor (T&O)						
Geosmin	ng/L	None	104	0 - 0	0.00	0
Secondary Contaminants						
Color	color units	15	450	0 - 5	0.01	0
pH	-	6.5-8.5	3,167	7.50-8.10	7.8	7.8
Hardness	mg/L as CaCO ₃	250	453	16.7 - 36.2	24.0	23.5
Odor	TON	3	448	0 - 3.3	1.1	1.2
Total Dissolved Solids (TDS)	mg/L	500	453	26.2 - 91.5	63.4	63.9
Aluminum	mg/L	0.05-2	34	0 - 0.016	0.0005	0
Chloride ⁽¹⁾	mg/L	250	n/a	n/a	n/a	n/a
Copper	mg/L	1 (MCL TT ⁽²⁾)	34	0.0078 - 0.036	0.015	0.0132
Fluoride	mg/L	2 (MCL 4.0)	33	0 - 0	0	0
Iron	mg/L	0.3	104	0 - 0	0	0
Manganese	mg/L	0.05	34	0 - 0.007	0.002	0.002
Silver	mg/L	0.1	34	0 - 0	0	0
Sulfate	mg/L	250	34	7.4 - 18	10.19	9.83
Zinc	mg/L	5	34	0 - 0.0196	0.001	0
Contaminant	Unit	Finished Water MCL	No. of Samples	No. of Detects	Value Range	Median
Inorganic Contaminants (IOCs)						
Antimony	mg/L	0.006	34	0	ND	ND
Arsenic	mg/L	0.010	34	0	ND	ND
Barium	mg/L	2	34	34	0.0029 - 0.0064	0.0047
Beryllium	mg/L	0.004	34	0	ND	ND
Boron	mg/L	Non-regulated	0	0	ND	ND
Cadmium	mg/L	0.005	0	0	ND	ND
Cyanide (as free cyanide)	mg/L	0.2	34	0	ND	ND
Lead	mg/L	TT ⁽²⁾	34	7	0 - 0.00171	0
Mercury	mg/L	0.002	0	0	ND	ND
Nickel	mg/L	Non-regulated	34	1	0 - 0.05	0
Nitrate-N	mg/L	10	34	34	0.16 - 0.8	0.4
Nitrite-N	mg/L	1	0	0	ND	ND
Selenium	mg/L	0.05	0	0	ND	ND
Sodium	mg/L	Non-regulated	34	34	7.6 - 15	9.4
Thallium	mg/L	0.002	0	0	ND	ND
Synthetic Organic Contaminants (SOCs)						
2,4-D	mg/L	0.07	0	0	ND	ND
2,4,5-TP Silvex	mg/L	0.05	0	0	ND	ND
Bis (2ethylhexyl)adipate	mg/L	0.4	32	0	ND	ND
Alachlor	mg/L	0.002	0	0	ND	ND
Atrazine	mg/L	0.003	0	0	ND	ND
Benzo(a)pyrene	mg/L	0.0002	33	1	0 - 0.00003	0
Lindane ⁽¹⁾	mg/L	0.0002	n/a	n/a	n/a	n/a
Carbofuran	mg/L	0.04	0	0	ND	ND
Chlordane	mg/L	0.002	0	0	ND	ND
Dalapon	mg/L	0.2	0	0	ND	ND
Dibromochloropropane(DB CP)	mg/L	0.0002	0	0	ND	ND
Dinoseb	mg/L	0.007	0	0	ND	ND
Dioxin (2,3,7,8-TCDD)	mg/L	0.00000003	0	0	ND	ND
Diquat	mg/L	0.02	0	0	ND	ND
Endothall	mg/L	0.1	0	0	ND	ND
Endrin	mg/L	0.002	0	0	ND	ND

Table 4.4 WRWTP Summary of Finished Water Quality (May 2006 through 2014) – (Continued)

Contaminant	Unit	Finished Water MCL	No. of Samples	No. of Detects	Value Range	Median
Ethylene Dibromide	mg/L	0.00005	0	0	ND	ND
Glyphosate	mg/L	0.7	0	0	ND	ND
Heptachlor	mg/L	0.0004	0	0	ND	ND
Heptachlor epoxide	mg/L	0.0002	0	0	ND	ND
Hexachlorobenzene	mg/L	0.001	33	0	ND	ND
Hexachlorocyclopentadiene	mg/L	0.05	0	0	ND	ND
Methoxychlor	mg/L	0.04	0	0	ND	ND
Pentachlorophenol	mg/L	0.001	0	0	ND	ND
Bis(2-ethylhexyl)phthalate	mg/L	0.006	31	0	ND	ND
Picloram	mg/L	0.5	0	0	ND	ND
Polychlorinated Biphenyls	mg/L	0.0005	0	0	ND	ND
Simazine	mg/L	0.004	0	0	ND	ND
Toxaphene	mg/L	0.003	0	0	ND	ND
Oxamyl(Vydate)	mg/L	0.2	0	0	ND	ND
Volatile Organic Contaminants (VOCs)						
Benzene	mg/L	0.005	0	0	ND	ND
Bromobenzene		Non-regulated	35	0	ND	ND
Bromochloromethane		Non-regulated	35	0	ND	ND
n-Butylbenzene		Non-regulated	34	0	ND	ND
sec-Butylbenzene		Non-regulated	34	0	ND	ND
tert-Butylbenzene		Non-regulated	33	0	ND	ND
Carbon Tetrachloride	mg/L	0.005	34	0	ND	ND
Chlorobenzene	mg/L	0.1	34	0	ND	ND
Chloroethane		Non-regulated	34	0	ND	ND
2-Chlorotoluene		Non-regulated	34	0	ND	ND
4-Chlorotoluene		Non-regulated	35	0	ND	ND
1,2-Dibromo- 3Chloropropane		Non-regulated	33	0	ND	ND
1,2-Dibromoethane		Non-regulated	35	0	ND	ND
Dibromomethane		Non-regulated	34	0	ND	ND
1,2-Dichlorobenzene	mg/L	0.6	34	0	ND	ND
1,3-Dichlorobenzene		Non-regulated	34	0	ND	ND
1,4-Dichlorobenzene	mg/L	0.075	34	0	ND	ND
Dichlorodifluoromethane		Non-regulated	33	0	ND	ND
1,2-Dichloroethane	mg/L	0.005	34	0	ND	ND
1,1-Dichloroethylene	mg/L	0.007	34	0	ND	ND
cis-1,2-Dichloroethylene	mg/L	0.07	34	0	ND	ND
trans-1,2-Dichloroethylene	mg/L	0.1	34	0	ND	ND
1,2-Dichloropropane	mg/L	0.005	34	0	ND	ND
1,3-Dichloropropane		Non-regulated	34	0	ND	ND
2,2-Dichloropropane		Non-regulated	34	0	ND	ND
1,1-Dichloropropene		Non-regulated	34	0	ND	ND
cis-1,3-Dichloropropane		Non-regulated	34	0	ND	ND
trans-1,3-Dichloropropene		Non-regulated	33	0	ND	ND
Ethylbenzene	mg/L	0.7	34	0	ND	ND
Hexachlorobutadiene		Non-regulated	33	0	ND	ND
Isopropylbenzene		Non-regulated	34	0	ND	ND
p-Isopropylbenzene		Non-regulated	34	0	ND	ND
Methylene Chloride		Non-regulated	35	0	ND	ND
Napthalene		Non-regulated	35	0	ND	ND
n-Propylbenzene		Non-regulated	33	0	ND	ND
Styrene	mg/L	0.1	34	0	ND	ND
1,1,1,2-Tetrachloroethane		Non-regulated	33	0	ND	ND
1,1,2,2-Tetrachloroethane		Non-regulated	34	0	ND	ND
Tetrachloroethylene	mg/L	0.005	34	0	ND	ND
Toluene	mg/L	1	34	0	ND	ND
1,2,3-Trichlorobenzene		Non-regulated	33	0	ND	ND
1,2,4-Trichlorobenzene	mg/L	0.07	34	0	ND	ND

Table 4.4 WRWTP Summary of Finished Water Quality (May 2006 through 2014) – (Continued)

Contaminant	Unit	Finished Water MCL	No. of Samples	No. of Detects	Value Range	Median
1,1,1-Trichloroethane	mg/L	0.2	34	0	ND	ND
1,1,2-Trichloroethane	mg/L	0.005	34	0	ND	ND
Trichloroethylene	mg/L	0.005	33	0	ND	ND
Trichlorofluoromethane		Non-regulated	33	0	ND	ND
1,2,4-Trimethylbenzene		Non-regulated	35	0	ND	ND
1,3,5-Trimethylbenzene		Non-regulated	33	0	ND	ND
Vinyl Chloride	mg/L	0.002	34	0	ND	ND
Xylenes (total)	mg/L	10	34	0	ND	ND
Disinfectant Residuals and Disinfection Byproducts (DBPs)						
Bromate	mg/L	0.01	104	22	0 - 0.0044	0
Bromoform	ug/L	10	35	0	ND	ND
Chloroform		Non-regulated	34	33	0 - 0.014	0.0049
Dibromochloromethane	ug/L	10	34	19	0 - 0.00134	0.00056
Dichloromethane	mg/L	0.00050	34	19	0 - 0.00134	0.00056
Bromodichloromethane		Non-regulated	35	34	0 - 0.00401	0.00176
Chlorine	mg/L	4.0	941	941	0.64 - 0.95	0.81
TTHM	mg/L	0.08	104	104	0.00261 - 0.0171	0.007095
HAA5	mg/L	0.06	104	95	0 - 0.0123	0.00473
Contaminant	Unit	Finished Water MCL	No. of Samples	% Detected	Value Range	Median
Microbial Contaminants						
Total Coliform	MPN/100 mL	<5% positive	940	0%	ND	ND
<i>E. Coli</i>	MPN/100 mL		941	0%	ND	ND
Viruses	MPN/100 L	2-log removal/2-log inactivation	36	0%	ND	ND
<i>Giardia</i>	MPN/100 L	2.5-log removal/ 0.5-log inactivation	14	0%	ND	ND
<i>Cryptosporidium</i>	MPN/100 L	2-log removal	14	0%	ND	ND

Notes:

(1) Parameter not actively sampled.

(2) TT: Treatment Technique.

All contaminants detected in the finished water were well below their respective MCLs. The WRWTP's finished water quality continues to meet or surpass regulatory requirements. Section 4.3.3 summarizes additional finished water quality data, collected in compliance with the Unregulated Contaminant Monitoring Rule (UCMR).

Data shown in Tables 4.1 through 4.4 were collected at the WRWTP. Table 4.5 gives the distribution system water quality, as reported in the *City of Wilsonville 2014 Annual Water Quality Report*.

Table 4.5 Summary of Wilsonville Distribution System Water Quality Data

Contaminant	Sample Frequency	Minimum	Average	Maximum
VOCs				
TTHM	Quarterly	1.3	13.7	25.8
HAA5	Quarterly	2.1	8.3	18
Bromate	Monthly	ND		3.6
TOC	Quarterly	0.416	0.552	0.608
Chlorine	Monthly	0.35		0.98

All contaminants in Table 4.5 are below the MCL and maximum contaminant level goal (MCLG) as applicable, further illustrating reliable finished water quality for the WRWTP and distribution system.

4.3 Regulatory Compliance

4.3.1 Existing Regulations

The WRWTP must comply with the following current state and federal drinking water regulations.

- National Primary Drinking Water Regulations (1975).
- Secondary Drinking Water Regulations (1979, 1991).
- Phase I, II, and V Regulations for IOCs, SOCs, and VOCs (1987, 1991, 1992; respectively).
- Surface Water Treatment Rule (1989).
- Total Coliform Rule (1989).
- Lead and Copper Rule (1991).
- Consumer Confidence Reports Rule (1998).
- Stage 2 Disinfection By-Product Rule (State 2 D/DBPR) (2006).
- Long-Term Stage 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) (2006).

4.3.2 Unregulated Contaminant Monitoring

The EPA uses the Unregulated Contaminant Monitoring (UCM) program to collect data for contaminants that are suspected in drinking water but lack health-based standards set by the Safe Drinking Water Act (SDWA). Every five years, the EPA reviews the list of contaminants, largely based on the Contaminant Candidate List. The SDWA Amendments of 1996 provide for:

- Monitoring no more than 30 contaminants every five years.
- Monitoring only a representative sample of public water systems serving fewer than 10,000 people.

- Storing analytical results in a National Contaminant Occurrence Database (NCOD).

The EPA manages the UCM program as specified in the UCMR. Historically, the program has progressed in several stages:

- UCM – State Rounds 1&2 (1988-1997) - State drinking water programs managed the original program and required public water systems (PWSs) serving more than 500 people to monitor contaminants.
- UCMR 1 (2001-2005) - The SDWA Amendments of 1996 redesigned the UCM program to incorporate a tiered monitoring approach and require monitoring for 25 contaminants (24 chemicals and one bacterial genus) during 2001-2003.
- UCMR 2 (2007-2011) - Established a new set of 25 chemical contaminants sampled during 2008-2010; EPA began monitoring UCMR 2 compliance.
- UCMR 3 (2012-2016) - Current regulation requires monitoring for 30 contaminants (28 chemicals and 2 viruses) from 2012-2015. These contaminants are separated into three lists. All public water systems serving populations >10,000 required to sample for List 1 (21 contaminants), and public water systems serving populations >100,000 required to sample for List 1 and List 2 (7 hormones). Unchlorinated public water systems with populations <1,000 required to sample for two viruses as part of List 3.
- UCMR 4 takes effect in 2018. The EPA administrator signed UCMR 4 on December 8, 2016, and the EPA submitted it for publication in the Federal Register. UCMR 4 requires monitoring 30 chemical contaminants between 2018 and 2022, including the following:
 - Ten cyanotoxin chemical contaminants.
 - Two metals.
 - Eight pesticides and one pesticide manufacturing by-product.
 - Three brominated haloacetic acid (HAA) groups.
 - Three alcohols.
 - Three semi-volatile chemicals.
 - One metal.

Table 4.6 summarizes the UCMR 3 data collected for Wilsonville’s distribution system and compares it to the other water utilities in Oregon and Washington. Water samples were collected at the distribution system entry point downstream of WRWTP (at the maximum residence time point) and compared to the other drinking water utilities in Oregon and Washington.

Table 4.6 Summary of UCMR 3 Finished and Distribution Water Quality

Contaminant	Range of Detects OR/WA (ug/L)	Range of Detects Wilsonville (ug/L)
List 1		
1,1-dichloroethane	0.036	-
1,2,3-trichloropropane	-	-
1,3-butadiene	-	-
1,4-dioxane	0.07-0.28	-
bromomethane	-	-
chlorate	20-3,000	43-130
chloromethane	0.2-2.2	-

Table 4.6 Summary of UCMR 3 Finished and Distribution Water Quality (Continued)

Contaminant	Range of Detects OR/WA (ug/L)	Range of Detects Wilsonville (ug/L)
chromium	0.2-55	0.2
chromium-6 (Cr-6)	0.03-4.0	0.038-0.072
cobalt	1.8-1.9	-
Halon 1011	0.087-1.0	-
HCFC-22	0.088-0.67	-
manganese	1-820	
molybdenum	1-13	-
PFBS	-	-
PFHpA	0.013-0.026	-
PFHxS	0.20-0.24	-
PFNA	0.027-0.028	-
PFOA	0.02-0.03	-
PFOS	0.51-0.60	-
strontium	0.9-531	36-41
vanadium	0.2-41.9	1.0-2.5
List 2 (not required for Wilsonville)		
17-alpha-ethynylestradiol	-	N/A
17-beta-estradiol	-	N/A
4-androstene-3,17-dione	0.0004	N/A
equilin	-	N/A
estriol	-	N/A
estrone	-	N/A
testosterone	0.0005	N/A

Of the UCMR 3 contaminants sampled for Wilsonville’s distribution system, only select metals and chlorate were detected at levels similar to those seen regionally and nationally. For additional information, see the discussion on *emerging contaminants* below. The concentration of detected contaminants is well below current published health reference levels and public health goals.

4.3.3 Contact Time Compliance

The WRWTP has always met the regulatory requirement of a minimum of 0.5-log *Giardia* inactivation downstream of filtration. As a contract requirement, the WRWTP has also met a minimum of 1.0-log *Cryptosporidium* inactivation using intermediate ozone.

Although the OHA does not recognize the use of intermediate ozone for *Giardia* or virus inactivation, the contact time (CT) required to achieve *Cryptosporidium* inactivation causes an excess of 10-fold inactivation of *Giardia* and viruses. The Ozone Coalition, supported by Oregon Water Utility Council (OWUC), has petitioned the OHA to change its rules by recognizing the

disinfection benefits of pre- or intermediate ozone disinfection in Oregon. This petition coincides with this 2017 MPU and is ongoing. A formal waiver application is planned for submission in spring 2018. If the collaboration changes the regulations, the CT compliance point for the WRWTP should be reevaluated.

4.3.4 Future Regulations

Although not expected to affect treatment process recommendations, several federal regulations are under development:

- **Lead and Copper Rule (LCR).** EPA is considering Long-Term Revisions to the LCR to further protect public health and streamline the rule's requirements. EPA's primary goals in considering LCR Long-Term Revisions are to:
 - Improve the effectiveness of corrosion control treatment in reducing exposure to lead and copper.
 - Trigger additional actions that equitably reduce the public's exposure to lead and copper when corrosion control treatment alone is not effective.
- **Perchlorate.** Perchlorate is a naturally-occurring and manufactured chemical anion that consists of one chlorine atom bonded to four oxygen atoms (ClO_4^-). It is commonly used as an oxidizer in rocket propellants, fireworks, airbag initiators for vehicles, matches, and signal flares. In 2011, the EPA determined that perchlorate meets the Safe Drinking Water Act (SDWA) criteria for regulation as a contaminant. Since then, the EPA has been reviewing the best available scientific data on a range of issues related to perchlorate in drinking water, including its occurrence, treatment technologies, analytical methods, and the costs and benefits of potential standards.

4.4 Emerging Contaminants

Numerous papers and presentations have documented a multitude of CECs in water supplies throughout the United States and elsewhere. Although the impacts of CECs are not fully understood, it is clear that drinking water regulations will change as more data is gathered via the UCM efforts (the current UCMR 3 and the future UCMR 4). This section focuses on the UCMR program, which likely encompasses future regulations. This chapter also discusses site-specific compounds of interest.

Typically characterized as particles of less than 100 nanometers (nm), manufactured nanomaterials can be found in electronics, personal care products, medical supplies, clothing, and other household items. They can help impart disinfectant/antimicrobial properties (nanosilver), are used in ultraviolet (UV) protection (nanoscale zinc oxide/titanium dioxide), and provide unique optical/electrical properties.

Although increased use of manufactured nanomaterials may introduce them to surface water supplies via stormwater runoff, industrial, and/or wastewater treatment plant discharges, research on the long-term impacts on public health and the environment is limited. Because the topic is nascent and the EPA has yet to take further action, this Chapter does not consider nanomaterials in its review.

The potential for CECs to be present in the Willamette River also needs to be better understood. CECs can influence the expanded WRWTP treatment process and procedure selection, capital and operations/maintenance costs, and water quality monitoring requirements. To better

account for these impacts, CECs were evaluated from national, regional, and local perspectives. Summarized below, this evaluation includes a review of recent literature, such as articles in national trade journals, a summary of data obtained from the national EPA UCMR 3 database, consultation with national water quality experts, and a summary of interviews with various local and regional water suppliers.

4.4.1 National Perspective and Literature Review

To quantify the occurrence of CECs throughout the United States, Carollo reviewed pertinent literature and the data from the National EPA Database summarizing UCMR 3 sampling results. Table 4.7 summarizes the results of this review.

Chlorate, vanadium, strontium, molybdenum, trichloropropane, and dioxane are the predominant contaminants. The prevalence of low levels of chlorate in drinking water is likely tied to widespread use of sodium hypochlorite, which in the past decade has replaced chlorine gas as the preferred chlorine chemical.

Low levels of some metals occur in various parts of the country, including the three most common--vanadium, strontium, and molybdenum--which occur naturally in some water supplies. Of the 14 compounds being tested in UCMR 3, 2 organic compounds (trichloropropane, a VOC, and dioxane, an SOC) were found in drinking water supplies across the nation, albeit at very low concentrations.

Although not part of the UCMR 3 testing, harmful algal blooms (HABs) and algal toxins captured national attention after a 2015 algal bloom on Lake Erie resulted in a "Do Not Use" order in Toledo, OH. Algal toxin monitoring will likely become a requirement for the upcoming UCMR 4 since the proposed list includes ten cyanotoxin chemical contaminants.

Table 4.7 Summary of Preliminary UCMR 3 Results⁽¹⁾

Contaminant	MRL ⁽²⁾ (ug/L)	Reference Concentration (ug/L) ⁽³⁾	Total Number of Results	Results >MRL %	Results >HRL ⁽²⁾ %	Total # of PWSs with Results	PWSs with Results >MRL %	PWSs with Results >HRL %
Oxyhalide Anion								
Chlorate	20	210	25,533	56.2	14.4	2,648	67.3	32.4
Metals								
Vanadium	0.2	21	25,683	60.8	2.9	2,640	69.8	3.3
Strontium	0.3	4,000	25,635	99.5	0.4	2,640	100	0.9
Molybdenum	1	40	25,685	42.6	0.5	2,640	50.7	0.6
SOCs								
1,2,3-Trichloropropane	0.03	0.0004/0.042	15,145	0.8	0.7-0.8	2,626	1.5	1.2-1.5
VOCs								
1,4-Dioxane	0.07	0.35/352	15,084	11.4	0-3.3	2,623	19.7	0-6.6

Notes:

- (1) Russell, C. "Status of Unregulated Contaminant Monitoring Rule 3 (UCMR 3)." Journal AWWA March 2015: 43-44. Print.
- (2) HRL - health reference level; MRL - minimum reporting level.
- (3) For reference concentrations with two values, first value is associated with 10⁻⁶ cancer risk and second is associated with a 10⁻⁴ cancer risk. Single values refer to contaminants with non-cancer reference values.

4.4.2 Regional Perspective

For a regional perspective on CEC-related issues, Carollo interviewed four regional utilities to collect and compile results from UCMR 3 testing and discuss issues of water quality, such as public concerns. Several of these utilities are now using or are considering using the Willamette River as a supply source. For all agencies, the primary question was, "In what way will CEC-related issues influence the agency's decisions regarding water treatment in the future?"

Appendix A of the 2015 MPU includes a copy of the interview questionnaire, and Table 4.8 summarizes the results. These regional UCMR 3 testing results are consistent with national findings for chlorate, strontium, and vanadium. However, they differ from national results since Pacific Northwest (PNW) utilities detected total and hexavalent chromium but not molybdenum, VOCs, or SOCs. Furthermore, most utilities have expressed concerns about algae and algal toxins, and some are concerned about the potential for regulating perchlorate/chlorate and chromium/hexavalent chromium.

Table 4.8 Summary of CECs Interview Responses by Regional Surface Water Suppliers

Water Supplier	Source of Supply	UCMR 3 Detects	Comments/Concerns - Re: CECs
Oak Lodge Water District	Clackamas River	Chlorate Total chromium Hexavalent chromium Strontium Vanadium	Concern about algal toxins, non-point source pollution.
City of Corvallis	Willamette River and Rock Creek Reservoir	Chlorate Total chromium Hexavalent chromium Strontium Vanadium	Algal toxins. Dioxins were of concern historically (no recent detects).
Tacoma Water	Green River	Total chromium Hexavalent chromium Strontium Vanadium No hormones detected	Will begin algal toxin monitoring and additional surveillance for algae in reservoir/source water.
Seattle Public Utilities	Cedar River and Tolt Reservoir	Total chromium Hexavalent chromium Strontium Vanadium No hormones detected	Algae in source water/reservoirs. Have performed PPCP testing (hormones) with no detects. Observation that chlorate levels are related to disinfectant usage; chlorine gas vs. sodium hypochlorite.
Eugene Water and Electric Board	McKenzie River	Chlorate Total chromium Hexavalent chromium Strontium Vanadium	Algal toxins.

Note that Seattle, Tacoma, and Eugene Water and Electric Board (EWEB) are large enough to be required to test both List 1 and List 2 contaminants for the UCMR 3. No hormones were detected in any of their supplies. Furthermore, other Pacific Northwestern utilities are concerned about algae and algal toxins: several in Tacoma and Bellingham, Washington, and one along the South Umpqua River in Oregon. This summary does not review these studies, but they should be considered in future design efforts.

4.4.3 2015 MPU Participant Interviews

Representatives were interviewed for each 2015 MPU participant potentially receiving water from the WWSP WTP. Discussions focused on each agency's concerns about using the Willamette River as a supply, as shown in Table 4.9. In addition, UCMR 3 data was discussed for each agency's current sources of supply.

Table 4.9 Summary of CECs Interview Responses by 2015 MPU Participant Water Suppliers

Water Supplier	Source of Supply	UCMR 3 Detects	Comments/Concerns - Re: CECs
City of Beaverton	JWC WTP, ASR	n/a	n/a
City of Hillsboro	JWC WTP	Total chromium Hexavalent chromium Strontium Vanadium	No chlorate detects, presumably due to use of chlorine gas at JWC WTP. Source water monitoring program to address algae or other changes in water quality.
City of Sherwood	WRWTP, PWB	Chlorate Total chromium Hexavalent chromium Strontium Vanadium	Limited complaints since switching to using Willamette River WTP as primary supply.
City of Tigard	PWB, LOTWTP, ASR	Chlorate Total chromium Hexavalent chromium Strontium Vanadium	Noticed that chlorate was tied to ASR well sites that use sodium hypochlorite for disinfection.
TVWD	PWB, JWC WTP, ASR	Total chromium Hexavalent chromium Strontium Vanadium Chlorate	Concern about algal toxins. Public perception about source switch and impacts to distribution system. No hormones were detected.
City of Wilsonville	WRWTP	Chlorate Total chromium Hexavalent chromium Strontium Vanadium	Some concern about potential strontium regulations. Levels of UCMR 3 detects well below published health reference goals.

Of all the participants, only TVWD was large enough to require testing for both List 1 and List 2 from the UCMR 3. No hormones were detected.

From all interviews and data collected for UCMR 3, the highest-profile CECs which should be seriously considered for the WRWTP are:

- Algal toxins.
- Chromium/hexavalent chromium.
- Vanadium and/or strontium.
- Chlorate.
- Low concentrations of site-specific trace organic compounds.

4.5 Conclusion

Historical water quality data confirms that the plant consistently meets or surpasses existing finished water regulatory requirements. The high-quality source water and robust treatment process produce excellent finished water in the region. With minor modifications, the current process train, with the built-in capability of adding UV or advanced oxidation (by adding hydrogen peroxide in conjunction with either ozone or UV treatment), or the implementation of biological filtration is expected to meet future regulatory requirements. See Chapter 6 for additional discussion on this topic.

-This Page Intentionally Left Blank-

Chapter 5

EXISTING INFRASTRUCTURE

5.1 Introduction

This chapter summarizes the Willamette River Water Treatment Plant (WRWTP) infrastructure and lays the groundwork for evaluating future expansion alternatives. The following topics are discussed:

- Site mapping
- Hydraulic assessment
- Electrical assessment
- Seismic evaluation and mitigation alternatives
- Life safety analysis
- Transient surge analysis

Additional analyses, such as river surveying, major plant component evaluation, computational fluid dynamic evaluation of the raw water pump station, and a geotechnical investigation, are found in Chapter 5 of the 2015 MPU.

5.2 Site Mapping

In June 2015, Compass Land Surveyors, using the North American Vertical Datum (NAVD) 1988, identified utility locations for the WRWTP. The work was coordinated with record drawings and input from Veolia staff. Figure 5.1 shows pertinent features for the existing site.

Included in the site mapping was a multi-beam bathymetric survey of the Willamette River from approximately one mile downstream to approximately 1/4-mile upstream of the existing raw water intake. This information helped to support the river hydrology analysis and HEC-RAS modeling.

To determine expected flows and elevations at the raw water intake, a hydrological model was developed in 2015 for the mid-Willamette River. The river stage (elevation) data from the United States Geological Survey (USGS) stations was in the National Geodetic Vertical Datum of 1929 (NGVD 29). To match the new site and bathymetric survey, the data were converted to NAVD 88, using a conversion factor consistent with that used by the Federal Emergency Management Agency (FEMA) in 2008 to update its Wilsonville flood plain mapping elevations. The resulting offset is +3.5 feet when going from NGVD 29 to NAVD 88 ($NGVD29+3.5=NAVD88$).

-This Page Intentionally Left Blank-




Figure 5.1 Lower Site Survey

-This Page Intentionally Left Blank-

Originally, the raw water intake pump station caisson was to be constructed with a finished floor at an elevation of approximately 24.0 ft (NGVD29). However, during construction, groundwater was hit before the desired elevation was reached, so the finished caisson floor was built at an elevation of 34.0 ft. With this, the intake pipeline was required to have two 45-degree fittings to reach the bottom of the river. To confirm the elevation of the caisson, the depth was measured from the top deck to the caisson floor. The depth was 81 feet, which coincides with a caisson floor at elevation 34.0 feet (NGVD29).

Comparing the 500-year flood, 100-year flood, low water elevations, and WRWTP construction record drawings to the most recent FEMA maps and to the hydrologic model confirmed that NGVD 29 was used for vertical control.

While low-flow conditions would typically correlate with low water elevations, the Willamette River elevation by the WRWTP intake is artificially raised during the summer, from July through August. As part of Portland General Electric (PGE) operations at the Willamette Falls Dam, the upstream water surface is elevated nominally 1.5 feet by inserting 18-inch flashboards. The reliable summer increase in river elevation observed from 2008 to 2015 coincides with PGE’s Federal Energy Regulatory Commission (FERC) 2005 license conditions and publication of the 2008 Willamette River Biological Opinion.

This elevation information was used to develop the computational fluid dynamic (CFD) model for the caisson and raw water pumps to evaluate hydraulic capacity. Intake piping and screen head losses at different flows were calculated and provided by screen manufacturers. Table 5.1 summarizes the elevation and resultant static water column depth in the caisson. As indicated in the table, the caisson maintains a high static water level even when the river is at minimum levels. Head loss information at varied flows and corresponding dynamic water column depths were evaluated for the WWSP RWF project (B&V, 2017).

Table 5.1 WRWTP Caisson and Willamette River Elevations

	Unit	NGVD 29	NAVD 88	Static Water Column
Raw Water Intake Caisson (finished floor)	feet	34.0	37.5	-
Willamette River Minimum Level (September-June)	feet	52.5	56.0	18.5
Willamette River Minimum Level (July-August 95% flow exceedance)	feet	54.0	57.5	20.0

5.3 Hydraulic Assessment

A hydraulic model of the WRWTP was developed in Carollo’s Hydraulix® software to compare water surface elevations in the treatment train at 15 mgd and 20 mgd to determine the feasibility of an interim expansion using the existing WRWTP infrastructure. The model also includes 10 percent internal recycle flow through the Actiflo®, Ozonation, and filter systems. The primary metric for feasibility of expansion in this analysis was flooding of control weirs in key process areas, but pipeline velocities and head losses were also considered.

The City’s WRWTP record drawings were used to develop the hydraulic model from the inlet of the Actiflo® basins to the Filter Control Weir. Weir crest elevations were obtained from Sheet G-6 and verified from structural details. General dimensions of process areas were obtained from the structural and mechanical drawings. All piping and fittings between process areas were

incorporated into the model from yard piping and mechanical drawings. Major and minor losses for piping were calculated using the Darcy-Weisbach equations. The modeling approach used for each of the three major process areas is described below and the hydraulic calculations are presented in Appendix A.

An analysis was conducted to define the impacts of increasing the maximum flow of each Actiflo® basin from 7.5 mgd to 10 mgd. The analysis of the WRWTP treatment trains included a hydraulic model of each tank and the launder system. The analysis concluded that water surface elevations through the trains would rise slightly with higher flow rates, but that head loss across the entire treatment train would not increase substantially. The results of this analysis were included in the hydraulic calculations as a total head loss and linear interpolation was used to identify head loss at flows not included in the analysis, such as the impact of a 10 percent recycle on the treatment trains.

The ozone system was modeled as two trains consisting of serpentine systems of four contactor over/under baffles with control weirs on either end. Increasing the flow through these contactors is anticipated to have minimal impact on the overall hydraulics. The head loss increase of less than one inch was observed from the maximum flow increase from 7.5 to 10 mgd.

The WRWTP's filters are operated in a constant head mode. Under this operation, a downstream control valve is used to throttle flow through the operating filters, with highest filter rates occurring when one filter is down for backwashing (i.e., when three out of four are operating). In this evaluation, the clean bed head loss was evaluated and compared to the maximum acceptable water surface elevation in the filters (145.65 feet) to determine the amount of head available for solids accumulation during operations. The hydraulic model indicated that the clean bed head loss is 1.97 feet at 15 mgd and 2.69 feet at 20 mgd. Therefore, the head available to solids accumulation is approximately 9.34 feet at 20 mgd, a reduction of 1.52 from the available head at 15 mgd. This decrease in solids accumulation capacity is not expected to impact plant operations as the City's filters are typically operated a minimum of 24 hours before requiring backwashing under normal conditions.

To verify the hydraulic profile, the results from the hydraulic analysis modeled with 15 mgd WRWTP flow were compared to the data obtained during plant start-up and from the initial design of the facility. Some small differences were observed in the record drawings compared to the hydraulic model, but were not considered to be significant. The hydraulic profile of the 20 mgd capacity expansion (including model results from 15 mgd flow) is shown in Figure 5.2.




Figure 5.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity

-This Page Intentionally Left Blank-

5.4 Equipment Assessment

An assessment of the existing plant facilities was included to determine how equipment replacement would be included in the 20-year planning horizon. This evaluation was used to identify likely equipment replacement periods in order to ensure continued successful operation. The equipment assessment was performed using two methods: (1) Veolia's equipment database management system; (2) Plant staff input.

Veolia maintains a database of WRWTP equipment that includes cost, service life, installation date, and estimated service life remaining. The database output was modified to exclude equipment costing less than \$10,000, electrical equipment (evaluated separately), and infrastructure. Following this modification, the remaining equipment service life was reviewed to identify the replacement period. This was then compared to the planned capacity expansions to identify when service life expiration would coincide with capacity increases requiring equipment upgrades. Equipment with a service life expiration that did not coincide with a capacity expansion were identified for replacement (either "in-kind" or upgraded) during an interim project. A copy of the Veolia Equipment Database is included in Appendix A.

Review of the plant equipment database was supplemented with plant staff interviews to identify equipment issues not included in the database. Staff interviews identified issues with performance, obsolescence, serviceability, and similar issues that indicate equipment replacement may be necessary sooner than is indicated by its service life. Additionally, the interviews were used to verify the evaluation of Veolia's Equipment Database to ensure plant staff agreed with the approach and results. Results of this discussion were documented in meeting minutes, included in Appendix A.

5.5 Electrical Assessment

The electrical assessment was conducted to evaluate the current status of the system and identify any upgrades or improvements that would be necessary for the planned capacity expansions. An initial site visit was performed to discuss the electrical system with plant staff and compare existing conditions to as-built drawings, solicit maintenance and operations observations, and identify outstanding issues. As-built one-line drawings were supplemented by reviewing MCC loads and photographing equipment name plates. Calculations were developed using this information to evaluate the connected and operating loads on the electrical distribution system. These calculations considered both existing loads and potential future loads to identify potential equipment or capacity deficiencies.

5.5.1 Evaluation Results

The power distribution system is a single-ended, simple radial system with a 15-kilovolt (KV) outdoor main switchgear (MS) receiving power from Portland General Electric (PGE) and distributing it to downstream switchboards.

New 15-KV feeder fuse sections can be added to the existing MS to allow expansion of this gear, however, the switchgear may not be upgradeable to a double-ended (main-tie-main) configuration because the location of existing feeder fuses may prevent extension of switchgear bus to the west. Using a double-ended switchgear along with redundant substation transformers will provide additional reliability and redundancy while also providing ease of maintenance.

Two existing outdoor liquid-filled unit substation-type transformers (T-1 and T-2) transform utility 12.47-KV voltage from MS to lower distribution voltages of 4.16-KV and 480-V at the two downstream distribution equipment locations.

- T-1 provides power to the medium-voltage (5KV) switchgear 17-MVMCC-A, which feeds three 500-hp high service pumps. It is an outdoor, liquid-filled primary unit substation type transformer with neutral resistance grounding, 65 degrees Celsius (C) temperature rise, rated OA (1,500 KVA)/FFA (1,725 KVA). OA rating is a transformer's normal liquid (oil) cooled rating and FFA is the Future Forced Air cooled rating, which means the rating of T-1 would increase from 1,500 KVA to 1,750 KVA if a fan cooling option is provided in the future. Therefore, the existing maximum continuous rating of T-1 is 1,500 KVA, or 208 amps at 4,160 V.
- T-2 provides power to the low voltage (480 volt [V]) switchboard 17-SWBD-A, which feeds two 200-hp raw water pumps and several distribution motor control centers (MCCs). It is an outdoor liquid-filled secondary unit substation type transformer with a 65 C temperature rise, rated OA (2,000 KVA)/ FFA (2,300 KVA). The existing maximum continuous rating of T-2 is 2,000 KVA, or 2,405 amps at 480 volts (V).

Table 5.2 shows the 100 percent and 80 percent rated capacity of all major electrical distribution equipment and transformers in the existing plant and current operating load demands on each equipment for 15 mgd plant flow condition. Based on standard engineering design guidelines, electrical distribution equipment and transformers should be loaded to approximately 80 percent of their capacity with 20 percent spare capacity reserved for future loads or unpredicted overload conditions. Hence, the available capacity values shown are based on comparison with 80 percent equipment rating values.

Table 5.2 WRWTP Electrical Load Summary

Equipment	Voltage	100% Capacity (Amps)	80% Capacity (Amps)	80% Capacity (KVA)	Existing Demand (Amps)	Existing Demand (KVA)	Available Capacity (Amps) ⁽⁴⁾	Available Capacity (KVA) ⁽⁴⁾
Main Switchgear "MS"	12.47 KV	600	480	10,368	168	3,629	312	6,739
XFMR T1	4.16 KV	208	166	1,200	210	1,513	(44)	(313)
17-MVMCC-A	4.16 KV	208 ⁽¹⁾	166	1,200	210	1,513	(44)	(313)
XFMR T2	480 V	2,405	1,924	1,600	2,543 ⁽³⁾	2,114	(619)	(190)
17-SWBD-A	480 V	2,405 ⁽²⁾	1,924	1,600	2,543 ⁽³⁾	2,114	(619)	(190)
15-MCC-A	480 V	1,200	960	798	491	408	469	398
13-DP-A	480 V	800	640	532	116	96	524	436
8-MCC-A	480 V	600	480	400	36	30	444	370
6-MCC-A	480 V	600	480	400	137	114	343	286
4-MCC-A	480 V	600	480	400	62	52	418	348
2-MCC-A	480 V	600	480	400	11	9	469	391

Table 5.2 WRWTP Electrical Load Summary (Continued)

Equipment	Voltage	100% Capacity (Amps)	80% Capacity (Amps)	80% Capacity (KVA)	Existing Demand (Amps)	Existing Demand (KVA)	Available Capacity (Amps) ⁽⁴⁾	Available Capacity (KVA) ⁽⁴⁾
Standby Equipment								
GEN1	480 V	1,500	1,200	998	1,222	1,016	(22)	(18)
19-MCC-A	480V	600	480	400	156	130	324	270
15-SWBD-B	480 V	2,000	1,600	1,330	1,222	1,016	378	314
13-DP-B	480 V	800	640	532	439	365	201	167
6-DP-B	480V	100	80	67	0 ⁽⁵⁾	0 ⁽⁵⁾	80	67
4-MCC-B	480 V	600	480	400	168	140	312	260
2-DP-B	480V	100	80	67	11	69	56	58

Notes:

- (1) 3,000-amp capacity. Limited by transformer T1 to 208 amps.
- (2) 3,000-amp capacity. Limited by transformer T2 to 2,405 amps.
- (3) Values retrieved from as-built one line drawings, which indicate the transformer and switchboard are overloaded.
- (4) Based on 80-percent capacity.
- (5) Load information not available.

Existing demand values were obtained from as-built drawings. Numbers in parentheses indicate negative capacity or under-rated equipment. In particular, existing demand values for switchboard 17-SWBD-A are too large, resulting in negative available capacity values, and suggesting the equipment may be overloaded or under-rated. Existing demand values for switchgear 17-MVMCC-A indicates the switchgear is operating at maximum capacity.

Calculations shown in Appendix A indicate the existing standby generator can provide power to all existing standby demand loads connected to switchboard 15-SWBD-B. The values in this evaluation should be field verified during design when the WRWTP is expanded.

5.5.2 Recommendations

Some of the main electrical equipment in the electrical system are loaded above 80 percent of listed capacity and are considered overloaded. Additionally, the existing emergency generator is not connected to all WRWTP equipment (e.g., it is wired only to Actiflo® Basin 2) and has sufficient capacity to power only the 4 mgd raw and finished water pumps.


Figure 5.3 shows the existing electrical load distribution configuration (at 15 mgd). Figure 5.4 depicts the existing electrical configuration and overloaded equipment following the 20-mgd WRWTP expansion if no improvements are provided for the plant's electrical infrastructure.

Based on the evaluation of the existing electrical system configuration and anticipated plant process upgrades, the 2017 MPU recommend that the existing electrical distribution system be upgraded under the 20-mgd expansion. The recommended upgrades will provide a more robust and reliable system along with ease of maintenance for plant staff. The following upgrades are recommended:

- **Switchgear Replacement:** Replace the existing single-ended 15-KV switchgear with a new double-ended main-tie-main type 15-KV metering switchgear, which would be sufficient to power the WRWTP through 60 mgd.
- **Transformers:** Provide redundant 5KV and 480V transformers for redundancy.

- **Emergency Generator Replacement:** Replace with a 2-MW generator wired directly to the 15-KV metering switchgear. This will allow all plant equipment to be run on the emergency generator.
- **Plant Re-wiring:** Connect all finished water pumps to the 5-KV transformer/switchgear, leaving sufficient capacity on the remaining transformers to power the rest of the plant.

Figure 5.5 depicts the electrical system following the improvements recommended above for the 20 mgd capacity expansion. These improvements lay the foundation for simple, low-risk expansion(s) in the future (for 30 mgd and beyond). Figure 5.6 illustrates the ease of adding future pumps and loads to the upgraded electrical system for the 30 mgd expansion. Note that Figures 5.3 through 5.6 are diagrammatic in nature and do not show the individual transformers or switchgears. A complete one-line diagram should be included during the design phase to depict the new and existing equipment.



Note 1:
 1,016KVA (813KW or 1,222A) of standby load is calculated based on electrical load study.
 1,110KVA (888KW or 1,335A) is based on standby load assumptions for 6MGD.
 1,529KVA (1,223KW or 1,839A) is based on standby load assumptions for 10MGD.


Not all standby loads have access to standby generator.

15 MGD CAPACITY

LEGEND

XXXXX	Existing Electrical Equipment
XXXXX	New Electrical Equipment
XXXXX	Overloaded Electrical Equipment
XXXXX	Standby Loads Connected to EGEN
XXXXX	Standby Loads Not Connected to EGEN

Figure 5.3 Current Electrical Load Distribution Diagram



Note 1:
Replace 100HP RW pump with new 200HP RW pump.

(E) 300HP FW pump #4 removed.

Note 2:
It appears there is available space in the existing gear to add the new pump 500HP FW pump. However, this needs to be confirmed by review of shop drawings and/or opening the equipment. The new 500HP FW pump #4 can be added since it will be redundant and not operate with the three existing FW pumps. In addition, none of the FW pumps will have access to standby generator with this option.

Connecting the new 500HP FW pump here does not facilitate or support the 30MGD electrical system upgrade. There will be an additional cost in 30MGD upgrade to move this pump to the new switchgear.

However, installation of the new switchgear and generator proposed in 30MGD scenario is recommended at this time to remedy shortcomings listed in this and other notes on this page.

Note 3:
Estimated standby load for 20MGD upgrade (10MGD standby) is 1,900HP or approximately 1,900KVA, which is about 1,520KW based on assumed PF of 0.8. Therefore, the existing Generator is too small and needs to be replaced.

Note 4:
Ozone generator upgraded from 100HP to 140HP, difference of 40HP (48A) added to equipment.

20 MGD CAPACITY

LEGEND

XXXXX	Existing Electrical Equipment
XXXXX	New Electrical Equipment
XXXXX	Overloaded Electrical Equipment
XXXXX	Standby Loads Connected to EGEN
XXXXX	Standby Loads Not Connected to EGEN

Figure 5.4 Existing Electrical System – 20 mgd Capacity





Figure 5.5 Upgraded Electrical System – 20 mgd Capacity



Note 1:
Three new 700HP (97A) FW pumps installed in this upgrade.
Two new 400HP (56A) RW pumps installed in this upgrade.

Estimated standby load for 30MGD (15MGD standby) upgrade is 2,076HP or approximately 2,076KVA, which is 1,981KW based on assumed PF of 0.8. The 2,000KW standby generator installed in the 20MGD upgrade is adequate to support the standby load requirements of 30MGD (15MGD standby) upgrade.

Note 2:
500HP FW pump installed in 20MGD upgrade.

One (E) 500HP (72A) FW pump will remain connected to this equipment. Recommend moving power feed to this pump to the new switchgear so that the equipment can be demolished.

Note 3:
Only one (E) 500HP (72A) FW pump will remain connected to 17-MVMCC-A and XFMR-T1 at this time. This pump can be rewired to be connected to the new 5KV switchgear as shown to allow demolition of 17-MVMCC-A and XFMR-T1.

Note 4:
Two (E) 200HP (240A) RW pump removed.

Note 5:
New 140HP (168A) Ozone Generator #4 added to 13-DP-A.

Note 8:
Equipment can be demolished by implementing work described in note 3 and feeding XFMR-2 from the new 15KV switchgear. (optional)

LEGEND

XXXXX	Existing Electrical Equipment
XXXXX	New Electrical Equipment
XXXXX	Overloaded Electrical Equipment
XXXXX	Standby Loads Connected to EGEN
XXXXX	Standby Loads Not Connected to EGEN

30 MGD CAPACITY

Figure 5.6 Upgraded Electrical System – 30 mgd Capacity

5.6 Seismic Evaluation and Mitigation Alternatives

5.6.1 Oregon Seismic Requirements

Seismic design and construction of Oregon structures is governed by a series of statewide building codes dating back to when the first code was adopted in 1974. That code, called the State of Oregon Structural Specialty and Fire and Life Safety Code (OSSC), incorporated the 1973 Uniform Building Code (UBC).

Based on the OSSC, all of Oregon was deemed to be in Seismic Risk Zone 2, meaning structures sustaining moderate damage in a seismic event are equivalent to intensity VII on the Modified Mercalli Scale (M.M.) and carry a 0.5 multiplier in the formation. An intensity of VII was defined as *Damage negligible in buildings of good design and construction; slight to moderate in well-built ordinary structures; considerable damage in poorly built or badly designed structures; some chimneys broken. Richter Scale Magnitude (RM) = 6.1.*

In 1976, a second statewide building code was adopted using the 1976 UBC. The Seismic Risk Zone for Oregon did not change, but the multiplier factor was changed to 0.375. The statewide building codes were subsequently modified in 1979 and 1985; however, the modifications had little or no effect on the seismic design criteria.

A significant shift occurred in the 1988 UBC (1990 OSSC) when the Seismic Risk Zone in Oregon was designated 2B. By adopting the 1991 UBC (1993 OSSC), additional significant changes in treating and analyzing seismic loading occurred. Counties west of the Cascade Mountains were designated Seismic Zone 3, and those east of the Cascades were designated Seismic Zone 2.

When the 1994 UBC (1996 OSSC, amended in 1998) was adopted, the seismic design criterion remained the same, but the tables delineating Occupancy Categories and Seismic Importance Factors were enhanced to provide more-intense design values for higher risk, important, and essential facilities. The overall seismic design values for loading did not increase under this code adoption; however the code considered the facilities' proximity to known seismic faults and the site's soils conditions. This code cycle revised the seismic zone mapping along the southern Oregon coast, upgrading it to Seismic Zone 4. The rest of the state remained at the previous zones. The 1998 OSSC remained in force for roughly six years with very few seismic-related revisions.

In 2004, the state of Oregon moved from the Uniform Building Code to the International Building Code (IBC) and adopted the amended 2003 International Building Code as the 2004 Oregon Structural Specialty Code. The IBC upgraded its design parameters by requiring design to a 2,500-year return period earthquake instead of the 500-year return period earthquake required by previous UBC codes.

The change to the IBC code was a substantial shift in earthquake regulations and in determining seismic base shear. The new formulation used very specific site characteristics and required specific latitude and longitude in conjunction with the United States Geological Survey (USGS) soils/ground response information. Advances in technology allowed for using spectral response acceleration for short and one-second periods and soil definitions that accounted for shear waves, penetration resistance, and shear strength of soils.

In addition, the Seismic Use Group was established, a modification of the previous Seismic Importance Factor. Types of structural systems were expanded considerably and, when used with the revised base-shear formulation, gave very site-specific seismic loading. The net result of

the new technology and more precise method of loading determination was an overall lowering of the seismic base-shear forces.

In 2007, the 2006 IBC was adopted with modifications. The 2009 IBC was adopted as the 2010 Oregon Structural Specialty Code and was carried forward from the previous code cycle with little change for earthquake design.

With the building codes' evolution over the years, substantially safer buildings are being constructed in the state of Oregon. The most recent codes have minimum design standards to maintain public safety during an earthquake's extreme ground shaking. Requirements are geared toward safeguarding against major failures and loss of life, not just limiting damage, maintaining function, or providing for easy repair.

Buildings that house essential facilities will have a greater level of protection because additional expenditures will make the facilities more stable. A structure's ability to resist earthquake ground-motion depends on many factors:

- Distance to the earthquake's epicenter,
- Type and location of the fault,
- Type of soil structure the building is sited on, and
- Type and quality of the building's construction.

For the original Willamette River Water Treatment Plant, the 1998 OSSC was the enforceable building code at the time. The 1998 OSSC required a structure's seismic design to meet a Seismic Zone 3 with a seismic event equivalent to intensity VII and corresponding to a Richter Scale Magnitude (RM) of 6.1. Since then, much more about the Cascadia Subduction Zone seismic event has become understood, an understanding that has heavily influenced subsequent building codes. The Oregon Resilience Plan (ORP) further assessed and determined that water systems built after the year 2000 have "stringent lateral force requirements" and are "likely to remain intact" after a large Cascadia Subduction Zone earthquake.

5.6.2 Geotechnical Investigation Summary

Shannon & Wilson prepared the Geotechnical Report for the WRWTP Lower Site and Upper Site (S&W, 2015), found in Appendix H of the 2015 MPU. This 2017 MPU summarizes the conceptual geotechnical engineering evaluations and recommendations and includes a seismic evaluation of the major existing process structures. This information can be used in future expansions and to develop potential mitigation alternatives. Appendix H also includes supplemental recommendations for the raw water pump station caisson mitigation.

5.6.3 Seismic Evaluation of Existing Facilities

A seismic and structural evaluation was performed for the WRWTP's existing facilities. The plant was designed to comply with the enforceable building code at the time--the 1998 Oregon Structural Specialty Code. The 1998 OSSC required seismic design to meet a Seismic Zone 3 with a seismic event equivalent to intensity VII and corresponding to an RM of 6.1.

5.6.3.1 Evaluation Approach

The existing facilities were structurally evaluated using American Society of Civil Engineers (ASCE) 41-13 for buildings and ASCE 7-10, ACI 350.3-06, and ACI 350-06 for the caisson and tanks. Seismic forces (hydrodynamic forces) were calculated using ASCE 7-10, Chapter 15. The

seismic response spectral accelerations for tankage, S_{DS} and S_{D1} , were based on data provided by Shannon & Wilson (S&W, 2015). The seismic response spectral accelerations for buildings, S_{XS} and S_{X1} , were based on 2008 seismic hazard data published by the United States Geological Survey (USGS).

5.6.3.2 Evaluation Results

Table 5.3 summarizes the structural retrofit requirements. Appendix B includes a technical memorandum (TM) detailing the evaluation parameters and calculations.

5.7 Life Safety Evaluation

In conjunction with the seismic assessment, life safety at the WRWTP was assessed. Table 5.4 summarizes the findings and includes seismic vulnerabilities that are potential life safety hazards. Where building code provisions and standards are applicable, the relevant sections are noted. Photographs in Appendix B illustrate the identified issues.

5.8 Transient Surge Analysis

For this 2017 MPU, a transient analysis was performed on the finished water pumping and delivery system to confirm the findings of *Hydraulic Transient Analysis – City of Wilsonville* (MWH, 2011). The 2011 analysis evaluated numerous scenarios with WRWTP flow rates up to 15 mgd. Modeling results led to a recommendation that a minimum 750-cubic foot (CF) (5,600 gallon) surge tank be located at the WRWTP. The surge tank would prevent negative pressure formation in the distribution system if power were lost at the WRWTP when Wilsonville demand exceeds 10 mgd or combined Wilsonville and Sherwood demands exceeds 12.5 mgd.

5.8.1 Evaluation Methodology

The City of Wilsonville's 2017 Innowyze Infowater hydraulic model was used for this hydraulic transient analysis. Based on discussions with the City of Wilsonville, the *2011 MDDW48, Existing Demand with Priority 1 Improvements* model scenario was used for the analyses in the demand scenarios shown in Table 5.5. In addition, the model was used to determine if a surge tank is required assuming no Sherwood demand. Table 5.5 summarizes the demand scenarios. Note that WRWTP currently operates at demands up to Scenario 3.

Table 5.3 Summary of Seismic Vulnerabilities

ID	Location	Description	Reference	Recommendation	Priority ⁽¹⁾
S1	Waste Washwater Equalization	The horizontal reinforcing steel in the north and south basin walls at the east corners (#8 @ 12" oc) have a demand to capacity ratio (DCR) of 1.53 for soil seismic loads..	ACI 350.3-06	Install three (3) concrete braces across the width of the basin with intermediate column support as required to brace the north and south walls. Braces should be located at the mid-height of the wall.	L ⁽²⁾
S2	Waste Washwater Equalization	The out-of-plane wall shear at the north and south walls where the existing concrete beam below the east wall of the building intersects the walls has a DCR of 1.67 for soil seismic loads.	ACI 350.3-06	Install three (3) concrete braces across the width of the basin with intermediate column support as required to brace the north and south walls. Braces should be located at the mid-height of the wall.	L ⁽²⁾
S3	High Service Pump Station	The roof joist wall anchorage along the east and west walls of the pump station have a DCR of 1.55.	ASCE 41-13, Tier 1	Add new wall anchorage along the east and west walls midway between the existing roof joists.	H
S4	High Service Pump Station	The roof diaphragm shear capacity is exceeded at approximately 50% of the roof deck area with DCR's that vary from 1.82 to 2.25.	ASCE 41-13, Tier 1	Replace existing deficient deck sections with 16 GA corrugated steel decking.	H
S5	High Service Pump Station	The tension capacity of the diaphragm chord at the pump room has a DCR of 1.20 at the connections at the east windows	ASCE 41-13, Tier 1	Strengthen the existing chord connections as required.	M
S6	High Service Pump Station	Roof deck shear transfer to the interior wall ledger bolts have DCR's of 3.20 to 3.90.	ASCE 41-13, Tier 1	Add a new top plate over the interior shear walls and install epoxied anchors as required.	H ⁽³⁾
S7	Solids Dewatering Building	The building has no lateral load resisting system in the transverse direction at the first floor level. The existing concrete joint at the elevated slab to the east and west walls does not have any seismic detailing to establish any concrete moment frame.	ASCE 41-13, Tier 1	Provide steel braced frames at the exterior of the building at the east side that brace the building at the second floor level. This system is anticipated to include three braces, each with its own concrete grade beam. It is assumed that the existing stair will need to be relocated to the west side of the building.	H

Table 5.3 Summary of Seismic Vulnerabilities (Continued)

ID	Location	Description	Reference	Recommendation	Priority ⁽¹⁾
S8	Solids Dewatering Building	The roof joist wall anchorage along the east and west walls of the building have a DCR of 1.17.	ASCE 41-13, Tier 1	Add new wall anchorage along the east and west walls midway between the existing roof joists.	M
S9	Solids Dewatering Building	The foundation elements do not have adequate ties across the building, as the floor slab is not connected to the walls or the footing.	ASCE 41-13, Tier 1	Tie the existing floor slab to the walls, which are already doweled to the existing footings. The retrofit is anticipated to include stainless steel angles and epoxy anchors.	M
S10	Various (estimated at 8 locations)	The space heaters at all facilities are laterally braced above their center of gravity, which allows the heaters to sway during an earthquake. The space heaters at the Switchgear Room at the High Service Pump Station are not braced at all.	ASCE 41-13, Tier 1	Provide seismic bracing.	H
S11	Ozonation	The ozone destruct piping located on the top deck of the Ozonation basin is not seismically braced.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipe down to the concrete deck.	M
S12	High Service Pump Station	The cable trays lack longitudinal seismic bracing.	ASCE 41-13, Tier 1	Provide longitudinal seismic bracing of the cable trays.	M
S13	Chemical Storage / Ozone Generation Room	The chemical pipes that run through the center of the Chemical Storage Room are not seismically braced. The balance of the chemical pipes in the Chemical Storage Room and Ozone Generation Room lack longitudinal seismic bracing.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	M
S14	Ozone Generation Room	The ozone and LOX piping is not seismically braced.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	M

Notes:

1. H = High, M = Medium, L = Low.
2. The same mitigation recommended for vulnerability S1 will address S2.
3. Assumes that vulnerability S4 is addressed simultaneously; otherwise the cost will need to include removal/replacement of the roofing.

Table 5.4 Summary of Life Safety Findings

ID	Location	Description	Code Reference	Recommendation	Priority ⁽¹⁾
LS1	Various	Tread plate hatches do not typically have any provisions for installing temporary fall protection barriers when in use.	OSHA 1910.23	Install sleeves or other hardware for temporary fall protection systems around hatches.	H
LS2	Various	Color coded chemical safety warning signs at exterior locations are faded so that colors are no longer clear.	2014 OFC (NFPA 704)	Replace safety signs throughout the plant as required.	H
LS3	Actiflo® / Ozonation / Filters	Exterior stair guardrail height is less than 42 inches above the stair tread and has no dedicated handrail. Installation met 1997 UBC provisions but not current code.	2014 OSSC, Chpt 10	Replace guardrail with current code-compliant installation.	M
LS4	Actiflo® / Higher Service PS / Chemical Storage	Doors exiting rooms with rated electrical service of 1,200 amps or greater do not have panic hardware.	2014 OSSC, Chpt 10	Provide panic door hardware on 4 affected doors.	H
LS5	Ozone Generation / Chemical Storage	Doors serving occupancy Group H are lacking panic hardware. Also, the door that connects the Ozone Generation Room to the Administration Building swings into the Ozone Generation Room, which is a Group H occupancy.	2014 OSSC, Chpt 10	Provide panic door hardware on 3 doors and replace the door between the Ozone Generation Room and the Administration Building to reverse the door swing direction.	H
LS6	Ozone Generation / Chemical Storage	Chemical piping passes directly over exit egress routes at the southwest door of the Ozone Generation Room, the east door of the Chemical Room, and the west door of the Chemical Room.		Add secondary containment pans below the chemical piping over exit routes.	M
LS7	Various	Doors were found propped open during the site visit, which suggests that the ventilation in the rooms may not be operating effectively and/or efficiently.		Verify that the ventilation system is operating as intended.	L
LS8	Actiflo® / Filters	The west guardrail on the top deck of the Actiflo® Basin and the top side of the ladder pit at the filters lack kickplates.		Install new kickplates at these locations.	L
LS9	Actiflo® / Ozonation / Filters	The below-grade galleries have active weeping leaks coming from cracks in the tank walls and through expansion joints, making the floor wet and potentially slippery.		Pressure inject a hydrophobic sealant into active leaks to seal them. Apply an exterior (negative side) waterstop on the surface of the joint.	M

Table 5.4 Summary of Life Safety Findings (Continued)

ID	Location	Description	Code Reference	Recommendation	Priority ⁽¹⁾
LS10	Actiflo® / Ozonation / Filters	The below-grade galleries typically have wet floors due to leaking walls and leaking pipes/equipment. The electrical receptacles do not appear to have any GFCI protection.		Remove and replace the electrical receptacles with ones that are GFCI protected.	M
LS11	Ozonation	The south stairwell does not have a dedicated ventilation system that serves it directly.		Investigate if ventilation is sufficient and provide as required.	M
LS12	Filters	The maximum distance of travel to exit the north door is approximately 85 feet. The maximum distance to a single exit per the building code is 75 feet. The doors at the east end of the Filter Gallery exit to a ladder pit, which is not considered an exit for egress determination.	2014 OSSC, Chpt 10	Add a fire-rated door at the bottom of the stairs and add signage to the existing ladder pit door to clarify that it is not an exit. This may also require revision to the ventilation of the existing stair.	M
LS13	Waste Washwater	The ladder into the basin does not have any permanent tie-off points for a fall restraint system.		Verify how fall restraint is provided when using the ladder and provide additional hardware as required.	M
LS14	Sludge Dewatering	The building roof does not appear to have any overflow scuppers.	2014 OSSC, Chpt 15	Saw-cut a notch in the parapet wall and install a scupper and downspout.	L
LS15	Ozone Generation Room	The emergency shut-off switch for the ozone generation equipment is located between the sensor and the generation equipment.		Install emergency shut-off switch at two other exits from the building.	M
LS16 (S4)	High Service Pump Station	The roof diaphragm shear capacity is exceeded at approximately 50% of the roof deck area with DCR's that vary from 1.82 to 2.25.	ASCE 41-13, Tier 1	Replace existing deficient deck sections with 16 GA corrugated steel decking.	H
LS17 (S6)	High Service Pump Station	Roof deck shear transfer to the interior wall ledger bolts have DCR's of 3.20 to 3.90.	ASCE 41-13, Tier 1	Add a new top plate over the interior shear walls and install epoxied anchors as required.	H ⁽²⁾

Table 5.4 Summary of Life Safety Findings (Continued)

ID	Location	Description	Code Reference	Recommendation	Priority ⁽¹⁾
LS18 (S7)	Solids Dewatering Building	The building has no lateral load resisting system in the transverse direction at the first floor level. The existing concrete joint at the elevated slab to the east and west walls does not have any seismic detailing to establish any concrete moment frame.	ASCE 41-13, Tier 1	Provide steel braced frames at the exterior of the building at the east side that braces the building at the second floor level. This system is anticipated to include three braces, each with its own concrete grade beam. It is assumed that the existing stair will need to be relocated to the west side of the building. Refer to	H
LS19 (S10)	Various (estimated at 8 locations)	The space heaters at all facilities are laterally braced above their center of gravity, which allows the heaters to sway during an earthquake. The space heaters at the Switchgear Room at the High Service Pump Station are not braced at all.	ASCE 41-13, Tier 1	Provide seismic bracing.	H
LS20 (S13)	Chemical Storage / Ozone Generation Room	The chemical pipes that run through the center of the Chemical Storage Room are not seismically braced. The balance of the chemical pipes in the Chemical Storage Room and Ozone Generation Room lack longitudinal seismic bracing.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	M
LS21 (S14)	Ozone Generation Room	The ozone and LOX piping is not seismically braced.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	M

Notes:

(1) H = High, M = Medium, L = Low.

(2) Assumes that vulnerability S4 is addressed simultaneously; otherwise the cost will need to include removal/replacement of the roofing.

Table 5.5 Hydraulic Transient Analysis Demand Scenarios

Scenario	WRWTP Flow Rate (mgd)	Wilsonville Demand (mgd)	Sherwood Demand (mgd)
1	12.5	12.5	0
2	15	15	0
3	15	10	5
4	20	15	5
5	25	17.5	7.5
6	30	22.5	7.5

5.8.2 Evaluation Results

For Scenarios 3 through 6, a hydropneumatic tank is recommended to mitigate the downsurge in the finished water piping system due to a power failure at the WRWTP. Recommended tank sizes for each scenario are listed in Table 5.6. For each scenario, model runs varied tank volume, air volume, and size of the connecting pipe until an optimized solution was reached.

Hydropneumatic tank sizing was evaluated assuming a 24-inch diameter pipe connected to the upstream end of the FWPS discharge header and air volume at 50 percent of the total volume. Table 5.6 summarizes the findings of the analysis. Appendix C includes a TM detailing the evaluation approach and transient analysis findings.

Table 5.6 Hydropneumatic Tank Sizing Recommendations

Scenario	WRWTP Flow Rate (mgd)	Wilsonville Demand (mgd)	Sherwood Demand (mgd)	Minimum Tank Size (CF)
1	12.5	12.5	0	N/A ¹
2	15	15	0	N/A ¹
3	15	10	5	750
4	20	15	5	1,000
5	25	17.5	7.5	1,250
6	30	22.5	7.5	1,500

Notes:

(1) Scenario was evaluated to determine maximum demand before surge mitigation is recommended.

5.8.3 Recommendations

Modeling confirmed the following results from previous studies: a hydropneumatic tank located at the WRWTP is recommended when the demand approaches 15 mgd; a 750 cubic foot (CF) hydropneumatic tank is recommended for a WRWTP flow of 15 mgd to meet current demand; and the recommended tank sizing increases by 250 CF with each 5 mgd increase in flow up to 1,500 CF at 30 mgd. Because costs are similar for each scenario, a 1,500 CF surge tank is recommended for the current installation. It will enhance near-term surge protection and eliminate the need for additional construction during the 20 and 30 mgd capacity expansions. Note that the surge tank project is being pursued as a separate construction project outside of the 2017 MPU and therefore is not included in the capital improvement plan (CIP).

Chapter 6

EXPANSION ALTERNATIVES ANALYSIS

6.1 Introduction

This Chapter describes the methodology used to determine the approach to expanding the Willamette River Water Treatment Plant (WRWTP) in increments, starting with a capacity expansion to 20 million gallons per day (mgd) and then to 30 mgd, as well as on-going repair and replacement capital improvement plan (CIP) coordination. For an explanation of alternative capacities for the expansion, the reader is referred to Chapter 2 and Chapter 6 of the 2015 Master Plan Update (MPU). The recommended approach in this chapter covers all existing and future treatment processes at the WRTWP:

1. Raw water pumping.
2. Rapid Mixing.
3. Ballasted flocculation/clarification (Actiflo®).
4. Ozonation.
5. Filtration with a deep bed of granular activated carbon (GAC) over sand.
6. Clearwell/chlorine disinfection.
7. Finished water pumping.
8. Waste washwater recovery.
9. Mechanical solids dewatering.
10. Chemical storage and metering facilities.

6.2 Treatment Technologies

To evaluate treatment processes, Carollo considered the water quality and redundancy/resiliency level of service goals (LOS) summarized in Chapter 2. This included treatment implications, such as the plant's ability to meet current and potential future regulatory MCLs, reduce DBP formation, meet *Cryptosporidium* removal/inactivation requirements, and remove potential contaminants of emerging concern (CECs), pharmaceutical and personal care products (PPCPs), and algal toxins. LOS goals were the basis for determining the overall treatment process redundancy and dictated the procedures a treatment process operates under.

6.3 Confirmation of Treatment Recommendation

In Spring 2016, a Blue Ribbon Panel (BRP) of treatment experts convened to evaluate and confirm the recommended treatment steps in the 2015 MPU. Appendix J of 2015 MPU documents the results of this effort in the *Blue Ribbon Panel Report*.

In summary, the BRP confirmed that the WRWTP's current treatment technologies are the most appropriate for continued treatment of the Willamette River at the expanded WRWTP, with the following provisions for minor process enhancements:

- Advanced oxidation using hydrogen peroxide with ozone.
- Enhanced biological filtration.
- Ultraviolet (UV) irradiation with or without hydrogen peroxide.

Leaving room for these enhancements creates future flexibility at the expanded WRWTP to accommodate and treat any CEC detected in the raw water.

6.4 20 mgd Expansion

As outlined in Chapter 2 and Chapter 6 of the 2015 MPU, expansion of the WRWTP to 20 mgd will rely on up-rating the existing treatment processes rather than installing additional concrete basins and equipment. Up-rating the equipment for the 20 mgd capacity increase (as opposed to constructing new process basins) will reduce plant capital and operating costs for this expansion. Additionally, since the up-rated design criteria will be used to design additional process units for the 30 mgd and future capacity increases, it will also reduce plant capital and operating costs and future expansions.

This section describes the approach used to up-rate the treatment systems and provides any steps required to demonstrate up-rated treatment efficacy. This section also describes any steps necessary to increase equipment redundancy or reliability.

As noted in Section 2.3.4 of this 2017 MPU, the WRWTP will not be able to meet their LOS goal until they construct additional infrastructure that meets the current seismic requirement. Since there is no new infrastructure included in the 20 mgd capacity expansion, WRWTP will not meet their LOS goals through this project.

Table 6.1 (included at the end of Section 6.4) summarizes flow projections, equipment quantities, and equipment sizing for the 20-mgd capacity expansion. This table presents two potential expansion options that can be implemented based on owner and operator preference or equipment performance. Though both options are viable, only Option 1 was included in the expansion cost estimate and CIP.

Figure 6.1 and Figure 6.2 show the site layout and hydraulic profile of the 20-mgd capacity expansion.

6.4.1 Flow Projections

The cities of Wilsonville and Sherwood provided future anticipated peak day flow projections. Projections for minimum and average day flow rates were calculated using the plant's current peak:minimum and peak:average ratios. The minimum and average day projections were then used to evaluate equipment performance and loadings as well as turn-down requirements for raw and finished water pumps, chemical feed facilities, and ozone generation units. Flow projections are listed in Table 6.1.

6.4.2 Raw Water Pumping

Current raw water pumping capacities were evaluated to determine if they can meet the 20 mgd firm capacity, which is the total pumping capacity when largest pump is out of service. Based on the current pump configuration, the raw water pumps provide only 19 mgd firm capacity. Therefore, to meet the firm capacity for the 20 mgd expansion, replacing the 4-mgd, VFD-controlled pump with a larger unit is recommended.

For this capacity analysis and related cost estimate, the pump is assumed to be replaced with a 7.5-mgd, VFD-controlled unit. Because this is a similar size with other installed pumps, it will use the same spare parts and have similar maintenance and operational requirements.

It should be noted that if installing a smaller pump were desired to meet low-demand requirements, a pump as small as 5 mgd would meet the firm capacity requirements. Regardless, improvements to the standby power system will be required, as the existing generator is not capable of meeting the plant's LOS goals.





Figure 6.1 WRWTP Site Layout – 20 mgd Capacity

-This Page Intentionally Left Blank-



twd1016r6-9865 ai



Figure 6.2 WRWTP Hydraulic Profile – 20 mgd Design Capacity

-This Page Intentionally Left Blank-

6.4.3 Flash Mix

The current flash mix system consists of one installed and one shelf-spares pump operating at approximately 10 percent of total plant flow. At the 20 mgd capacity expansion, this system will operate at approximately 7 percent of total plant flow. Since the recommended flash mix rate is 2 to 5 percent of the total plant flow, this system is still sufficiently sized. If installed redundancy is preferred, a permanent shelf-spares pump could be installed. However, it is not entirely necessary because of a potential for chemical addition at the Actiflo® coagulation basin.

6.4.4 Ballasted Flocculation (Actiflo®)

6.4.4.1 System Up-rating

The 2015 MPU evaluated the feasibility of up-rating the Actiflo® process. Though the system is rated at 7.5 mgd per basin as currently designed, it can operate up to 10 mgd per basin without changes to the equipment's size or configuration, which includes the sand recycle pumps. To facilitate the capacity expansion, then, the Actiflo® system will be up-rated to 10 mgd per basin.

6.4.4.2 Equipment Redundancy

For this 2017 MPU evaluation, WRWTP operations staff was interviewed to identify equipment that may need additional redundancy for ideal system performance. For the Actiflo® system, plant operators recommended purchasing an additional "shelf-spares" sand recirculation pump, since these pumps can be difficult to service and parts have a long lead time.

6.4.5 Ozonation and Ozone Generation

6.4.5.1 System Up-rating

The feasibility of up-rating the ozone system was evaluated in the 2015 MPU. The ozonation system operates with both basins in service for a total treatment capacity of 15 mgd, or 7.5 mgd per basin. As mentioned in Chapter 3, the minimum ozone contact time at 15 mgd is 15 minutes when both basins operate and 7.5 minutes when one basin is down for maintenance.

Up-rating the ozone contact basins to 20 mgd will allow for 11 minutes of contact time when both basins are operating, or 5.5 minutes when one basin is down for maintenance. This is still sufficient contact time to meet the 1-log *Cryptosporidium* inactivation goal, as long as higher doses of ozone are maintained. This dose will also achieve the required 0.5-log inactivation of *Giardia* and will serve as the primary disinfection system for the plant. This means that up-rating the basins from 15 mgd to 20 mgd will not affect finished water quality.

To accommodate the increased ozone dosages, the 20 mgd expansion should include the following:

- Conduct tracer study in Finished Water Pump Station clearwell to identify contact time (CT).
- Upgrade ozone diffusers in ozonation basins.
- Replace existing, leased 6,000-gallon LOX storage tank with a new 12,000- to 15,000-gallon tank to ensure sufficient onsite storage. This additional capacity will also suffice for the 30 mgd expansion.
- Install one additional 300 ppd ozone generator for a total of three **OR** replace two existing units with two 400 ppd ozone generators.

6.4.5.2 Equipment Redundancy

No equipment redundancy upgrades are necessary for the ozonation or ozone generation system.

6.4.6 Filtration

6.4.6.1 System Up-rating

As designed, the four filters were rated at 7.5 gallons per minute per square-foot (gpm/sf) with one filter out of service for backwashing, and at 5.7 gpm/sf when all four filters are in service. When one filter was off-line, empty bed contact time (EBCT) through the GAC media was 5.9 minutes. When all filters are operating, it is 7.9 minutes.

The feasibility of up-rating the filtration system was evaluated in the 2015 MPU. Up-rating the filters to 20 mgd will increase the maximum filtration rate to 10 gpm/sf with one filter out of service for backwashing, and 7.5 gpm/sf when all four filters are operating. The EBCT through the GAC media will be 4.5 minutes when one filter is off-line, and 5.9 minutes when all filters are operating.

OHA requires a full year of pilot data to support filter operations exceeding 6 gpm/sf. As documented in Chapter 6 of the 2015 MPU, filtration rates of 10 to 12 gpm/sf have already gained OHA approval at two plants with similar raw water quality: the Lake Oswego-Tigard WTP and the proposed new Grants Pass WTP. Despite these precedents, pilot testing will likely be required to demonstrate to OHA that the increased filtration rate will not adversely affect finished water quality.

To save time and expense, this 2017 MPU recommends the Cities of Wilsonville and Sherwood negotiate a different approach to OHA's pilot filter requirements. Instead of pilot testing, the existing plant would gradually increase its filtration rate (e.g., 0.5 gpm/sf increments for an OHA-specified duration, etc.) and collect treated water data to compare to WRWTP finished water requirements. After successful operation in the first increment of the increased rate, the filtration rate can be increased again and the process repeated until the desired rate is achieved and approved.

6.4.6.2 Equipment Redundancy

No equipment redundancy upgrades are necessary for the filtration system.

6.4.7 Clearwell/Chlorine Disinfection

6.4.7.1 System Up-rating

Chlorine is the primary disinfection approach in the clearwell governed by the inactivation of 0.5-log *Giardia*. However, at summer flows greater than 15 mgd and winter flows exceeding 10 mgd, the existing clearwell cannot reach this disinfection level. This deficiency has been well documented, most recently in the *Willamette River WTP Disinfection (CT) Analysis* (MWH, February 2010).

Moving forward, the cities have two alternatives for meeting the disinfection requirements:

- Install UV disinfection downstream of the existing filters.
- Work with OHA to obtain *Giardia* disinfection credit from the intermediate ozonation system.

The cities have already begun the process of petitioning the state. As a founding member of the Oregon Water Utility Council's (OWUC) Ozone Coalition, Wilsonville is drafting a petition to OHA. Final submission, review, and approval are expected in summer 2018, well before plant production rates exceed the existing clearwell's disinfection capabilities. After receiving OHA approval, the clearwell will simply serve as a wet well for the finished water pump station.

6.4.7.2 Equipment Redundancy

No equipment redundancy upgrades are necessary for the clear well.

6.4.8 Finished Water Pumping

An evaluation of the current pump configuration to find out if the finished water pumps could meet 20 mgd firm capacity showed they can deliver only 19 mgd firm capacity. Therefore, the preliminary 2017 MPU recommendation for the 20 mgd expansion is to replace the 4-mgd, variable-frequency drive (VFD)-controlled pump with a 7.5-mgd, VFD-controlled unit. Since this size is similar to other installed pumps, it will use the same spare parts and have similar maintenance and operational requirements. If the Cities and operations staff want to maintain a smaller pump to meet low-demand requirements, two options exist:

- Replace existing 4 mgd pump with a 5 mgd VFD-controlled pump.
- Install a fifth pump to meet at least 20 mgd firm capacity.

6.4.8.1 Equipment Redundancy

Once firm capacity requirements are met, no additional upgrades are necessary in the finished water pump station.

6.4.9 Waste Washwater Recovery

No modifications are necessary for the waste washwater recovery system for the 20-mgd capacity expansion.

6.4.10 Mechanical Solids Dewatering

No modifications are necessary for the mechanical solids dewatering system for the 20-mgd capacity expansion.

6.4.11 Chemical Storage and Metering

The following modifications are recommended for the 20-mgd capacity expansion:

- **Chemical Piping Replacement:** WRWTP operators say the existing chemical lines and spares have become inoperable during their 15-year operating period. Therefore, we recommend that the 20-mgd capacity expansion include replacing all in-place chemical lines.
- **Utilidor Extension:** To facilitate the current and future chemical line replacements, we recommend extending the existing utilidor to the southern half of the WRWTP. To traverse the waste washwater equalization basin, the chemical pipelines should be installed along the interior western wall to route them to the utilidor.
- **Addition of a Second Dry Polymer System:** WRWTP operators say the existing dry polymer batching system unreliable at times. Since this system is key to successful operation of the Actiflo® system, installing a redundant dry polymer batching system is recommended.

- **Increased LOX Storage:** As mentioned, the existing leased 6,000-gallon LOX storage tank and associated evaporators should be replaced with a larger leased system to ensure sufficient onsite storage at the increased plant capacity.
- **Sodium Hypochlorite Tank Replacement:** One of the two 4,400-gallon tanks installed during plant construction failed during plant operation and was replaced with a 3,900-gallon tank. To prevent unexpected failure of the second tank, the WRWTP should plan to replace the remaining 4,400-gallon original tank with a new tank.
- **Strainers on Pump Suction:** WRWTP operators reported difficulty with pump maintenance due to clogging in the suction line. To avoid this in the future, wye or basket strainers should be installed on chemical pump suction lines.
- **Hypochlorite Vent Return:** WRWTP operators reported concerns with the hypochlorite pump vents off-gassing. To ensure a safe work environment, pump and line vents will be plumbed to return to the hypochlorite storage tanks.

6.4.12 Electrical Upgrades

This section summarizes the recommended electrical upgrades for the WRWTP capacity expansions. See Appendix A for more on the electrical evaluation.

As mentioned in Chapter 5, the electrical system is loaded above 80 percent of listed capacity and is considered overloaded. Additionally, the existing emergency generator is not connected to all WRWTP equipment (e.g., it is wired only to Actiflo® Basin 2) and has sufficient capacity to power only the 4-mgd raw and finished water pumps. The existing electrical configuration (at 15 mgd) is included in Chapter 5. Figure 5.4 depicts the electrical configuration and overloaded equipment following the 20-mgd WRWTP expansion if nothing is done to improve the plant's electrical infrastructure.

Based on these evaluations, this 2017 MPU recommend that the plant upgrade its electrical equipment as part of the 20-mgd expansion project to ensure that an electrical fault does not interrupt service. The following upgrades are recommended:

- **Switchgear Replacement:** Replacing with a 15-KV metering switchgear and 5-KV transformer, which should be sufficient to power the WRWTP through 60 mgd.
- **Emergency Generator Replacement:** Replacing with a 2-MW generator wired directly to the 15-KV metering switchgear. This will allow all plant equipment to be run on the emergency generator.
- **Plant Re-wiring:** Connecting all finished water pumps to the 5-KV transformer/switchgear, leaving sufficient capacity on the remaining transformers to power the rest of the plant.

Figure 5.5 depicts the electrical system following the improvements recommended above for the 20 mgd capacity expansion. These improvements lay the foundation for simple, low-risk expansion moving forward. Figure 5.6 depicts the system improvements recommended to accommodate the 30-mgd expansion.

Note that the recommended improvements are limited to the connection of additional finished and raw water pumps to the 5-KV transformer.

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures

Flow Rate	Units	Option 1	Option 2
Minimum	mgd	3.3	3.3
Annual Average	mgd	6.4	6.4
Maximum (Plant Design)	mgd	20	20
	GPM	13,889	13,889
Willamette River			
Minimum River Level	FT	52.5	--
100 Year Flood Elevation	FT	91.1	--
500 Year Flood Elevation	FT	102.3	--
Intake Screens⁽¹⁾			
Type: Horizontal cylindrical			
Number	#	2	--
Capacity, total	mgd	70	--
Diameter	IN	66	--
Screen Opening Size	mm	1.75	--
Maximum Face Velocity	FPS	0.4	--
Top of Screen Elevation	FT	42.75	--
Screen Cleaning			
Cleaning method: air burst			
Number of Compressors	#	2	--
Compressor Capacity	CFM	200	--
Air receiver volume	CF	2,200	--
Motor Size per compressor	HP	50	--
Raw Water Pumps			
Type: Vertical Turbine, Single-stage			
Number	#	4 (3+1)	--
Total capacity w/ stand-by	mgd	30	--
Firm capacity	mgd	22.5	--
Capacity (each)			
1 VFD Driven pump	mgd	7.5	--
1 VFD Driven Pump	mgd	7.5	--
1 VFD Driven Pump	mgd	7.5	--
1 Constant speed pump	mgd	≥ 7.5	--
Total dynamic head (20 mgd)	FT	111	--
Total motor horsepower	HP	4@200	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Initial Flash Mix			
Type: Pumped			
Number (Installed)	#	1	2 (1+1)
Mixing energy (ea)	s ⁻¹	1,000	1,000
Pump capacity (ea)	gpm	1,000	1,000
Pump flow as a percentage of plant flow rate (PFR)	%	7%	7%
Total dynamic head	FT	16	16
Total motor horsepower (ea)	HP	7.5	7.5
Clarification Process			
Type: Ballasted Flocculation (Actiflo®)			
Number of Basins	#	2	--
Design flow (per basin)	mgd	10	--
Max process hydraulic flow (per basin)	mgd	15	--
Mixing/Flocculation (per basin)			
Coagulation chamber volume	CF	2,000	--
Coagulation chamber HRT	MIN	2.2	--
Injection chamber volume	CF	2,165	--
Injection chamber HRT	MIN	2.3	--
Maturation chamber volume	CF	6,330	--
Maturation chamber HRT	MIN	6.82	--
Clarification			
Settling chamber volume	CF	7,570	--
Settling chamber HRT	MIN	8.2	--
Lamella tube settlers, surface area (ea)	SF	260	--
Maximum design surface loading rate w/ all basins	GPM/SF	--	--
Design Surface Loading Rate w/ All Basins	GPM/SF	27	--
Maximum surface loading rate (1 basin OOS)	GPM/SF	53	--
Sand slurry recirculation system			
Number of sludge recirculation pumps per Basin	#	2 (2+0)	--
Pumps in operation	#	2	--
Sludge recirculation rate	%	4.8	--
Capacity per pump	GPM	165	--
Total design head	FT	75	--
Pump horsepower	HP	10	--
Number of sand hydrocyclones (per basin)	#	2	--
Average Sand Loss Rate	LB/MG	23	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Approx. Daily Sand Loss	PPD	460	--
Ozone Contact Basins			
Type: 8-stage counter-co-counter w/ fine-bubble diffusers			
Number of basins	#	2	--
Detention time w/ all in service @ Design Flow	MIN	11.20	--
Detention time w/ one out of service @ Design Flow	MIN	5.60	--
Average water depth	FT	21	--
Inside dimensions (each basin)	FT x FT	6 x 10	--
Volume (total)	CF	20,800	--
Ozone Destruct Units	#	2	--
Ozone Generators			
Number	#	3 (2+1)	2 (1+1)
Feed Gas	-	LOX	LOX
Capacity (ea)	PPD	300	400
% Ozone by Weight (max)	%	8	8
Design Ozone Dose	mg/L	2.4	2.4
Max Ozone Dose @ Design Flow	mg/L	5.40	4.80
Dose with one unit out of service @ Design Flow	mg/L	3.60	2.40
Liquid Oxygen (100% LOX)			
Number of tanks	#	1	-
Storage capacity, total	GAL	12,000	-
Storage (avg dose x max flow)	DAYS	26	-
Average Oxygen Dosage	mg/L	26	-
Storage Density	LB/GAL	9.5	-
Filters			
Type: Deep bed, dual granular media with influent flow splitting			
Number of filters	#	4	--
Number of bays/filter	#	1	--
Filter bay dimensions	FT x FT	20 x 23	--
Filter area (each filter)	SF	460	--
Total filter area	SF	1,840	--
Maximum filtration rate (Q/A)			
All filters on-line @ Design Flow	GPM/SF	7.5	--
One filter off-line @ Design Flow	GPM/SF	10.1	--
Hydraulic maximum	GPM/SF	12	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Flow Rate Each Filter			
All filters on-line @ Design Flow	mgd	5.0	--
One filter off-line @ Design Flow	mgd	6.7	--
Filter media			
GAC			
Depth	IN	72	--
Effective size	mm	1.4	--
Uniformity coefficient		<1.4	--
Depth: Diameter (L:D)		1,306	--
Minimum Empty bed contact time (EBCT)			
All filters on-line @ Design Flow	MIN	5.9	--
One filter off-line @ Design Flow	MIN	4.5	--
Sand			
Depth	IN	12	--
Effective size	MM	0.45	--
Uniformity coefficient		<1.4	--
Depth: Diameter (L:D)	MM:MM	677	--
Total media			
Depth (maximum)	IN	84	--
Depth: Diameter (L:D)	MM:MM	1,984	--
Filter wash system			
Air scour blowers			
Number	#	2	--
Air scour rate	CFM/SF	3.2	--
Blower capacity (each)	ACFM	1,500	--
Blower horsepower (each)	HP	100	--
Backwash pumps			
Number	#	2	--
Maximum backwash rate	GPM/SF	20	--
Pump capacity (each)	GPM	9,200	--
Pump horsepower (each) – constant speed	HP	150	--
Maximum Backwash Volume	mgd	2.8	--
Clearwell			
Type: Buried, reinforced concrete			
Active volume	MG	2.9	--
Max Operating Side Water Depth	FT	21.5	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Dimensions	FT x FT	135 x 135	--
Detention Time (HRT) at Design Flow when full	HOURS	3.48	--
Hydraulic Efficiency up to 15 mgd	T10:HRT	0.11	--
Hydraulic Efficiency >15 mgd	T10:HRT	n/a	--
Finished Water Pumps			
Type: Vertical turbine, Two-stage			
Number	#	4 (3+1)	5 (4+1)
Total capacity with stand-by	mgd	30	30.5
Firm capacity	mgd	22.5	23
Capacity each			
1 VFD Driven pump	mgd	7.5	4
1 VFD driven pump	mgd	7.5	7.5
1 VFD driven pump	mgd	7.5	7.5
1 Constant speed pump	mgd	7.5	7.5
1 VFD driven pump		--	4
Total dynamic head	FT	--	--
Motor Size	HP	4@500	2@300 3@500
Waste Washwater Equalization & Pump Station			
Equalization basins			
Type: Concrete			
Number of basins	#	1	--
Volume	GAL	244,000	--
Maximum Backwash Volume	mgd	2.8	--
Hydrocyclone Overflow @ Design Rate	mgd	0.8	
Basin HRT	HRS	1.6	--
Washwater recycle pumps			
Type: Vertical turbine			
Number	#	3 (2+1)	--
Firm capacity	GPM	1,500	--
Capacity each			
1 VFD driven pump	GPM	500	--
1 VFD driven pump	GPM	500	
1 constant speed pump	GPM	500	--
Time to empty basin (all pumps on-line)	HRS	2.7	--
Time to empty basin (one pump off-line)	HRS	4.1	--
Total dynamic head	FT	25	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Motor horsepower	HP	3 @ 5	--
Solids Treatment			
Type: Gravity thickener and centrifuges			
Estimated Max Solids Production (dry) @ Design Flow	LB/DAY	2,667	--
Estimated Max Hydraulic Flow Rate @ Design Flow	GPM	321	--
Gravity thickener (circular)			
Number of units (total, existing + new)	#	1	--
Diameter	FT	35	--
Side Water Depth	FT	12	--
Max solids loading rate	PPD/SF	8	--
Max hydraulic loading rate	GPM/SF	1	--
Operating solids loading rate	PPD/SF	2.8	--
Operating hydraulic loading rate	GPM/SF	0.33	--
Storage Capacity @ Design Rate (7-day ops)	HRS	4.5	--
Storage Capacity @ Design Rate (5-day ops)	HRS	3.2	--
Solids Storage & Mixing			
Storage Volume	GAL	33,000	--
Estimated solids flow @ 2.5%	GAL/MG	765	--
	GPD	15,300	--
Mixing Tank HRT (7-day ops)	HRS	51	--
Mixing Tank HRT (5-day ops)	HRS	36	--
Mixing Pumps	#	1	--
Pumping capacity	GPM	600	--
Pump horsepower	HP	5	--
Solids pump station			
Progressive Cavity Transfer Pumps	#	2	--
Pumping capacity (ea)	GPM	60	--
Motor Size (ea)	HP	10	--
Total dynamic head	FT	60	--
Centrifuges			
Type		Horz. Scroll	--
Number of units	#	2	--
Capacity, each	GPM	60	--
Max solids loading, each	LB/HR	750	--
Maximum 8-hr Processing Capacity (ea)	PPD	6,000	--
Maximum 8-hr Processing Capacity (ea)	GPD	28,800	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Motor horsepower-scroll, each	HP	40	--
Motor horsepower-back drive, each	HP	15	--
Centrifuge operation period (1 standby, 7-day ops)	HR/DAY	3.6	--
Centrifuge operation period (1 standby, 5-day ops)	HR/DAY	5.0	--
Chemical Storage			
Primary coagulant (49% alum sol'n)			
Number of tanks	#	2	--
Storage capacity, total	GAL	13,000	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	28	--
Average Dosage	mg/L	15	--
Minimum volume for 21-day Storage	GAL	9,750	--
Solution Strength (alum)	LB/GAL	5.4	--
Cationic polymer (dry polymer)			
Type	-	Dry Feeder	--
Feed Capacity	LB/HR	17.6	--
Required Days Storage	DAYS	14	--
% solution	%	1	--
Storage (avg dose x max flow)	DAYS	--	--
Mixing Time	min	30	--
Sodium hypochlorite (12.5% NaOCl sol'n)			
Number of tanks	#	2	--
Storage capacity, total	GAL	7,800	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	24	--
Average Dosage	mg/L	2	--
Minimum volume for 21-day Storage	GAL	6,825	--
Solution Strength	LB/GAL	1.05	--
Caustic soda (25% NaOH sol'n)			
Number of tanks	#	2	--
Storage capacity, total	GAL	13,000	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	31	--
Average Dosage	mg/L	6.5	--
Minimum volume for 21-day Storage	GAL	8,806	--
Solution Strength	LB/GAL	2.65	--

Table 6.1 WRWTP 20 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Aqueous ammonia (19% NH ₄ OH sol'n)			
Number of tanks	#	1	--
Storage capacity, total	GAL	1,400	--
Anionic polymer			
Number of tanks	#	1	--
Storage capacity, total	GAL	55	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	> 1 year	--
Average Dosage	mg/L	0.4	--
Non-ionic polymer			
Number of tanks	#	1	--
Storage capacity, total	GAL	55	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	> 1 year	--
Average Dosage	mg/L	0.4	--
Calcium Thiosulfate			
Number of tanks	#	2	--
Storage capacity, total	GAL	440	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	47	--
Minimum volume for 21-day Storage	GAL	197	--
Average Dosage	mg/L	0.2	--
Solution Strength	LB/GAL	3.6	--

Notes:

- (1) Intake screen replacement will be completed as part of the WWSP RWF construction project and is not included in this expansion.

6.5 30-mgd Expansion

To maximize the available space at the WRWTP with the goal of achieving a total ultimate capacity of 60 mgd in the existing site boundary, the 30-mgd capacity expansion will be designed based on updated process design criteria for the 20-mgd capacity expansion. This will allow the plant to maximize the available space at the WRWTP with the intention of achieving a total capacity of 60 mgd within the existing site boundary. Additionally, using the up-rated criteria will allow the WRWTP to deliver high-quality finished water to the cities of Wilsonville, Sherwood, and any potential distribution partners while minimizing rate increases.

As noted in Section 2.3.4 of this 2017 MPU, the WRWTP will not be able to meet their LOS goal until they construct additional infrastructure that meets the current seismic requirement. Since the 30 mgd expansion includes construction of new process trains, WRWTP will be able to meet their LOS goals ahead of the 50-year period recommended in the ORP.

6.5.1 Expansion Alternatives

The 2017 MPU evaluated two 30 mgd expansion alternatives for each of the plant’s main treatment processes (i.e., ballasted flocculation, ozonation, and filtration):

- Alternative 1. Expansion at up-rated design criteria.
- Alternative 2. Expansion at up-dated design criteria with post seismic basin redundancy (install a completely redundant basin).

Figures 6.3 and 6.4 show the basins assumed to be active after a seismic event, and Table 6.2 lists them. As the table shows, Alternative 1 would allow the WRWTP to meet its LOS goal following a regional seismic event but would not provide basin redundancy when a basin must be taken off-line.

Alternative 2 provides sufficient redundancy following a regional seismic event, but is significantly more expensive.

Table 6.2 WRWTP 30 mgd Expansion Alternatives

Treatment Process	Number of Basins On-line: Total (Duty + Standby)			
	Alternative 1	Alternative 2	Alternative 1 PRSE	Alternative 2 PRSE
Actiflo®	3 (3+0)	4 (3+1)	1 (1+0)	2 (1+1)
Ozonation	3 (3+0)	4 (3+1)	1 (1+0)	2 (1+1)
Filtration	6 (5+1)	8 (7+1)	2 (2+0)	4 (3+1)

Notes:

(1) PRSE = post regional seismic event.




Figure 6.3 WRWTP 30 mgd Expansion – LOS




Figure 6.4 WRWTP 30 mgd Expansion – LOS + Post Regional Seismic Event (PRSE) Resiliency

6.5.1.1 Alternatives Evaluation

Per the WRWTP LOS goal presented in Chapter 2, within 48 hours of a regional seismic event the WRWTP would be required to produce half its nameplate capacity of 30 mgd (or 15 mgd) at the minimum potable water standard. For this evaluation, this 2017 MPU assumed the treatment basins installed during initial plant construction would not be initially functional, limiting treatment to the basins installed during the 30-mgd expansion. Table 6.3 shows the primary treatment process operating criteria.

For Alternative 1, the impacts to treatment following a regional seismic event are as follows:

- Actiflo®:** The remaining Actiflo® basin would treat 15 mgd. Based on discussions with the vendor (Kruger), the basins installed at WRWTP can treat this flow rate. However, both sand pumps must operate in parallel to ensure the basins can maintain a minimum 3 percent solids recycle rate with the existing 165 gpm sand pumps.
- Ozonation:** The remaining ozone basin would treat 15 mgd, limiting detention time in the ozonation basin to 7.5 minutes. Although this is sufficient to achieve 0.5-log *Giardia* inactivation, the ozonation system would not be operable if the basin required maintenance. Though 1-log inactivation of *Cryptosporidium* isn't necessary because water quality LOS goals are limited to regulatory requirements, ozone redundancy is desirable because the ozone basin would still be providing primary disinfection for the plant. However, at flows up to 15 mgd in the summer and 10 mgd in the winter, the clear well can achieve *Giardia* disinfection using free chlorine. It could be used on an interim basis to allow maintenance of the ozone facilities.

- **Filtration:** The filtration system would treat 15 mgd through two filters. This would result in a nominal filtration rate of 11.3 gpm/sf and a maximum filtration rate of 22.6 gpm/sf. Plant flows must be limited when one filter is down for backwashing. Assuming the maximum permitted filtration rate is 12 gpm/sf, the WRWTP could produce only 8 mgd instantaneously during backwash cycles.

For Alternative 2, no treatment impacts follow a regional seismic event because the remaining basins and maximum production rate would be identical to the expanded plant under normal operations (with one basin out of service). However, adopting Alternative 2 would approximately double the cost of the 30 mgd capacity expansion. The additional equipment would increase operations and maintenance costs and create stranded capacity for most of the operational life, particularly since the new equipment would be useful only during maximum demand conditions.

This 2017 MPU recommends considering Alternative 1 for the 30-mgd capacity expansion planning and designing all other resiliency options to minimize the risks associated with Alternative 1.

6.5.1.2 Alternative Water Supplies

Since the capital and operating costs of additional basins make Alternative 2 impractical, additional resiliency options were evaluated. These options included alternative supplies that may be necessary when plant demand is 15 mgd but production is reduced, such as during filter backwash or equipment maintenance. Alternative water supplies identified during this evaluation include:

- **Wilsonville and Sherwood Well Fields:** Both cities maintain well fields plumbed to the potable water distribution system and able to produce approximately 3 mgd each.
- **WWSP Supply:** Temporary supply could be requested from the WWSP. This would require adding a tie point and meter between the two systems, likely near the site of the future WWSS WTP in Sherwood, as well as a temporary pump station to be used when supply is needed. It would also require an Intergovernmental Agreement (IGA) dictating the costs and maximum allowable diversion to avoid impacting WWSP customers. Additional studies are required to demonstrate what additional infrastructure, such as temporary booster pump stations, may be required to back-feed Wilsonville's distribution system from Sherwood.
- **Alternative Supply from Sherwood:** This would require both an additional source of supply to Sherwood (City of Portland, or equal) and the previously mentioned additional infrastructure to convey water to Wilsonville's distribution system.

Based on this evaluation, sufficient water supply alternatives are in the region and partner cities to supplement the WRWTP.

6.5.1.3 Alternative Recommendation

For the 30-mgd capacity expansion, this 2017 MPU recommends Alternative 1, which requires no redundant basins following a catastrophic seismic event and identifies an alternate water supply source such as existing groundwater to supplement WRWTP production during maintenance. Alternative 1 is considered sufficiently conservative since it is unlikely the original basins will be completely inoperable following a regional seismic event. Identifying an additional water supply will furnish significant regional resiliency.

Table 6.3 WRWTP 30 mgd Expansion Alternatives – Design and Operating Criteria following a Catastrophic Seismic Event

Flow Rate	Units	ALT 1	ALT 2
Minimum	mgd	2.5	2.5
Average	mgd	4.8	4.8
Max (Plant Design)	mgd	15	15
	GPM	10,417	10,417
Clarification Process			
Type: Ballasted Flocculation (Actiflo®)			
Number of Basins	#	1	2
PRSE Flow Rate (per basin)	mgd	15	7.5
Max process hydraulic flow (per basin)	mgd	15	15
Mixing/Flocculation (per basin)			
Coagulation chamber volume	CF	2,000	2,000
Coagulation chamber HRT	MIN	1.4	2.9
Injection chamber volume	CF	2,165	2,165
Injection chamber HRT	MIN	1.6	3.1
Maturation chamber volume	CF	6,330	6,330
Maturation chamber HRT	MIN	4.55	9.09
Clarification			
Settling chamber volume	CF	7,570	7,570
Settling chamber HRT	MIN	5.4	10.9
Lamella tube settlers, surface area (ea)	SF	260	520
Design Surface Loading Rate w/ All Basins	GPM/SF	40	20
Maximum surface loading rate	GPM/SF	40	40
Sand slurry recirculation system			
Number of sludge recirculation pumps/basin	#	2	2
Pumps in operation	#	2	1
Sludge recirculation rate	%	3.2	3.1
Capacity per pump	GPM	165	165
Total design head	FT	75	75
Pump horsepower	HP	10	10
Number of sand hydrocyclones (per basin)	#	2	2
Average Sand Loss Rate	LB/MG	23	23
Approx. Daily Sand Loss	PPD	345	345
Ozone Contact Basins			
Number of basins	#	1	2
Detention time w/ all in service @Design Flow	MIN	7.47	14.94

Table 6.3 WRWTP 30 mgd Expansion Alternatives – Design and Operating Criteria following a Catastrophic Seismic Event (Continued)

Flow Rate	Units	ALT 1	ALT2
Detention time w/ one out of service @Design Flow	MIN	N/A	7.47
Average water depth	FT	21	21
Inside dimensions (each basin)	FT x FT	6 x 10	6 x 10
Volume (total)	CF	10,400	20,800
Filters			
Number of filters	#	2	4
Number of bays/filter	#	1	1
Filter bay dimensions	FT x FT	20 x 23	20 x 23
Filter area (each filter)	SF	460	460
Total filter area	SF	920	1,840
Maximum filtration rate (Q/A)			
All filters on-line @ Design Flow	GPM/SF	11.3	5.7
One filter off-line @ Design Flow	GPM/SF	22.6	7.5
Hydraulic maximum	GPM/SF	12	12
Flow Rate Each Filter			
All filters on-line @ Design Flow	mgd	7.5	3.8
One filter off-line @ Design Flow	mgd	15.0	5.0
Minimum Empty bed contact time (EBCT)			
All filters on-line @ Design Flow	MIN	4.0	7.9
One filter off-line @ Design Flow	MIN	2.0	5.9

6.5.2 Flow Projections

The Cities of Wilsonville and Sherwood projected future peak day flows. They calculated minimum and average day flow rates using the plant's current peak:minimum and peak:average ratios. These minimum and average day projections were used to evaluate equipment performance and loadings as well as turn-down requirements for raw and finished water pumps, chemical feed facilities, and ozone generation units. Table 6.4 (located at the end of Section 6.5) lists flow projections. Figure 6.5 shows the site layout for the 30 mgd capacity expansion.

Table 6.4 presents two potential expansion options that can be implemented based on owner and operator preference or equipment performance. Though both options are viable, only Option 1 was included in the expansion cost estimate and CIP.

6.5.3 Raw Water Pumping

Pumps will need replacing to support the 30-mgd expansion. The WRWTP will have three dedicated pumps and share one pump with the WWSP RWF. Assuming four 7.5 mgd pumps are included at the 20-mgd expansion, the WRWTP firm capacity will be 22.5 mgd.

This 2017 MPU recommends replacing two 7.5 mgd pumps with 15 mgd pumps, which will provide a firm capacity of 30 mgd. Additionally, this 2017 MPU recommends that all pumps are VFD-controlled to ensure WRWTP can meet its capacity requirements.

-This Page Intentionally Left Blank-




Figure 6.5 WRWTP Site Layout – 30 mgd Design Capacity

-This Page Intentionally Left Blank-

6.5.4 Flash Mix

At the 30-mgd capacity expansion, the flash mix system will operate at approximately 5 percent of total plant flow. Since the recommended flash mix rate is 2 to 5 percent of total plant flow, the system is sufficiently sized. If installed redundancy is preferred, this 2017 MPU recommends permanently installing the shelf-spare pump.

6.5.5 Ballasted Flocculation (Actiflo®)

At the 30-mgd capacity expansion, installing one additional Actiflo® basin is recommended. This will maintain the uprated capacity of 10 mgd per basin as described in the 20 mgd capacity expansion.

6.5.6 Ozonation

At the 30 mgd capacity expansion, installation of one ozone basin is recommended to maintain the uprated capacity of 10 mgd per basin (as described for the 20 mgd capacity expansion). Basin construction will include the shared ozone gallery, common with the fourth ozone basin when it is constructed during the next (i.e. 40 mgd) capacity expansion in the future. This expanded ozone contact facility will be able to provide both the OHA-required 0.5-log inactivation of *Giardia* and the non-regulated 1-log inactivation of *Cryptosporidium*, defined in the plant's LOS goals.

6.5.7 Filtration

At the 30-mgd capacity expansion, installing two additional filters is recommended. This will maintain the uprated maximum filtration rate of 10 gpm/sf when one basin is off-line for backwashing, as described in the 20-mgd capacity expansion.

6.5.8 Clearwell/Chlorine Disinfection

As previously discussed, after OHA approval of the plant's petition to recognize the disinfection benefits of ozone, the clear well will continue to serve as a wet well for the finished water pump station. The clear well can serve in this capacity to flows in excess of 60 mgd, or the plant's ultimate build-out capacity. That being said, the disinfection capability at the clear well should be maintained because free chlorine disinfection at reduced rates can serve as temporary backup to ozone disinfection in a catastrophic event.

6.5.9 Finished Water Pumping

The finished water pumping capacity after the 20-mgd capacity expansion will depend on which option is selected. If four pumps are installed, the firm capacity will be up 22.5 mgd. With a fifth pump, firm capacity rises to 23 mgd. Therefore, replacing or adding a pump is necessary to meet 30 mgd firm capacity. Installation options include:

- Assuming four total pumps: Replace three 7.5 mgd pumps with 12 mgd pumps to give a firm capacity of 31.5 mgd (included as Option 1 in Table 6.4).
- Assuming five total pumps: Replace three 7.5 mgd pumps with 12 mgd pumps to give a firm capacity of up to 39 mgd (included as Option 2 in Table 6.4).

Note that the 12-mgd recommended finished water pump size is not consistent with the recommended 15-mgd raw water pump size. Space restrictions in the finished water pump

station and greater total dynamic head (TDH) of the finished water pumps make it unlikely that 15-mgd, VFD-controlled pumps could fit in the allotted space.

This 2017 MPU recommends reviewing final pump sizing and required space before beginning design for the 30 mgd capacity expansion to determine if consistent pump sizes can be used in the finished and raw water facilities. Otherwise, the plant control systems will need to be upgraded to compensate for these variations in pump rate.

6.5.10 Waste Washwater Recovery

Expired service life means waste washwater pumps must be replaced for the 30-mgd expansion. To accommodate additional filters and the resulting increase in waste washwater flow rate, the 30-mgd capacity expansion should include upgrading from 500 gpm to 1,000 gpm pumps or installing a fourth 500 gpm pump. This will ensure that the washwater recycle rate is high enough to empty the washwater equalization within one to two hours, as indicated in Table 6.4. The basin itself, which serves as a wet well for the pump station, is adequately sized for flows in excess of 60 mgd, the plant build-out flow rate.

6.5.11 Mechanical Solids Dewatering

6.5.11.1 Gravity Thickener

At 30 mgd, the hydraulic loading rate of the single gravity thickener will be up to 0.50 gpm/sf, which could negatively affect performance. Solids loading rates are still within reasonable range. Therefore, this 2017 MPU recommends installing a second 35-foot diameter gravity thickener at the 30-mgd capacity expansion.

6.5.11.2 Solids Mixing

The solids mixing system is sufficiently sized for 30-mgd design capacity; however, the current configuration includes one installed pump and a shelf-spare pump rather than installed redundancy. Due to the increased complexity of two gravity thickeners and the increased solids generation rate, the 30-mgd expansion should include installing a shelf-spare mixing pump.

6.5.11.3 Solids Transfer and Thickening

The current 60-gpm solids transfer pumps and centrifuges will have exceeded their service life at the 30-mgd capacity expansion, and the two existing transfer pumps and centrifuges must be replaced. Installing a third transfer pump and centrifuge is also recommended if five-day solids processing operations are preferable.

With two centrifuges, the five- and seven-day solids processing time will be 7.5 and 5.3 hours, respectively, assuming one unit is on standby. With a third centrifuge, the five- and seven-day solids processing times are 3.7 and 2.7 hours assuming one unit is on standby, which is consistent with current design criteria. This is recommended in lieu of increasing the transfer pump and centrifuge processing rate to ensure the WRWTP has sufficient redundancy. Based on discussions with plant operators, the centrifuges regularly require maintenance, and three centrifuges would offer welcome redundancy.

6.5.12 Chemical Storage and Metering

The following projects are recommended during the 30 mgd expansion:

- Chemical Storage Room Modifications:** The current Chemical Storage Room configuration limits potential storage expansion. The entryway is too restricted to bring in new chemical storage tanks, chemical containments are too small to add additional tanks, and several chemical systems (such as aqueous ammonia) have been installed but never used. The 2015 MPU recommended expanding the chemical storage room, but the suggested layouts would either hinder road traffic or block access around the solids handling building. Therefore, this 2017 MPU recommends that the interior of the chemical storage room be modified as follows:
 - Replace and expand existing roll-up door.
 - Expand the alum, caustic, hypochlorite, and polymer containment areas.
 - Remove the aqueous ammonia system.
 - Consolidate chemical storage with appropriate chemical containment.
- Dry Hypochlorite Batching System:** To supply sufficient resiliency for a regional seismic event, upgrading the hypochlorite system from a liquid to an on-site generation system is recommended. Existing hypochlorite storage is limited to approximately 14 days; in a regional seismic event chemical delivery could be hindered, making it difficult to maintain plant chemical storage. Since hypochlorite is the most important water treatment chemical, installing an onsite generation system will help ensure that at a minimum the primary chemical (salt) will have multiple suppliers and that chemical disinfection is not interrupted. Note that the electrical requirements of on-site hypochlorite generation will need to be re-evaluated as part of the 30 mgd capacity expansion project.
- Purchase LOX Tank and Evaporators:** The WRWTP currently leases the LOX tank and evaporators from one of several chemical supply companies in the region. Though cost-effective, this arrangement prevents the plant from working with other chemical vendors. To increase chemical supplier and pricing options for the WRWTP as their LOX consumption increases, this 2017 MPU recommends purchasing the tank and evaporators as part of the 30-mgd expansion.

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures

Flow Rate	Units	Option 1	Option 2
Minimum	mgd	5.0	5.0
Average	mgd	9.6	9.6
Max (Plant Design)	mgd	30	30
	GPM	20,833	20,833
Willamette River			
Minimum River Level	FT	52.5	--
100 Year Flood Elevation	FT	91.1	--
500 Year Flood Elevation	FT	102.3	--
Intake Screens			
Type: Horizontal cylindrical			
Number	#	2	--
Capacity, total	mgd	150	--

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Diameter	IN	66	--
Screen Opening Size	mm	1.75	--
Maximum Face Velocity	FPS	0.4	--
Top of Screen Elevation	FT	42.75	--
<i>Screen Cleaning</i>			
Cleaning method: air burst			
Number of Compressors	#	2	--
Compressor Capacity	CFM	200	--
Air receiver volume	CF	2,200	--
Motor Size per compressor	HP	50	--
Raw Water Pumps			
Type: Vertical Turbine, Single-stage			
Number	#	4 (3+1)	--
Total capacity with stand-by	mgd	45	--
Firm capacity	mgd	30	--
Capacity (each)			
1 VFD Driven pump	mgd	7.5	--
1 VFD Driven Pump	mgd	15	--
1 VFD Driven Pump	mgd	15	--
1 Constant speed pump (Swing Pump?)	mgd	≥ 7.5	--
Total dynamic head (15 mgd)	FT	115	--
Total motor horsepower	HP	2@200 2@400	--
Initial Flash Mix			
Type: Pumped			
Number (Installed)	#	1	2 (1+1)
Mixing energy (ea)	s ⁻¹	1,000	1,000
Pump capacity (ea)	gpm	1,000	1,000
Pump flow as a percentage of plant flow rate (PFR)	%	5%	5%
Total dynamic head	FT	16	16
Total motor horsepower (ea)	HP	7.5	7.5
Clarification Process			
Type: Ballasted Flocculation (Actiflo®)			
Number of Basins	#	3	--
Design flow (per basin)	mgd	10	--
Max process hydraulic flow (per basin)	mgd	15	--

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Mixing/Flocculation (per basin)			
Coagulation chamber volume	CF	2,000	--
Coagulation chamber HRT	MIN	2.2	--
Injection chamber volume	CF	2,165	--
Injection chamber HRT	MIN	2.3	--
Maturation chamber volume	CF	6,330	--
Maturation chamber HRT	MIN	6.82	--
Clarification			
Settling chamber volume	CF	7,570	--
Settling chamber HRT	MIN	8.2	--
Lamella tube settlers, surface area (ea)	SF	260	--
Maximum design surface loading rate w/ all basins	GPM/SF	--	--
Design Surface Loading Rate w/ All Basins	GPM/SF	27	--
Maximum surface loading rate	GPM/SF	40	--
Sand slurry recirculation system			
Number of sludge recirculation pumps per Basin	#	2 (2+0)	--
Pumps in operation	#	2	--
Sludge recirculation rate	%	4.8	--
Capacity per pump	GPM	165	--
Total design head	FT	75	--
Pump horsepower	HP	10	--
Number of sand hydrocyclones (per basin)	#	2	--
Average Sand Loss Rate	LB/MG	23	--
Approx. Daily Sand Loss	PPD	690	--
Ozone Contact Basins			
Type: 8-stage counter-co-counter w/ fine-bubble diffusers			
Number of basins	#	3	--
Detention time w/ all in service @ Design Flow	MIN	11.20	--
Detention time w/ one out of service @ Design Flow	MIN	7.47	--
Average water depth	FT	21	--
Inside dimensions (each basin)	FT x FT	6 x 10	--
Volume (total)	CF	31,200	--
Ozone Destruct Units	#	3	--

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Ozone Generators			
Number	#	3 (2+1)	3 (2+1)
Feed Gas	-	LOX	LOX
Capacity (ea)	ppd	300	400
% Ozone by Weight (max)	%	8	8
Design Ozone Dose	mg/L	2.4	2.4
Max Ozone Dose @ Design Flow	mg/L	3.60	4.80
Dose with one unit out of service @ Design Flow	mg/L	2.40	6.39
Liquid Oxygen (100% LOX)			
Number of tanks	#	1	--
Storage capacity, total	GAL	12,000	--
Storage (avg dose x max flow)	DAYS	17	--
Average Oxygen Dosage	mg/L	26	--
Storage Density	#/gal	9.5	--
Filters			
Type: Deep bed, dual granular media			
With influent flow splitting			
Number of filters	#	6	--
Number of bays/filter	#	1	--
Filter bay dimensions	FT x FT	20 x 23	--
Filter area (each filter)	SF	460	--
Total filter area	SF	2,760	--
Maximum filtration rate (Q/A)			
All filters on-line @ Design Flow	GPM/SF	7.5	--
One filter off-line @ Design Flow	GPM/SF	9.1	--
Hydraulic maximum	GPM/SF	12	--
Flow Rate Each Filter			
All filters on-line @ Design Flow	mgd	5.0	--
One filter off-line @ Design Flow	mgd	6.0	--
Filter media			
GAC			
Depth	IN	72	--
Effective size	mm	1.4	--
Uniformity coefficient		<1.4	--
Depth: Diameter (L:D)		1,306	--

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Minimum Empty bed contact time (EBCT)			
All filters on-line @ Design Flow	MIN	5.9	--
One filter off-line @ Design Flow	MIN	5.0	--
Sand			
Depth	IN	12	--
Effective size	mm	0.45	--
Uniformity coefficient		<1.4	--
Depth: Diameter (L:D)	MM:MM	677	--
Total media			
Depth (maximum)	IN	84	--
Depth: Diameter (L:D)	MM:MM	1,984	--
Filter wash system			
Air scour blowers			
Number	#	2	--
Air scour rate	CFM/SF	3.2	--
Blower capacity (each)	ACFM	1,500	--
Blower horsepower (each)	HP	100	--
Backwash pumps			
Number	#	2	--
Maximum backwash rate	GPM/SF	20	--
Pump capacity (each)	GPM	9,200	--
Pump horsepower (each) – constant speed	HP	150	--
Maximum Backwash Volume	mgd	6.3	--
Clearwell			
Type: Buried, reinforced concrete			
Active volume	MG	2.9	--
Max Operating Side Water Depth	FT	21.5	--
Dimensions	FT x FT	135 x 135	--
Detention Time (HRT) at Design Flow when full	HRS	2.32	--
Hydraulic Efficiency up to 9.6 mgd	T10:HRT	--	--
Hydraulic Efficiency >9.6 mgd	T10:HRT	--	--
Finished Water Pumps			
Type: Vertical turbine, Two-stage			
Number	#	4 (3+1)	5 (4+1)
Total capacity w/ stand-by	mgd	43.5	51
Firm capacity	mgd	31.5	39

Table 6.4 WRWTP 30 MGD Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Capacity each			
1 VFD Driven pump	mgd	7.5	7.5
1 VFD driven pump	mgd	12	12
1 VFD driven pump	mgd	12	12
1 Constant speed pump	mgd	12	12
1 VFD driven pump		--	7.5
Total dynamic head	FT	--	--
Motor Size	HP	1@500 3@700	2@500 3@700
Waste Washwater Equalization & Pump Station			
Equalization basins			
Type: Concrete			
Number of basins	#	1	1
Volume	GAL	244,000	244,000
Maximum Backwash Volume	mgd	6.3	11.2
Hydrocyclone Overflow @ Design Rate	mgd	1.1	0.8
Basin Hydraulic Retention Time	HRS	0.8	0.5
Washwater recycle pumps			
Type: Vertical turbine			
Number	#	4 (3+1)	3 (2+1)
Total capacity w/ stand-by	GPM	2,000	3,000
Capacity each			
1 VFD driven pump	GPM	500	1,000
1 VFD driven pump	GPM	500	1,000
1 VFD driven pump	GPM	500	--
1 constant speed pump	GPM	500	1,000
Time to empty basin w/ stand-by	HRS	2	1
Time to empty basin w/o stand-by	HRS	2.7	2.0
Total dynamic head	FT	25	25
Motor horsepower	HP	4 @ 10	3 @ 15
Solids Treatment			
Type: Gravity thickener and centrifuges			
Estimated Max Solids Production (dry) @ Design Flow	LB/DAY	4,000	4,000
Estimated Max Hydraulic Flow Rate @ Design Flow	GPM	481	481
Gravity thickener (circular)			

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Number of units (total, existing + new)	#	1	2
Diameter	FT	35	35
Side Water Depth	FT	12	12
Max solids loading rate	PPD/SF	8	8
Max hydraulic loading rate	GPM/SF	1	1
Operating solids loading rate	PPD/SF	4.2	2.1
Operating hydraulic loading rate	GPM/SF	0.50	0.25
Storage Capacity @ Design Rate (7-day ops)	HRS	3.0	6.0
Storage Capacity @ Design Rate (5-day ops)	HRS	2.1	4.3
Solids Storage & Mixing			
Storage Volume	GAL	33,000	--
Estimated solids flow @ 2.5%	GAL/MG	765	--
	GPD	22,950	--
Mixing Tank HRT (7-day ops)	HRS	34	--
Mixing Tank HRT (5-day ops)	HRS	24	--
Mixing Pumps	#	1	--
Pumping capacity	GPM	600	--
Pump horsepower	HP	5	--
Solids pump station			
Progressive Cavity Transfer Pumps	#	2	3
Pumping capacity (ea)	GPM	60	60
Motor Size (ea)	HP	10	10
Total dynamic head	FT	60	60
Centrifuges			
Type		Horz. Scroll	Horz. Scroll
Number of units	#	2	3
Capacity, each	GPM	60	60
Max solids loading, each	LB/HR	750	750
Maximum 8-hr Processing Capacity (ea)	PPD	6,000	6,000
Maximum 8-hr Processing Capacity (ea)	GPD	28,800	28,800
Motor horsepower-scroll, each	HP	40	40
Motor horsepower-back drive, each	HP	15	15
Centrifuge operation period (1 standby, 7-day ops)	HR/DAY	5.3	2.7
Centrifuge operation period (1 standby, 5-day ops)	HR/DAY	7.5	3.7

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Chemical Storage			
Primary coagulant (49% alum sol'n)			
Number of tanks	#	2	--
Storage capacity, total	GAL	13,000	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	18	--
Average Dosage	mg/L	15	--
Minimum volume for 21-day Storage	GAL	15,167	
Solution Strength (alum)	LB/GAL	5.4	--
Cationic polymer (dry polymer)			
Type	-	Dry Feeder	--
Feed Capacity	LB/HR	17.6	--
Required Days Storage	DAYS	14	--
% solution	%	1	--
Storage (avg dose x max flow)	DAYS	--	--
Mixing Time	min	30	--
Sodium hypochlorite (12.5% NaOCl sol'n)			
Number of tanks	#	2	--
Storage capacity, total	GAL	7,800	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	16	--
Average Dosage	mg/L	2	--
Minimum volume for 21-day Storage	GAL	10,238	
Solution Strength	LB/GAL	1.05	--
Caustic soda (25% NaOH sol'n)			
Number of tanks	#	2	--
Storage capacity, total	GAL	13,000	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	21	--
Average Dosage	mg/L	6.5	--
Minimum volume for 21-day Storage	GAL	13,000	
Solution Strength	LB/GAL	2.65	--
Aqueous ammonia (19% NH ₄ OH sol'n)			
Number of tanks	#	1	--
Storage capacity, total	GAL	1,400	--

Table 6.4 WRWTP 30 mgd Expansion Processes and Procedures (Continued)

Flow Rate	Units	Option 1	Option 2
Anionic polymer			
Number of tanks	#	1	--
Storage capacity, total	GAL	55	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	> 1 year	--
Average Dosage	mg/L	0.4	--
Non-ionic polymer			
Number of tanks	#	1	--
Storage capacity, total	GAL	55	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	> 1 year	--
Average Dosage	mg/L	0.4	--
Calcium Thiosulfate			
Number of tanks	#	2	--
Storage capacity, total	GAL	440	--
Required Days Storage	DAYS	14	--
Storage (avg dose x max flow)	DAYS	31	--
Minimum volume for 21-day Storage	GAL	298	--
Average Dosage	mg/L	0.2	--
Solution Strength	LB/GAL	3.6	--

6.6 Repair and Replace

In addition to the seismic and life-safety CIP recommended in Chapter 5 and the capacity expansion CIP recommendations in Chapter 6, the plant requires ongoing maintenance/repair and replacement (R&R) of its existing infrastructure. Table 6.5 summarizes recommended R&R for the WRWTP across a 20-year planning horizon. The details and timing of these projects will be discussed in Chapter 7 – Implementation Plan.

Table 6.5 WRWTP Repair and Replace Projects

Repair and Replace Project	Approx. Service Year
Annual maintenance on the existing site fire alarm	Annual
Annual maintenance on the existing site sprinkler system	Annual
Replace VFDs on three finished water pumps.	2019
Replace obsolete Robocon VFDs on two raw water pumps.	2019
Replace obsolete ABB magnetic flow meters installed throughout the WRWTP and at Wilsonville Road.	2019
Replace the four hydrocyclones installed in the two existing Actiflo Basins	2020

Table 6.5 WRWTP Repair and Replace Projects (Continued)

Repair and Replace Project	Approx. Service Year
Replace lamella settling tubes in the two existing Actiflo basins, which are damaged due to UV exposure.	2020
Replace the two flash mix pumps (installed and standby)	2020
Upgrade site security monitoring system camera and computer	2020
Replace existing raw water sump pump	2020
Replace two existing sludge mixing pumps (one installed, one shelf spare)	2020
Replace three existing filter waste washwater recycle pumps	2020
Upgrade vendor PLC components in the two existing Actiflo basins	2022
Replace the six mixers installed in the two existing Actiflo Basins	2022
Replace the two sample pumps installed in the two existing Actiflo Basins	2022
Upgrade vendor PLC components in the existing dry polymer blending unit	2022
Replate two existing 300 PPD ozone generators with 400 PPD units	2022
Inspect existing alum tank and repair as needed	2022
Inspect existing caustic soda tank and repair as needed	2022
Replace existing air scour blowers and motors on existing media filtration system	2022
Replace the existing safety and warning signs throughout the site	2022
Replace sitewide fire extinguishers	2022
Replace the two existing irrigation waste pumps	2022
Replace the existing dewatered sludge screw conveyor in the Solids Handling Building	2022
Replace original dry polymer batching system	2027
PLC upgrade for Actiflo® Local Control Panels.	2027
Replace existing soft-start controller on High Service Pump 3.	2027
Replace the two existing water feature pumps	2027
Replace two existing air burst compressors.	2027
Replace existing air burst control panel PLC and local control panel.	2027
Replace two existing 60 GPM centrifuges.	2027
Replace existing PLC and local control panel for two dewatering centrifuges.	2027
Replace two existing backwash supply pumps in the wastewater equalization basin.	2032
Replace the two existing sludge mixing pumps.	2032
Replace existing streaming current analyzer on Actiflo® inlet.	2036
Replace the five solids pumps (installed and standby) on the existing Actiflo® basins.	2036
Replace the two installed flash mix pumps.	2036
Replace the six mixers installed in the two existing Actiflo® Basins.	2036
Replace the four hydrocyclones installed in the two existing Actiflo® Basins.	2036

Table 6.5 WRWTP Repair and Replace Projects (Continued)

Repair and Replace Project	Approx. Service Year
Replace the LOX evaporator equipment.	2036
Replace aging MCC in existing filter gallery.	2036
Replace air scour blowers and motors on existing media filtration system.	2036
Replace existing constant-speed 7.5 mgd pump with a VFD-controlled pump	2036
Replace two existing 60 GPM solids transfer pumps.	2036
Replace the existing gravity thickener drive.	2036

-This Page Intentionally Left Blank-

Chapter 7

CIP APPROACH AND SCHEDULE

7.1 Introduction

This chapter summarizes the assumptions, contingencies, and classifications in the latest capital cost estimates developed for the 2017 Master Plan Update (MPU). It also summarizes the design and construction schedule outlined in the 2017 MPU.

7.2 Capital Cost Assumptions

7.2.1 Cost Estimate Classification

The expected level of accuracy for the estimates followed the Recommended Practice 18R-97 Cost Estimate Classification System for the Process Industries (Association for the Advancement of Cost Engineering, 1998) designations. For better accuracy, the 20 mgd capacity expansion, electrical upgrades, seismic retrofits, life-safety repairs, and repair and replace tasks occurring before 2027 were classified as Class 4 estimates, whereas the 30 mgd capacity expansion project and repair and replace tasks occurring in 2027 or later were classified as Class 5 estimates.

The definitions for Class 4 and Class 5 estimates are as follows:

- Class 4 estimates have an expected level of accuracy of +50 percent to -30 percent. This means that bids for these estimates are expected to fall within a range of 50 percent over the estimate or 30 percent under the estimate.
- Class 5 estimates have an expected level of accuracy of +100 percent to -50 percent. This means that bids for these estimates are expected to fall within a range of 100 percent over the estimate or 50 percent under the estimate.

Estimated project costs are escalated to 2017 dollars.

7.2.2 Opinion-of-Probable Construction Cost Estimate

To generate capital cost estimates, an opinion of probable construction cost (OPCC) was developed. An OPCC estimate provides assumptions for the labor, materials, construction, and major process equipment used to develop the total cost of work (COW) subtotal for each project in the CIP. The OPCC is included in Appendix D.

The July 2017 Means Construction Cost Indexes for Portland, Oregon, were used to develop baselines for local costs. For commodity costs, the September 2017 Engineering News Record (ENR) Construction Economics data were used.

Various cost factors were applied to create the build-up to the COW subtotal, including cost factors for insurance, bonds, profit, overhead, general conditions, and equipment and labor. Prime contractor costs, burdens, and mark-up were then added to the COW subtotal to develop the total COW. For a detailed summary of cost factors, assumptions, contingencies, and contractor factors, refer to the OPCC in Appendix D.

7.2.3 Cost Factoring Workbook

The cost factoring workbook outlines total COW for equipment that was not included in the OPCC. The total COW for these items includes the direct equipment cost increased by a costing factor to account for anticipated installation cost along with all applicable burdens and markups. The cost factoring workbook is included in Appendix D.

7.2.4 CIP Workbook

The WRWTP 2017 MPU CIP was generated using the cost estimates created in the OPCC. The CIP (Appendix E) is included as both a hard copy and as an electronic file. The electronic CIP workbook is an interactive tool for facilitating budget allocation efforts during the 20-year planning horizon. With this workbook, the user can modify the escalation rate, completion year, project duration, and type of cost projection calculation used. Based on the user's input, the workbook automatically updates all calculations in the financial and cost planning summaries.

The user can, for example, modify the escalation rate based on inflation, construction cost index, consumer price index, or other rates, as shown in the red cells in Figure 7.1. The user can also modify the legal and administration contingency and the design contingency added to all projects requiring engineering design.

General Assumptions:		
Escalation Rate		1.03
Estimate Date		Sep-17
ENR @ Date		10823
Design Contingency		15%
Admin Contingency		10%
Revised Estimate Date		Sep-17
ENR @ Revised Estimate Date		10823

Figure 7.1 Example Assumptions in CIP Workbook

To compare the estimated construction costs to the actual construction costs, the user can input the actual construction costs in the appropriate column, as shown in Table 7.1. The workbook contains instructions and notes to help the user. Note that the year used to estimate the future project value mentioned in Table 7.1 is not documented in the example but is included as part of the CIP summary table.

Table 7.1 Example of CIP Actual Construction Cost

Estimated Construction Cost	Design Project?	Estimated Task Cost	Future Value in Approx. Project Year	Future Value in Approx. Project Year, Using Revised Estimate Date	Actual Construction Cost
\$4,147,606	Yes	\$5,184,508	\$5,184,508	\$ -	
\$180,000	Yes	\$225,000	\$225,000	\$ -	
\$285,988	Yes	\$357,485	\$357,485	\$ -	
\$4,014,088	Yes	\$5,017,610	\$5,017,610	\$ -	
\$238,323	Yes	\$297,904	\$297,904	\$ -	

7.3 Design and Construction Schedule

For all CIP project stages, estimates for the design duration and construction duration were developed. The required project start year was calculated using each stage's project completion year and the duration of design and construction. Table 7.2 shows the design and construction schedule for the 20 mgd and 30 mgd expansion projects, electrical upgrades, seismic retrofits, life-safety repairs, and repair and replace projects.

Table 7.2 WRWTP Expansion Design and Construction Schedule

Project	Approx. Service Year	Duration (Months)			Start Date
		Design	Construction	Float	
20 MGD Capacity Expansion	2020	12	18	6	2018
Life Safety Repairs	2022	6	6	3	2020
Seismic Retrofits	2022	6	6	3	2020
30 MGD Capacity Expansion	2034	12	24	6	2032
Operations – Repair and Replace					
Year 1	2019	0	6	6	--
Year 2	2020	0	6	6	2019
Year 3	2021	0	6	6	2020
Year 4	2022	0	6	6	2021
Year 5	2023	0	6	6	2022
Year 6	2024	0	6	6	2023
Year 7	2025	0	6	6	2024
Year 8	2026	0	6	6	2025
Year 9	2027	0	6	6	2026
Year 10	2028	0	6	6	2027
Year 11	2029	0	6	6	2028
Year 12	2030	0	6	6	2029
Year 13	2031	0	6	6	2030
Year 14	2032	0	6	6	2031
Year 15	2033	0	6	6	2032
Year 16	2034	0	6	6	2033
Year 17	2035	0	6	6	2034
Year 18	2036	0	6	6	2035

7.4 Financial Summary

Table 7.3 and Figure 7.2 summarize near-term CIP costs. Capital costs are broken down by expansion projects, electrical upgrades, seismic retrofits, life-safety repairs, and repair and replace projects. For the overall 20-year CIP cost estimate summary, refer to Table 7.4 and Figure 7.3.

Design was assumed to be completed before the start of construction. As such, the design costs were allocated to the first year of the project. Construction costs were split evenly into the

proceeding years based on the construction duration. The assumed financial responsibilities and fee structures for the CIP projects are listed in Table 7.5

Table 7.3 WRWTP Near-Term CIP Costs (2017 Dollars)

Project	FY	2018	2019	2020	2021	2022
20 MGD Expansion						
Design ⁽¹⁾		\$1,885,517	--	--	--	--
Administration ⁽²⁾		\$419,004	\$419,004	\$419,004	--	--
Construction		--	\$6,285,055	\$6,285,055	--	--
Total		\$2,304,520	\$6,704,059	\$6,704,059	--	--
Life Safety Repairs						
Design ⁽¹⁾		--	--	--	--	--
Administration ⁽²⁾		--	--	\$28,007	\$28,007	--
Construction		--	--	--	\$560,139	--
Total		--	--	\$28,007	\$588,146	--
Seismic Retrofits						
Design ⁽¹⁾		--	--	\$138,224	--	--
Administration ⁽²⁾		--	--	\$46,075	\$46,075	--
Construction		--	--	--	\$921,493	--
Total		--	--	\$184,299	\$967,568	--
Operations - Repair and Replace						
Design ⁽¹⁾		--	--	--	--	--
Administration ⁽²⁾		--	\$135,611	\$144,729	\$1,138	\$310,899
Construction		--	\$1,356,111	\$1,447,291	\$11,375	\$3,108,994
Total		--	\$1,491,722	\$1,592,020	\$12,513	\$3,419,893
Total		\$2,304,520	\$8,195,781	\$8,508,384	\$1,568,226	\$3,419,893

Notes:

(1) Assumes 15% contingency for engineering design.

(2) Assumes 10% contingency for legal and administration costs




Figure 7.2 WRWTP Near-Term CIP Costs (2017 Dollars)

-This Page Intentionally Left Blank-

Table 7.4 WRWTP Total CIP Costs (2017 Dollars)

Project	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	Total
20 MGD Expansion																				
Design ⁽¹⁾	\$1,885,517	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$1,885,517
Administration ⁽²⁾	\$419,004	\$419,004	\$419,004	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$1,257,011
Construction	--	\$6,285,055	\$6,285,055	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$12,570,110
Total	\$2,304,520	6,704,059	\$6,704,059	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$15,712,638
Life Safety Repairs																				
Design ⁽¹⁾	--	--	\$28,007	\$28,007	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Administration ⁽²⁾	--	--	--	\$560,139	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$56,014
Construction	--	--	\$28,007	\$588,146	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$560,139
Total	--	--	\$28,007	\$588,146	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$616,153
Seismic Retrofits																				
Design ⁽¹⁾	--	--	\$138,224	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$138,224
Administration ⁽²⁾	--	--	\$46,075	\$46,075	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$92,149
Construction	--	--	--	\$921,493	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$921,493
Total	--	--	\$184,299	\$967,568	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$1,151,866
30 MGD Expansion																				
Design ⁽¹⁾	--	--	--	--	--	--	--	--	--	--	--	--	--	\$4,636,647	--	--	--	--	--	\$4,636,647
Administration ⁽²⁾	--	--	--	--	--	--	--	--	--	--	--	--	--	\$1,030,366	\$1,030,366	\$1,030,366	--	--	--	\$3,091,098
Construction	--	--	--	--	--	--	--	--	--	--	--	--	--	--	\$15,455,489	\$15,455,489	--	--	--	\$30,910,978
Total	--	--	--	--	--	--	--	--	--	--	--	--	--	\$5,667,013	\$16,485,855	\$16,485,855	--	--	--	\$38,638,723
Operations - Repair and Replace																				
Design ⁽¹⁾	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Administration ⁽²⁾	--	\$135,611	\$144,729	\$1,138	\$310,899	\$1,138	\$1,138	\$1,138	\$1,138	\$473,950	\$1,138	\$1,138	\$1,138	\$1,138	\$225,138	\$1,138	\$1,138	\$1,138	\$1,138	\$308,663
Construction	--	\$1,356,111	\$1,447,291	\$11,375	\$3,108,994	\$11,375	\$11,375	\$11,375	\$11,375	\$4,739,500	\$11,375	\$11,375	\$11,375	\$11,375	\$2,251,375	\$11,375	\$11,375	\$11,375	\$11,375	\$3,086,634
Total	--	\$1,491,722	\$1,592,020	\$12,513	\$3,419,893	\$12,513	\$12,513	\$12,513	\$12,513	\$5,213,450	\$12,513	\$12,513	\$12,513	\$12,513	\$2,476,513	\$12,513	\$12,513	\$12,513	\$12,513	\$3,395,297
CIP TOTAL	\$2,304,520	\$8,195,781	\$8,508,384	\$1,568,226	\$3,419,893	\$12,513	\$12,513	\$12,513	\$12,513	\$5,213,450	\$12,513	\$12,513	\$12,513	\$5,679,525	\$18,962,367	\$16,498,367	\$12,513	\$12,513	\$3,395,297	\$73,858,425

Notes:
 (1) Assuming 15% contingency for Design and 10% for legal and administration costs.
 (2) All costs are rounded up to nearest \$10,000.

-This Page Intentionally Left Blank-




Figure 7.3 WRWTP Total CIP Costs (2017 Dollars)

Table 7.5 WRWTP 2017 MPU Stakeholder Responsibility

CIP Project	%City of Wilsonville	%City of Sherwood	%Water Operations	%SDCs
20 mgd Expansion	66.7	33.3	37	63
Life Safety Repairs	66.7	33.3	100	--
Seismic Retrofits	66.7	33.3	100	--
30 mgd Expansion	68	32	37	63
Operations – Repair and Replace	66.7	33.3	85	15

Appendix A

CONDITION ASSESSMENT CALCULATIONS

- *Hydraulic Assessment Calculations*
- *WRWTP Equipment List*
- *WRWTP Equipment Discussion Notes*
- *Electrical Assessment Calculations*
- *WRWTP 20-Year NPV Calculation*



WRWTP Hydraulics - HGL

TABLE OF CONTENTS

SECTION	DESCRIPTION	PAGES
1	HYDRAULIC PROFILE – 15 MGD	1-9
2	HYDRAULIC PROFILE – 20 MGD	10 - 18

HYDRAULIC PROFILE MODELING SCENARIO SUMMARY

SECTION 1: HYDRAULIC PROFILE – 15 MGD

SUMMARY: OPERATION OF WRWTP AT 15 MGD FLOW WITH 10% INTERNAL RECYCLE FLOW. CLEARWELL/HIGH SERVICE PUMP STATION AT MAX WS EL (123.00). THREE OF FOUR FILTERS ONLINE WITH FLOW SPLIT EVENLY BETWEEN THREE FILTERS. OZONATION SPLIT EQUALLY BETWEEN TWO TREATMENT TRAINS. ACTIFLO® SPLIT EQUALLY BETWEEN TWO TREATMENT TRAINS WITH HEADLOSS PROVIDED BY KRUGER.

SECTION 2: HYDRAULIC PROFILE – 20 MGD

SUMMARY: OPERATION OF WRWTP AT 20 MGD FLOW WITH 10% INTERNAL RECYCLE FLOW. CLEARWELL/HIGH SERVICE PUMP STATION AT MAX WS EL (123.00). THREE OF FOUR FILTERS ONLINE WITH FLOW SPLIT EVENLY BETWEEN THREE FILTERS. OZONATION SPLIT EQUALLY BETWEEN TWO TREATMENT TRAINS. ACTIFLO® SPLIT EQUALLY BETWEEN TWO TREATMENT TRAINS WITH HEADLOSS PROVIDED BY KRUGER.



PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

										Equation Ref.	HGL	EGL				
DOWNSTREAM CONTROL																
<table border="1"> <tr> <td>EGL =</td> <td>123.00</td> </tr> <tr> <td>Flow =</td> <td>15.00 mgd = 23.21 cfs</td> </tr> </table>										EGL =	123.00	Flow =	15.00 mgd = 23.21 cfs		123.00	123.00
EGL =	123.00															
Flow =	15.00 mgd = 23.21 cfs															
Filter Control Weir																
[STRAIGHT EDGED SHARP CRESTED WEIR]																
Flow	15.00	mgd =	23.2	cfs												
WSE Downstream of Weir	123.00	ft														
Weir Crest Elevation	131.50	ft														
Downstream head, Hd	-8.50	ft														
Length of Weir, L	28.00	ft														
WEIR IS FREE-DISCHARGING																
<u>Free Discharging Weir Computation</u>																
Head on Weir, H	0.40	ft								{ 6 }						
Upstream WSE	131.90	ft														
<u>Submerged Weir Computation</u>																
K	NA									{ 7 }						
M	NA															
Increment	NA	ft														
Upstream Head, Hu1	NA	ft														
F(H1)	NA															
F'(H1)	NA															
Upstream Head, Hu2	NA	ft														
Upstream WSE	NA	ft														
Head over Weir	0.40	ft														
<i>Condition Upstream of Weir</i>											131.90	131.90				
Piping from Filters to Filter Control Weir																
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]																
Flow	15.0	mgd =	23.2	cfs						{ 4 }						
Pipe Diameter, D	60	inch														
Pipe Length, L	50	ft														
Absolute Roughness, ε	0.00040	ft														
Pipe velocity, v	1.18	fps														
Kinematic Viscosity	1.000E-05	ft ² /sec														
Reynold's Number, R	590910															
Friction factor, f	0.0139															
Equivalent Hazen-Williams "C" = 148.8559																
Friction Energy Loss, h _f	0.00	ft														
MINOR PIPE LOSS HEADING																
Flow, Q	15.0	mgd =	23.2	cfs												
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)						
1	Outlet Loss - Still Water	15.00	23.21	1.00	----	60	----	1.18	0.02	0.02						
1	Tee - Thru Straight Run	15.00	23.21	0.60	60	----	1.18	----	0.02	0.01						
1	Increaser	15.00	23.21	0.25	60	54	1.18	1.46	-0.01	0.00						
Sum =										0.03						
Total Energy Loss =			0.03	ft												
<i>Upstream Condition</i>											131.93	131.93				

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

Equation Ref.	HGL	EGL
{ 4 }		
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]		
Flow	15.0 mgd = 23.2 cfs	
Pipe Diameter, D	54 inch	
Pipe Length, L	75 ft	
Absolute Roughness, ε	0.00040 ft	
Pipe velocity, v	1.46 fps	
Kinematic Viscosity	1.000E-05 ft ² /sec	
Reynold's Number, R	656567	
Friction factor, f	0.0139	Equivalent Hazen-Williams "C" = 148.0406
Friction Energy Loss, h _f	0.01 ft	
<i>Condition Upstream of Pipe</i>		
	131.94	131.94

Piping from Filter Underdrains to FW Pipe

{ 4 }		
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]		
Flow	5.0 mgd = 7.7 cfs	
Pipe Diameter, D	20 inch	No. of Filters in Service 3
Pipe Length, L	15 ft	
Absolute Roughness, ε	0.00040 ft	
Pipe velocity, v	3.55 fps	
Kinematic Viscosity	1.000E-05 ft ² /sec	
Reynold's Number, R	590910	
Friction factor, f	0.0156	Equivalent Hazen-Williams "C" = 141.2289
Friction Energy Loss, h _f	0.03 ft	

MINOR PIPE LOSS HEADING

Flow, Q	5.0 mgd = 7.7 cfs									
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)
1	Entrance Loss - Flush	5.00	7.74	0.50	---	20	---	3.55	0.20	0.10
1	Tee - Thru Side Outlet	5.00	7.74	1.80	20	---	3.55	---	0.20	0.35
1	90 ° Elbow - Regular Fl.	5.00	7.74	0.30	20	---	3.55	---	0.20	0.06
1	Mitre Bend - 90 ° Deflection	5.00	7.74	1.27	20	---	3.55	---	0.20	0.25
1	Entrance Loss - Flush	5.00	7.74	0.50	---	20	---	3.55	0.20	0.10
									Sum =	0.85
Total Energy Loss per Filter =		0.88 ft								
<i>Upstream Condition</i>										
									132.82	132.82

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

		Equation Ref.	HGL	EGL
Filters (1 of 4)				
[GRAVITY SAND FILTER]		{ 10 }		
Flow	5.5 mgd = 8.5 cfs			
Area of Filter Bed	460 sf			
Superficial Velocity, Vo	0.018 fps			
Vo, SI Units	0.006 m/s			
Kinematic viscosity, v	1.1E-06 m ² /s			
GAC Layer				
Grain diameter, d	0.0014 m			
Bed Porosity, E'	0.5			
Bed Foulness (% of E)	0%			
Effective Porosity, E	0.5			
Bed depth, L	6 ft			
Bed depth, L - SI Units	1.83 m			
Head Loss, SI Units	0.24 m			
Head Loss	0.79 ft			
Sand Layer				
Grain diameter, d	0.00045 m			
Bed Porosity, E'	0.5			
Bed Foulness (% of E)	0%			
Effective Porosity, E	0.5			
Bed depth, L	1 ft			
Bed depth, L - SI Units	0.30 m			
Head Loss, SI Units	0.36 m			
Head Loss	1.17 ft			
Total Filter Energy Loss	1.97 ft			
<i>Condition Upstream of Filter</i>			134.79	134.79
Filter Distribution/Influent Weir				
[STRAIGHT EDGED SHARP CRESTED WEIR]				
Flow	5.5 mgd = 8.5 cfs			
WSE Downstream of Weir	145.65 ft			
Weir Crest Elevation	146.50 ft			
Downstream head, Hd	-0.85 ft			
Length of Weir, L	10.00 ft			
WEIR IS FREE-DISCHARGING				
<u>Free Discharging Weir Computation</u>		{ 6 }		
Head on Weir, H	0.40 ft			
Upstream WSE	146.90 ft			
<u>Submerged Weir Computation</u>		{ 7 }		
K	NA			
M	NA			
Increment	NA ft			
Upstream Head, Hu1	NA ft			
F(H1)	NA			
F'(H1)	NA			
Upstream Head, Hu2	NA ft			
Upstream WSE	NA ft			
Head over Weir	0.40 ft			
<i>Condition Upstream of Weir</i>			146.90	146.90



PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

											Equation Ref.	HGL	EGL	
Filter Distribution Channel														
MINOR CHANNEL LOSS HEADING														
Flow, Q		16.5 mgd = 25.5 cfs			Channel Invert		141.5							
No.	Description	Flow (mgd)	Flow (cfs)	K	Width Up (ft)	Width Down (ft)	Depth (ft)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)			
1	Entrance - Sharp Corners	16.50	25.53	0.50	10	10	5.40	0.47	0.47	0.00	0.00			
1	90 Degree Bend - 0° Radius	16.50	25.53	1.30	10	----	5.40	0.47	----	0.00	0.00			
											Sum =	0.00		
Total Energy Loss =		0.00 ft												
												Upstream Condition	146.91	146.91
Ozone to Filter Pipe														
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]														
{ 4 }														
Flow		16.5 mgd = 25.5 cfs												
Pipe Diameter, D		60 inch												
Pipe Length, L		60 ft												
Absolute Roughness, ε		0.00040 ft												
Pipe velocity, v		1.30 fps												
Kinematic Viscosity		1.000E-05 ft ² /sec												
Reynold's Number, R		650002												
Friction factor, f		0.0138			Equivalent Hazen-Williams "C" =			148.6114						
Friction Energy Loss, h _f		0.00 ft												
MINOR PIPE LOSS HEADING														
Flow, Q		16.5 mgd = 25.5 cfs												
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)				
1	Entrance Loss - Flush	16.50	25.53	0.50	----	60	----	1.30	0.03	0.01				
1	Outlet Loss - Still Water	16.50	25.53	1.00	60	----	1.30	----	0.03	0.03				
											Sum =	0.04		
Total Energy Loss =		0.04 ft												
												Upstream Condition	146.95	146.95

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

	Equation Ref.	HGL	EGL
Ozone Contactor Effluent Weir			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow			
			8.3 mgd = 12.8 cfs
WSE Downstream of Weir		146.95 ft	
Weir Crest Elevation		148.67 ft	
Downstream head, Hd		-1.72 ft	
Length of Weir, L		10.00 ft	
WEIR IS FREE-DISCHARGING			
<u>Free Discharging Weir Computation</u>			
Head on Weir, H	{ 6 }	0.53 ft	
Upstream WSE		149.20 ft	
<u>Submerged Weir Computation</u>			
K	{ 7 }	NA	
M		NA	
Increment		NA ft	
Upstream Head, Hu1		NA ft	
F(H1)		NA	
F'(H1)		NA	
Upstream Head, Hu2		NA ft	
Upstream WSE		NA ft	
Head over Weir		0.53 ft	
		<i>Condition Upstream of Weir</i>	
		149.20	149.20
Last Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]			
Flow			8.3 mgd = 12.8 cfs
Number of Ports		1	
Flow Per Port		8.3 mgd = 12.8 cfs	
Port Width		10 ft	
Port Height		3 ft	
Discharge Coefficient, C		0.61	
Velocity through port, v		0.43 fps	
Orifice Energy Loss, h _L		0.01 ft	
		<i>Condition Upstream of Orifice</i>	
		149.21	149.21
Last Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow			8.3 mgd = 12.8 cfs
WSE Downstream of Weir		149.21 ft	
Weir Crest Elevation		146.00 ft	
Downstream head, Hd		3.21 ft	
Length of Weir, L		10.00 ft	
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>			
Head on Weir, H	{ 6 }	NA ft	
Upstream WSE		NA ft	
<u>Submerged Weir Computation</u>			
K	{ 7 }	0.08	
M		5.74	
Increment		0.10 ft	
Upstream Head, Hu1		3.21 ft	
F(H1)		0.00	
F'(H1)		-0.47	
Upstream Head, Hu2		3.21 ft	
Upstream WSE		149.21 ft	
Head over Weir		3.21 ft	
		<i>Condition Upstream of Weir</i>	
		149.21	149.21



JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

	Equation Ref.	HGL	EGL
Third Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]	{ 2 }		
Flow	8.3 mgd = 12.8 cfs		
Number of Ports	1		
Flow Per Port	8.3 mgd = 12.8 cfs		
Port Width	10 ft		
Port Height	3 ft		
Discharge Coefficient, C	0.61		
Velocity through port, v	0.43 fps		
Orifice Energy Loss, h _L	0.01 ft		
<i>Condition Upstream of Orifice</i>		149.21	149.21
Third Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow	8.3 mgd = 12.8 cfs		
WSE Downstream of Weir	149.21 ft		
Weir Crest Elevation	146.00 ft		
Downstream head, Hd	3.21 ft		
Length of Weir, L	10.00 ft		
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>	{ 6 }		
Head on Weir, H	NA ft		
Upstream WSE	NA ft		
<u>Submerged Weir Computation</u>	{ 7 }		
K	0.08		
M	5.76		
Increment	0.10 ft		
Upstream Head, Hu1	3.22 ft		
F(H1)	0.00		
F'(H1)	-0.47		
Upstream Head, Hu2	3.22 ft		
Upstream WSE	149.22 ft		
Head over Weir	3.22 ft		
<i>Condition Upstream of Weir</i>		149.22	149.22
Second Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]	{ 2 }		
Flow	8.3 mgd = 12.8 cfs		
Number of Ports	1		
Flow Per Port	8.3 mgd = 12.8 cfs		
Port Width	10 ft		
Port Height	3 ft		
Discharge Coefficient, C	0.61		
Velocity through port, v	0.43 fps		
Orifice Energy Loss, h _L	0.01 ft		
<i>Condition Upstream of Orifice</i>		149.22	149.22



JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

	Equation Ref.	HGL	EGL
Second Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow			
WSE Downstream of Weir			
Weir Crest Elevation			
Downstream head, Hd			
Length of Weir, L			
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>			
Head on Weir, H	{ 6 }		
Upstream WSE			
<u>Submerged Weir Computation</u>			
K	{ 7 }		
M			
Increment			
Upstream Head, Hu1			
F(H1)			
F'(H1)			
Upstream Head, Hu2			
Upstream WSE			
Head over Weir			
		Condition Upstream of Weir	
		149.23	149.23
First Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]			
Flow			
Number of Ports			
Flow Per Port			
Port Width			
Port Height			
Discharge Coefficient, C			
Velocity through port, v			
Orifice Energy Loss, h _L			
		Condition Upstream of Orifice	
		149.23	149.23
First Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow			
WSE Downstream of Weir			
Weir Crest Elevation			
Downstream head, Hd			
Length of Weir, L			
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>			
Head on Weir, H	{ 6 }		
Upstream WSE			
<u>Submerged Weir Computation</u>			
K	{ 7 }		
M			
Increment			
Upstream Head, Hu1			
F(H1)			
F'(H1)			
Upstream Head, Hu2			
Upstream WSE			
Head over Weir			
		Condition Upstream of Weir	
		149.33	149.33

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

		Equation Ref.	HGL	EGL							
Pipe from Actiflo™ to Ozone											
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]		{ 4 }									
Flow	8.3 mgd = 12.8 cfs										
Pipe Diameter, D	30 inch										
Pipe Length, L	20 ft										
Absolute Roughness, ε	0.00040 ft										
Pipe velocity, v	2.60 fps										
Kinematic Viscosity	1.000E-05 ft ² /sec										
Reynold's Number, R	650002										
Friction factor, f	0.0147	Equivalent Hazen-Williams "C" = 144.1939									
Friction Energy Loss, h _f	0.01 ft										
MINOR PIPE LOSS HEADING											
Flow, Q	8.3 mgd = 12.8 cfs										
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)	
1	Entrance Loss - Flush	8.25	12.76	0.50	---	30	---	2.60	0.10	0.05	
1	Mitre Bend - 90 ° Deflection	8.25	12.76	1.27	30	---	2.60	---	0.10	0.13	
1	Butterfly Valve (Open)	8.25	12.76	0.50	30	---	2.60	---	0.10	0.05	
1	Outlet Loss - Still Water	8.25	12.76	1.00	30	---	2.60	---	0.10	0.10	
									Sum =	0.34	
Total Energy Loss =		0.36 ft									
			<i>Upstream Condition</i>			149.69	149.69				
Actiflo™ Treatment Train (Headloss provided by Kruger)											
Actiflo™ Headloss		1.184		Confirm and update for each flow condition							
			<i>Upstream Condition</i>			150.87	150.87				

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

Equation Ref.	HGL	EGL
---------------	-----	-----

Raw Water Pipe from RW Meter to Actiflo™

[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]

{ 4 }

Flow	15.0	mgd =	23.2	cfs
Pipe Diameter, D	54	inch		
Pipe Length, L	795	ft		
Absolute Roughness, ε	0.00040	ft		
Pipe velocity, v	1.46	fps		
Kinematic Viscosity	1.000E-05	ft ² /sec		
Reynold's Number, R	656567			
Friction factor, f	0.0139			
			Equivalent Hazen-Williams "C" = 148.0406	
Friction Energy Loss, h _f	0.08	ft		

MINOR PIPE LOSS HEADING

Flow, Q 15.0 mgd = 23.2 cfs

No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)
1	Outlet Loss - Still Water	15.00	23.21	1.00	54	----	1.46	----	0.03	0.03
3	Mitre Bend - 90 ° Deflection	15.00	23.21	1.27	54	----	1.46	----	0.03	0.13
1	Tee - Standard	15.00	23.21	1.50	54	----	1.46	----	0.03	0.05
1	Reducer	15.00	23.21	0.25	24	54	7.39	1.46	0.81	0.20
									Sum =	0.41

Total Energy Loss = 0.49 ft

Upstream Condition 151.36 151.36

Meter Section of RW Pipeline

[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]

{ 4 }

Flow	15.0	mgd =	23.2	cfs
Pipe Diameter, D	24	inch		
Pipe Length, L	77	ft		
Absolute Roughness, ε	0.00040	ft		
Pipe velocity, v	7.39	fps		
Kinematic Viscosity	1.000E-05	ft ² /sec		
Reynold's Number, R	1477276			
Friction factor, f	0.0144			
			Equivalent Hazen-Williams "C" = 136.6324	
Friction Energy Loss, h _f	0.47	ft		

MINOR PIPE LOSS HEADING

Flow, Q 15.0 mgd = 23.2 cfs

No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)
1	Reducer	15.00	23.21	0.25	54	24	1.46	7.39	0.85	0.21
									Sum =	0.2118

Total Energy Loss = 0.68 ft

Upstream Condition 152.04 152.04



PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

										Equation Ref.	HGL	EGL						
DOWNSTREAM CONTROL																		
<table border="1"> <tr> <td>EGL =</td> <td colspan="2">123.00</td> </tr> <tr> <td>Flow =</td> <td colspan="2">20.00 mgd = 30.94 cfs</td> </tr> </table>										EGL =	123.00		Flow =	20.00 mgd = 30.94 cfs			123.00	123.00
EGL =	123.00																	
Flow =	20.00 mgd = 30.94 cfs																	
Filter Control Weir																		
[STRAIGHT EDGED SHARP CRESTED WEIR]																		
Flow	20.00 mgd = 30.9 cfs																	
WSE Downstream of Weir	123.00 ft																	
Weir Crest Elevation	131.50 ft																	
Downstream head, Hd	-8.50 ft																	
Length of Weir, L	28.00 ft																	
WEIR IS FREE-DISCHARGING																		
<u>Free Discharging Weir Computation</u>																		
Head on Weir, H	0.48 ft									{ 6 }								
Upstream WSE	131.98 ft																	
<u>Submerged Weir Computation</u>																		
K	NA									{ 7 }								
M	NA																	
Increment	NA ft																	
Upstream Head, Hu1	NA ft																	
F(H1)	NA																	
F'(H1)	NA																	
Upstream Head, Hu2	NA ft																	
Upstream WSE	NA ft																	
Head over Weir	0.48 ft																	
<i>Condition Upstream of Weir</i>											131.98	131.98						
Piping from Filters to Filter Control Weir																		
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]																		
Flow	20.0 mgd = 30.9 cfs									{ 4 }								
Pipe Diameter, D	60 inch																	
Pipe Length, L	50 ft																	
Absolute Roughness, ε	0.00040 ft																	
Pipe velocity, v	1.58 fps																	
Kinematic Viscosity	1.000E-05 ft ² /sec																	
Reynold's Number, R	787881																	
Friction factor, f	0.0135																	
Friction Energy Loss, h _f	0.01 ft																	
MINOR PIPE LOSS HEADING																		
Flow, Q	20.0 mgd = 30.9 cfs																	
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)								
1	Outlet Loss - Still Water	20.00	30.94	1.00	----	60	----	1.58	0.04	0.04								
1	Tee - Thru Straight Run	20.00	30.94	0.60	60	----	1.58	----	0.04	0.02								
1	Increaser	20.00	30.94	0.25	60	54	1.58	1.95	-0.02	-0.01								
									Sum =	0.06								
	Total Energy Loss =		0.06 ft															
<i>Upstream Condition</i>											132.04	132.04						

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

Equation Ref.	HGL	EGL
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]		
{ 4 }		
Flow	20.0 mgd = 30.9 cfs	
Pipe Diameter, D	54 inch	
Pipe Length, L	75 ft	
Absolute Roughness, ε	0.00040 ft	
Pipe velocity, v	1.95 fps	
Kinematic Viscosity	1.000E-05 ft ² /sec	
Reynold's Number, R	875423	
Friction factor, f	0.0134	Equivalent Hazen-Williams "C" = 146.9879
Friction Energy Loss, h _f	0.01 ft	
<i>Condition Upstream of Pipe</i>		
	132.05	132.05

Piping from Filter Underdrains to FW Pipe

[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]		
{ 4 }		
Flow	6.7 mgd = 10.3 cfs	
Pipe Diameter, D	20 inch	No. of Filters in Service 3
Pipe Length, L	15 ft	
Absolute Roughness, ε	0.00040 ft	
Pipe velocity, v	4.73 fps	
Kinematic Viscosity	1.000E-05 ft ² /sec	
Reynold's Number, R	787881	
Friction factor, f	0.0153	Equivalent Hazen-Williams "C" = 139.3849
Friction Energy Loss, h _f	0.05 ft	

MINOR PIPE LOSS HEADING

Flow, Q	6.7 mgd = 10.3 cfs									
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)
1	Entrance Loss - Flush	6.67	10.31	0.50	---	20	---	4.73	0.35	0.17
1	Tee - Thru Side Outlet	6.67	10.31	1.80	20	---	4.73	---	0.35	0.62
1	90 ° Elbow - Regular Fl.	6.67	10.31	0.30	20	---	4.73	---	0.35	0.10
1	Mitre Bend - 90 ° Deflection	6.67	10.31	1.27	20	---	4.73	---	0.35	0.44
1	Entrance Loss - Flush	6.67	10.31	0.50	---	20	---	4.73	0.35	0.17
									Sum =	1.51
Total Energy Loss per Filter =		1.56 ft								
<i>Upstream Condition</i>										
									133.62	133.62

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

		Equation Ref.	HGL	EGL
Filters (1 of 4)				
[GRAVITY SAND FILTER]		{ 10 }		
Flow	7.3 mgd = 11.3 cfs			
Area of Filter Bed	460 sf			
Superficial Velocity, Vo	0.025 fps			
Vo, SI Units	0.008 m/s			
Kinematic viscosity, v	1.1E-06 m ² /s			
GAC Layer				
Grain diameter, d	0.0014 m			
Bed Porosity, E'	0.5			
Bed Foulness (% of E)	0%			
Effective Porosity, E	0.5			
Bed depth, L	6 ft			
Bed depth, L - SI Units	1.83 m			
Head Loss, SI Units	0.34 m			
Head Loss	1.10 ft			
Sand Layer				
Grain diameter, d	0.00045 m			
Bed Porosity, E'	0.5			
Bed Foulness (% of E)	0%			
Effective Porosity, E	0.5			
Bed depth, L	1 ft			
Bed depth, L - SI Units	0.30 m			
Head Loss, SI Units	0.48 m			
Head Loss	1.59 ft			
Total Filter Energy Loss	2.69 ft			
<i>Condition Upstream of Filter</i>			136.31	136.31
Filter Distribution/Influent Weir				
[STRAIGHT EDGED SHARP CRESTED WEIR]				
Flow	7.3 mgd = 11.3 cfs			
WSE Downstream of Weir	145.65 ft			
Weir Crest Elevation	146.50 ft			
Downstream head, Hd	-0.85 ft			
Length of Weir, L	10.00 ft			
WEIR IS FREE-DISCHARGING				
<u>Free Discharging Weir Computation</u>		{ 6 }		
Head on Weir, H	0.49 ft			
Upstream WSE	146.99 ft			
<u>Submerged Weir Computation</u>		{ 7 }		
K	NA			
M	NA			
Increment	NA ft			
Upstream Head, Hu1	NA ft			
F(H1)	NA			
F'(H1)	NA			
Upstream Head, Hu2	NA ft			
Upstream WSE	NA ft			
Head over Weir	0.49 ft			
<i>Condition Upstream of Weir</i>			146.99	146.99

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00

REVISION: _____

CHECKED : _____
DATE : _____

BY : Josh Miner
DATE : 1/22/2018

											Equation Ref.	HGL	EGL		
Filter Distribution Channel															
MINOR CHANNEL LOSS HEADING															
Flow, Q		22.0 mgd = 34.0 cfs		Channel Invert		141.5									
No.	Description	Flow (mgd)	Flow (cfs)	K	Width Up (ft)	Width Down (ft)	Depth (ft)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)				
1	Entrance - Sharp Corners	22.00	34.03	0.50	10	10	5.49	0.62	0.62	0.00	0.00				
1	90 Degree Bend - 0° Radius	22.00	34.03	1.30	10	----	5.49	0.62	----	0.01	0.01				
											Sum =			0.01	
Total Energy Loss =		0.01 ft													
											Upstream Condition	147.00	147.00		
Ozone to Filter Pipe															
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]											{ 4 }				
Flow		22.0 mgd = 34.0 cfs													
Pipe Diameter, D		60 inch													
Pipe Length, L		60 ft													
Absolute Roughness, ε		0.00040 ft													
Pipe velocity, v		1.73 fps													
Kinematic Viscosity		1.000E-05 ft ² /sec													
Reynold's Number, R		866669													
Friction factor, f		0.0133		Equivalent Hazen-Williams "C" = 147.668											
Friction Energy Loss, h _f		0.01 ft													
MINOR PIPE LOSS HEADING															
Flow, Q		22.0 mgd = 34.0 cfs													
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)					
1	Entrance Loss - Flush	22.00	34.03	0.50	----	60	----	1.73	0.05	0.02					
1	Outlet Loss - Still Water	22.00	34.03	1.00	60	----	1.73	----	0.05	0.05					
											Sum =			0.07	
Total Energy Loss =		0.08 ft													
											Upstream Condition	147.07	147.07		

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

		Equation Ref.	HGL	EGL
Ozone Contactor Effluent Weir				
[STRAIGHT EDGED SHARP CRESTED WEIR]				
Flow	11.0 mgd = 17.0 cfs			
WSE Downstream of Weir	147.07 ft			
Weir Crest Elevation	148.67 ft			
Downstream head, Hd	-1.60 ft			
Length of Weir, L	10.00 ft			
Free Discharging Weir Computation				
Head on Weir, H	0.64 ft	{ 6 }		
Upstream WSE	149.31 ft			
Submerged Weir Computation				
K	NA	{ 7 }		
M	NA			
Increment	NA ft			
Upstream Head, Hu1	NA ft			
F(H1)	NA			
F'(H1)	NA			
Upstream Head, Hu2	NA ft			
Upstream WSE	NA ft			
Head over Weir	0.64 ft			
			Condition Upstream of Weir	149.31 149.31
Last Ozone Under Baffle				
[SUBMERGED ORIFICE (RECTANGULAR)]				
Flow	11.0 mgd = 17.0 cfs			
Number of Ports	1			
Flow Per Port	11.0 mgd = 17.0 cfs			
Port Width	10 ft			
Port Height	3 ft			
Discharge Coefficient, C	0.61			
Velocity through port, v	0.57 fps			
Orifice Energy Loss, h _L	0.01 ft			
			Condition Upstream of Orifice	149.32 149.32
Last Ozone Contactor Weir/Over Baffle				
[STRAIGHT EDGED SHARP CRESTED WEIR]				
Flow	11.0 mgd = 17.0 cfs			
WSE Downstream of Weir	149.32 ft			
Weir Crest Elevation	146.00 ft			
Downstream head, Hd	3.32 ft			
Length of Weir, L	10.00 ft			
WEIR IS SUBMERGED				
Free Discharging Weir Computation				
Head on Weir, H	NA ft	{ 6 }		
Upstream WSE	NA ft			
Submerged Weir Computation				
K	0.17	{ 7 }		
M	6.06			
Increment	0.10 ft			
Upstream Head, Hu1	3.33 ft			
F(H1)	0.00			
F'(H1)	-0.45			
Upstream Head, Hu2	3.33 ft			
Upstream WSE	149.33 ft			
Head over Weir	3.33 ft			
			Condition Upstream of Weir	149.33 149.33



JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

	Equation Ref.	HGL	EGL
Third Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]	{ 2 }		
Flow	11.0 mgd = 17.0 cfs		
Number of Ports	1		
Flow Per Port	11.0 mgd = 17.0 cfs		
Port Width	10 ft		
Port Height	3 ft		
Discharge Coefficient, C	0.61		
Velocity through port, v	0.57 fps		
Orifice Energy Loss, h _L	0.01 ft		
<i>Condition Upstream of Orifice</i>		149.34	149.34
Third Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow	11.0 mgd = 17.0 cfs		
WSE Downstream of Weir	149.34 ft		
Weir Crest Elevation	146.00 ft		
Downstream head, Hd	3.34 ft		
Length of Weir, L	10.00 ft		
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>	{ 6 }		
Head on Weir, H	NA ft		
Upstream WSE	NA ft		
<u>Submerged Weir Computation</u>	{ 7 }		
K	0.17		
M	6.10		
Increment	0.10 ft		
Upstream Head, Hu1	3.34 ft		
F(H1)	0.00		
F'(H1)	-0.45		
Upstream Head, Hu2	3.34 ft		
Upstream WSE	149.34 ft		
Head over Weir	3.34 ft		
<i>Condition Upstream of Weir</i>		149.34	149.34
Second Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]	{ 2 }		
Flow	11.0 mgd = 17.0 cfs		
Number of Ports	1		
Flow Per Port	11.0 mgd = 17.0 cfs		
Port Width	10 ft		
Port Height	3 ft		
Discharge Coefficient, C	0.61		
Velocity through port, v	0.57 fps		
Orifice Energy Loss, h _L	0.01 ft		
<i>Condition Upstream of Orifice</i>		149.36	149.36



JOB # : 10721A00

REVISION:

CHECKED :
DATE :

BY : Josh Miner
DATE : 1/22/2018

	Equation Ref.	HGL	EGL
Second Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow			
			11.0 mgd = 17.0 cfs
WSE Downstream of Weir		149.36 ft	
Weir Crest Elevation		146.00 ft	
Downstream head, Hd		3.36 ft	
Length of Weir, L		10.00 ft	
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>			
Head on Weir, H	{ 6 }	NA ft	
Upstream WSE		NA ft	
<u>Submerged Weir Computation</u>			
K	{ 7 }	0.17	
M		6.15	
Increment		0.10 ft	
Upstream Head, Hu1		3.36 ft	
F(H1)		0.00	
F'(H1)		-0.45	
Upstream Head, Hu2		3.36 ft	
Upstream WSE		149.36 ft	
Head over Weir		3.36 ft	
		<i>Condition Upstream of Weir</i>	
		149.36	149.36
First Ozone Under Baffle			
[SUBMERGED ORIFICE (RECTANGULAR)]			
Flow			11.0 mgd = 17.0 cfs
Number of Ports		1	
Flow Per Port		11.0 mgd = 17.0 cfs	
Port Width		10 ft	
Port Height		3 ft	
Discharge Coefficient, C		0.61	
Velocity through port, v		0.57 fps	
Orifice Energy Loss, h _L		0.01 ft	
		<i>Condition Upstream of Orifice</i>	
		149.37	149.37
First Ozone Contactor Weir/Over Baffle			
[STRAIGHT EDGED SHARP CRESTED WEIR]			
Flow			11.0 mgd = 17.0 cfs
WSE Downstream of Weir		149.37 ft	
Weir Crest Elevation		148.50 ft	
Downstream head, Hd		0.87 ft	
Length of Weir, L		10.00 ft	
WEIR IS SUBMERGED			
<u>Free Discharging Weir Computation</u>			
Head on Weir, H	{ 6 }	NA ft	
Upstream WSE		NA ft	
<u>Submerged Weir Computation</u>			
K	{ 7 }	0.17	
M		0.82	
Increment		0.10 ft	
Upstream Head, Hu1		1.00 ft	
F(H1)		0.00	
F'(H1)		-1.94	
Upstream Head, Hu2		1.00 ft	
Upstream WSE		149.50 ft	
Head over Weir		1.00 ft	
		<i>Condition Upstream of Weir</i>	
		149.50	149.50

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

		Equation Ref.	HGL	EGL							
Pipe from Actiflo™ to Ozone											
[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]		{ 4 }									
Flow	11.0 mgd = 17.0 cfs										
Pipe Diameter, D	30 inch										
Pipe Length, L	20 ft										
Absolute Roughness, ε	0.00040 ft										
Pipe velocity, v	3.47 fps										
Kinematic Viscosity	1.000E-05 ft ² /sec										
Reynold's Number, R	866669										
Friction factor, f	0.0144	Equivalent Hazen-Williams "C" =		142.603							
Friction Energy Loss, h _f	0.02 ft										
MINOR PIPE LOSS HEADING											
Flow, Q	11.0 mgd = 17.0 cfs										
No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)	
1	Entrance Loss - Flush	11.00	17.02	0.50	---	30	---	3.47	0.19	0.09	
1	Mitre Bend - 90 ° Deflection	11.00	17.02	1.27	30	---	3.47	---	0.19	0.24	
1	Butterfly Valve (Open)	11.00	17.02	0.50	30	---	3.47	---	0.19	0.09	
1	Outlet Loss - Still Water	11.00	17.02	1.00	30	---	3.47	---	0.19	0.19	
									Sum =	0.61	
Total Energy Loss =		0.63 ft									
					<i>Upstream Condition</i>					150.13	150.13
Actiflo™ Treatment Train (Headloss provided by Kruger)											
Actiflo™ Headloss		1.184			Confirm and update for each flow condition						
					<i>Upstream Condition</i>					151.31	151.31

PROJECT : Willamette River Water Treatment Plant 2017 MPU

JOB # : 10721A00 REVISION:

CHECKED : BY : Josh Miner
DATE : DATE : 1/22/2018

Equation Ref.	HGL	EGL
---------------	-----	-----

Raw Water Pipe from RW Meter to Actiflo™

[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]

{ 4 }

Flow	20.0	mgd =	30.9	cfs
Pipe Diameter, D	54	inch		
Pipe Length, L	795	ft		
Absolute Roughness, ε	0.00040	ft		
Pipe velocity, v	1.95	fps		
Kinematic Viscosity	1.000E-05	ft ² /sec		
Reynold's Number, R	875423			
Friction factor, f	0.0134			
			Equivalent Hazen-Williams "C" = 146.9879	
Friction Energy Loss, h _f	0.14	ft		

MINOR PIPE LOSS HEADING

Flow, Q 20.0 mgd = 30.9 cfs

No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)
1	Outlet Loss - Still Water	20.00	30.94	1.00	54	----	1.95	----	0.06	0.06
3	Mitre Bend - 90 ° Deflection	20.00	30.94	1.27	54	----	1.95	----	0.06	0.22
1	Tee - Standard	20.00	30.94	1.50	54	----	1.95	----	0.06	0.09
1	Increaser	20.00	30.94	0.25	24	54	9.85	1.95	1.45	0.36
									Sum =	0.73

Total Energy Loss = 0.87 ft

Upstream Condition 152.18 152.18

Meter Section of RW Pipeline

[PIPE FRICTION LOSSES (DARCY-WEISBACH / COLEBROOK)]

{ 4 }

Flow	20.0	mgd =	30.9	cfs
Pipe Diameter, D	24	inch		
Pipe Length, L	77	ft		
Absolute Roughness, ε	0.00040	ft		
Pipe velocity, v	9.85	fps		
Kinematic Viscosity	1.000E-05	ft ² /sec		
Reynold's Number, R	1969702			
Friction factor, f	0.0142			
			Equivalent Hazen-Williams "C" = 134.2704	
Friction Energy Loss, h _f	0.83	ft		

MINOR PIPE LOSS HEADING

Flow, Q 20.0 mgd = 30.9 cfs

No.	Description	Flow (mgd)	Flow (cfs)	K	Dia Up (in)	Dia Down (in)	Vel Up (fps)	Vel Down (fps)	Vel Head (ft)	Minor Loss (ft)
1	Reducer	20.00	30.94	0.25	54	24	1.95	9.85	1.51	0.38
									Sum =	0.3765

Total Energy Loss = 1.20 ft

Upstream Condition 153.38 153.38



MEETING MEMORANDUM (Rev 1)

Project: Willamette River Water Treatment Plant 2017 Master Plan Update
Conf. Date: August 15, 2017

Client: City of Wilsonville, City of Sherwood
Issue Date: September 5, 2017

Location: City of Wilsonville Conference Room
Project No.: 10721A00

Purpose: The goals of this meeting was to: discuss equipment and instrumentation status to support the on-going CIP evaluation.

Attendees: **Veolia:** Kim Reid, Shane Wyer
Portland Engineering: Carl Serpa
Carollo: Meghann Chell

Distribution: Attendees, Eric Mende (City of Wilsonville), Mike Green (Veolia), Jude Grounds (Carollo)

Discussion:

The following is our understanding of the subject matter covered in this conference. If this differs from your understanding, please notify us.

- 1) Confirm HP sizes attached to MCC-19
 - a) Estimate total loads at 15 HP
 - i) Seven of the loads are exhaust fans, estimated at 1.5 HP each
 - ii) Booster pumps for aqueous ammonia system estimated at 7.5 HP but are not used
 - b) Carollo will follow up if more information needed
- 2) Request for daily electrical loads and plant flow rates from SCADA historian
 - a) Veolia emailed requested information to Carollo on Tuesday August 15th
- 3) Electrical and mechanical equipment discussion:
 - a) Concerned about insufficient redundancy for raw and finished water pump stations, which primarily operate on the 4 MGD pumps
 - b) Plant-wide PLC upgrade taking place before end of 2017 fiscal year. Recommend vendor PLC upgrade within next five years. Plant PLCs should be able to supply spare parts for vendor PLC maintenance during that period.
 - c) Robocon VFDs on finished water pumps 9-P-1 and 9-P-2 are obsolete and no longer supported. On CIP for replacement of one each year in next two fiscal years.
 - d) ABB flow meters are obsolete and no longer supported. Transmitters are failing and cannot be replaced. Primary concern is meter on the intake vault, which controls all downstream processes. This meter recently failed and required manual plant control until transmitter was temporarily replaced with transmitter from finished water unit. This also impacts the meter on Wilsonville Road.
 - e) Currently only two Actiflo solids pumps in service, one standing by but not connected, and two pending service by Mather&Sons. May require additional shelf spare pumps for higher flow rates due to some lag in pump service.

- f) Actiflo troughs over the lamella tubes are becoming brittle, so operators no longer walk on them. If replaced would recommend upgrading to stainless steel. Priority is Actiflo train #2 since that it is connected to emergency generator.
 - g) Several IQ Analyzers on MCCs are burned out or broken
 - h) CIP evaluation should review analyzers (e.g., turbidimeters, ozone sensors, etc.) for replacement of obsolete and unserviceable units
 - i) Recommend sparge valves added to the washwater basin near pump bells to prevent solids uptake
 - j) During intake pipe screen upgrade, recommended extending the sparge system to the intake pipe improve solids/sediment removal.
 - k) Plant is currently utilizing all chemical pipe capacity, so will need to take this into consideration for CIP. This is a larger concern than chemical pumps since those are low dollar value.
- 4) Life safety and security discussion:
- a) Exterior lighting system is a concern now that plant is operating 24-hours. Initial design utilized sodium vapor lamps and was concerned with off-site spillage. Nighttime operator cannot see into process units on the Actiflo deck and the lighting by the thickener is not functional. Temporary spotlights are currently required when working in these areas.
 - b) Plant security system is becoming unreliable. Nighttime operator cannot see who is at the front door.
 - c) Adding connection points for temporary safety barriers at centrifuges and other equipment

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA

REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	SWGR-MAIN 'MS'	PHASE, WIRE, KASC	3PH, 3W, 14 KASC
DESCRIPTION		LARGEST MOTOR	500HP
LOCATION	OUTDOOR MAIN MS	COMMENTS	OWNED BY THE CITY OF WILSONVILLE 300 MVA PER ASBUIT
VOLTAGE	12470		
BUS AMPS	600		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
3627.4	167.9

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
4534.3	209.9

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
3868.1	179.1

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

SUBFED EQUIPMENT

TAG	DESCRIPTION	EQUIPMENT SIZE	EQUIPMENT UNITS	STATUS	OPERATING KVA	OPERATING AMPS	BUS COMMENTS
XFMR T1		1,500.0	KVA	EXISTING	1513.1	70.1	
XFMR T2		2,000.0	KVA	EXISTING	2114.3	97.9	
OPERATING LOAD SUBFED SUBTOTAL					3627.4	167.9	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	17-MVMCC-A	PHASE, WIRE, KASC	3PH, 3W, 14 KASC
DESCRIPTION	WALKIN	LARGEST MOTOR	500HP
LOCATION	OUTDOOR MAIN MS	COMMENTS	350 MVA PER AS BUILT
VOLTAGE	4160		
BUS AMPS	3000		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
1513.1	210.0

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
1891.4	262.5

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
1639.2	227.5

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
9-P-1	FINISHED WATER PUMP	500	HP	VFD-18	DUTY / CONTINUOUS	EXISTING	504.4	70.0	
9-P-2	FINISHED WATER PUMP	500	HP	VFD-18	DUTY / CONTINUOUS	EXISTING	504.4	70.0	
9-P-3	FINISHED WATER PUMP	500	HP	RVSS	DUTY / CONTINUOUS	EXISTING	504.4	70.0	
OPERATING LOAD SUBTOTAL							1513.1	210.0	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 17-SWBD-A
DESCRIPTION
LOCATION OUTDOOR MAIN MS
VOLTAGE 480
BUS AMPS 3000
PHASE, WIRE, KASC 3PH, 3W, 65 KAIC KASC
LARGEST MOTOR 300HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
2114.3	2543.1

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
2642.9	3178.9

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
2303.9	2771.2

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

SUBFED EQUIPMENT

TAG	DESCRIPTION	EQUIPMENT SIZE	EQUIPMENT UNITS	STATUS	OPERATING KVA	OPERATING AMPS	BUS COMMENTS
15-MCC-A	TO HSPS	1,200.0	AMPS	EXISTING	408.0	490.8	
4-MCC-A	TO ACTIFLO BLDG	600.0	AMPS	EXISTING	51.4	61.8	
6-MCC-A	TO FILTER GALLERY	600.0	AMPS	EXISTING	113.6	136.7	
8-MCC-A	TO WASTE WASH. EQ.	600.0	AMPS	EXISTING	29.5	35.5	
15-SWBD-B	TO HSPS (STDBY)	2,000.0	AMPS	EXISTING	1015.9	1221.9	
13-DP-A	TO CHEM BUILDING	800.0	AMPS	EXISTING	96.8	116.4	
OPERATING LOAD SUBFED SUBTOTAL					1715.2	2063.1	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
2-P-1	RAW WATER PUMP	200	HP	VFD-18	DUTY / CONTINUOUS	EXISTING	199.5	240.0	
2-P-2	RAW WATER PUMP	200	HP	VFD-18	DUTY / CONTINUOUS	EXISTING	199.5	240.0	
OPERATING LOAD SUBTOTAL							399.1	480.0	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 13-DP-A
DESCRIPTION TO CHEM BUILDING
LOCATION
VOLTAGE 480
BUS AMPS 800
PHASE, WIRE, KASC 3PH, 3W, 42 KAIC KASC
LARGEST MOTOR 55HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
96.8	116.4

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
121.0	145.5

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
120.3	144.8

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
12-ME-1	CENTRIFUGE #1	55	HP	RVSS	DUTY / CONTINUOUS	EXISTING	0.0	0.0	
12-ME-2	CENTRIFUGE #2	55	HP		STANDBY	EXISTING	0.0	0.0	
12-ME-3	CENTRIFUGE SOLIDS CONVEYOR	2	HP		DUTY / CONTINUOUS	EXISTING	2.8	3.4	
12-ME-4	CENTRIFUGE HOIST	5	HP		STANDBY	EXISTING	0.0	0.0	
13-MAU-1	CHEM BLDG. FAN	1.50	HP		DUTY / CONTINUOUS	EXISTING	2.5	3.0	
19-ME-1	OZONE GENERATOR 1	100	KW		STANDBY	EXISTING	0.0	0.0	
RTU-1	ADMIN KITCHEN	27	AMP		DUTY / CONTINUOUS	EXISTING	22.4	27.0	
RTU-3	ADMIN-LAB	23	AMP		DUTY / CONTINUOUS	EXISTING	19.1	23.0	
SPARE	XX	40	AMP		DUTY / CONTINUOUS	EXISTING	33.3	40.0	
SPARES	(TYP OF 7)	20	AMP		DUTY / CONTINUOUS	EXISTING	16.6	20.0	
OPERATING LOAD SUBTOTAL							96.8	116.4	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 15-MCC-A
DESCRIPTION TO HSPS
LOCATION
VOLTAGE 480
BUS AMPS 1200
PHASE, WIRE, KASC 3PH, 3W, 65 KAIC KASC
LARGEST MOTOR 200HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
408.0	490.8

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
510.1	613.5

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
457.9	550.8

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
07-MOV-1	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
07-MOV-2	MOV	1	HP		STANDBY	EXISTING	0.0	0.0	
07-P-1	BACKWASH PUMP	150	HP	FVNR	DUTY / CONTINUOUS	EXISTING	149.6	180.0	
07-P-2	BACKWASH PUMP	150	HP	FVNR	STANDBY	EXISTING	0.0	0.0	
09-MOV-1	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
09-MOV-2	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
09-MOV-3	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
16-F-2	ELECTRICAL RM FAN	3	HP	FVNR	DUTY / CONTINUOUS	EXISTING	4.0	4.8	
1-ME-2	INTAKE SCREEN COMPRESSOR	50	HP	RVSS	STANDBY	EXISTING	0.0	0.0	
2-P-3	RAW WATER PUMP	200	HP	FVNR	DUTY / CONTINUOUS	EXISTING	199.5	240.0	
30-P-1	IRRIGATION RECIRC PUMP	40	HP		DUTY / CONTINUOUS	EXISTING	43.2	52.0	
7-F-2	ELECTRICAL RM FAN	2	HP	FVNR	DUTY / CONTINUOUS	EXISTING	2.8	3.4	
9-F-1	ELECTRICAL RM FAN	1/4	HP	FVNR	DUTY / CONTINUOUS	EXISTING	0.9	1.1	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	15-MCC-A	
DESCRIPTION	TO HSPS	PHASE, WIRE, KASC 3PH, 3W, 65 KAIC KASC
LOCATION		LARGEST MOTOR 200HP
VOLTAGE	480	COMMENTS
BUS AMPS	1200	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
9-F-2	ELECTRICAL RM FAN	1/2	HP	FVNR	DUTY / CONTINUOUS	EXISTING	0.9	1.1	
BRIDGE CRANE-15-MCC-A	HSPS	20	HP		STANDBY	EXISTING	0.0	0.0	
OPERATING LOAD SUBTOTAL							408.0	490.8	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 15-SWBD-B
DESCRIPTION TO HSPS (STDBY) **PHASE, WIRE, KASC** 3PH, 3W, 65 KAIC KASC
LOCATION **LARGEST MOTOR** 300HP
VOLTAGE 480 **COMMENTS**
BUS AMPS 2000

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
1015.9	1221.9

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
1269.9	1527.4

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
1180.9	1420.4

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

SUBFED EQUIPMENT

TAG	DESCRIPTION	EQUIPMENT SIZE	EQUIPMENT UNITS	STATUS	OPERATING KVA	OPERATING AMPS	BUS COMMENTS
4-MCC-B	TO ACTI FLD BLDG.	600.0	AMPS	EXISTING	139.7	168.0	
13-DP-B	TO CHEM BLDG.	800.0	AMPS	EXISTING	364.8	438.8	
17-MVMCC-A-LP	LIGHTING PANEL	100.0	AMPS	EXISTING	0.0	0.0	
2-DP-B	INTAKE PS DISTR PANEL	100.0	AMPS	EXISTING	47.7	57.3	
6-DP-B	FILTER GALLERY DISTR PANEL	100.0	AMPS	EXISTING	0.0	0.0	
XFMR-8-LP-B		30.0	KVA	EXISTING	15.0	18.0	
XFMR-9-LP-B	TRANSFORMER	30.0	KVA	EXISTING	15.0	18.0	
OPERATING LOAD SUBFED SUBTOTAL					582.2	700.2	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
1-ME-1	INTAKE SCREEN COMPRESSOR	50	HP	RVSS	STANDBY	EXISTING	0.0	0.0	
20-P-1	SANITARY SEWER PUMP 1	5	HP		DUTY / CONTINUOUS	EXISTING	6.3	7.6	
20-P-2	SANITARY SEWER PUMP 2	5	HP		STANDBY	EXISTING	0.0	0.0	
2-P-4	RAW WATER PUMP	100	HP	VFD-18	DUTY / CONTINUOUS	EXISTING	103.1	124.0	
30-P-2	IRRIGATION WASTE PUMPS	20	HP		DUTY / CONTINUOUS	EXISTING	22.4	27.0	
30-P-3	IRRIGATION WASTE PUMPS	20	HP		STANDBY	EXISTING	0.0	0.0	

Date/Time displayed in this report reflect time in PST

LOAD STUDY REPORT

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 15-SWBD-B
DESCRIPTION TO HSPS (STDBY)
LOCATION
VOLTAGE 480
BUS AMPS 2000
PHASE, WIRE, KASC 3PH, 3W, 65 KAIC KASC
LARGEST MOTOR 300HP
COMMENTS

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
9-MOV-4	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
9-P-4	FINISHED WATER PUMP	300	HP	VFD-18	DUTY / CONTINUOUS	EXISTING	300.1	361.0	
OPERATING LOAD SUBTOTAL							433.7	521.7	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 13-DP-B
DESCRIPTION TO CHEM BLDG.
LOCATION
VOLTAGE 480
BUS AMPS 800
PHASE, WIRE, KASC 3PH, 3W, 42 KAIC KASC
LARGEST MOTOR 125HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
364.8	438.8

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
456.0	548.4

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
450.5	541.9

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

SUBFED EQUIPMENT

TAG	DESCRIPTION	EQUIPMENT SIZE	EQUIPMENT UNITS	STATUS	OPERATING KVA	OPERATING AMPS	BUS COMMENTS
19-MCC-A		600.0	AMPS	EXISTING	129.7	156.0	
13-XFMR-LP-B	CHEMICAL BUILDING	30.0	KVA	EXISTING	15.0	18.0	
18-XFMR-LAB	TRANSFORMER	45.0	KVA	EXISTING	22.5	27.1	
18-XFMR-LP-B		30.0	KVA	EXISTING	15.0	18.0	
OPERATING LOAD SUBFED SUBTOTAL					182.2	219.1	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
10-MOV-1	FINISH WATER VAULT	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
19-MAU-1	OZONE GEN	10	AMP		DUTY / CONTINUOUS	EXISTING	8.3	10.0	
19-ME-2	OZONE GENERATOR 2	100	KW		DUTY / CONTINUOUS	EXISTING	117.6	141.5	
5-ME-3&4	NITROGEN BOOST CP	15	HP		DUTY / CONTINUOUS	EXISTING	17.5	21.0	
BRIDGE ONLY GATES POWER	XX	10	AMP		DUTY / CONTINUOUS	EXISTING	8.3	10.0	
EF-4	ADMIN EXHAUST FAN	1.50	HP		DUTY / CONTINUOUS	EXISTING	2.5	3.0	
RTU-2	ADMIN HAVC	22	AMP		DUTY / CONTINUOUS	EXISTING	18.3	22.0	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	13-DP-B	
DESCRIPTION	TO CHEM BLDG.	PHASE, WIRE, KASC 3PH, 3W, 42 KAIC KASC
LOCATION		LARGEST MOTOR 125HP
VOLTAGE	480	COMMENTS
BUS AMPS	800	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
SITE LIGHT CONTACTOR	XX	10	AMP		DUTY / CONTINUOUS	EXISTING	8.3	10.0	
OPERATING LOAD SUBTOTAL							182.6	219.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	13-LP-B	
DESCRIPTION	CHEMICAL BUILDING	PHASE, WIRE, KASC 3PH, 3W, 22 KAIC KASC
LOCATION		LARGEST MOTOR 0HP
VOLTAGE	208	COMMENTS
BUS AMPS	100	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
15.0	41.6

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
	13-LP-B LOAD	15	KVA		DUTY / CONTINUOUS	EXISTING	15.0	41.6	
OPERATING LOAD SUBTOTAL							15.0	41.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	18-LP-LAB	PHASE, WIRE, KASC	3PH, 3W, 22 KAIC KASC
DESCRIPTION	ADMIN LAB PANEL	LARGEST MOTOR	0HP
LOCATION		COMMENTS	
VOLTAGE	208		
BUS AMPS	100		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
22.5	62.5

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
28.1	78.1

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
28.1	78.1

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
	18-LP-LAB-LOAD	22.50	KVA		DUTY / CONTINUOUS	EXISTING	22.5	62.5	
OPERATING LOAD SUBTOTAL							22.5	62.5	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	18-LP-B	
DESCRIPTION	ADMIN BUILDING PANEL	PHASE, WIRE, KASC 3PH, 3W, 22 KAIC KASC
LOCATION		LARGEST MOTOR 0HP
VOLTAGE	208	COMMENTS
BUS AMPS	100	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
15.0	41.6

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
18-LP-B-LOAD		15	KVA		DUTY / CONTINUOUS	EXISTING	15.0	41.6	
OPERATING LOAD SUBTOTAL							15.0	41.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 19-MCC-A
DESCRIPTION
LOCATION
VOLTAGE 480
BUS AMPS 600
PHASE, WIRE, KASC 3PH, 3W, 65 KAIC KASC
LARGEST MOTOR 125HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
129.7	156.0

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
162.1	195.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
162.1	195.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
13-EF-1	CHEMICAL NORTH	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
13-EF-2	CHEMICAL SOUTH	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
18-EF-4	ADMIN	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
18-EF-5	ADMIN	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
19-F-1	OZONE GEN	125	HP	RVSS	DUTY / CONTINUOUS	EXISTING	129.7	156.0	LOAD HP IS ASSUMED AND IS FOR THE ENTIRE MCC
BOOSTER PUMP 1	CHEMICAL BUILDING	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
BOOSTER PUMP 2	CHEMICAL BUILDING	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
SPARE-19-MCC-A	TYP OF 2	0			DUTY / CONTINUOUS	EXISTING	0.0	0.0	
OPERATING LOAD SUBTOTAL							129.7	156.0	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	17-MVMCC-A-LP	
DESCRIPTION	LIGHTING PANEL	PHASE, WIRE, KASC 3PH, 3W, 22 KAIC KASC
LOCATION		LARGEST MOTOR 0HP
VOLTAGE	480	COMMENTS
BUS AMPS	100	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
0.0	0.0

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
0.0	0.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
0.0	0.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

PROJECT INFORMATION

PROJECT	WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT	CITY OF WILSONVILLE
PROJECT NUMBER	10002A60
REPORT BY	JAMSHID DORAFSHA
REPORT DATE	1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	2-DP-B	PHASE, WIRE, KASC	3PH, 3W, 22 KAIC KASC
DESCRIPTION	INTAKE PS DISTR PANEL	LARGEST MOTOR	2HP
LOCATION		COMMENTS	
VOLTAGE	480		
BUS AMPS	100		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
47.7	57.3

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
59.6	71.7

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
56.3	67.7

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

SUBFED EQUIPMENT

TAG	DESCRIPTION	EQUIPMENT SIZE	EQUIPMENT UNITS	STATUS	OPERATING KVA	OPERATING AMPS	BUS COMMENTS
2-MCC-A	INTAKE PUMP STATION	600.0	AMPS	EXISTING	9.1	10.9	
2-XFMR	TRANSFORMER	30.0	KVA	EXISTING	15.0	18.0	
OPERATING LOAD SUBFED SUBTOTAL					24.1	28.9	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
2-MOV-1	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
2-P-6	CASSION DEWATERING PUMP	10	HP		STANDBY	EXISTING	0.0	0.0	
3-MOV-1	MOV	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
AIR COMPRESSOR ROOM HEATER	XX	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
BRIDGE CRANE	XX	1	HP		STANDBY	EXISTING	0.0	0.0	
SANITARY SEWAGE CONTROL PANEL CP		20	AMP		DUTY / CONTINUOUS	EXISTING	16.6	20.0	
SUMP PUMP	XX	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
OPERATING LOAD SUBTOTAL							23.6	28.4	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	2-MCC-A	
DESCRIPTION	INTAKE PUMP STATION	PHASE, WIRE, KASC 3PH, 3W, 65 KAIC KASC
LOCATION		LARGEST MOTOR 2HP
VOLTAGE	480	COMMENTS
BUS AMPS	600	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
9.1	10.9

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
11.3	13.6

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
9.8	11.8

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
2-F-1	VENTILATION FAN	1/4	HP		DUTY / CONTINUOUS	EXISTING	0.9	1.1	
2-F-11	COMPRESSOR ROOM COOLING FAN	2	HP		DUTY / CONTINUOUS	EXISTING	2.8	3.4	
2-F-2	PUMP ROOM COOLING FAN	2	HP		DUTY / CONTINUOUS	EXISTING	2.8	3.4	
2-F-7	ELECTRICAL ROOM COOLING FAN	1.50	HP		DUTY / CONTINUOUS	EXISTING	2.5	3.0	
OPERATING LOAD SUBTOTAL							9.1	10.9	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	2-LP-13	PHASE, WIRE, KASC	3PH, 3W, 22 KAIC KASC
DESCRIPTION	LIGHTING PANEL	LARGEST MOTOR	0HP
LOCATION		COMMENTS	
VOLTAGE	208		
BUS AMPS	100		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
15.0	41.6

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
	2-LP-13-LOAD	15	KVA		DUTY / CONTINUOUS	NEW	15.0	41.6	
OPERATING LOAD SUBTOTAL							15.0	41.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 4-MCC-B
DESCRIPTION TO ACTI FLD BLDG.
LOCATION
VOLTAGE 480
BUS AMPS 600
PHASE, WIRE, KASC 3PH, 3W, 42 KAIC KASC
LARGEST MOTOR 15HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
139.7	168.0

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
174.6	210.1

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
165.3	198.8

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

SUBFED EQUIPMENT

TAG	DESCRIPTION	EQUIPMENT SIZE	EQUIPMENT UNITS	STATUS	OPERATING KVA	OPERATING AMPS	BUS COMMENTS
XFMR-4-LP-B		30.0	KVA	NEW	15.0	18.0	
OPERATING LOAD SUBFED SUBTOTAL					15.0	18.0	

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
04-ME-10	MECHANICAL MIXER	10	HP	VFD-6	DUTY / CONTINUOUS	EXISTING	11.6	14.0	
04-ME-11	SLUDGE SCRAPER (SETTLING TANK)	3	HP	VFD-6	DUTY / CONTINUOUS	EXISTING	4.0	4.8	
04-ME-8	MECHANICAL MIXER	7.50	HP		DUTY / CONTINUOUS	EXISTING	9.1	11.0	
04-ME-9	MECHANICAL MIXER	7.50	HP		DUTY / CONTINUOUS	EXISTING	9.1	11.0	
04-MOV-1	XX	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
04-MOV-2	XX	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
04-P-3	RECIRC. PUMP	15	HP		DUTY / CONTINUOUS	EXISTING	17.5	21.0	
04-P-4	RECIRC. PUMP MICROSAND	15	HP		STANDBY	EXISTING	0.0	0.0	
05-LCP-4	TO DESTRUCT BUILDING	14	AMP		DUTY / CONTINUOUS	EXISTING	11.6	14.0	
5-F-1	XX	50	AMP		DUTY / CONTINUOUS	EXISTING	41.6	50.0	
5-MAU-1	XX	20	AMP		DUTY / CONTINUOUS	EXISTING	16.6	20.0	
OPERATING LOAD SUBTOTAL							124.7	150.0	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	4-LP-B	
DESCRIPTION	ACTIIFLO BLDG LIGHTING PANEL	PHASE, WIRE, KASC 3PH, 3W, 22 KAIC KASC
LOCATION		LARGEST MOTOR 0HP
VOLTAGE	208	COMMENTS
BUS AMPS	100	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
15.0	41.6

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
4-LP-B-LOAD		15	KVA		DUTY / CONTINUOUS	EXISTING	15.0	41.6	
OPERATING LOAD SUBTOTAL							15.0	41.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	6-DP-B	
DESCRIPTION	FILTER GALLERY DISTER PANEL	PHASE, WIRE, KASC 3PH, 3W, 22 KAIC KASC
LOCATION		LARGEST MOTOR 0HP
VOLTAGE	480	COMMENTS
BUS AMPS	100	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
0.0	0.0

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
0.0	0.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
0.0	0.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	8-LP-B	
DESCRIPTION	WWPS LIGHTING PANEL	PHASE, WIRE, KASC 3PH, 3W, 22 KAIC KASC
LOCATION		LARGEST MOTOR 0HP
VOLTAGE	208	COMMENTS
BUS AMPS	100	

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
15.0	41.6

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
	8-LP-B-LOAD	15	KVA		DUTY / CONTINUOUS	EXISTING	15.0	41.6	
OPERATING LOAD SUBTOTAL							15.0	41.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONWILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	9-LP-B	PHASE, WIRE, KASC	3PH, 3W, 22 KAIC KASC
DESCRIPTION	HSPS LIGHTING PANEL	LARGEST MOTOR	0HP
LOCATION		COMMENTS	
VOLTAGE	208		
BUS AMPS	100		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
15.0	41.6

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
18.8	52.0

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
	9-LP-B-LOAD	15	KVA		DUTY / CONTINUOUS	EXISTING	15.0	41.6	
OPERATING LOAD SUBTOTAL							15.0	41.6	

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 4-MCC-A
DESCRIPTION TO ACTIFLO BLDG
LOCATION
VOLTAGE 480
BUS AMPS 600
PHASE, WIRE, KASC 3PH, 3W, 42 KAIC KASC
LARGEST MOTOR 15HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
51.4	61.8

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
64.2	77.3

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
55.7	67.1

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
04-ME-1	MECHANICAL MIXER	7.50	HP	FVNR	DUTY / CONTINUOUS	EXISTING	9.1	11.0	
04-ME-2	MECHANICAL MIXER	7.50	HP	FVNR	DUTY / CONTINUOUS	EXISTING	9.1	11.0	
04-ME-3	MECHANICAL MIXER	10	HP	VFD-6	DUTY / CONTINUOUS	EXISTING	11.6	14.0	
04-ME-4	SLUDGE SCRAPER (SETTLING TANK)	3	HP	VFD-6	DUTY / CONTINUOUS	EXISTING	4.0	4.8	
04-P-1	RECIRC. PUMP (MICROSAND)	15	HP	FVNR	DUTY / CONTINUOUS	EXISTING	17.5	21.0	
04-P-2	RECIRC. PUMP (MICROSAND)	15	HP	FVNR	STANDBY	EXISTING	0.0	0.0	
OPERATING LOAD SUBTOTAL							51.4	61.8	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG 6-MCC-A
DESCRIPTION TO FILTER GALLERY
LOCATION
VOLTAGE 480
BUS AMPS 600
PHASE, WIRE, KASC 3PH, 3W, 42 KAIC KASC
LARGEST MOTOR 100HP
COMMENTS

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
113.6	136.7

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
142.1	170.9

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
141.2	169.8

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single-phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
06-ME-1	AIR SCOUR BLOWER	100	HP	FVNR	DUTY / CONTINUOUS	EXISTING	103.1	124.0	
06-ME-2	AIR SCOUR BLOWER	100	HP	FVNR	STANDBY	EXISTING	0.0	0.0	
6-F-3	AIR SCOUR RM FAN	1	HP	FVNR	DUTY / CONTINUOUS	EXISTING	1.7	2.1	
6-F-4	AIR SCOUR RM FAN	1	HP	FVNR	DUTY / CONTINUOUS	EXISTING	1.7	2.1	
HEATER EAST	XX	3	KW		DUTY / CONTINUOUS	EXISTING	3.5	4.2	
HEATER WEST	XX	3	KW		DUTY / CONTINUOUS	EXISTING	3.5	4.2	
OPERATING LOAD SUBTOTAL							113.6	136.7	

Date/Time displayed in this report reflect time in PST

PROJECT INFORMATION

PROJECT WILLAMETTE RIVER WATER TREATMENT PLANT-15 MGD
CLIENT CITY OF WILSONVILLE
PROJECT NUMBER 10002A60
REPORT BY JAMSHID DORAFSHA
REPORT DATE 1/3/2018 12:03 PM

EQUIPMENT INFORMATION

TAG	8-MCC-A	PHASE, WIRE, KASC	3PH, 3W, 42 KAIC KASC
DESCRIPTION	TO WASTE WASH. EQ.	LARGEST MOTOR	5HP
LOCATION		COMMENTS	
VOLTAGE	480		
BUS AMPS	600		

LOAD TOTALS

OPERATING KVA	OPERATING AMPS
29.5	35.5

NEC 215 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
36.9	44.4

NEC 430 EQUIPMENT SIZING

EQUIPMENT KVA	EQUIPMENT AMPS
31.1	37.4

DEFINITIONS

OPERATING = CONTINUOUS + INTERMITTENT

NEC 215 EQUIPMENT SIZING = 1.25 x CONTINUOUS + 1.0 x INTERMITTENT (BASED ON NEC ARTICLE 215)

NEC 430 EQUIPMENT SIZING = 1.25 x LARGEST MOTOR + 1.0 x ALL OTHER MOTORS + 1.25 x CONTINUOUS NON-MOTOR + 1.0 x INTERMITTENT NON-MOTOR (BASED ON NEC ARTICLE 430)

EQUIPMENT SIZING IS BASED ON THE LARGER OF NEC 215 AND NEC 430 CALCULATIONS (LARGER IS HIGHLIGHTED WHEN APPLICABLE)

Note: For 3-phase busses that feed single -phase loads, the amp summation under loads will not match the bus amps due to the difference in voltage.

Note: The values in this report are rounded from higher precision numbers. Manually summing the values shown may yield slightly varied results due to rounding error.

LOADS

TAG	DESCRIPTION	LOAD VALUE	LOAD UNITS	STARTING METHOD	LOAD DESIGNATION	LOAD STATUS	OPERATING KVA	OPERATING AMPS	COMMENTS
11-ME-1	THICKENER MECHANISM	1.50	HP		DUTY / CONTINUOUS	EXISTING	2.5	3.0	
11-MOV-1	MOTOR OPERATED VALVE	1	HP		DUTY / CONTINUOUS	EXISTING	1.7	2.1	
11-P-1	THICKENED SOLIDS PUMP	5	HP		DUTY / CONTINUOUS	EXISTING	6.3	7.6	
11-P-2	THICKENED SOLIDS PUMP	5	HP		STANDBY	EXISTING	0.0	0.0	
11-P-3	RECYCLED SOLIDS MIXING PUMP	5	HP	FVNR	DUTY / CONTINUOUS	EXISTING	6.3	7.6	
8-P-1	WASH WATER RECYCLE PUMP	5	HP		DUTY / CONTINUOUS	EXISTING	6.3	7.6	
8-P-2	WASH WATER RECYCLE PUMP	5	HP		DUTY / CONTINUOUS	EXISTING	6.3	7.6	
8-P-3	WASH WATER RECYCLE PUMP	5	HP	FVNR	STANDBY	EXISTING	0.0	0.0	
OPERATING LOAD SUBTOTAL							29.5	35.5	

Date/Time displayed in this report reflect time in PST

WRWTP 20-Year NPV Summary

	Alternative A Baseline	Alternative B Modified	Alternative C Compliance
20-Year NPV	\$ 88,400,000	\$ 81,200,000	\$ 76,700,000
<i>Cost Comparison (\$)</i>			
Alternative A	--	\$ (7,200,000)	\$ (11,700,000)
Alternative B	\$ 7,200,000	--	\$ (4,500,000)
Alternative C	\$ 11,700,000	\$ 4,500,000	--
<i>Cost Comparison (%)</i>			
Alternative A	--	-9%	-15%
Alternative B	8%	--	-6%
Alternative C	13%	6%	--

This sheet provides the references used for the NPV calculation sheets. In most cases, this sheet references the cost summary tables.

Summarized A Cost Data (for NPV Use)		Year Applied
Lower Site Interim Expansions	\$20,550,870	2020
Lower Site Expansion	\$19,487,928	2034
Lower Site Fixed Costs	\$1,891,405	2015
Lower Site Variable Costs (per MG)	\$412	2015

Summarized B Cost Data (for NPV Use)		Year Applied
Lower Site Interim Expansions	\$10,663,463	2020
Lower Site Expansion	\$22,487,442	2034
Lower Site Fixed Costs	\$1,881,405	2015
Lower Site Variable Costs (per MG)	\$410	2015

Summarized C Cost Data (for NPV Use)		Year Applied
Lower Site Interim Expansions	\$8,441,300	2020
Lower Site Expansion	\$21,650,443	2034
Lower Site Fixed Costs	\$1,881,405	2015
Lower Site Variable Costs (per MG)	\$374	2015

Constants	
Discount Rate	5.50%
Inflation	4.00%
Real Rate	1.500%

NPV: Alternative A Total Net Present Value **LOWER SITE**
\$88,328,940.04

Construction and Maintenance Costs							
Year	Year No.	Non-Program (Lower Site) WTP Capital Cost	Lower Site Average Flow, mgd	Lower Site Variable O&M Costs	Lower Site Fixed O&M Costs	Non-Program (Lower Site) Total Cost	Non-Program WTP Present Value
2015	0	\$0.00	5.67	\$853,094	\$1,891,405	\$2,744,499	\$2,744,499
2016	1	\$0.00	5.86	\$881,065	\$1,891,405	\$2,772,469	\$2,731,497
2017	2	\$0.00	6.05	\$909,035	\$1,891,405	\$2,800,440	\$2,718,280
2018	3	\$0.00	6.23	\$937,005	\$1,891,405	\$2,828,410	\$2,704,856
2019	4	\$0.00	6.42	\$964,975	\$1,891,405	\$2,856,380	\$2,691,236
2020	5	\$20,550,870.00	6.61	\$993,645	\$1,891,405	\$23,435,920	\$21,754,634
2021	6	\$0.00	6.82	\$1,025,112	\$1,891,405	\$2,916,516	\$2,667,277
2022	7	\$0.00	7.03	\$1,056,578	\$1,891,405	\$2,947,983	\$2,656,212
2023	8	\$0.00	7.24	\$1,088,045	\$1,891,405	\$2,979,450	\$2,644,890
2024	9	\$0.00	7.44	\$1,119,511	\$1,891,405	\$3,010,916	\$2,633,324
2025	10	\$0.00	7.66	\$1,151,677	\$1,891,405	\$3,043,082	\$2,622,124
2026	11	\$0.00	7.78	\$1,169,858	\$1,891,405	\$3,061,263	\$2,598,808
2027	12	\$0.00	7.90	\$1,187,339	\$1,891,405	\$3,078,744	\$2,575,023
2028	13	\$0.00	8.02	\$1,205,520	\$1,891,405	\$3,096,925	\$2,551,950
2029	14	\$0.00	8.14	\$1,223,701	\$1,891,405	\$3,115,106	\$2,528,996
2030	15	\$0.00	8.26	\$1,242,581	\$1,891,405	\$3,133,985	\$2,506,723
2031	16	\$0.00	8.45	\$1,270,551	\$1,891,405	\$3,161,956	\$2,491,719
2032	17	\$0.00	8.64	\$1,299,221	\$1,891,405	\$3,190,625	\$2,477,154
2033	18	\$0.00	8.83	\$1,327,890	\$1,891,405	\$3,219,295	\$2,462,476
2034	19	\$19,487,927.50	9.02	\$1,356,560	\$1,891,405	\$22,735,892	\$17,133,938
2035	20	\$0.00	9.22	\$1,385,929	\$1,891,405	\$3,277,333	\$2,433,323

Constants	
Discount Rate	5.50%
Inflation	4.00%
Interest Rate	1.500%

NPV: Alternative B Total Net Present Value **\$81,131,664.88**

Construction and Maintenance Costs							
Year	Year No.	Non-Program (Lower Site) WTP Capital Cost	Lower Site Average Flow, mgd	Lower Site Variable O&M Costs	Lower Site Fixed O&M Costs	Non-Program (Lower Site) Total Cost	Lower Site Present Value
2015	0	\$0.00	5.67	\$848,958	\$1,881,405	\$2,730,362	\$2,730,362
2016	1	\$0.00	5.86	\$876,792	\$1,881,405	\$2,758,197	\$2,717,436
2017	2	\$0.00	6.05	\$904,627	\$1,881,405	\$2,786,032	\$2,704,294
2018	3	\$0.00	6.23	\$932,462	\$1,881,405	\$2,813,866	\$2,690,948
2019	4	\$0.00	6.42	\$960,296	\$1,881,405	\$2,841,701	\$2,677,406
2020	5	\$10,663,462.50	6.61	\$988,827	\$1,881,405	\$13,533,694	\$12,562,791
2021	6	\$0.00	6.82	\$1,020,141	\$1,881,405	\$2,901,546	\$2,653,586
2022	7	\$0.00	7.03	\$1,051,455	\$1,881,405	\$2,932,860	\$2,642,585
2023	8	\$0.00	7.24	\$1,082,769	\$1,881,405	\$2,964,174	\$2,631,330
2024	9	\$0.00	7.44	\$1,114,083	\$1,881,405	\$2,995,488	\$2,619,830
2025	10	\$0.00	7.66	\$1,146,093	\$1,881,405	\$3,027,498	\$2,608,695
2026	11	\$0.00	7.78	\$1,164,185	\$1,881,405	\$3,045,590	\$2,585,503
2027	12	\$0.00	7.90	\$1,181,582	\$1,881,405	\$3,062,987	\$2,561,844
2028	13	\$0.00	8.02	\$1,199,675	\$1,881,405	\$3,081,079	\$2,538,893
2029	14	\$0.00	8.14	\$1,217,767	\$1,881,405	\$3,099,172	\$2,516,060
2030	15	\$0.00	8.26	\$1,236,556	\$1,881,405	\$3,117,960	\$2,493,905
2031	16	\$0.00	8.45	\$1,264,390	\$1,881,405	\$3,145,795	\$2,478,984
2032	17	\$0.00	8.64	\$1,292,921	\$1,881,405	\$3,174,326	\$2,464,500
2033	18	\$0.00	8.83	\$1,321,451	\$1,881,405	\$3,202,856	\$2,449,902
2034	19	\$22,487,441.67	9.02	\$1,349,982	\$1,881,405	\$25,718,828	\$19,381,901
2035	20	\$0.00	9.22	\$1,379,208	\$1,881,405	\$3,260,613	\$2,420,909

Constants	
Discount Rate	5.50%
Inflation	4.00%
Interest Rate	1.500%

NPV: Alternative C Total Net Present Value **LOWER SITE**
\$76,648,629.51

Construction and Maintenance Costs							
Year	Year No.	Non-Program (Lower Site) WTP Capital Cost	Lower Site Average Flow, mgd	Lower Site Variable O&M Costs	Lower Site Fixed O&M Costs	Non-Program (Lower Site) Total Cost	Lower Site Present Value
2015	0	\$0.00	5.67	\$773,389	\$1,881,405	\$2,654,794	\$2,654,794
2016	1	\$0.00	5.86	\$798,746	\$1,881,405	\$2,680,151	\$2,640,543
2017	2	\$0.00	6.05	\$824,103	\$1,881,405	\$2,705,508	\$2,626,133
2018	3	\$0.00	6.23	\$849,460	\$1,881,405	\$2,730,865	\$2,611,572
2019	4	\$0.00	6.42	\$874,817	\$1,881,405	\$2,756,222	\$2,596,869
2020	5	\$8,441,300.00	6.61	\$900,808	\$1,881,405	\$11,223,513	\$10,418,342
2021	6	\$0.00	6.82	\$929,335	\$1,881,405	\$2,810,739	\$2,570,540
2022	7	\$0.00	7.03	\$957,861	\$1,881,405	\$2,839,266	\$2,558,255
2023	8	\$0.00	7.24	\$986,388	\$1,881,405	\$2,867,793	\$2,545,771
2024	9	\$0.00	7.44	\$1,014,915	\$1,881,405	\$2,896,319	\$2,533,098
2025	10	\$0.00	7.66	\$1,044,075	\$1,881,405	\$2,925,480	\$2,520,790
2026	11	\$0.00	7.78	\$1,060,557	\$1,881,405	\$2,941,962	\$2,497,529
2027	12	\$0.00	7.90	\$1,076,405	\$1,881,405	\$2,957,810	\$2,473,875
2028	13	\$0.00	8.02	\$1,092,887	\$1,881,405	\$2,974,292	\$2,450,897
2029	14	\$0.00	8.14	\$1,109,369	\$1,881,405	\$2,990,774	\$2,428,058
2030	15	\$0.00	8.26	\$1,126,485	\$1,881,405	\$3,007,890	\$2,405,865
2031	16	\$0.00	8.45	\$1,151,842	\$1,881,405	\$3,033,247	\$2,390,293
2032	17	\$0.00	8.64	\$1,177,833	\$1,881,405	\$3,059,238	\$2,375,147
2033	18	\$0.00	8.83	\$1,203,824	\$1,881,405	\$3,085,229	\$2,359,927
2034	19	\$21,650,443.33	9.02	\$1,229,815	\$1,881,405	\$24,761,663	\$18,660,575
2035	20	\$0.00	9.22	\$1,256,440	\$1,881,405	\$3,137,845	\$2,329,757

Multiplicative Factors				Year Applies (and beyond)	
Peaking Factor (avg day from peak day)			0.465	ALL	
Year	Wilsonville	Sherwood	Combined Demands	Lower Site Peak Demands	Lower Site Average Demands
2010	6.70	3.53	10.23	10.23	4.76
2011	7.02	3.60	10.62	10.62	4.94
2012	7.34	3.67	11.01	11.01	5.12
2013	7.66	3.74	11.40	11.40	5.30
2014	7.98	3.82	11.80	11.80	5.49
2015	8.30	3.90	12.20	12.20	5.67
2016	8.62	3.98	12.60	12.60	5.86
2017	8.94	4.06	13.00	13.00	6.05
2018	9.26	4.14	13.40	13.40	6.23
2019	9.58	4.22	13.80	13.80	6.42
2020	9.90	4.31	14.21	14.21	6.61
2021	10.26	4.40	14.66	14.66	6.82
2022	10.62	4.49	15.11	15.11	7.03
2023	10.98	4.58	15.56	15.56	7.24
2024	11.34	4.67	16.01	16.01	7.44
2025	11.70	4.77	16.47	16.47	7.66
2026	11.86	4.87	65.07	16.73	7.78
2027	12.02	4.96	67.21	16.98	7.90
2028	12.18	5.06	69.36	17.24	8.02
2029	12.34	5.16	71.51	17.50	8.14
2030	12.50	5.27	72.44	17.77	8.26
2031	12.80	5.37	74.02	18.17	8.45
2032	13.10	5.48	75.62	18.58	8.64
2033	13.40	5.59	77.21	18.99	8.83
2034	13.70	5.70	78.81	19.40	9.02
2035	14.00	5.82	81.34	19.82	9.22
2036	14.30	5.98	82.70	20.28	9.43
2037	14.60	6.05	83.98	20.65	9.60
2038	14.90	6.17	85.31	21.07	9.80
2039	15.20	6.30	86.64	21.50	10.00
2040	15.50	6.42	88.98	21.92	10.19
2041	15.80	6.55	100.32	22.35	10.39
2042	16.10	6.68	101.66	22.78	10.59
2043	16.40	6.82	103.02	23.22	10.80
2044	16.70	6.95	104.36	23.65	11.00
2045	17.00	7.09	106.72	24.09	11.20
2046	17.30	7.23	108.01	24.53	11.41
2047	17.60	7.38	109.31	24.98	11.62
2048	17.90	7.53	110.61	25.43	11.82
2049	18.20	7.68	111.91	25.88	12.03
2050	18.50	7.83	114.22	26.33	12.24

Appendix B

LIFE SAFETY AND SEISMIC ASSESSMENT
TECHNICAL MEMORANDUM



City of Wilsonville

Willamette River Water Treatment Plant 2017 Master Plan Update

TECHNICAL MEMORANDUM LIFE SAFETY AND SEISMIC ASSESSMENT

Final | January 2018





CITY OF WILSONVILLE
WILLAMETTE RIVER WATER TREATMENT PLANT
2017 MASTER PLAN UPDATE

TECHNICAL MEMORANDUM
LIFE SAFETY AND SEISMIC ASSESSMENT

Digitally signed by James A. Doering
Contact Info: Carollo Engineers, Inc.
Date: 2018.01.31 13:56:20-08'00'



EXPIRES: 12/31/19

Contents

Technical Memorandum 1 - Life Safety and Seismic Assessment	1-1
1.1 Introduction	1-1
1.2 Life Safety Assessment	1-3
1.2.1 Findings and Recommendations	1-3
1.3 Seismic Evaluation	1-7
1.3.1 Structural Description	1-7
1.3.2 Structural Conditions	1-10
1.3.3 Seismic Evaluation Approach	1-10
1.3.4 Seismic Evaluation Criteria	1-11
1.3.5 Data Collection and Review	1-13
1.3.6 Analysis Procedures	1-14
1.3.7 Acceptance Criteria	1-14
1.4 Findings and Recommendations	1-15
1.5 Geo-seismic Hazards	1-28
1.6 Summary	1-28

Attachments

Attachment A	Photographs
Attachment B	Tier 1 Checklists
Attachment C	Calculations

Tables

Table 1.1	Summary of Life Safety Findings	1-4
Table 1.2	Summary of Performance Levels	1-12
Table 1.3	Seismic Evaluation Parameters	1-13
Table 1.4	Material Properties	1-14
Table 1.5	Load Intensities	1-14
Table 1.6	Summary of Seismic Vulnerabilities	1-16
Table 1.7	Summary of Mitigation Costs	1-29

Figures

Figure 1.1 WRWTP Facilities Included in the 2017 Life Safety and Seismic Assessment	1-2
Figure 1.2 Negative Bending Stresses on the Exterior of the North and South Walls at the East Corners Exceed the Reinforcing Steel Capacity	1-19
Figure 1.3 Addition of Concrete Braces to Reduce the Bending and Out-of-Plane Shear Forces Applied to the North and South Walls of the Waste Washwater EQ Basin	1-20
Figure 1.4 Out-of-Plane Shear Force Due to Soil Seismic Loads Exceeds the Wall Shear Capacity at the Intersection of the Concrete Beam with the North and South Walls	1-21
Figure 1.5 Wall Anchorage Forces at the Roof Joist Connections to the Walls Exceed the Existing Anchorage Capacity	1-22
Figure 1.6 Addition of New Wall Anchorage Between Existing Joists to Enhance the Wall Anchorage Capacity	1-23
Figure 1.7 Diaphragm Shear Stress at the High Service PS Roof Exceeds the Capacity of the Roof Decking	1-23
Figure 1.8 Chord Bars are Discontinuous at 3 Large Windows at the West Wall of the High Service PS	1-24
Figure 1.9 Chord Splice as Required at the Ends of the Window to Ensure Chord Continuity is Maintained at the High Service PS	1-24
Figure 1.10 Diaphragm Shear Transfer to the Interior Shear Walls of the High Service PS Exceeds the Capacity of the Bolted Connections to the Walls	1-25
Figure 1.11 Conceptual Retrofit for Increasing the Capacity of the Diaphragm Shear Transfer to the Interior Walls at the High Service PS	1-25
Figure 1.12 Conceptual Retrofit Scheme to Provide East-West Seismic Bracing for the Solids Dewatering Building	1-26
Figure 1.13 Conceptual Retrofit to Tie the Floor Slab Together with the East and West Wall Footings at the Solids Dewatering Building	1-27

Abbreviations

ACI	American Concrete Institute
amps	amperes
ASCE	American Society of Civil Engineers
BPOE	Basic Performance Objective for Existing Buildings
BSE-1E	basic safety earthquake 1
Carollo	Carollo Engineers, Inc.
DCR	demand-to-capacity ratio
ft	feet
GFCI	ground fault circuit interrupter
lb	pounds
mgd	million gallons per day
MWH	Montgomery Watson Harza
NFPA	National Fire Protection Association
oc	on center
OFC	Oregon Fire Code
OSHA	Occupational Safety and Health Administration
OSSC	Oregon Structural Specialty Code
pcf	pounds per cubic foot
psf	pounds per square foot
psi	pounds per square inch
S&W	Shannon & Wilson
sec	second
Sherwood	City of Sherwood
TVWD	Tualatin Valley Water District
UBC	Uniform Building Code
USGS	United States Geological Survey
Wilsonville	City of Wilsonville
WRWTP	Willamette River Water Treatment Plant

Technical Memorandum 1

LIFE SAFETY AND SEISMIC ASSESSMENT

1.1 Introduction

The City of Wilsonville (Wilsonville) and Tualatin Valley Water District (TVWD) share joint ownership of the Willamette River Water Treatment Plant (WRWTP) located in Wilsonville, Oregon. Construction of the WRWTP began in 2000 and was commissioned in 2002. The WRWTP provides potable drinking water to Wilsonville and the City of Sherwood (Sherwood) with a current production capacity of approximately 15 million gallons per day (mgd) and future production capacity of approximately 60 MGD. The WRWTP is situated on the north bank of the Willamette River at approximately River Mile 39. Water is drawn into the WRWTP through a raw water intake structure located within the river. The water then flows through an intake pipe into the raw water concrete caisson, where it is then pumped into the plant at the raw water pump station.

In 2015, Tualatin Valley Water District (TVWD) updated their master plan for their water supply system, which includes a substantial increase in potable water production at the site of the WRWTP. To meet the increased requirements, additional treatment facilities located off of the current WRWTP site have been planned to augment the capacity, but a number of WRWTP facilities have been determined to be common to the new facilities and will be relied upon to meet the long-term water production requirements. As a part of the 2015 TVWD Master Plan Update, a seismic evaluation was prepared for these “common” facilities, which included the raw water caisson, the raw water pump station, high service pump station, finished water reservoir, and operations/administration building.


Similar to TVWD, Wilsonville is planning future upgrades and/or modifications to the WRWTP, which likewise provides an opportunity to simultaneously address any life safety and/or seismic vulnerabilities. To identify what potential vulnerabilities exist, Carollo Engineers, Inc., (Carollo) has been tasked to prepare a life safety and seismic assessment of the balance of the WRWTP facilities that were not included in the 2015 TVWD Master Plan Update. Although the plant was constructed approximately 17 years ago, seismic ground accelerations used in design and evaluation have generally increased in the Pacific Northwest, design detailing requirements in adopted building codes have become more stringent and focused, and in particular, geo-seismic hazard analyses for liquefaction and lateral spread have more well-defined methods prescribed by current building codes and evaluation standards. Therefore, in the interest of helping to ensure that the WRWTP facilities are resilient, a life safety and seismic assessment of the remaining WRWTP facilities that are not common to TVWD’s planned expansion was requested by Wilsonville. These facilities and their associated support systems and structural and architectural components, include the following (see Figure 1.1):

- Actiflo® (Ballasted Flocculation)
- Ozonation
- Filters

- Waste Washwater Equalization
- High Service Pump Station (Switchgear and Generator Rooms)
- Sludge Thickening
- Sludge Dewatering
- Chemical Storage
- Ozone Generation

This life safety and seismic assessment is a two-fold effort to both identify potential life safety deficiencies that may exist in the structural connections, equipment anchors, mechanical and electrical systems, and other ancillary components, and to identify potential seismic performance deficiencies that can jeopardize the safe and reliable operation of the WRWTP. Planning level mitigation strategies/measures to address identified deficiencies were then developed. Subsequent studies or planning adjustments may be prudent if findings at this stage suggest large-scale mitigation efforts are required.

The balance of this chapter provides a brief description of the structures, procedures, criteria, findings, and recommendations derived from the onsite walk-down and the seismic evaluation of the facilities.



1. Actiflo™
2. Ozonation
3. Filters
4. Waste Washwater
5. High Service PS
6. Sludge Thickening
7. Sludge Dewatering
8. Chemical Storage
9. Ozone Generation

Figure 1.1 WRWTP Facilities Included in the 2017 Life Safety and Seismic Assessment

1.2 Life Safety Assessment

In conjunction with the seismic assessment, Wilsonville requested that Carollo assess life safety deficiencies at the WRWTP. Carollo conducted a site visit on Tuesday, July 25, 2017, for the purpose of identifying potential life safety issues and for the purpose of fulfilling the seismic evaluation requirements of the scope of work.

The site visit was performed by James Doering, an Oregon licensed structural engineer. The site visit included both interior and exterior inspections. Interior access was limited to portions of the structures that were readily accessible and did not include entry into tanks, onto roofs, or into confined space. The plant was in full operation at the time of the site visit.

1.2.1 Findings and Recommendations

Life safety assessment findings were presented in a workshop with Wilsonville and Sherwood, held at the WRWTP on Friday, August 18, 2017. These life safety findings are summarized in Table 1.1 and include those seismic vulnerabilities that are also a potential life safety hazard. Additionally, each issue has been assigned a priority of high (H), medium (M), or low (L), which can be used to facilitate integration of any mitigation measures into separate projects or in a phased implementation over time. Where building code provisions and standards are applicable, the relevant sections have been noted. Photographs are provided in Appendix A to assist with the description of the issues that were identified.

Table 1.1 Summary of Life Safety Findings

Issue #	Location	Description	Code Reference	Recommendation	Cost ⁽¹⁾⁽²⁾⁽³⁾	Priority ⁽⁴⁾
LS1	Various	Tread plate hatches do not typically have any provisions for installing temporary fall protection barriers when in use.	OSHA 1910.23	Install sleeves or other hardware for temporary fall protection systems around hatches.	\$12,000	H
LS2	Various	Color coded chemical safety warning signs at exterior locations are faded so that colors are not clear any longer.	2014 OFC (NFPA 704)	Replace safety signs throughout the plant as required.	< \$2,000	H
LS3	Actiflo® / Ozonation / Filters	Exterior stair guardrail height is less than 42 inches above the stair tread and has no dedicated handrail. Installation met 1997 UBC provisions, but not current code.	2014 OSSC, Chapter 10	Replace guardrail with current code-compliant installation.	\$17,000	M
LS4	Actiflo® / Higher Service PS / Chemical Storage	Doors exiting rooms that have rated electrical service that is 1,200 amps or greater do not have panic hardware.	2014 OSSC, Chapter 10	Provide panic door hardware on 4 affected doors.	\$7,000	H
LS5	Ozone Generation / Chemical Storage	Doors serving occupancy Group H are lacking panic hardware. Also, the door that connects the Ozone Generation Room to the Administration Building swings into the Ozone Generation Room, which is a Group H occupancy.	2014 OSSC, Chapter 10	Provide panic door hardware on 3 doors and replace the door between the Ozone Generation Room and the Administration Building to reverse the door swing direction.	\$9,500	H
LS6	Ozone Generation / Chemical Storage	Chemical piping passes directly over exit egress routes at the southwest door of the Ozone Generation Room, the east door of the Chemical Room, and the west door of the Chemical Room.		Add secondary containment pans below the chemical piping over exit routes.	< \$2,000	M
LS7	Various	Doors were found propped open during the site visit, which may suggest that the ventilation in the rooms may not be operating effectively and/or efficiently.		Verify that the ventilation system is operating as intended.	N/A	L
LS8	Actiflo® / Filters	The west guardrail on the top deck of the Actiflo® Basin and the top side of the ladder pit at the filters lack kick plates.		Install new kickplates at these locations.	< \$2,000	L

Table 1.1 Summary of Life Safety Findings (Continued)

Issue #	Location	Description	Code Reference	Recommendation	Cost ⁽¹⁾⁽²⁾⁽³⁾	Priority ⁽⁴⁾
LS9	Actiflo® / Ozonation / Filters	The below-grade galleries have active weeping leaks that are coming from cracks in the tank walls and through expansion joints leaving the floor wet and potentially slippery.		Pressure inject a hydrophobic sealant into active leaks to seal them. Apply an exterior (negative side) waterstop on the surface of the joint.	\$20,000 (100 lineal foot allowance)	M
LS10	Actiflo® / Ozonation / Filters	The below-grade galleries typically have wet floors due to leaking walls and leaking pipes/equipment. The electrical receptacles do not appear to have any GFCI protection.		Remove and replace the electrical receptacles with ones that are GFCI protected.	< \$2,000	M
LS11	Ozonation	The south stairwell does not have a dedicated ventilation system that serves it directly.		Investigate if ventilation is sufficient and provide as required.	N/A	M
LS12	Filters	The maximum distance of travel to exit the north door is approximately 85 feet. The maximum distance to a single exit per the building code is 75 feet. The doors at the east end of the Filter Gallery exit to a ladder pit, which is not considered to be an exit for egress determination.	2014 OSSC, Chapter 10	Add a fire-rated door at the bottom of the stairs and add signage to the existing ladder pit door to clarify that it is not an exit. This may also require revision to the ventilation of the existing stair.	\$8,000	M
LS13	Waste Washwater	The ladder into the basin does not have any permanent tie-off points for a fall restraint system.		Verify how fall restraint is provided when using the ladder and provide additional hardware as required.	< \$2,000	M
LS14	Sludge Dewatering	The building roof does not appear to have any overflow scuppers.	2014 OSSC, Chapter 15	Saw-cut out a notch in the parapet wall and install a scupper and downspout.	\$6,000	L
LS15	Ozone Generation Room	The emergency shut-off switch for the ozone generation equipment is located between the sensor and the generation equipment.		Install emergency shut-off switch at two other exits from the building.	\$10,000	M
LS16 (S4)	High Service Pump Station	The roof diaphragm shear capacity is exceeded at approximately 50% of the roof deck area with DCR's that vary from 1.82 to 2.25. Refer to Figure 1.7.	ASCE 41-13, Tier 1	Replace existing deficient deck sections with 16 GA corrugated steel decking.	\$85,000	H

Issue #	Location	Description	Code Reference	Recommendation	Cost ⁽¹⁾⁽²⁾⁽³⁾	Priority ⁽⁴⁾
LS17 (S6)	High Service Pump Station	Roof deck shear transfer to the interior wall ledger bolts have DCR's of 3.20 to 3.90. Refer to Figure 1.10.	ASCE 41-13, Tier 1	Add a new top plate over the interior shear walls and install epoxied anchors as required. Refer to Figure 1.11.	\$20,000 ⁽⁵⁾	H
LS18 (S7)	Solids Dewatering Building	The building has no lateral load resisting system in the transverse direction at the first floor level. The existing concrete joint at the elevated slab to the east and west walls does not have any seismic detailing to establish any concrete moment frame.	ASCE 41-13, Tier 1	Provide steel braced frames at the exterior of the building at the east side that braces the building at the second floor level. This system is anticipated to include three braces, each with their own concrete grade beam. It is assumed that the existing stair will need to be relocated to the west side of the building. Refer to Figure 1.12.	\$210,000	H
LS19 (S10)	Various (estimated at 8 locations)	The space heaters at all facilities are laterally braced above their center of gravity, which allows the heaters to sway during an earthquake. The space heaters at the Switchgear Room at the High Service Pump Station are not braced at all.	ASCE 41-13, Tier 1	Provide seismic bracing.	\$5,000	H
LS20 (S13)	Chemical Storage / Ozone Generation Room	The chemical pipes that run through the center of the Chemical Storage Room are not seismically braced. The balance of the chemical pipes in the Chemical Storage Room and Ozone Generation Room lack longitudinal seismic bracing.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	\$10,000	M
LS21 (S14)	Ozone Generation Room	The ozone and LOX piping is not seismically braced.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	\$5,000	M

Notes:

1. Cost estimate includes an indirect cost multiplier of 2.0, which is meant to account for contingency, overhead, profit, taxes, etc...
2. The cost threshold is considered to be \$2,000. Anything less than this amount will be indicated as such.
3. Soft costs, such as, engineering services, inspection, permitting, etc..., are not included in the cost estimate.
4. H = High, M = Medium, L = Low.
5. Assumes that vulnerability S4 is addressed simultaneously, otherwise the cost will need to include removal/replacement of the roofing.

1.3 Seismic Evaluation

The seismic evaluation of the WRWTP facilities consisted of both analytical and visual assessments. The analytical review is a quantitative estimate of the potential material stresses of the structural members when subjected to estimated loads due to self-weight, soils, water, seismic, and other potential loads that may be present during an earthquake. The visual condition assessment is a qualitative evaluation of the structural conditions, which can have a significant bearing on the available structural capacity and the ability of the structure to remain serviceable for a period of time. The goal of this evaluation is to identify those structural vulnerabilities and conditions, whether by analytical or visual assessment methods, that have the potential to have a significant impact on the ability of the facility to remain serviceable during and after an earthquake, or that pose life safety risks. Initially, the evaluation is comprised of data gathering, establishment of a seismic evaluation and acceptance criteria, assumptions regarding material properties, and mathematical analyses of the structural systems and members. The results of this evaluation include both quantitative and qualitative findings, which may serve as a basis for the development of mitigation strategies.

1.3.1 Structural Description

The subject facilities were constructed between 2000 and 2002 under a design-build contract. Construction is generally comprised of cast-in-place concrete, masonry, and steel materials. Refer to Figure 1.1 for a map of the facilities included in the scope of work.

1.3.1.1 Actiflo® (Ballasted Flocculation)

The Actiflo® facility is a partially buried process basin constructed of cast-in-place concrete construction and includes a small single-story masonry building that houses equipment to support the process. The footprint of the basin is approximately 40 feet wide and 70 feet long with a height of 22 feet from the top of the roof deck to the top of the bottom slab. The top of the basin is located approximately 6 feet above the surrounding grade, which slopes downward toward the river to the south. The basin includes a small gallery that is located below grade at the south side of the structure. The basin has numerous interior concrete walls that form the cells and channels for the water treatment process. The basin abuts the north end of the Ozonation basin, but is separated by an expansion joint. The single-story masonry building on top of the Actiflo® basin has a floor area of approximately 400 square feet and has a steel-framed roof with light gauge corrugated steel deck diaphragm and open-web steel joists. The building roof is located approximately 11 feet above the floor.

The facility also includes electrical equipment, pumps, and piping that are supported off of the structure. The Actiflo® building is also equipped with a space heater that is suspended from the roof framing.

1.3.1.2 Ozonation

The Ozonation facility is a partially buried process basin that is constructed of cast-in-place concrete construction. The footprint of the basin is approximately 40 feet wide by 70 feet long with a height of 25 feet from the top of the roof deck to the top of the bottom slab. The top of the basin is located approximately 14 feet above the surrounding grade at the south side of the structure. The basin includes a gallery located below grade that is interconnected to the Actiflo®

gallery. The basin has numerous interior concrete walls and slabs that form the cells and channels of the water treatment process.

The facility also includes mechanical equipment and piping that is supported from the structure. Ozone destruct pipes are located on the roof deck.

1.3.1.3 Filters

The Filter facility is a partially buried process basin that is constructed of cast-in-place concrete construction and includes a small steel-framed control house supported on the top deck of the structure. The footprint of the basin is approximately 70 feet wide by 70 feet long with a height of 19 feet from the top of the roof deck to the top of the bottom slab. The top of the basin is located approximately 10 feet above grade at the north side of the structure. The basin includes a gallery located below grade and traverses the middle of the structure from east to west. The basin has numerous interior concrete walls and slabs that form the cells and channels of the water treatment process.

The facility also includes large diameter piping and blower equipment that is located in the gallery below grade. The filters are also equipped with braced/stiffened launders.

1.3.1.4 Waste Washwater Equalization

The Waste Washwater Equalization facility includes a basin that is constructed of cast-in-place concrete construction and includes an 18 feet by 36 feet, single-story masonry building supported on top of the basin walls at the west end of the structure. The footprint of the basin is approximately 36 feet wide by 63 feet long with a height of 21 feet from the top of the wall to the top of the bottom slab. The basin is open to the atmosphere to the east of the building and covered by the building floor slab at the west side. The building has an approximate floor area of 600 square feet and has a steel-framed roof constructed with a light gauge corrugated steel deck diaphragm and open-web steel joists. The building roof is located approximately 11 feet above the floor.

The building houses vertical turbine pumps, electrical equipment, and a space heater that is suspended from the roof framing.

1.3.1.5 High Service Pump Station (Switchgear and Generator Rooms)

The pump station is constructed over the top of the east side of the clearwell and is a single-story building that has a footprint of approximately 32 feet by 138 feet. The interior and exterior walls are constructed of cast-in-place concrete and the roof is constructed with a light gauge corrugated steel deck with open-web steel joists. The building roof is located approximately 22 feet above the floor. The building has a generator room, switchgear room, and a pump station room that are all separated by full-height interior concrete walls.

The generator room houses a diesel engine generator along with associated exhaust piping. The switchgear room houses electrical equipment along with numerous suspended cable tray runs that distribute cable/wiring to the equipment. The pump station includes vertical turbine pumps, more electrical cable tray, and a bridge crane. The switchgear and pump station rooms include space heaters that are suspended from the roof framing.

1.3.1.6 Sludge Thickening

The sludge thickening facility is comprised of a 35-foot diameter circular thickener with a side water depth of 12 feet and a small pump station located below grade. The structures are constructed with cast-in-place concrete construction. The thickener is partially buried with the top of the perimeter wall located approximately 6.5 feet above the surrounding grade. The pump station has a wet well section and a dry area where the pumps reside. The pump station has an area of approximately 800 square feet and the bottom slab is located approximately 16 feet below the finished grade.

The pump station room houses pumps that are mounted on the bottom slab.

1.3.1.7 Sludge Dewatering

The Sludge Dewatering facility is comprised of a two-story building that is constructed of cast-in-place concrete construction. The building has a footprint that is approximately 22 feet wide by 34 feet long. The building is located entirely above grade and has first and second floor heights of approximately 16 and 14 feet, respectively. The first floor serves as a truck bay and is completely open at the north and south ends. The second floor houses sludge dewatering equipment and is enclosed by cast-in-place concrete walls on all four sides. The roof is framed with a light gauge corrugated steel deck diaphragm and open web steel joists. The building is founded on shallow concrete spread footings below the east and west walls.

The equipment room, located at the second floor, houses dewatering equipment and associated electrical equipment. The room also includes a space heater that is suspended from the roof framing. The truck bay also includes process piping and conveying equipment that is suspended from the bottom side of the second floor concrete deck.

1.3.1.8 Chemical Storage Room

The Chemical Storage Room is located within a building that houses the Administration Facility and the Ozone Generation Room. The Chemical Storage Room is situated at the northeast corner of the building and is separated from the Administration Facility to the west and the Ozone Generation Room to the south by interior reinforced masonry walls. The Chemical Storage Room has an approximate footprint measuring 48 feet by 70 feet. The building has one story and is founded on shallow spread footings. The roof structure is comprised of open-web steel joists with a light gauge corrugated steel deck diaphragm. The roof framing is supported down to the foundation by tube steel columns and masonry bearing walls.

The Chemical Storage Room houses several chemical tanks that have their own secondary containment. The room also has an abundance of small diameter chemical piping that traverses the room and is suspended from the roof framing.

1.3.1.9 Ozone Generation

The Ozone Generation Room is located within a building that houses the Administration Facility and the Chemical Storage Room. The Ozone Generation Room is situated at the southeast corner of the building and is separated from the Administration Facility to the west and the Chemical Storage Room to the north by interior reinforced masonry walls. The Ozone Generation Room has an approximate footprint measuring 30 feet by 70 feet. The building has one story and is founded on shallow spread footings. The roof structure is comprised of open-

web steel joists with a light gauge corrugated steel deck diaphragm. The roof framing is supported down to the foundation by the masonry bearing walls.

The Ozone Generation Room houses ozone generation equipment along with the associated ozone and LOX piping. Chemical pipes are also suspended from the roof framing and traverse the room at the west end.

1.3.2 Structural Conditions

Based on our review of the available documentation and visual inspection during the site visit, the buildings appear to be in good condition with no obvious signs of deterioration, corrosion, or damage that would be considered to reduce the capacity of the structural members.

1.3.3 Seismic Evaluation Approach

Numerous standards and guidelines have been published by professional organizations and government agencies to assist the public with the seismic evaluation and retrofit of existing structures. To date, most of these publications have been developed for buildings, with a focus on commercial buildings. American Society of Civil Engineers (ASCE) 41-13, "Seismic Evaluation and Retrofit of Existing Buildings," is the most current seismic evaluation standard, which is intended to be applied to buildings. Since many of the structures included in the scope of work are non-building structures with structural systems and load paths that are not similar to buildings, for the seismic evaluation we chose to apply the relevant design standard, which is American Concrete Institute (ACI) 350.3-06, "Seismic Design of Liquid-Containing Concrete Structures and Commentary," recognizing that no relevant seismic evaluation guides or standards are available for concrete tanks. The balance of the buildings and non-structural contents were evaluated using ASCE 41-13.

In general, the seismic evaluation process is comprised of the following steps when using ASCE 41-13:

- Establish the seismic evaluation criteria:
 - Selection of a performance objective
 - Define the building performance levels
 - Define the seismic hazard level
- Collect and review as-built information.
- Perform seismic/structural analyses:
 - Tier 1 level
 - Tier 2 level as required
- Identify vulnerabilities.
- Recommend mitigation measures.

The seismic evaluation of the water-bearing structures made use of ACI 350.3-06, which does not have a formal seismic evaluation process. In this case, the structure is evaluated against design standards for new structures, except that the load combinations were adjusted to more accurately reflect the actual load scenarios.

The seismic evaluation for the building structures using ASCE 41-13 is multi-tiered, with Tier 1, referred to as the screening procedure, and Tier 2, referred to as the deficiency based evaluation procedure. Tier 1 is a rapid evaluation procedure that involves completion of checklists that include a list of potential deficiencies. Each checklist item requires the evaluator to select a

status of compliant (C), non-compliant (NC), not applicable (N/A), and unknown (U). Overall, the Tier 1 screening procedure checklists include one for the basic configuration, one for the structural systems of the particular building type, and one for non-structural elements. Checklists are completed by the combination of a physical reconnaissance of the building and by performing quick-check calculations that are intended to allow the evaluator to make a rapid assessment.

When a checklist item is determined to be non-compliant or where a potential vulnerability not included in the checklists is to be evaluated, the seismic evaluation continues onto Tier 2. The Tier 2 evaluation requires a more in-depth analysis for the item being considered and may include a complete building analysis that may involve linear static or linear dynamic modeling depending on the Tier 1 deficiency. The Tier 2 evaluation involves checking the structural member for strength or deformation capacity against the seismic load. Where a member is found to have a demand-capacity ratio (DCR) less than 1.0, the member is identified as being non-compliant.

1.3.4 Seismic Evaluation Criteria

Defining the seismic evaluation criteria is the first step in the evaluation process. It sets the stage for the execution of the evaluation work. This step involves the selection of a performance objective, definition of building performance levels, and the definition of the seismic hazard level.

1.3.4.1 Performance Objectives

The performance objective is typically a two-fold objective that establishes building performance levels for different seismic hazards. For example, a typical performance objective for a non-essential building might be meeting the life safety performance level when subjected to an earthquake having a return period of 225 years and meeting the collapse prevention performance level when subjected to an earthquake having a return period of 975 years. The scope of work indicates that the structures are to be evaluated for a life safety performance for a seismic event having a return period of 500 years, which is an objective that is typically associated with new construction for non-essential buildings. The performance objective for existing building structures has been adjusted to consider that the existing structures require an increased level of seismic performance due to their inherent use importance. However, to apply this increased performance objective against the 500-year and 2500-year event hazard levels can result in exceedingly conservative findings for existing buildings. Typically, it is acceptable to tolerate a slightly reduced hazard level when seeking to identify seismic deficiencies in an existing building. Therefore the hazard level has been adjusted downward for the existing buildings, but the performance requirements have been elevated above that of the life safety level. This is consistent with the approach used for the evaluation of the common facilities under the 2015 TVWD Master Plan Update.

It is the prevailing practice to assign Risk Category III classification to water treatment plant structures and assign Risk Category IV classification to essential facilities, such as fire stations and emergency response centers, and more critical components of water treatment plants, such as, reservoirs, pump stations, and intake structures. Risk Category III/IV structures are evaluated with a more stringent performance objective, since an interruption in the operation of these facilities can result in a significant and immediate hazard to the general public.

Non-structural components, such as equipment anchorage, piping, and architectural features are evaluated on a qualitative basis in accordance with ASCE 41-13 checklists.

1.3.4.2 Building Performance Levels

Basic Performance Objective for Existing Buildings (BPOE) levels include both structural and non-structural performance levels. The structural performance levels defined in ASCE 41-13 are as follows:

- S-1: Immediate Occupancy
- S-2: Damage Control
- S-3: Life Safety
- S-4: Limited Safety
- S-5: Collapse Prevention

Non-structural performance levels defined in ASCE 41-13 are as follows:

- N-A: Operational
- N-B: Position Retention
- N-C: Life Safety

The BPOE for Risk Category III structures establishes a structural performance level of S-2 (Damage Control) and a non-structural performance level of N-B (Position Retention). While that for Risk Category IV structures establishes a structural performance level of S-1 (Immediate Occupancy) and a non-structural performance level of N-A (Operational). These performance levels are evaluated against the basic seismic hazard level for existing buildings. Refer to Table 1.2 for a summary of the structural and non-structural performance levels assigned to the facilities in this evaluation. Tanks, while not explicitly covered by ASCE 41-13, have similar performance levels that are achieved by following the seismic design provisions of ACI 350.3-06.

Table 1.2 Summary of Performance Levels

Structure	Risk Category	Structural Performance Level	Non-structural Performance Level
Actiflo®	III	S-2	N-B
Ozonation	III	S-2	N-B
Filters	III	S-2	N-B
Waste Washwater Equalization	III	S-2	N-B
High Service Pump Station	IV	S-1	N-A
Sludge Thickening	III	S-2	N-B
Sludge Dewatering	III	S-2	N-B
Chemical Storage	III	S-2	N-B
Ozone Generation	III	S-2	N-B

1.3.4.3 Seismic Hazard Level

The BPOE for existing buildings requires that the Tier 1 and Tier 2 evaluations be performed using a seismic hazard level input referred to as the basic safety earthquake-1 or BSE-1E, which is the ground motion level associated with an earthquake that has a 20 percent probability of being exceeded in a 50-year period. The ground accelerations associated with this hazard level

have been derived from the 2008 United States Geological Survey (USGS) seismic data available at <https://earthquake.usgs.gov/designmaps/us/application.php>.

The seismic hazard level used for the evaluation of the tanks is consistent with an earthquake that has a 10 percent probability of being exceeded in a 50-year period. The ground accelerations associated with this hazard level have been derived from the 2008 USGS seismic data available at <https://earthquake.usgs.gov/designmaps/us/application.php>.

1.3.4.4 Seismic Evaluation Parameters

The seismic evaluation parameters are set forth in Table 1.3.

Table 1.3 Seismic Evaluation Parameters

Parameter	Value
Risk Category	III / IV
Structural Performance Level	S-2 / S-1
Non-Structural Performance Level	N-B / N-A
Soil Site Class	D
Seismic Hazard Level for Buildings	ASCE 41-13 / BSE-1E
S _{XS}	0.445
S _{X1}	0.254
Seismic Hazard Level for Tanks	ACI 350.3 / ASCE 7-10
S _{DS}	0.696
S _{D1}	0.435
T _L	16 sec

1.3.5 Data Collection and Review

To obtain data and information necessary for use in the evaluation of the facilities, we reviewed the following documents and media:

- Record drawings for the Willamette River Water Treatment Plant, prepared by Montgomery Watson Harza (MWH), dated December 2002.
- Geotechnical Analyses and Recommendations in Support of 30 Percent Design Effort, prepared by Squier Associates, dated March 2000.
- Geotechnical Report for the WRWTP Lower Site and Upper Site, prepared by Shannon & Wilson (S&W), dated November 2016.

Based on a review of these documents, the material properties used in this evaluation are summarized in Table 1.4.

Table 1.4 Material Properties

Material	Property
Concrete compressive strength	$f'_c = 4,000$ psi
Masonry compressive strength	$f'_m = 1,500$ psi
Reinforcing steel yield strength	$f_y = 60,000$ psi
Wide-flange steel yield strength	$f_y = 36,000$ psi
Steel shape yield strength	$f_y = 36,000$ psi
Steel deck yield strength	$f_y = 38,000$ psi

1.3.6 Analysis Procedures

Analysis procedures followed the requirements set forth in ASCE 41-13. For the most part, the structures did not have any significant irregularities that prohibited the use of linear static procedures and two-dimensional mathematical models.

Two-dimensional linear static analyses were advanced using a combination of calculation tools. Where required by ASCE 41-13 and where structural framing systems and load paths were sufficiently complicated, we used three-dimensional mathematical models, which were performed using STAADPro v8i, a finite element structural analysis software package. Where inclusion of hydrostatic and hydrodynamic loads were necessary, Carollo's proprietary, in-house spreadsheets tailored for analysis of water-bearing structures were used.

The analyses include the structure above grade and those portions of the structure below grade that are within the seismic load path for load resistance. Loads applied to the structures include dead loads, live loads, surcharge loads, active earth pressure, soil seismic pressures, fluid loads, hydrodynamic loads, and inertial seismic loads. Load combinations analyzed were limited to those that include seismic loads. Load intensities and material weights assumed for the evaluation are presented in Table 1.5.

Refer to Appendix B for the Tier 1 checklists and Appendix C for the supporting calculations for both the Tier 1 and Tier 2 level seismic evaluations.

Table 1.5 Load Intensities

Material	Property
Unit weight of concrete	150 pcf
Unit weight of water	62.4 pcf
Unit weight of steel	490 pcf
Unit weight of soil	110 pcf
Active earth pressure	55 psf/ft
Soil seismic pressure ⁽¹⁾	35 psf/ft

Notes:

1. Applied as in inverted triangular load distribution. See Squier 2000.

1.3.7 Acceptance Criteria

The analysis involves the estimation of seismic load and deformation demands placed upon structural members. These demands are compared against their estimated capacity, which is a

function of the member proportions, material properties, and desired performance level. The metric used in this evaluation to quantify the degree of distress of an existing member or connection is referred to as the “demand-capacity ratio” or DCR.

$$\text{DCR} = \frac{\text{Load Demand}}{\text{Available Capacity}}$$

DCR values that exceed 1.0 are typically considered to have exceeded their capacity for the evaluated performance level.

The estimated capacity is a function of the material properties. For this evaluation, the material properties have been obtained from the record construction documents. For Tier 2 investigations and beyond, ASCE 41-13 requires that a knowledge factor be applied to the material property depending on what type of construction documents the material information was obtained from. For any Tier 2 evaluations, a knowledge factor of 0.75 was applied where the material properties were not specified on the construction documents and a knowledge factor of 0.90 was applied where the material properties were obtained from the construction drawings, specifications, mill certificates and material test results. Material test data from the original construction was not available to justify use of a higher knowledge factor.

1.4 Findings and Recommendations

Findings include structural vulnerabilities and non-structural vulnerabilities. A geo-seismic hazard was previously provided for the site as part of the 2015 TVWD Master Plan Update. A discussion on the impact to the subject facilities is included in Section 2.5.

Structural vulnerabilities identified for the subject facilities and important connected components, the recommended mitigation, and estimated costs are provided in Table 1.6. Additionally, each finding has been assigned a priority of high (H), medium (M), or low (L), which can be used to facilitate integration of mitigation measures into separate projects or in a phased implementation over time. Photographs are provided in Appendix A to assist with the description of the issues that were identified. Findings are also accompanied with figures as required to show the recommended mitigation.

Table 1.6 Summary of Seismic Vulnerabilities

Vulnerability	Location	Description	Reference	Recommendation	Cost ⁽¹⁾⁽²⁾⁽³⁾	Priority ⁽⁴⁾
S1	Waste Washwater Equalization	The horizontal reinforcing steel in the north and south basin walls at the east corners (#8 @ 12" oc) have a DCR of 1.53 for soil seismic loads. Refer to Figure 1.2.	ACI 350.3-06	Install three (3) concrete braces across the width of the basin with intermediate column support as required to brace the north and south walls. Braces should be located at the mid-height of the wall. Refer to Figure 1.3.	\$52,000	L
S2	Waste Washwater Equalization	The out-of-plane wall shear at the north and south walls where the existing concrete beam below the east wall of the building intersects the walls has a DCR of 1.67 for soil seismic loads. Refer to Figure 1.4.	ACI 350.3-06	Install three (3) concrete braces across the width of the basin with intermediate column support as required to brace the north and south walls. Braces should be located at the mid-height of the wall. Refer to Figure 1.2.	\$52,000 ⁽⁵⁾	L
S3	High Service Pump Station	The roof joist wall anchorage along the east and west walls of the pump station have a DCR of 1.55. Refer to Figure 1.5.	ASCE 41-13, Tier 1	Add new wall anchorage along the east and west walls mid-way between the existing roof joists. Refer to Figure 1.6.	\$72,000 ⁽⁶⁾	H
S4	High Service Pump Station	The roof diaphragm shear capacity is exceeded at approximately 50% of the roof deck area with DCR's that vary from 1.82 to 2.25. Refer to Figure 1.7.	ASCE 41-13, Tier 1	Replace existing deficient deck sections with 16 GA corrugated steel decking.	\$85,000	H
S5	High Service Pump Station	The tension capacity of the diaphragm chord at the pump room has a DCR of 1.20 at the connections at the east windows. Refer to Figure 1.8	ASCE 41-13, Tier 1	Strengthen the existing chord connections as required. Refer to Figure 1.9.	\$5,000	M
S6	High Service Pump Station	Roof deck shear transfer to the interior wall ledger bolts have DCR's of 3.20 to 3.90. Refer to Figure 1.10.	ASCE 41-13, Tier 1	Add a new top plate over the interior shear walls and install epoxied anchors as required. Refer to Figure 1.11.	\$20,000 ⁽⁶⁾	H

Table 1.6 Summary of Seismic Vulnerabilities (Continued)

Vulnerability	Location	Description	Reference	Recommendation	Cost ⁽¹⁾⁽²⁾⁽³⁾	Priority ⁽⁴⁾
S7	Solids Dewatering Building	The building has no lateral load resisting system in the transverse direction at the first floor level. The existing concrete joint at the elevated slab to the east and west walls does not have any seismic detailing to establish any concrete moment frame.	ASCE 41-13, Tier 1	Provide steel braced frames at the exterior of the building at the east side that braces the building at the second floor level. This system is anticipated to include three braces, each with their own concrete grade beam. It is assumed that the existing stair will need to be relocated to the west side of the building. Refer to Figure 1.12.	\$210,000	H
S8	Solids Dewatering Building	The roof joist wall anchorage along the east and west walls of the building have a DCR of 1.17.	ASCE 41-13, Tier 1	Add new wall anchorage along the east and west walls mid-way between the existing roof joists. Refer to Figure 1.6.	\$32,000	M
S9	Solids Dewatering Building	The foundation elements do not have adequate ties across the building, as the floor slab is not connected to the walls or the footing.	ASCE 41-13, Tier 1	Tie the existing floor slab to the walls, which are already doweled to the existing footings. The retrofit is anticipated to include stainless steel angles and epoxy anchors. Refer to Figure 1.13.	\$13,000	M
S10	Various (estimated at 8 locations)	The space heaters at all facilities are laterally braced above their center of gravity, which allows the heaters to sway during an earthquake. The space heaters at the Switchgear Room at the High Service Pump Station are not braced at all.	ASCE 41-13, Tier 1	Provide seismic bracing.	\$5,000	H
S11	Ozonation	The ozone destruct piping located on the top deck of the Ozonation tank is not seismically braced.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipe down to the concrete deck.	\$5,000	M
S12	High Service Pump Station	The cable trays lack longitudinal seismic bracing.	ASCE 41-13, Tier 1	Provide longitudinal seismic bracing of the cable tray.	\$5,000	M


Table 1.6 Summary of Seismic Vulnerabilities (Continued)

Vulnerability	Location	Description	Reference	Recommendation	Cost ⁽¹⁾⁽²⁾⁽³⁾	Priority ⁽⁴⁾
S13	Chemical Storage / Ozone Generation Room	The chemical pipes that run through the center of the Chemical Storage Room are not seismically braced. The balance of the chemical pipes in the Chemical Storage Room and Ozone Generation Room lack longitudinal seismic bracing.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	\$10,000	M
S14	Ozone Generation Room	The ozone and LOX piping is not seismically braced.	ASCE 41-13, Tier 1	Provide seismic bracing of the pipes as required.	\$5,000	M


Notes:

1. Cost estimate includes an indirect cost multiplier of 2.0, which is meant to account for contingency, overhead, profit, taxes, etc...
2. The cost threshold is considered to be \$2,000. Anything less than this amount will be indicated as such.
3. Soft costs, such as, engineering services, inspection, permitting, etc..., are not included in the cost estimate.
4. H = High, M = Medium, L = Low.
5. The same mitigation recommended for vulnerability S1 will address S2.
6. Assumes that vulnerability S4 is addressed simultaneously, otherwise the cost will need to include removal/replacement of the roofing.

BENDING MOMENT DUE TO SEISMIC SOIL LOAD HAS A DCR OF 1.53 AT THE CORNERS.




ELEVATION OF THE NORTH WALL LOOKING NORTH WITH BENDING CONTOURS.




PLAN VIEW OF THE WASTE WASHWATER EQUALIZATION BASIN.

Figure 1.2 Negative Bending Stresses on the Exterior of the North and South Walls at the East Corners Exceed the Reinforcing Steel Capacity




PLAN VIEW OF THE WASTE WASHWATER EQUALIZATION BASIN.




SECTION VIEW OF THE WASTE WASHWATER EQUALIZATION BASIN.

Figure 1.3 Addition of Concrete Braces to Reduce the Bending and Out-of-Plane Shear Forces Applied to the North and South Walls of the Waste Washwater EQ Basin




ELEVATION OF THE NORTH WALL LOOKING NORTH WITH SHEAR CONTOURS SHOWN.




PLAN VIEW OF THE WASTE WASHWATER EQUALIZATION BASIN.

Figure 1.4 Out-of-Plane Shear Force Due to Soil Seismic Loads Exceeds the Wall Shear Capacity at the Intersection of the Concrete Beam with the North and South Walls



PARTIAL SECTION OF THE BUILDING AT THE ROOF LEVEL



PLAN VIEW OF THE HIGH SERVICE PUMP STATION ROOF

Figure 1.5 Wall Anchorage Forces at the Roof Joist Connections to the Walls Exceed the Existing Anchorage Capacity




Figure 1.6 Addition of New Wall Anchorage Between Existing Joists to Enhance the Wall Anchorage Capacity





Figure 1.7 Diaphragm Shear Stress at the High Service PS Roof Exceeds the Capacity of the Roof Decking



STRENGTHEN CHORD SPLICES AT 6 LOCATIONS

PLAN VIEW OF THE HIGH SERVICE PUMP STATION ROOF

Figure 1.8 Chord Bars are Discontinuous at 3 Large Windows at the West Wall of the High Service PS




Figure 1.9 Chord Splice as Required at the Ends of the Window to Ensure Chord Continuity is Maintained at the High Service PS




Figure 1.10 Diaphragm Shear Transfer to the Interior Shear Walls of the High Service PS Exceeds the Capacity of the Bolted Connections to the Walls






Figure 1.11 Conceptual Retrofit for Increasing the Capacity of the Diaphragm Shear Transfer to the Interior Walls at the High Service PS



FLOOR PLAN VIEW OF THE SOLIDS DEWATERING BUILDING



SECTION VIEW OF THE SOLIDS DEWATERING BUILDING

Figure 1.12 Conceptual Retrofit Scheme to Provide East-West Seismic Bracing for the Solids Dewatering Building




Figure 1.13 Conceptual Retrofit to Tie the Floor Slab Together with the East and West Wall Footings at the Solids Dewatering Building

1.5 Geo-seismic Hazards

Geo-seismic hazards were evaluated by S&W as part of the 2015 TVWD Master Plan Update at the site of the subject facilities and are not further evaluated in this report. It was estimated that the soils below the structures are susceptible to liquefaction and that the soils closer to the Willamette River are additionally susceptible to lateral spread. Lateral spread is a potentially gross instability of the soils and can result in large-scale movement of structures laterally, potentially causing significant structural damage and severance of utility connections that may move differentially.

TVWD is moving forward with mitigation measures to stabilize the soils in the vicinity of the southern section of the plant to help prevent lateral spreading from occurring during an earthquake. Provided that the site soils are stabilized to preclude lateral spreading, the facilities at the site would not be expected to sustain damage to lateral spreading. However, without mitigating liquefaction from occurring, vertical dynamic settlement below the subject facilities at the site can still occur. S&W estimates that the vertical dynamic settlement below the plant, in the vicinity of the subject facilities included in this evaluation, may be on the order of 2.5 to 6.2 inches considering both the 500-year and 2500-year seismic events.

Structures exposed to downward uniform displacements are not generally viewed as creating any gross instability or significant damage to the structure. However, differential settlement can cause tilting, cracking, and other structural damage that can negatively impact the seismic performance of the structure. This is a consideration that is in addition to the findings presented herein for the seismic evaluation of the structures, which is based on exposure to ground-shaking hazards only. Differential settlement is typically estimated to be 1/2 to 2/3 of the total settlement. The level of differential settlement is anticipated to cause some degree of structural damage, but it is not expected to create structural instability or damage that would render the structure unserviceable.

1.6 Summary

The life safety and seismic assessment has revealed some safety issues and seismic vulnerabilities, each of which has been provided with a recommended mitigation along with a cost estimate. The mitigation recommendations have been prioritized as high, medium, or low to help facilitate future planning of projects. Note that seismic vulnerabilities that also pose a potential life safety hazard have also been identified as a life safety issue. Table 1.7 provides a summary of the costs with a corresponding break-down according to the deficiency type and priority.

Table 1.7 Summary of Mitigation Costs

Deficiency Type	Priority ⁽³⁾	Cost ⁽¹⁾⁽²⁾
Life Safety	H	\$350,500
Life Safety	M	\$76,000
Life Safety	L	\$8,000
Life Safety	ALL	\$434,500
Seismic	H	\$392,000
Seismic	M	\$75,000
Seismic	L	\$52,000
Seismic	ALL	\$519,000
Combined	H	\$422,500
Combined	M	\$136,000
Combined	L	\$60,000
Total	ALL	\$618,500

Notes:

1. Cost estimate includes an indirect cost multiplier of 2.0, which is meant to account for contingency, overhead, profit, taxes, etc...
2. Soft costs, such as, engineering services, inspection, permitting, etc..., are not included in the cost estimate.
3. H = High, M = Medium, L = Low.

Attachment A
PHOTOGRAPHS



Photo 1 – LS1 – Access hatch at the Sludge Thickening PS as seen from the underside of the concrete deck



Photo 2 – LS1 – Access hatch at the Sludge Thickening PS as seen from the top side.



Photo 3 – LS2 – Color coded safety warning signs are faded at the south wall of the Ozone Generation Room.



Photo 4 – LS2 – Color coded safety warning signs are faded at the east wall of the Chemical Storage Room.



Photo 5 – LS3 – Guardrail at the north Actiflo™ staircase is less than 42 inches in height.



Photo 6 – LS3 – Guardrail at the north Filter staircase is less than 42 inches in height.



Photo 7 – LS4 – The Actiflo™ gallery has electrical service rated at 1200 amps or higher requiring panic hardware on doors.



Photo 8 – LS4 – The Switchgear Room at the High Service Pump Station has electrical service rated at 1200 amps or higher requiring panic hardware on doors



Photo 9 – LS5 – Group occupancy H at the Ozone Generation Room requires panic hardware on the exit doors (one of the south doors shown).



Photo 10 – LS5 – Group occupancy H at the Chemical Storage Room requires panic hardware on the exit doors (the east door shown).



Photo 11 – LS6 – Chemical piping passing directly over the west door at the Ozone Generation Room.



Photo 12 – LS6 – Chemical piping passing directly over the egress route to the east door at the Chemical Storage Room.



Photo 13 – LS7 – Door at the Waste Washwater Pump Station was found propped open.



Photo 14 – LS7 – Door at the Actiflo™ Room was found propped open.



Photo 15 – LS8 – West guardrail on top of the Actiflo™ Basin lacks a kick plate and it is located over a public walkway.



Photo 16 – LS8 – Gate at the Filter ladder pit lacks a kick plate.




Photo 17 – LS9 – Ponding water on the floor of the Ozone Gallery that is fed by an active leaking expansion joint.



Photo 18 – LS9 – Water on the floor of the south blower room at the Filter Gallery due to active leaks from the water channels above.



Photo 19 – LS10 – Standard electrical receptacle inside the Ozone Gallery.



Photo 20 – LS10 – Standard electrical receptacle inside the Filter Gallery.



Photo 21 – LS11 – The south stairwell at the Ozonation Basin has no dedicated ventilation.



Photo 22 – LS12 – Entrance to the Filter Gallery. The door is located at the top of the stairs.



Photo 23 – LS12 – The east end of the Filter Gallery has a double door that leads out to a ladder pit.



Photo 24 – LS13 – The access ladder to the Waste Washwater EQ Basin does not have any tie-offs for a fall restraint system.



Photo 25 – LS14 – The Solids Dewatering Building does not have any overflow scuppers visible.



Photo 26 – LS14 – The Solids Dewatering Building does not have any overflow scuppers visible.



Photo 27 – LS15 – The southeast door that exits from the Ozone Generation Room does not have an emergency shut-off switch for the ozone generation equipment.



Photo 28 – S3 – The roof joist wall anchorage to the walls at the High Service Pump Station lack capacity to meet seismic performance goals.



Photo 29 – S5 – Diaphragm chord splices at the windows along the west wall require strengthening.



Photo 30 – S6 – Interior walls lack diaphragm shear capacity transfer from the roof diaphragm to the shear walls.



Photo 31 – S7 – The Solids Dewatering Building has no lateral load resisting system at the lower level in the east-west direction.



Photo 32 – S8 - The roof joist wall anchorage to the walls at the Solids Dewatering Building lack capacity to meet seismic performance goals.



Photo 33 – S10 – The space heater at the Washwater Pump Station is suspended and unbraced for seismic loads.



Photo 34 – S10 – The space heater at the Switchgear Room at the High Service PS is suspended without any seismic bracing.



Photo 35 – S11 – The ozone destruct piping lacks seismic bracing at the top of the Ozonation Basin.



Photo 36 – S12 – The cable tray within the High Service PS lacks longitudinal seismic bracing.



Photo 37 – S13 – The chemical piping at the Chemical Storage Room lacks transverse seismic bracing.



Photo 38 – S14 – The ozone and LOX piping at the Ozone Generation Room lacks seismic bracing.

Attachment B
TIER 1 CHECKLISTS

APPENDIX C SUMMARY DATA SHEET

BUILDING DATA

Building Name: ActiFlo Date: 9 / 5 / 2017
 Building Address: 13050 SW Arrowhead Creek Lane, Wilsonville, Oregon 97070
 Latitude: North: 45.295 Longitude: West: 122.783 By: Carollo Engineers
 Year Built: 2003 Year(s) Remodeled: N/A Original Design Code: 2000 International Building Code
 Area (sf): 361 Length (ft): 19.33 Width (ft): 18.67
 No. of Stories: 1 Story Height: 10.0 ft Total Height: 10.0 ft
 USE Industrial Office Warehouse Hospital Residential Educational Other: Municipal

CONSTRUCTION DATA

Gravity Load Structural System: Metal Deck, Roof Truss Joist, CMU Walls and Concrete Slab
 Exterior Transverse Walls: Solid Grouted CMU Walls Openings? No
 Exterior Longitudinal Walls: Solid Grouted CMU Walls Openings? Man doors
 Roof Materials/Framing: Metal deck & Truss Joist
 Intermediate Floors/Framing: N/A
 Ground Floor: Concrete Slab
 Columns: No Foundation: Concrete Slab
 General Condition of Structure: _____
 Levels Below Grade? Yes. Buried concrete structure
 Special Features and Comments: _____

LATERAL-FORCE-RESISTING SYSTEM

	Longitudinal	Transverse
System:	<u>Solid CMU Shear Walls</u>	<u>Solid CMU Shear Walls</u>
Vertical Elements:	<u>Solid CMU Shear Walls</u>	<u>Solid CMU Shear Walls</u>
Diaphragms:	<u>Metal Deck</u>	<u>Metal Deck</u>
Connections:	_____	_____

EVALUATION DATA

BSE-1N Spectral Response Accelerations: $S_{Dn} =$ 0.611g $S_{D1} =$ 0.656g
 Soil Factors: Class = E $F_a =$ 0.992 $F_v =$ 2.40
 BSE-1E Spectral Response Accelerations: $S_{Xn} =$ 0.611g $S_{X1} =$ 0.372g
 Level of Seismicity: High Performance Level: S2 (Damage Control)
 Building Period: $T =$ 0.121 sec
 Spectral Acceleration: $S_a =$ 0.611g
 Modification Factor: $C_m C_1 C_2 =$ 1.40 Building Weight: $W =$ 39 kips
 Pseudo Lateral Force: $V =$ _____
 $C_m C_1 C_2 S_a W =$ 33 kips

BUILDING CLASSIFICATION: CMU Shear Wall with Flexible Diaphragm

REQUIRED TIER 1 CHECKLISTS

	Yes	No
Basic Configuration Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Type <u>RM1</u> Structural Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Nonstructural Component Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FURTHER EVALUATION REQUIREMENT: _____

Project: Wilamette River WTP

Location: ActiFlo

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.1.2LS LIFE SAFETY BASIC CONFIGURATION CHECKLIST

Low Seismicity

Building System

General

- C NC N/A U LOAD PATH: The structure shall contain a complete, well defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation. (Commentary: Sec. A.2.1.1. Tier 2: Sec. 5.4.1.1)
- C NC N/A U ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 4% of the height of the shorter building. This statement shall not apply for the following building types: W1, W1a, and W2. (Commentary: Sec. A.2.1.2. Tier 2: Sec. 5.4.1.2) [No adjacent building]
- C NC N/A U MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure. (Commentary: Sec. A.2.1.3. Tier 2: Sec. 5.4.1.3)

Building Configuration

- C NC N/A U WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction is not less than 80% of the strength in the adjacent story above. (Commentary: Sec. A.2.2.2. Tier 2: Sec. 5.4.2.1)
- C NC N/A U SOFT STORY: The stiffness of the seismic-force-resisting system in any story is not less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above. (Commentary: Sec. A.2.2.3. Tier 2: Sec. 5.4.2.2)
- C NC N/A U VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation. (Commentary: Sec. A.2.2.4. Tier 2: Sec. 5.4.2.3)
- C NC N/A U GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding one-story penthouses and mezzanines. (Commentary: Sec. A.2.2.5. Tier 2: Sec. 5.4.2.4)
- C NC N/A U MASS: There is no change in effective mass more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered. (Commentary: Sec. A.2.2.6. Tier 2: Sec. 5.4.2.5) [Light roof]
- C NC N/A U TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. (Commentary: Sec. A.2.2.7. Tier 2: Sec. 5.4.2.6)

Moderate Seismicity: Complete the Following Items in Addition to the Items for Low Seismicity.

Geologic Site Hazards

- C NC N/A U LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance shall not exist in the foundation soils at depths within 50 ft under the building. (Commentary: Sec. A.6.1.1. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SLOPE FAILURE: The building site is sufficiently remote from potential earthquake-induced slope failures or rockfalls to be unaffected by such failures or is capable of accommodating any predicted movements without failure. (Commentary: Sec. A.6.1.2. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated. (Commentary: Sec. A.6.1.3. Tier 2: 5.4.3.1) [Based on USGS earthquake map]

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Foundation Configuration

- C NC N/A U OVERTURNING: The ratio of the least horizontal dimension of the seismic-force-resisting system at the foundation level to the building height (base/height) is greater than $0.6S_w$. (Commentary: Sec. A.6.2.1. Tier 2: Sec. 5.4.3.3)
- C NC N/A U TIES BETWEEN FOUNDATION ELEMENTS: The foundation has ties adequate to resist seismic forces where footings, piles, and piers are not restrained by beams, slabs, or soils classified as Site Class A, B, or C. (Commentary: Sec. A.6.2.2. Tier 2: Sec. 5.4.3.4) [CMU building on top of buried concrete structure]

Project: Wilamette River WTP

Location: ActiFlo

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.15LS LIFE SAFETY STRUCTURAL CHECKLIST FOR BUILDING TYPES RM1: REINFORCED MASONRY BEARING WALLS WITH FLEXIBLE DIAPHRAGMS AND RM2: REINFORCED MASONRY BEARING WALLS WITH STIFF DIAPHRAGMS

Low and Moderate Seismicity

Seismic-Force-Resisting System

- C NC N/A U REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2. (Commentary: Sec. A.3.2.1.1. Tier 2: Sec. 5.5.1.1)
- C NC N/A U SHEAR STRESS CHECK: The shear stress in the reinforced masonry shear walls, calculated using the Quick Check procedure of Section 4.5.3.3, is less than 70 lb/in.². (Commentary: Sec. A.3.2.4.1. Tier 2: Sec. 5.5.3.1.1)
- C NC N/A U REINFORCING STEEL: The total vertical and horizontal reinforcing steel ratio in reinforced masonry walls is greater than 0.002 of the wall with the minimum of 0.0007 in either of the two directions; the spacing of reinforcing steel is less than 48 in., and all vertical bars extend to the top of the walls. (Commentary: Sec. A.3.2.4.2. Tier 2: Sec. 5.5.3.1.3)

Stiff Diaphragms

- C NC N/A U TOPPING SLAB: Precast concrete diaphragm elements are interconnected by a continuous reinforced concrete topping slab. (Commentary: Sec. A.4.5.1. Tier 2: Sec. 5.6.4)

Connections

- C NC N/A U WALL ANCHORAGE: Exterior concrete or masonry walls that are dependent on the diaphragm for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections shall have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.5.3.7. (Commentary: Sec. A.5.1.1. Tier 2: Sec. 5.7.1.1)
- C NC N/A U WOOD LEDGERS: The connection between the wall panels and the diaphragm does not induce cross-grain bending or tension in the wood ledgers. (Commentary: Sec. A.5.1.2. Tier 2: Sec. 5.7.1.3)
- C NC N/A U TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of seismic forces to the shear walls. (Commentary: Sec. A.5.2.1. Tier 2: Sec. 5.7.2)
- C NC N/A U TOPPING SLAB TO WALLS OR FRAMES: Reinforced concrete topping slabs that interconnect the precast concrete diaphragm elements are doweled for transfer of forces into the shear wall or frame elements. (Commentary: Sec. A.5.2.3. Tier 2: Sec. 5.7.2) [The roof is flexible diaphragm with metal deck]
- C NC N/A U FOUNDATION DOWELS: Wall reinforcement is doweled into the foundation. (Commentary: Sec. A.5.3.5. Tier 2: Sec. 5.7.3.4) [Foundation dowels matching to wall vertical reinforcing bars]
- C NC N/A U GIRDER-COLUMN CONNECTION: There is a positive connection using plates, connection hardware, or straps between the girder and the column support. (Commentary: Sec. A.5.4.1. Tier 2: Sec. 5.7.4.1)

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Stiff Diaphragms

- C NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- C NC N/A U OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft long. (Commentary: Sec. A.4.1.6. Tier 2: Sec. 5.6.1.3)

Flexible Diaphragms

- C NC N/A U CROSS TIES: There are continuous cross ties between diaphragm chords. (Commentary: Sec. A.4.1.2. Tier 2: Sec. 5.6.1.2)
- C NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- C NC N/A U OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft long. (Commentary: Sec. A.4.1.6. Tier 2: Sec. 5.6.1.3)

- C NC **N/A** U STRAIGHT SHEATHING: All straight sheathed diaphragms have aspect ratios less than 2-to-1 in the direction being considered. (Commentary: Sec. A.4.2.1. Tier 2: Sec. 5.6.2)
- C NC **N/A** U SPANS: All wood diaphragms with spans greater than 24 ft consist of wood structural panels or diagonal sheathing. (Commentary: Sec. A.4.2.2. Tier 2: Sec. 5.6.2)
- C NC **N/A** U DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 40 ft and aspect ratios less than or equal to 4-to-1. (Commentary: Sec. A.4.2.3. Tier 2: Sec. 5.6.2)
- C** NC N/A U OTHER DIAPHRAGMS: The diaphragm shall not consist of a system other than wood, metal deck, concrete, or horizontal bracing. (Commentary: Sec. A.4.7.1. Tier 2: Sec. 5.6.5)

Connections

- C NC **N/A** U STIFFNESS OF WALL ANCHORS: Anchors of concrete or masonry walls to wood structural elements are installed taut and are stiff enough to limit the relative movement between the wall and the diaphragm to no greater than 1/8 in. before engagement of the anchors. (Commentary: Sec. A.5.1.4. Tier 2: Sec. 5.7.1.2)

APPENDIX C SUMMARY DATA SHEET

BUILDING DATA

Building Name: Washwater Basin Pump Station Date: 9 / 5 / 2017
 Building Address: 13050 SW Arrowhead Creek Lane, Wilsonville, Oregon 97070
 Latitude: North: 45.295 Longitude: West: 122.783 By: Carollo Engineers
 Year Built: 2003 Year(s) Remodeled: N/A Original Design Code: 2000 International Building Code
 Area (sf): 611 Length (ft): 36.67 Width (ft): 16.67
 No. of Stories: 1 Story Height: 11.33-ft Total Height: 11.33-ft
 USE Industrial Office Warehouse Hospital Residential Educational Other: Municipal

CONSTRUCTION DATA

Gravity Load Structural System: Metal Deck, Roof Truss Joist, CMU Walls and Concrete Slab
 Exterior Transverse Walls: Solid Grouted CMU Walls Openings? Man door & Louver
 Exterior Longitudinal Walls: Solid Grouted CMU Walls Openings? Windows
 Roof Materials/Framing: Metal deck & Truss Joist
 Intermediate Floors/Framing: N/A
 Ground Floor: Concrete Slab
 Columns: No Foundation: Concrete Slab
 General Condition of Structure: _____
 Levels Below Grade? Yes. Buried concrete structure
 Special Features and Comments: _____

LATERAL-FORCE-RESISTING SYSTEM

	Longitudinal	Transverse
System:	<u>Solid CMU Shear Walls</u>	<u>Solid CMU Shear Walls</u>
Vertical Elements:	<u>Solid CMU Shear Walls</u>	<u>Solid CMU Shear Walls</u>
Diaphragms:	<u>Metal Deck</u>	<u>Metal Deck</u>
Connections:	_____	_____

EVALUATION DATA

BSE-1N Spectral Response Accelerations: $S_{Dn} =$ 0.611g $S_{D1} =$ 0.656g
 Soil Factors: Class = E $F_a =$ 0.992 $F_v =$ 2.40
 BSE-1E Spectral Response Accelerations: $S_{Xn} =$ 0.611g $S_{X1} =$ 0.372g
 Level of Seismicity: High Performance Level: S2 (Damage Control)
 Building Period: $T =$ 0.124 Sec
 Spectral Acceleration: $S_a =$ 0.611g
 Modification Factor: $C_m C_1 C_2 =$ 1.40 Building Weight: $W =$ 83 kips
 Pseudo Lateral Force: $V =$ _____
 $C_m C_1 C_2 S_a W =$ 71 kips

BUILDING CLASSIFICATION: CMU Shear Wall with Flexible Diaphragm

REQUIRED TIER 1 CHECKLISTS

	Yes	No
Basic Configuration Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Type <u>RM1</u> Structural Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Nonstructural Component Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FURTHER EVALUATION REQUIREMENT: _____

Project: Wilamette River WTP

Location: Washwater Basin Pump Station

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.1.2LS LIFE SAFETY BASIC CONFIGURATION CHECKLIST

Low Seismicity

Building System

General

- C NC N/A U LOAD PATH: The structure shall contain a complete, well defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation. (Commentary: Sec. A.2.1.1. Tier 2: Sec. 5.4.1.1)
- C NC N/A U ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 4% of the height of the shorter building. This statement shall not apply for the following building types: W1, W1a, and W2. (Commentary: Sec. A.2.1.2. Tier 2: Sec. 5.4.1.2) [No adjacent building]
- C NC N/A U MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure. (Commentary: Sec. A.2.1.3. Tier 2: Sec. 5.4.1.3)

Building Configuration

- C NC N/A U WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction is not less than 80% of the strength in the adjacent story above. (Commentary: Sec. A.2.2.2. Tier 2: Sec. 5.4.2.1)
- C NC N/A U SOFT STORY: The stiffness of the seismic-force-resisting system in any story is not less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above. (Commentary: Sec. A.2.2.3. Tier 2: Sec. 5.4.2.2)
- C NC N/A U VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation. (Commentary: Sec. A.2.2.4. Tier 2: Sec. 5.4.2.3)
- C NC N/A U GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding one-story penthouses and mezzanines. (Commentary: Sec. A.2.2.5. Tier 2: Sec. 5.4.2.4)
- C NC N/A U MASS: There is no change in effective mass more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered. (Commentary: Sec. A.2.2.6. Tier 2: Sec. 5.4.2.5) [Light roof]
- C NC N/A U TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. (Commentary: Sec. A.2.2.7. Tier 2: Sec. 5.4.2.6)

Moderate Seismicity: Complete the Following Items in Addition to the Items for Low Seismicity.

Geologic Site Hazards

- C NC N/A U LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance shall not exist in the foundation soils at depths within 50 ft under the building. (Commentary: Sec. A.6.1.1. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SLOPE FAILURE: The building site is sufficiently remote from potential earthquake-induced slope failures or rockfalls to be unaffected by such failures or is capable of accommodating any predicted movements without failure. (Commentary: Sec. A.6.1.2. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated. (Commentary: Sec. A.6.1.3. Tier 2: 5.4.3.1) [Based on USGS earthquake map]

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Foundation Configuration

- C NC N/A U OVERTURNING: The ratio of the least horizontal dimension of the seismic-force-resisting system at the foundation level to the building height (base/height) is greater than $0.6S_w$. (Commentary: Sec. A.6.2.1. Tier 2: Sec. 5.4.3.3)
- C NC N/A U TIES BETWEEN FOUNDATION ELEMENTS: The foundation has ties adequate to resist seismic forces where footings, piles, and piers are not restrained by beams, slabs, or soils classified as Site Class A, B, or C. (Commentary: Sec. A.6.2.2. Tier 2: Sec. 5.4.3.4) [CMU building on top of buried concrete structure]

Project: Wilamette River WTP

Location: Washwater Basin Pump Station

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.15LS LIFE SAFETY STRUCTURAL CHECKLIST FOR BUILDING TYPES RM1: REINFORCED MASONRY BEARING WALLS WITH FLEXIBLE DIAPHRAGMS AND RM2: REINFORCED MASONRY BEARING WALLS WITH STIFF DIAPHRAGMS

Low and Moderate Seismicity

Seismic-Force-Resisting System

- C NC N/A U REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2. (Commentary: Sec. A.3.2.1.1. Tier 2: Sec. 5.5.1.1)
- C NC N/A U SHEAR STRESS CHECK: The shear stress in the reinforced masonry shear walls, calculated using the Quick Check procedure of Section 4.5.3.3, is less than 70 lb/in.². (Commentary: Sec. A.3.2.4.1. Tier 2: Sec. 5.5.3.1.1)
- C NC N/A U REINFORCING STEEL: The total vertical and horizontal reinforcing steel ratio in reinforced masonry walls is greater than 0.002 of the wall with the minimum of 0.0007 in either of the two directions; the spacing of reinforcing steel is less than 48 in., and all vertical bars extend to the top of the walls. (Commentary: Sec. A.3.2.4.2. Tier 2: Sec. 5.5.3.1.3)

Stiff Diaphragms

- C NC N/A U TOPPING SLAB: Precast concrete diaphragm elements are interconnected by a continuous reinforced concrete topping slab. (Commentary: Sec. A.4.5.1. Tier 2: Sec. 5.6.4)

Connections

- C NC N/A U WALL ANCHORAGE: Exterior concrete or masonry walls that are dependent on the diaphragm for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections shall have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.5.3.7. (Commentary: Sec. A.5.1.1. Tier 2: Sec. 5.7.1.1) [East & West Walls: Wall anchorage at truss joist support adequate for wall out-of-plane]
[North & South Walls: Anchor bolts, ledger angle & steel deck adequate for wall out-of-plane]
- C NC N/A U WOOD LEDGERS: The connection between the wall panels and the diaphragm does not induce cross-grain bending or tension in the wood ledgers. (Commentary: Sec. A.5.1.2. Tier 2: Sec. 5.7.1.3)
- C NC N/A U TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of seismic forces to the shear walls. (Commentary: Sec. A.5.2.1. Tier 2: Sec. 5.7.2)
- C NC N/A U TOPPING SLAB TO WALLS OR FRAMES: Reinforced concrete topping slabs that interconnect the precast concrete diaphragm elements are doweled for transfer of forces into the shear wall or frame elements. (Commentary: Sec. A.5.2.3. Tier 2: Sec. 5.7.2) [The roof is flexible diaphragm with metal deck]
- C NC N/A U FOUNDATION DOWELS: Wall reinforcement is doweled into the foundation. (Commentary: Sec. A.5.3.5. Tier 2: Sec. 5.7.3.4) [Foundation dowels matching to wall vertical reinforcing bars]
- C NC N/A U GIRDER-COLUMN CONNECTION: There is a positive connection using plates, connection hardware, or straps between the girder and the column support. (Commentary: Sec. A.5.4.1. Tier 2: Sec. 5.7.4.1)

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Stiff Diaphragms

- C NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- C NC N/A U OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft long. (Commentary: Sec. A.4.1.6. Tier 2: Sec. 5.6.1.3)

Flexible Diaphragms

- C NC N/A U CROSS TIES: There are continuous cross ties between diaphragm chords. (Commentary: Sec. A.4.1.2. Tier 2: Sec. 5.6.1.2)
- C NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- C NC N/A U OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft long. (Commentary: Sec. A.4.1.6. Tier 2: Sec. 5.6.1.3)

- C NC (N/A) U STRAIGHT SHEATHING: All straight sheathed diaphragms have aspect ratios less than 2-to-1 in the direction being considered. (Commentary: Sec. A.4.2.1. Tier 2: Sec. 5.6.2)
- C NC (N/A) U SPANS: All wood diaphragms with spans greater than 24 ft consist of wood structural panels or diagonal sheathing. (Commentary: Sec. A.4.2.2. Tier 2: Sec. 5.6.2)
- C NC (N/A) U DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 40 ft and aspect ratios less than or equal to 4-to-1. (Commentary: Sec. A.4.2.3. Tier 2: Sec. 5.6.2)
- (C) NC N/A U OTHER DIAPHRAGMS: The diaphragm shall not consist of a system other than wood, metal deck, concrete, or horizontal bracing. (Commentary: Sec. A.4.7.1. Tier 2: Sec. 5.6.5)

Connections

- C NC (N/A) U STIFFNESS OF WALL ANCHORS: Anchors of concrete or masonry walls to wood structural elements are installed taut and are stiff enough to limit the relative movement between the wall and the diaphragm to no greater than 1/8 in. before engagement of the anchors. (Commentary: Sec. A.5.1.4. Tier 2: Sec. 5.7.1.2)

APPENDIX C SUMMARY DATA SHEET

BUILDING DATA

Building Name: High Service Pump Station Date: 5 / 18 / 2015
 Building Address: 13050 SW Arrowhead Creek Lane, Wilsonville, Oregon 97070
 Latitude: North: 45.295 Longitude: West: 122.783 By: Carollo Engineers
 Year Built: 2003 Year(s) Remodeled: N/A Original Design Code: 2000 International Building Code
 Area (sf): 4180 Length (ft): 138.33 Width (ft): 29.17
 No. of Stories: 1 Story Height: 22.33 ft Total Height: 22.33 ft
 USE Industrial Office Warehouse Hospital Residential Educational Other: Municipal

CONSTRUCTION DATA

Gravity Load Structural System: Metal Deck, Steel Truss Joist, Concrete Walls and Concrete Slab
 Exterior Transverse Walls: Cast-in-Place Reinforced Concrete Walls Openings? Windows and doors
 Exterior Longitudinal Walls: Cast-in-Place Reinforced Concrete Walls Openings? Windows and doors
 Roof Materials/Framing: Metal deck supported on steel truss joist
 Intermediate Floors/Framing: N/A
 Ground Floor: Concrete Slab
 Columns: No columns Foundation: Concrete Slab
 General Condition of Structure: _____
 Levels Below Grade? Buried concrete structure
 Special Features and Comments: _____

LATERAL-FORCE-RESISTING SYSTEM

	Longitudinal	Transverse
System:	<u>Concrete Shear Walls</u>	<u>Concrete Shear Walls</u>
Vertical Elements:	<u>Concrete Shear Walls</u>	<u>Concrete Shear Walls</u>
Diaphragms:	<u>Metal Deck</u>	<u>Metal Deck</u>
Connections:	_____	_____

EVALUATION DATA

BSE-1N Spectral Response Accelerations: $S_{Ds} =$ 0.611g $S_{D1} =$ 0.656g
 Soil Factors: Class = E $F_a =$ 0.992 $F_v =$ 2.40
 BSE-1E Spectral Response Accelerations: $S_{XS} =$ 0.611g $S_{X1} =$ 0.372g
 Level of Seismicity: High Performance Level: S1 (Immediate Occupancy)
 Building Period: $T =$ 0.205 sec
 Spectral Acceleration: $S_a =$ 0.611g
 Modification Factor: $C_m C_1 C_2 =$ 1.40 Building Weight: $W =$ 691 kips
 Pseudo Lateral Force: $V =$ _____
 $C_m C_1 C_2 S_a W =$ 591 kips

BUILDING CLASSIFICATION: Concrete Shear Wall with Flexible Diaphragm

REQUIRED TIER 1 CHECKLISTS

	Yes	No
Basic Configuration Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Type <u>C2a</u> Structural Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Nonstructural Component Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FURTHER EVALUATION REQUIREMENT: _____

Project: Wilamette River WTP

Location: High Service Pump Station

Completed by: Carollo Engineers (James Doering)

Date: 5 / 18 / 2015

16.1.2IO IMMEDIATE OCCUPANCY BASIC CONFIGURATION CHECKLIST

Very Low Seismicity

Building System

General

- C NC N/A U LOAD PATH: The structure shall contain a complete, well-defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation. (Commentary: Sec. A.2.1.1. Tier 2: Sec. 5.4.1.1)
- C NC N/A U ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 4% of the height of the shorter building. This statement need not apply for the following building types: W1, W1a, and W2. (Commentary: Sec. A.2.1.2. Tier 2: Sec. 5.4.1.2)
- C NC N/A U MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure. (Commentary: Sec. A.2.1.3. Tier 2: Sec. 5.4.1.3)

Building Configuration

- C NC N/A U WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction shall not be less than 80% of the strength in the adjacent story above. (Commentary: Sec. A.2.2.2. Tier 2: Sec. 5.4.2.1)
- C NC N/A U SOFT STORY: The stiffness of the seismic-force-resisting system in any story shall not be less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above. (Commentary: Sec. A.2.2.3. Tier 2: Sec. 5.4.2.2)
- C NC N/A U VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation. (Commentary: Sec. A.2.2.4. Tier 2: Sec. 5.4.2.3)
- C NC N/A U GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding one-story penthouses and mezzanines. (Commentary: Sec. A.2.2.5. Tier 2: Sec. 5.4.2.4)
- C NC N/A U MASS: There is no change in effective mass more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered. (Commentary: Sec. A.2.2.6. Tier 2: Sec. 5.4.2.5)
- C NC N/A U TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. (Commentary: Sec. A.2.2.7. Tier 2: Sec. 5.4.2.6)

Low Seismicity: Complete the Following Items in Addition to the Items for Very Low Seismicity.

Geologic Site Hazards

- C NC N/A U LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance shall not exist in the foundation soils at depths within 50 ft under the building. (Commentary: Sec. A.6.1.1. Tier 2: 5.4.3.1)
- C NC N/A U SLOPE FAILURE: The building site is sufficiently remote from potential earthquake-induced slope failures or rockfalls to be unaffected by such failures or is capable of accommodating any predicted movements without failure. (Commentary: Sec. A.6.1.2. Tier 2: 5.4.3.1)
- C NC N/A U SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated. (Commentary: Sec. A.6.1.3. Tier 2: 5.4.3.1)

Moderate and High Seismicity: Complete the Following Items in Addition to the Items for Low Seismicity.

Foundation Configuration

- C NC N/A U OVERTURNING: The ratio of the least horizontal dimension of the seismic-force-resisting system at the foundation level to the building height (base/height) is greater than $0.6S_w$. (Commentary: Sec. A.6.2.1. Tier 2: Sec. 5.4.3.3)
- C NC N/A U TIES BETWEEN FOUNDATION ELEMENTS: The foundation has ties adequate to resist seismic forces where footings, piles, and piers are not restrained by beams, slabs, or soils classified as Site Class A, B, or C. (Commentary: Sec. A.6.2.2. Tier 2: Sec. 5.4.3.4)

Project: Wilamette River WTP

Location: High Service Pump Station

Completed by: Carollo Engineers (James Doering)

Date: 5 / 18 / 2015

16.10IO IMMEDIATE OCCUPANCY STRUCTURAL CHECKLIST FOR BUILDING TYPES C2: CONCRETE SHEAR WALLS WITH STIFF DIAPHRAGMS AND C2A: CONCRETE SHEAR WALLS WITH FLEXIBLE DIAPHRAGMS

Very Low Seismicity

Seismic-Force-Resisting System

- C NC **(N/A)** U COMPLETE FRAMES: Steel or concrete frames classified as secondary components form a complete vertical-load-carrying system. (Commentary: Sec. A.3.1.6.1. Tier 2: Sec. 5.5.2.5.1)
- (C)** NC N/A U REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2. (Commentary: Sec. A.3.2.1.1. Tier 2: Sec. 5.5.1.1)
- (C)** NC N/A U SHEAR STRESS CHECK: The shear stress in the concrete shear walls, calculated using the Quick Check procedure of Section 4.5.3.3, is less than the greater of 100 lb/in.^2 or $2\sqrt{f'_c}$. (Commentary: Sec. A.3.2.2.1. Tier 2: Sec. 5.5.3.1.1)
- (C)** NC N/A U REINFORCING STEEL: The ratio of reinforcing steel area to gross concrete area is not less than 0.0012 in the vertical direction and 0.0020 in the horizontal direction. The spacing of reinforcing steel is equal to or less than 18 in. (Commentary: Sec. A.3.2.2.2. Tier 2: Sec. 5.5.3.1.3)

Connections

- C **(NC)** N/A U WALL ANCHORAGE AT FLEXIBLE DIAPHRAGMS: Exterior concrete or masonry walls that are dependent on flexible diaphragms for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.5.3.7. (Commentary: Sec. A.5.1.1. Tier 2: Sec. 5.7.1.1)
- (C)** NC N/A U TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of loads to the shear walls, and the connections are able to develop the lesser of the shear strength of the walls or diaphragms. (Commentary: Sec. A.5.2.1. Tier 2: Sec. 5.7.2)
- (C)** NC N/A U FOUNDATION DOWELS: Wall reinforcement is doweled into the foundation, and the dowels are able to develop the lesser of the strength of the walls or the uplift capacity of the foundation. (Commentary: Sec. A.5.3.5. Tier 2: Sec. 5.7.3.4)

Foundation System

- C NC **(N/A)** U DEEP FOUNDATIONS: Piles and piers are capable of transferring the lateral forces between the structure and the soil. (Commentary: Sec. A.6.2.3)
- C NC **(N/A)** U SLOPING SITES: The difference in foundation embedment depth from one side of the building to another shall not exceed one story high. (Commentary: Sec. A.6.2.4)

Low, Moderate, and High Seismicity: Complete the Following Items in Addition to the Items for Very Low Seismicity.

Seismic-Force-Resisting System

- C NC **(N/A)** U DEFLECTION COMPATIBILITY: Secondary components have the shear capacity to develop the flexural strength of the components and are compliant with the following items: COLUMN-BAR SPLICES, BEAM-BAR SPLICES, COLUMN-TIE SPACING, STIRRUP SPACING, and STIRRUP AND TIE HOOK in the Immediate Occupancy Structural Checklist for Building Type C1. (Commentary: Sec. A.3.1.6.2. Tier 2: Sec. 5.5.2.5.2)
- C NC **(N/A)** U FLAT SLABS: Flat slabs or plates not part of seismic-force-resisting system have continuous bottom steel through the column joints. (Commentary: Sec. A.3.1.6.3. Tier 2: Sec. 5.5.2.5.3)
- C NC **(N/A)** U COUPLING BEAMS: The stirrups in coupling beams over means of egress are spaced at or less than $d/2$ and are anchored into the confined core of the beam with hooks of 135 degrees or more. The ends of both walls to which the coupling beam is attached are supported at each end to resist vertical loads caused by overturning. Coupling beams have the capacity in shear to develop the uplift capacity of the adjacent wall. (Commentary: Sec. A.3.2.2.3. Tier 2: Sec. 5.5.3.2.1)
- (C)** NC N/A U OVERTURNING: All shear walls have aspect ratios less than 4-to-1. Wall piers need not be considered. (Commentary: Sec. A.3.2.2.4. Tier 2: Sec. 5.5.3.1.4)

- Ⓒ NC N/A U CONFINEMENT REINFORCING: For shear walls with aspect ratios greater than 2-to-1, the boundary elements are confined with spirals or ties with spacing less than $8d_b$. (Commentary: Sec. A.3.2.2.5. Tier 2: Sec. 5.5.3.2.2)
- Ⓒ NC N/A U WALL REINFORCING AT OPENINGS: There is added trim reinforcement around all wall openings with a dimension greater than three times the thickness of the wall. (Commentary: Sec. A.3.2.2.6. Tier 2: Sec. 5.5.3.1.5)
- C Ⓒ N/A U WALL THICKNESS: Thicknesses of bearing walls are not less than 1/25 the unsupported height or length, whichever is shorter, nor less than 4 in. (Commentary: Sec. A.3.2.2.7. Tier 2: Sec. 5.5.3.1.2)

Connections

- C NC Ⓒ U UPLIFT AT PILE CAPS: Pile caps shall have top reinforcement, and piles are anchored to the pile caps; the pile cap reinforcement and pile anchorage are able to develop the tensile capacity of the piles. (Commentary: Sec. A.5.3.8. Tier 2: Sec. 5.7.3.5)

Diaphragms (Flexible or Stiff)

- Ⓒ NC N/A U DIAPHRAGM CONTINUITY: The diaphragms are not composed of split-level floors and do not have expansion joints. (Commentary: Sec. A.4.1.1. Tier 2: Sec. 5.6.1.1)
- Ⓒ NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 15% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- Ⓒ NC N/A U PLAN IRREGULARITIES: There is tensile capacity to develop the strength of the diaphragm at reentrant corners or other locations of plan irregularities. (Commentary: Sec. A.4.1.7. Tier 2: Sec. 5.6.1.4)
- C NC Ⓒ U DIAPHRAGM REINFORCEMENT AT OPENINGS: There is reinforcing around all diaphragm openings larger than 50% of the building width in either major plan dimension. (Commentary: Sec. A.4.1.8. Tier 2: Sec. 5.6.1.5)

Flexible Diaphragms

- Ⓒ NC N/A U CROSS TIES: There are continuous cross ties between diaphragm chords. (Commentary: Sec. A.4.1.2. Tier 2: Sec. 5.6.1.2)
- C NC Ⓒ U STRAIGHT SHEATHING: All straight sheathed diaphragms have aspect ratios less than 1-to-1 in the direction being considered. (Commentary: Sec. A.4.2.1. Tier 2: Sec. 5.6.2)
- C NC Ⓒ U SPANS: All wood diaphragms with spans greater than 12 ft consist of wood structural panels or diagonal sheathing. (Commentary: Sec. A.4.2.2. Tier 2: Sec. 5.6.2)
- C NC Ⓒ U DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 30 ft and aspect ratios less than or equal to 3-to-1. (Commentary: Sec. A.4.2.3. Tier 2: Sec. 5.6.2)
- C Ⓒ N/A U NONCONCRETE FILLED DIAPHRAGMS: Untopped metal deck diaphragms or metal deck diaphragms with fill other than concrete consist of horizontal spans of less than 40 ft and have aspect ratios less than 4-to-1. (Commentary: Sec. A.4.3.1. Tier 2: Sec. 5.6.3)
- C NC Ⓒ U OTHER DIAPHRAGMS: The diaphragm does not consist of a system other than wood, metal deck, concrete, or horizontal bracing. (Commentary: Sec. A.4.7.1. Tier 2: Sec. 5.6.5)

APPENDIX C SUMMARY DATA SHEET

BUILDING DATA

Building Name: Sludge Thickener (Stair Housing) Date: 9 / 5 / 2017
 Building Address: 13050 SW Arrowhead Creek Lane, Wilsonville, Oregon 97070
 Latitude: North: 45.295 Longitude: West: 122.783 By: Carollo Engineers
 Year Built: 2003 Year(s) Remodeled: N/A Original Design Code: 2000 International Building Code
 Area (sf): 97 Length (ft): 15.0 Width (ft): 12.0
 No. of Stories: 1 Story Height: 10.5-ft Total Height: 10.5 ft
 USE Industrial Office Warehouse Hospital Residential Educational Other: Municipal

CONSTRUCTION DATA

Gravity Load Structural System: Metal Deck, Concrete Walls and Foundation Slab
 Exterior Transverse Walls: Cast-in-Place Reinforced Concrete Walls Openings? No
 Exterior Longitudinal Walls: Cast-in-Place Reinforced Concrete Walls Openings? Man access door
 Roof Materials/Framing: Metal deck supported on concrete walls
 Intermediate Floors/Framing: N/A
 Ground Floor: Concrete Slab
 Columns: No Foundation: Concrete Slab
 General Condition of Structure: _____
 Levels Below Grade? Yes. Buried concrete structure
 Special Features and Comments: _____

LATERAL-FORCE-RESISTING SYSTEM

	Longitudinal	Transverse
System:	<u>Concrete Shear Walls</u>	<u>Concrete Shear Walls</u>
Vertical Elements:	<u>Concrete Shear Walls</u>	<u>Concrete Shear Walls</u>
Diaphragms:	<u>Metal Deck</u>	<u>Metal Deck</u>
Connections:	_____	_____

EVALUATION DATA

BSE-1N Spectral Response Accelerations: $S_{Ds} =$ 0.611g $S_{D1} =$ 0.656g
 Soil Factors: Class = E $F_a =$ 0.992 $F_v =$ 2.40
 BSE-1E Spectral Response Accelerations: $S_{Xs} =$ 0.611g $S_{X1} =$ 0.372g
 Level of Seismicity: High Performance Level: S2 (Damage Control)
 Building Period: $T =$ 0.117 sec
 Spectral Acceleration: $S_a =$ 0.611g
 Modification Factor: $C_m C_1 C_2 =$ 1.40 Building Weight: $W =$ 54 kips
 Pseudo Lateral Force: $V =$ _____
 $C_m C_1 C_2 S_a W =$ 46 kips

BUILDING CLASSIFICATION: Concrete Shear Wall with Flexible Diaphragm

REQUIRED TIER 1 CHECKLISTS

	Yes	No
Basic Configuration Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Type <u>C2a</u> Structural Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Nonstructural Component Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FURTHER EVALUATION REQUIREMENT: _____

Project: Wilamette River WTP

Location: Sludge Thickener (Stair Housing)

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.1.2LS LIFE SAFETY BASIC CONFIGURATION CHECKLIST

Low Seismicity

Building System

General

- C NC N/A U LOAD PATH: The structure shall contain a complete, well defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation. (Commentary: Sec. A.2.1.1. Tier 2: Sec. 5.4.1.1)
- C NC N/A U ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 4% of the height of the shorter building. This statement shall not apply for the following building types: W1, W1a, and W2. (Commentary: Sec. A.2.1.2. Tier 2: Sec. 5.4.1.2) [No adjacent building]
- C NC N/A U MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure. (Commentary: Sec. A.2.1.3. Tier 2: Sec. 5.4.1.3)

Building Configuration

- C NC N/A U WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction is not less than 80% of the strength in the adjacent story above. (Commentary: Sec. A.2.2.2. Tier 2: Sec. 5.4.2.1)
- C NC N/A U SOFT STORY: The stiffness of the seismic-force-resisting system in any story is not less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above. (Commentary: Sec. A.2.2.3. Tier 2: Sec. 5.4.2.2)
- C NC N/A U VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation. (Commentary: Sec. A.2.2.4. Tier 2: Sec. 5.4.2.3)
- C NC N/A U GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding one-story penthouses and mezzanines. (Commentary: Sec. A.2.2.5. Tier 2: Sec. 5.4.2.4)
- C NC N/A U MASS: There is no change in effective mass more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered. (Commentary: Sec. A.2.2.6. Tier 2: Sec. 5.4.2.5) [Light roof]
- C NC N/A U TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. (Commentary: Sec. A.2.2.7. Tier 2: Sec. 5.4.2.6)

Moderate Seismicity: Complete the Following Items in Addition to the Items for Low Seismicity.

Geologic Site Hazards

- C NC N/A U LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance shall not exist in the foundation soils at depths within 50 ft under the building. (Commentary: Sec. A.6.1.1. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SLOPE FAILURE: The building site is sufficiently remote from potential earthquake-induced slope failures or rockfalls to be unaffected by such failures or is capable of accommodating any predicted movements without failure. (Commentary: Sec. A.6.1.2. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated. (Commentary: Sec. A.6.1.3. Tier 2: 5.4.3.1) [Based on USGS earthquake map]

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Foundation Configuration

- C NC N/A U OVERTURNING: The ratio of the least horizontal dimension of the seismic-force-resisting system at the foundation level to the building height (base/height) is greater than $0.6S_w$. (Commentary: Sec. A.6.2.1. Tier 2: Sec. 5.4.3.3)
- C NC N/A U TIES BETWEEN FOUNDATION ELEMENTS: The foundation has ties adequate to resist seismic forces where footings, piles, and piers are not restrained by beams, slabs, or soils classified as Site Class A, B, or C. (Commentary: Sec. A.6.2.2. Tier 2: Sec. 5.4.3.4) [Stair housing resting on 12-in thick slab]

Project: Wilamette River WTP

Location: Sludge Thickener (Stair Housing)

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.10LS LIFE SAFETY STRUCTURAL CHECKLIST FOR BUILDING TYPES C2: CONCRETE SHEAR WALLS WITH STIFF DIAPHRAGMS AND C2A: CONCRETE SHEAR WALLS WITH FLEXIBLE DIAPHRAGMS

Low and Moderate Seismicity

Seismic-Force-Resisting System

- C NC **(N/A)** U COMPLETE FRAMES: Steel or concrete frames classified as secondary components form a complete vertical-load-carrying system. (Commentary: Sec. A.3.1.6.1. Tier 2: Sec. 5.5.2.5.1)
- (C)** NC N/A U REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2. (Commentary: Sec. A.3.2.1.1. Tier 2: Sec. 5.5.1.1)
- (C)** NC N/A U SHEAR STRESS CHECK: The shear stress in the concrete shear walls, calculated using the Quick Check procedure of Section 4.5.3.3, is less than the greater of 100 lb/in.^2 or $2\sqrt{f'_c}$. (Commentary: Sec. A.3.2.2.1. Tier 2: Sec. 5.5.3.1.1)
- (C)** NC N/A U REINFORCING STEEL: The ratio of reinforcing steel area to gross concrete area is not less than 0.0012 in the vertical direction and 0.0020 in the horizontal direction. (Commentary: Sec. A.3.2.2.2. Tier 2: Sec. 5.5.3.1.3)

Connections

- (C)** NC N/A U WALL ANCHORAGE AT FLEXIBLE DIAPHRAGMS: Exterior concrete or masonry walls that are dependent on flexible diaphragms for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.5.3.7. (Commentary: Sec. A.5.1.1. Tier 2: Sec. 5.7.1.1) [Anchor bolts, ledger and roof deck adequate for wall out-of-plane] [Walls can also span between the side walls]
- (C)** NC N/A U TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of seismic forces to the shear walls. (Commentary: Sec. A.5.2.1. Tier 2: Sec. 5.7.2)
- (C)** NC N/A U FOUNDATION DOWELS: Wall reinforcement is doweled into the foundation with vertical bars equal in size and spacing to the vertical wall reinforcing immediately above the foundation. (Commentary: Sec. A.5.3.5. Tier 2: Sec. 5.7.3.4) [Foundation dowels are same as wall vertical reinforcing bars]

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Seismic-Force-Resisting System

- C NC **(N/A)** U DEFLECTION COMPATIBILITY: Secondary components have the shear capacity to develop the flexural strength of the components. (Commentary: Sec. A.3.1.6.2. Tier 2: Sec. 5.5.2.5.2) [No secondary components]
- C NC **(N/A)** U FLAT SLABS: Flat slabs or plates not part of the seismic-force-resisting system have continuous bottom steel through the column joints. (Commentary: Sec. A.3.1.6.3. Tier 2: Sec. 5.5.2.5.3)
- C NC **(N/A)** U COUPLING BEAMS: The stirrups in coupling beams over means of egress are spaced at or less than $d/2$ and are anchored into the confined core of the beam with hooks of 135 degrees or more. The ends of both walls to which the coupling beam is attached are supported at each end to resist vertical loads caused by overturning. (Commentary: Sec. A.3.2.2.3. Tier 2: Sec. 5.5.3.2.1)

Connections

- C NC **(N/A)** U UPLIFT AT PILE CAPS: Pile caps have top reinforcement, and piles are anchored to the pile caps. (Commentary: Sec. A.5.3.8. Tier 2: Sec. 5.7.3.5)

Diaphragms (Flexible or Stiff)

- (C)** NC N/A U DIAPHRAGM CONTINUITY: The diaphragms are not composed of split-level floors and do not have expansion joints. (Commentary: Sec. A.4.1.1. Tier 2: Sec. 5.6.1.1)
- C NC **(N/A)** U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3) [No openings]

Flexible Diaphragms

- C NC **N/A** U CROSS TIES: There are continuous cross ties between diaphragm chords. (Commentary: Sec. A.4.1.2, Tier 2; Sec. 5.6.1.2) **[Rood deck spans between walls]**
- C NC **N/A** U STRAIGHT SHEATHING: All straight sheathed diaphragms have aspect ratios less than 2-to-1 in the direction being considered. (Commentary: Sec. A.4.2.1, Tier 2; Sec. 5.6.2)
- C NC **N/A** U SPANS: All wood diaphragms with spans greater than 24 ft consist of wood structural panels or diagonal sheathing. (Commentary: Sec. A.4.2.2, Tier 2; Sec. 5.6.2)
- C NC **N/A** U DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 40 ft and aspect ratios less than or equal to 4-to-1. (Commentary: Sec. A.4.2.3, Tier 2; Sec. 5.6.2)
- C** NC N/A U OTHER DIAPHRAGMS: The diaphragm does not consist of a system other than wood, metal deck, concrete, or horizontal bracing. (Commentary: Sec. A.4.7.1, Tier 2; Sec. 5.6.5)

APPENDIX C SUMMARY DATA SHEET

BUILDING DATA

Building Name: Sludge Dewatering Building Date: 9 / 5 / 2017
 Building Address: 13050 SW Arrowhead Creek Lane, Wilsonville, Oregon 97070
 Latitude: North: 45.295 Longitude: West: 122.783 By: Carollo Engineers
 Year Built: 2003 Year(s) Remodeled: N/A Original Design Code: 2000 International Building Code
 Area (sf): 680 Length (ft): 35.0 Width (ft): 22.0
 No. of Stories: 2 Story Height: 1st: 16ft; 2nd: 13.83ft Total Height: 30.83 ft
 USE Industrial Office Warehouse Hospital Residential Educational Other: Municipal

CONSTRUCTION DATA

Gravity Load Structural System: Metal Deck, Steel Truss Joist, Concrete Slab, Concrete Walls and Wall Footing
 Exterior Transverse Walls: Cast-in-Place Reinforced Concrete Walls Openings? Windows and Truck Access
 Exterior Longitudinal Walls: Cast-in-Place Reinforced Concrete Walls Openings? Man access doors
 Roof Materials/Framing: Metal deck supported on steel truss joist
 Intermediate Floors/Framing: Concrete slab supported on concrete walls
 Ground Floor: Slab-on-grade
 Columns: No columns Foundation: Continuous wall footing
 General Condition of Structure: _____
 Levels Below Grade? No
 Special Features and Comments: _____

LATERAL-FORCE-RESISTING SYSTEM

	Longitudinal	Transverse
System:	<u>Concrete Shear Walls</u>	<u>Concrete Shear Walls</u>
Vertical Elements:	<u>Concrete Shear Walls</u>	<u>Concrete Shear Walls</u>
Diaphragms:	<u>Metal Deck & Concrete Slab</u>	<u>Metal Deck & Concrete Slab</u>
Connections:	_____	_____

EVALUATION DATA

BSE-1N Spectral Response Accelerations: $S_{Ds} =$ 0.611g $S_{D1} =$ 0.656g
 Soil Factors: Class = E $F_a =$ 0.992 $F_v =$ 2.40
 BSE-1E Spectral Response Accelerations: $S_{XS} =$ 0.611g $S_{X1} =$ 0.372g
 Level of Seismicity: High Performance Level: S2 (Damage Control)
 Building Period: $T =$ 0.263 sec
 Spectral Acceleration: $S_a =$ 0.611g
 Modification Factor: $C_m C_1 C_2 =$ 1.40 Building Weight: $W =$ 506 kips
 Pseudo Lateral Force: $V =$ _____
 $C_m C_1 C_2 S_a W =$ 433 kips

BUILDING CLASSIFICATION: Concrete Shear Wall

REQUIRED TIER 1 CHECKLISTS

	Yes	No
Basic Configuration Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Type <u>C2</u> Structural Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Nonstructural Component Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FURTHER EVALUATION REQUIREMENT: _____

Project: Wilamette River WTP

Location: Sludge Dewatering Building

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.1.2LS LIFE SAFETY BASIC CONFIGURATION CHECKLIST

Low Seismicity

Building System

General

- C NC N/A U LOAD PATH: The structure shall contain a complete, well defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation. (Commentary: Sec. A.2.1.1. Tier 2: Sec. 5.4.1.1) [Shear wall discontinuous in transverse direction]
- C NC N/A U ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 4% of the height of the shorter building. This statement shall not apply for the following building types: W1, W1a, and W2. (Commentary: Sec. A.2.1.2. Tier 2: Sec. 5.4.1.2) [No adjacent building]
- C NC N/A U MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure. (Commentary: Sec. A.2.1.3. Tier 2: Sec. 5.4.1.3)

Building Configuration

- C NC N/A U WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction is not less than 80% of the strength in the adjacent story above. (Commentary: Sec. A.2.2.2. Tier 2: Sec. 5.4.2.1) [Shear wall discontinuous in transverse direction]
- C NC N/A U SOFT STORY: The stiffness of the seismic-force-resisting system in any story is not less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above. (Commentary: Sec. A.2.2.3. Tier 2: Sec. 5.4.2.2) [Shear wall discontinuous in transverse direction]
- C NC N/A U VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation. (Commentary: Sec. A.2.2.4. Tier 2: Sec. 5.4.2.3) [Shear wall discontinuous in transverse direction]
- C NC N/A U GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding one-story penthouses and mezzanines. (Commentary: Sec. A.2.2.5. Tier 2: Sec. 5.4.2.4) [Shear wall discontinuous in transverse direction]
- C NC N/A U MASS: There is no change in effective mass more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered. (Commentary: Sec. A.2.2.6. Tier 2: Sec. 5.4.2.5) [Light roof]
- C NC N/A U TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. (Commentary: Sec. A.2.2.7. Tier 2: Sec. 5.4.2.6)

Moderate Seismicity: Complete the Following Items in Addition to the Items for Low Seismicity.

Geologic Site Hazards

- C NC N/A U LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance shall not exist in the foundation soils at depths within 50 ft under the building. (Commentary: Sec. A.6.1.1. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SLOPE FAILURE: The building site is sufficiently remote from potential earthquake-induced slope failures or rockfalls to be unaffected by such failures or is capable of accommodating any predicted movements without failure. (Commentary: Sec. A.6.1.2. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated. (Commentary: Sec. A.6.1.3. Tier 2: 5.4.3.1) [Based on USGS earthquake map]

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Foundation Configuration

- C NC N/A U OVERTURNING: The ratio of the least horizontal dimension of the seismic-force-resisting system at the foundation level to the building height (base/height) is greater than $0.6S_a$. (Commentary: Sec. A.6.2.1. Tier 2: Sec. 5.4.3.3) [Shear wall discontinuous in transverse direction]
- C NC N/A U TIES BETWEEN FOUNDATION ELEMENTS: The foundation has ties adequate to resist seismic forces where footings, piles, and piers are not restrained by beams, slabs, or soils classified as Site Class A, B, or C. (Commentary: Sec. A.6.2.2. Tier 2: Sec. 5.4.3.4)

Project: Wilamette River WTP

Location: Sludge Dewatering Building

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.10LS LIFE SAFETY STRUCTURAL CHECKLIST FOR BUILDING TYPES C2: CONCRETE SHEAR WALLS WITH STIFF DIAPHRAGMS AND C2A: CONCRETE SHEAR WALLS WITH FLEXIBLE DIAPHRAGMS

Low and Moderate Seismicity

Seismic-Force-Resisting System

- C NC **(N/A)** U COMPLETE FRAMES: Steel or concrete frames classified as secondary components form a complete vertical-load-carrying system. (Commentary: Sec. A.3.1.6.1. Tier 2: Sec. 5.5.2.5.1)
- C **(NC)** N/A U REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2. (Commentary: Sec. A.3.2.1.1. Tier 2: Sec. 5.5.1.1) **[Shear wall discontinuous in transverse direction]**
- C **(NC)** N/A U SHEAR STRESS CHECK: The shear stress in the concrete shear walls, calculated using the Quick Check procedure of Section 4.5.3.3, is less than the greater of 100 lb/in.^2 or $2\sqrt{f'_c}$. (Commentary: Sec. A.3.2.2.1. Tier 2: Sec. 5.5.3.1.1) **[Shear wall discontinuous in transverse direction]**
- (C)** NC N/A U REINFORCING STEEL: The ratio of reinforcing steel area to gross concrete area is not less than 0.0012 in the vertical direction and 0.0020 in the horizontal direction. (Commentary: Sec. A.3.2.2.2. Tier 2: Sec. 5.5.3.1.3)

Connections

- C **(NC)** N/A U WALL ANCHORAGE AT FLEXIBLE DIAPHRAGMS: Exterior concrete or masonry walls that are dependent on flexible diaphragms for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.5.3.7. (Commentary: Sec. A.5.1.1. Tier 2: Sec. 5.7.1.1) **[Wall anchorage at truss joist support is not adequate; DCR = 1.60]**
- C **(NC)** N/A U TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of seismic forces to the shear walls. (Commentary: Sec. A.5.2.1. Tier 2: Sec. 5.7.2) **[Shear wall discontinuous in transverse direction]**
- (C)** NC N/A U FOUNDATION DOWELS: Wall reinforcement is doweled into the foundation with vertical bars equal in size and spacing to the vertical wall reinforcing immediately above the foundation. (Commentary: Sec. A.5.3.5. Tier 2: Sec. 5.7.3.4)

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Seismic-Force-Resisting System

- C NC **(N/A)** U DEFLECTION COMPATIBILITY: Secondary components have the shear capacity to develop the flexural strength of the components. (Commentary: Sec. A.3.1.6.2. Tier 2: Sec. 5.5.2.5.2)
- C NC **(N/A)** U FLAT SLABS: Flat slabs or plates not part of the seismic-force-resisting system have continuous bottom steel through the column joints. (Commentary: Sec. A.3.1.6.3. Tier 2: Sec. 5.5.2.5.3)
- C NC **(N/A)** U COUPLING BEAMS: The stirrups in coupling beams over means of egress are spaced at or less than $d/2$ and are anchored into the confined core of the beam with hooks of 135 degrees or more. The ends of both walls to which the coupling beam is attached are supported at each end to resist vertical loads caused by overturning. (Commentary: Sec. A.3.2.2.3. Tier 2: Sec. 5.5.3.2.1)

Connections

- C NC **(N/A)** U UPLIFT AT PILE CAPS: Pile caps have top reinforcement, and piles are anchored to the pile caps. (Commentary: Sec. A.5.3.8. Tier 2: Sec. 5.7.3.5)

Diaphragms (Flexible or Stiff)

- (C)** NC N/A U DIAPHRAGM CONTINUITY: The diaphragms are not composed of split-level floors and do not have expansion joints. (Commentary: Sec. A.4.1.1. Tier 2: Sec. 5.6.1.1)
- (C)** NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)

Flexible Diaphragms

- ③ NC N/A U CROSS TIES: There are continuous cross ties between diaphragm chords. (Commentary: Sec. A.4.1.2. Tier 2: Sec. 5.6.1.2)
- C NC ③ N/A U STRAIGHT SHEATHING: All straight sheathed diaphragms have aspect ratios less than 2-to-1 in the direction being considered. (Commentary: Sec. A.4.2.1. Tier 2: Sec. 5.6.2)
- C NC ③ N/A U SPANS: All wood diaphragms with spans greater than 24 ft consist of wood structural panels or diagonal sheathing. (Commentary: Sec. A.4.2.2. Tier 2: Sec. 5.6.2)
- C NC ③ N/A U DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 40 ft and aspect ratios less than or equal to 4-to-1. (Commentary: Sec. A.4.2.3. Tier 2: Sec. 5.6.2)
- ③ NC N/A U OTHER DIAPHRAGMS: The diaphragm does not consist of a system other than wood, metal deck, concrete, or horizontal bracing. (Commentary: Sec. A.4.7.1. Tier 2: Sec. 5.6.5)

APPENDIX C SUMMARY DATA SHEET

BUILDING DATA

Building Name: Chemical / Admin / Ozone Generation Building Date: 9 / 5 / 2017
 Building Address: 13050 SW Arrowhead Creek Lane, Wilsonville, Oregon 97070
 Latitude: North: 45.295 Longitude: West: 122.783 By: Carollo Engineers
 Year Built: 2003 Year(s) Remodeled: N/A Original Design Code: 2000 International Building Code
 Area (sf): 13,255 Length (ft): 124.67 Width (ft): 116.33
 No. of Stories: 1 Story Height: 16.0 ft Total Height: 16.0 ft
 USE Industrial Office Warehouse Hospital Residential Educational Other: Municipal

CONSTRUCTION DATA

Gravity Load Structural System: Metal Deck, Roof Truss Joist or Steel Beams, Steel Columns, Brick Masonry Walls and Concrete Wall Footing
 Exterior Transverse Walls: Solid Grouted Brick Masonry Walls Openings? Access Doors
 Exterior Longitudinal Walls: Solid Grouted Brick Masonry Walls Openings? Access Doors
 Roof Materials/Framing: Metal deck, Truss Joist & Steel Beams
 Intermediate Floors/Framing: N/A
 Ground Floor: Concrete Slab
 Columns: Steel Tube Columns Foundation: Concrete Wall Footing
 General Condition of Structure: _____
 Levels Below Grade? No.
 Special Features and Comments: _____

LATERAL-FORCE-RESISTING SYSTEM

	Longitudinal	Transverse
System:	<u>Solid Grouted Brick Masonry Walls</u>	<u>Solid Grouted Brick Masonry Walls</u>
Vertical Elements:	<u>Solid Grouted Brick Masonry Walls</u>	<u>Solid Grouted Brick Masonry Walls</u>
Diaphragms:	<u>Metal Deck</u>	<u>Metal Deck</u>
Connections:		

EVALUATION DATA

BSE-1N Spectral Response Accelerations: $S_{Dn} =$ 0.611g $S_{D1} =$ 0.656g
 Soil Factors: Class = E $F_a =$ 0.992 $F_v =$ 2.40
 BSE-1E Spectral Response Accelerations: $S_{Xn} =$ 0.611g $S_{X1} =$ 0.372g
 Level of Seismicity: High Performance Level: S2 (Damage Control)
 Building Period: $T =$ 0.121 sec
 Spectral Acceleration: $S_a =$ 0.611g
 Modification Factor: $C_m C_1 C_2 =$ 1.40 Building Weight: $W =$ 659 kips
 Pseudo Lateral Force: $V =$ _____
 $C_m C_1 C_2 S_a W =$ 564 kips

BUILDING CLASSIFICATION: Brick Masonry Wall with Flexible Diaphragm

REQUIRED TIER 1 CHECKLISTS

	Yes	No
Basic Configuration Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Type <u>RM1</u> Structural Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Nonstructural Component Checklist	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FURTHER EVALUATION REQUIREMENT: _____

Project: Wilamette River WTP

Location: Chemical / Admin / Ozone Generation Building

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.1.2LS LIFE SAFETY BASIC CONFIGURATION CHECKLIST

Low Seismicity

Building System

General

- C NC N/A U LOAD PATH: The structure shall contain a complete, well defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation. (Commentary: Sec. A.2.1.1. Tier 2: Sec. 5.4.1.1)
- C NC N/A U ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 4% of the height of the shorter building. This statement shall not apply for the following building types: W1, W1a, and W2. (Commentary: Sec. A.2.1.2. Tier 2: Sec. 5.4.1.2) [No adjacent building]
- C NC N/A U MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure. (Commentary: Sec. A.2.1.3. Tier 2: Sec. 5.4.1.3)

Building Configuration

- C NC N/A U WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction is not less than 80% of the strength in the adjacent story above. (Commentary: Sec. A.2.2.2. Tier 2: Sec. 5.4.2.1)
- C NC N/A U SOFT STORY: The stiffness of the seismic-force-resisting system in any story is not less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above. (Commentary: Sec. A.2.2.3. Tier 2: Sec. 5.4.2.2)
- C NC N/A U VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation. (Commentary: Sec. A.2.2.4. Tier 2: Sec. 5.4.2.3)
- C NC N/A U GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding one-story penthouses and mezzanines. (Commentary: Sec. A.2.2.5. Tier 2: Sec. 5.4.2.4)
- C NC N/A U MASS: There is no change in effective mass more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered. (Commentary: Sec. A.2.2.6. Tier 2: Sec. 5.4.2.5) [Light roof]
- C NC N/A U TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. (Commentary: Sec. A.2.2.7. Tier 2: Sec. 5.4.2.6)

Moderate Seismicity: Complete the Following Items in Addition to the Items for Low Seismicity.

Geologic Site Hazards

- C NC N/A U LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance shall not exist in the foundation soils at depths within 50 ft under the building. (Commentary: Sec. A.6.1.1. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SLOPE FAILURE: The building site is sufficiently remote from potential earthquake-induced slope failures or rockfalls to be unaffected by such failures or is capable of accommodating any predicted movements without failure. (Commentary: Sec. A.6.1.2. Tier 2: 5.4.3.1) [Based on available soil report]
- C NC N/A U SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated. (Commentary: Sec. A.6.1.3. Tier 2: 5.4.3.1) [Based on USGS earthquake map]

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Foundation Configuration

- C NC N/A U OVERTURNING: The ratio of the least horizontal dimension of the seismic-force-resisting system at the foundation level to the building height (base/height) is greater than $0.6S_w$. (Commentary: Sec. A.6.2.1. Tier 2: Sec. 5.4.3.3)
- C NC N/A U TIES BETWEEN FOUNDATION ELEMENTS: The foundation has ties adequate to resist seismic forces where footings, piles, and piers are not restrained by beams, slabs, or soils classified as Site Class A, B, or C. (Commentary: Sec. A.6.2.2. Tier 2: Sec. 5.4.3.4) [Wall footings restrained by slab]

Project: Wilamette River WTP

Location: Chemical / Admin / Ozone Generation Building

Completed by: Carollo Engineers (Caleb Che)

Date: 9 / 5 / 2017

16.15LS LIFE SAFETY STRUCTURAL CHECKLIST FOR BUILDING TYPES RM1: REINFORCED MASONRY BEARING WALLS WITH FLEXIBLE DIAPHRAGMS AND RM2: REINFORCED MASONRY BEARING WALLS WITH STIFF DIAPHRAGMS

Low and Moderate Seismicity

Seismic-Force-Resisting System

- NC N/A U REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2. (Commentary: Sec. A.3.2.1.1. Tier 2: Sec. 5.5.1.1)
- NC N/A U SHEAR STRESS CHECK: The shear stress in the reinforced masonry shear walls, calculated using the Quick Check procedure of Section 4.5.3.3, is less than 70 lb/in.². (Commentary: Sec. A.3.2.4.1. Tier 2: Sec. 5.5.3.1.1)
- NC N/A U REINFORCING STEEL: The total vertical and horizontal reinforcing steel ratio in reinforced masonry walls is greater than 0.002 of the wall with the minimum of 0.0007 in either of the two directions; the spacing of reinforcing steel is less than 48 in., and all vertical bars extend to the top of the walls. (Commentary: Sec. A.3.2.4.2. Tier 2: Sec. 5.5.3.1.3)

Stiff Diaphragms

- C NC N/A U TOPPING SLAB: Precast concrete diaphragm elements are interconnected by a continuous reinforced concrete topping slab. (Commentary: Sec. A.4.5.1. Tier 2: Sec. 5.6.4)

Connections

- NC N/A U WALL ANCHORAGE: Exterior concrete or masonry walls that are dependent on the diaphragm for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections shall have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.5.3.7. (Commentary: Sec. A.5.1.1. Tier 2: Sec. 5.7.1.1)
 [Perpendicular to Steel Deck: Wall anchorage at truss joist support adequate for wall out-of-plane]
 [Parallel to Steel Deck: Anchor bolts, ledger angle & steel deck adequate for wall out-of-plane]
- C NC N/A U WOOD LEDGERS: The connection between the wall panels and the diaphragm does not induce cross-grain bending or tension in the wood ledgers. (Commentary: Sec. A.5.1.2. Tier 2: Sec. 5.7.1.3)
- NC N/A U TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of seismic forces to the shear walls. (Commentary: Sec. A.5.2.1. Tier 2: Sec. 5.7.2)
- C NC N/A U TOPPING SLAB TO WALLS OR FRAMES: Reinforced concrete topping slabs that interconnect the precast concrete diaphragm elements are doweled for transfer of forces into the shear wall or frame elements. (Commentary: Sec. A.5.2.3. Tier 2: Sec. 5.7.2) [The roof is flexible diaphragm with metal deck]
- NC N/A U FOUNDATION DOWELS: Wall reinforcement is doweled into the foundation. (Commentary: Sec. A.5.3.5. Tier 2: Sec. 5.7.3.4) [Foundation dowels matching to wall vertical reinforcing bars]
- C NC N/A U GIRDER-COLUMN CONNECTION: There is a positive connection using plates, connection hardware, or straps between the girder and the column support. (Commentary: Sec. A.5.4.1. Tier 2: Sec. 5.7.4.1)

High Seismicity: Complete the Following Items in Addition to the Items for Low and Moderate Seismicity.

Stiff Diaphragms

- C NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- C NC N/A U OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft long. (Commentary: Sec. A.4.1.6. Tier 2: Sec. 5.6.1.3)

Flexible Diaphragms

- NC N/A U CROSS TIES: There are continuous cross ties between diaphragm chords. (Commentary: Sec. A.4.1.2. Tier 2: Sec. 5.6.1.2)
- NC N/A U OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length. (Commentary: Sec. A.4.1.4. Tier 2: Sec. 5.6.1.3)
- NC N/A U OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft long. (Commentary: Sec. A.4.1.6. Tier 2: Sec. 5.6.1.3)

- C NC **N/A** U STRAIGHT SHEATHING: All straight sheathed diaphragms have aspect ratios less than 2-to-1 in the direction being considered. (Commentary: Sec. A.4.2.1. Tier 2: Sec. 5.6.2)
- C NC **N/A** U SPANS: All wood diaphragms with spans greater than 24 ft consist of wood structural panels or diagonal sheathing. (Commentary: Sec. A.4.2.2. Tier 2: Sec. 5.6.2)
- C NC **N/A** U DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 40 ft and aspect ratios less than or equal to 4-to-1. (Commentary: Sec. A.4.2.3. Tier 2: Sec. 5.6.2)
- C** NC N/A U OTHER DIAPHRAGMS: The diaphragm shall not consist of a system other than wood, metal deck, concrete, or horizontal bracing. (Commentary: Sec. A.4.7.1. Tier 2: Sec. 5.6.5)

Connections

- C NC **N/A** U STIFFNESS OF WALL ANCHORS: Anchors of concrete or masonry walls to wood structural elements are installed taut and are stiff enough to limit the relative movement between the wall and the diaphragm to no greater than 1/8 in. before engagement of the anchors. (Commentary: Sec. A.5.1.4. Tier 2: Sec. 5.7.1.2)

Attachment C
CALCULATIONS

**WILLAMETTE RIVER WATER TREATMENT PLANT
SEISMIC EVALUATION
STRUCTURAL CALCULATIONS**

**PREPARED BY
CAROLLO ENGINEERS**

**DATE: AUGUST 14, 2017
JOB #: 10721A.10**

WILLAMETTE RIVER WATER TREATMENT PLANT
SEISMIC EVALUATION
STRUCTURAL CALCULATIONS

TABLE OF CONTENTS

ASCE 41 Existing Buildings Evaluation Criteria & Parameters.....	01
ACI 350 Existing Concrete Structures Evaluation Criteria & Parameters.....	27
Area 4 - ActiFlo Building (ASCE 41 Evaluation).....	38
Area 4 - ActiFlo Concrete Structure (ACI 350 Evaluation).....	52
Area 5 - Ozonation Concrete Structure (ACI 350 Evaluation).....	187
Area 6 - Filters Concrete Structure (ACI 350 Evaluation).....	251
Area 8 - Washwater Basin Pump Station (ASCE 41 Evaluation).....	341
Area 8 - Washwater Basin Concrete Structure (ACI 350 Evaluation).....	357
Area 9 - High Service Pump Station (ASCE 41 Evaluation).....	440
Area 11 - Sludge Thickener Stair Housing (ASCE 41 Evaluation).....	468
Area 11 - Sludge Thickener Concrete Structures (ACI 350 Evaluation).....	483
Area 12 - Sludge Dewatering Building (ASCE 41 Evaluation).....	528
Areas 13,18,19 - Chemical / Admin / Ozone Building (ASCE 41 Evaluation).....	553

ASCE 41 - EXISTING BUILDINGS
EVALUATION CRITERIA & PARAMETERS

Table C2-1. Probability of Exceedance and Mean Return Period

Probability of Exceedance	Mean Return Period (years)
50%/30 years	43
50%/50 years	72
20%/50 years	225
10%/50 years	475
5%/50 years	975
2%/50 years	2,475

Table C2-2. Performance Objectives

Target Building Performance Levels				
Seismic Hazard Level	Operational Performance Level (1-A)	Immediate Occupancy Performance Level (1-B)	Life Safety Performance Level (3-C)	Collapse Prevention Performance Level (5-D)
50%/50 years	a	b	c	d
BSE-1E (20%/50 years)	e	f	g	h
BSE-2E (5%/50 years)	i	j	k	l
BSE-2N (ASCE 7 MCE_R)	m	n	o	p

NOTES: Each cell in the above matrix represents a discrete Performance Objective. The Performance Objectives in the matrix above can be used to represent the three specific Performance Objectives for a standard building that would be considered Risk Category I & II defined in Sections 2.2.1, 2.2.2, and 2.2.3, as follows:

Basic Performance Objective for Existing Buildings (BPOE)	g and l
Enhanced Objectives	g and i, j, m, n, o, or p l and e or f g and l and a, or b k, m, n, or o alone
Limited Objectives	g alone l alone c, d, e, or f

The BPOE varies by Risk Category. This standard does not specify how to assign a building to a Risk Category. Risk Categories are used here to facilitate the coordination with regulations, building codes, and policies, such as the *International Building Code* and the *International Existing Building Code*, which do use them. The intention is that regulations, building codes, and policies need to cover all Risk Categories but might prefer to cite this standard in a simple way. Defining the BPOE as in Table 2-1 allows a regulation, building code, or policy to simply cite the BPOE without creating its own table to spell out the Seismic Hazard Level and Performance Levels for each Risk Category.

The BPOE, or objectives close to it, has been used for characterizing seismic performance in other standards and regulations and has been implemented in many individual projects and mitigation programs. The BPOE also approximates the regulatory policy traditionally applied to existing buildings in many seismically active areas of the United States. The BPOE accepts a lower level of safety and a higher risk of collapse than would that provided by similar standards for new buildings. Buildings meeting the BPOE are expected to experience little damage from relatively frequent, moderate earthquakes but significantly more damage and potential economic loss from the most severe and infrequent earthquakes that could affect them. The level of damage and potential economic loss experienced by buildings rehabilitated to the BPOE likely will be greater than that expected in similar, properly designed and constructed new buildings or existing buildings evaluated and retrofitted to the Basic Performance Objective Equivalent to New Building Standards (BPN) in Section 2.2.4.

There are three overarching historical reasons for accepting a somewhat greater risk in existing buildings:

- Accepting performance less than “full code” ensures that recent buildings are not immediately rendered deficient whenever the code changes in such a manner as to become more conservative.
- The increase in risk is tempered by the recognition that an existing building often has a shorter remaining life than a new building. That is, if the traditional code-based demand

Table 2-1. Basic Performance Objective for Existing Buildings (BPOE)

Risk Category	Tier 1 ^a	Tier 2 ^a	Tier 3	
	BSE-1E	BSE-1E	BSE-1E	BSE-2E
I & II	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Collapse Prevention Structural Performance Nonstructural Performance Not Considered (5-D)
III All Structures Except Noted Below	See footnote <i>b</i> for Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Limited Safety Structural Performance Nonstructural Performance Not Considered (4-D)
IV High Service Pump Station	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Life Safety Structural Performance Nonstructural Performance Not Considered (3-D)

^aFor Tier 1 and 2 assessments, seismic performance for the BSE-2E is not explicitly evaluated.

^bFor Risk Category III, the Tier 1 screening checklists shall be based on the Life Safety Performance Level (S-3), except that checklist statements using the Quick Check procedures of Section 4.5.3 shall be based on MS-factors and other limits that are an average of the values for Life Safety and Immediate Occupancy.

Table 4-7. Checklists Required for a Tier 1 Screening

Level of Seismicity ^b	Level of Building Performance ^c	Required Checklists ^a					
		Very Low Seismicity Checklist (Sec. 16.1.1)	Basic Configuration Checklist (Sec. 16.1.2)	Life Safety Checklist (Sec. 16.2LS through 16.15LS)	Immediate Occupancy Checklist (Sec. 16.2IO through 16.15IO)	Life Safety Nonstructural Checklist (Sec. 16.17)	Position Retention Nonstructural Checklist (Sec. 16.17)
Very low	LS	X					
Very low	IO		X		X		X
Low	LS		X	X		X	
Low	IO		X		X		X
Moderate	LS		X	X		X	
Moderate	IO		X		X		X
High	LS		X	X		X	
High	IO		X		X		X

^aAn X designates the checklist that must be completed for a Tier 1 screening as a function of the level of seismicity and level of performance.

^bDefined in Section 2.5.

^cLS = Life Safety Performance Level, and IO = Immediate Occupancy Performance Level (defined in Section 2.3.3).

marked “Compliant” (C), “Noncompliant” (NC), “Unknown” (U), or “Not Applicable” (N/A). Compliant statements identify issues that are acceptable according to the criteria of this standard, whereas noncompliant or unknown statements identify issues that require further investigation to demonstrate compliance with the applicable Performance Objective. Certain evaluation statements may not apply to the specific building being evaluated.

Quick Checks for Tier 1 shall be performed in accordance with Section 4.5 where necessary to complete an evaluation statement.

The checklist for Very Low Seismicity, located in Section 16.1.1, shall be completed for buildings in Very Low Seismicity being evaluated to the Life Safety Performance Level. For buildings in Very Low Seismicity being evaluated to the Immediate Occupancy Performance Level and buildings in levels of Low, Moderate, or High Seismicity, the appropriate structural and nonstructural checklists shall be completed in accordance with Table 4-7.

The appropriate structural checklists shall be selected based on the common building types defined in Table 3-1. Buildings being evaluated to the Life Safety Performance Level shall use the applicable checklists in Chapter 16 denoted “LS” after the section number. Buildings being evaluated to the Immediate Occupancy Performance Level shall use the applicable checklists in Chapter 16 denoted “IO” after the section number.

A building with a different lateral-force-resisting system in each principal direction shall use two sets of structural checklists, one for each direction. A building with more than one type of lateral-force-resisting system along a single axis of the building being evaluated to the Life Safety Performance Level, including changes in seismic-force-resisting system over the height, may be evaluated using the applicable checklist(s) in Chapter 16 subject to the requirements in Section 3.3.1.2.2.

Two nonstructural checklists also are provided in Chapter 16: Life Safety and Position Retention. Refer to Table 4-7 for the applicability of the nonstructural checklists.

C4.4 SELECTION AND USE OF CHECKLISTS

The evaluation statements provided in the checklists form the core of the Tier 1 screening methodology. These evaluation statements are based on observed earthquake structural damage during actual earthquakes. The checklists do not necessarily identify the response of the structure to ground motion; rather,

the design professional obtains a general sense of the structure’s deficiencies and potential behavior during an earthquake.

Although the section numbers in parentheses after each evaluation statement correspond to Tier 2 evaluation procedures, they also correspond to commentary in Appendix A regarding the statement’s purpose. If additional information on the evaluation statement is required, please refer to the commentary in the Tier 2 procedure and Appendix A for that evaluation statement.

4.5 TIER 1 ANALYSIS

4.5.1 Overview Analyses performed as part of the Tier 1 screening process are limited to Quick Checks. Quick Checks shall be used to calculate the stiffness and strength of certain building components to determine whether the building complies with certain evaluation criteria. Quick Checks shall be performed in accordance with Section 4.5.3 where they are triggered by evaluation statements from the checklists of Chapter 16. Seismic forces for use in the Quick Checks shall be computed in accordance with Section 4.5.2.

4.5.2 Seismic Forces

4.5.2.1 Pseudo Seismic Force The pseudo seismic force, in a given horizontal direction of a building, shall be calculated in accordance with Eqs. (4-1) or (4-2), if applicable.

$$V = CS_aW \quad (4-1)$$

where V = Pseudo seismic force.

C = Modification factor to relate expected maximum inelastic displacements to displacements calculated for linear elastic response; C shall be taken from Table 4-8.

S_a = Response spectral acceleration at the fundamental period of the building in the direction under consideration. The value of S_a shall be calculated in accordance with the procedures in Section 4.5.2.3.

W = Effective seismic weight of the building, including the total dead load and applicable portions of other gravity loads listed below:

1. In areas used for storage, a minimum of 25% of the floor live load shall be applicable. The live load shall be permitted to be reduced for tributary area as approved by the code official. Floor live load in public garages and open parking structures need not be considered.

Table 4-8. Modification Factor, C

Building Type ^a	Number of Stories			
	1	2	3	≥4
Wood (W1, W1a, W2) Moment frame (S1, S3, C1, PC2a)	1.3	1.1	1.0	1.0
Shear wall (S4, S5, C2, C3, PC1a, PC2, RM2, URMa)	1.4	1.2	1.1	1.0
Braced frame (S2)				
Unreinforced masonry (URM) Flexible diaphragms (S1a, S2a, S5a, C2a, C3a, PC1, RM1)	1.0	1.0	1.0	1.0

^aDefined in Table 3-1.

- Where an allowance for partition load is included in the floor load design, the actual partition weight or a minimum weight of 10 lb/ft² of floor area, whichever is greater, shall be applied.
- Total operating weight of permanent equipment.
- Where the design flat roof snow load calculated in accordance with ASCE 7 exceeds 30 lb/ft², the effective snow load shall be taken as 20% of the design snow load. Where the design flat roof snow load is 30 lb/ft² or less, the effective snow load shall be permitted to be zero.

Alternatively, for buildings in which the bottom of the foundation is less than 3 ft below exterior grade with a slab or tie beams to connect interior footings and being evaluated for the Life Safety Performance Level, Eq. (4-2) shall be permitted to be used to compute the pseudo seismic force:

$$V = 0.75W \quad (4-2)$$

If Eq. (4-2) is used, an M_s -factor of 1.0 shall be used to compute the component forces and stresses for the Quick Checks of Section 4.5.3.

C4.5.2.1 Pseudo Seismic Force The seismic evaluation procedure of this standard, as well as those in FEMA P-750 (2009c), (BSSC 2009), and ASCE 7 (2010), is based on a widely accepted philosophy that permits nonlinear response of a building where subjected to a ground motion that is representative of the design earthquake. FEMA P-750 (2009c) and ASCE 7 (2010) account for nonlinear seismic response in a linear static analysis procedure by including a response modification factor, R , in calculating a reduced equivalent base shear to produce a rough approximation of the internal forces during a design earthquake. In other words, the base shear is representative of the force that the building is expected to resist, but the building displacements are significantly less than the actual displacements of the building during a design earthquake. Thus, in this R -factor approach, displacements calculated from the reduced base shear need to be increased by another factor (C_d or R) where checking drift or ductility requirements. In summary, this procedure is based on equivalent seismic forces and pseudo displacements.

The linear static analysis procedure in this standard takes a different approach to account for the nonlinear seismic response. Pseudo static seismic forces are applied to the structure to obtain actual displacements during a design earthquake. The pseudo seismic force of Eq. (4-1) represents the force required, in a linear static analysis, to impose the expected deformation of the structure in its yielded state where subjected to the design earthquake motions. The modification factor C in Eq. (4-1) is intended to replace the product of modification factors C_1 , C_2 , and C_m in

Chapter 7. The factor C increases the pseudo seismic force where the period of the structure is low. The effect of the period of the structure is replaced by the number of stories in Table 4-8. Furthermore, the factor C is larger where a higher level of ductility in the building is relied upon. Thus, unreinforced masonry buildings have a lower factor as compared with concrete shear wall or moment-frame structures. In assigning values for coefficient C , representative average values (instead of using most conservative values) for coefficients C_1 , C_2 , and C_m were considered.

The pseudo seismic force does not represent an actual seismic force that the building must resist in traditional design codes. In summary, this procedure is based on equivalent displacements and pseudo seismic forces. For additional commentary regarding this linear static analysis approach, please refer to the Commentary in Chapter 7.

For short and stiff buildings with low ductility located in levels of High Seismicity, the required building strength in accordance with Eq. (4-1) may exceed the force required to cause sliding at the foundation level. The strength of the structure, however, does not need to exceed the sliding resistance at the foundation-soil interface. It is assumed that this sliding resistance is equal to 0.75 W . Thus, where Eq. (4-2) is applied to these buildings, the required strength of structural components need not exceed 0.75 W .

4.5.2.2 Story Shear Forces The pseudo seismic force calculated in accordance with Section 4.5.2.1 shall be distributed vertically in accordance with Eqs. (4-3a and 4-3b). For buildings six stories or fewer high, the value of k shall be permitted to be taken as 1.0.

$$F_x = \frac{w_x h_x^k}{\sum_{i=1}^n w_i h_i^k} V \quad (4-3a)$$

$$V_j = \sum_{x=j}^n F_x \quad (4-3b)$$

where V_j = Story shear at story level j ;

n = Total number of stories above ground level;

j = Number of story levels under consideration;

W = Total seismic weight, per Section 4.5.2.1;

V = Pseudo seismic force from Eq. (4-1) or (4-2);

w_i = Portion of total building weight W located on or assigned to floor level i ;

w_x = Portion of total building weight W located on or assigned to floor level x ;

h_i = Height (ft) from the base to floor level i ;

h_x = Height (ft) from the base to floor level x ; and

k = 1.0 for $T \leq 0.5$ s and 2.0 for $T > 2.5$ s; linear interpolation shall be used for intermediate values of k .

For buildings with stiff or rigid diaphragms, the story shear forces shall be distributed to the lateral-force-resisting elements based on their relative rigidities. For buildings with flexible diaphragms (Types S1a, S2a, S5a, C2a, C3a, PC1, RM1, and URM), story shear shall be calculated separately for each line of lateral resistance.

4.5.2.3 Spectral Acceleration Spectral acceleration, S_a , for use in computing the pseudo seismic force shall be computed in accordance with Eq. (4-4).

$$S_a = \frac{S_{X1}}{T} \quad (4-4)$$

but S_a shall not exceed S_{X5} .

where T is the fundamental period of vibration of the building, calculated in accordance with Section 4.5.2.4, and

S_{X1} and S_{XS} are as defined in Section 2.4 for the Seismic Hazard Level specified in Section 4.1.2. Alternatively, a site-specific response spectrum shall be permitted to be developed according to Section 2.4.2 for the Seismic Hazard Level specified in Section 4.1.2.

4.5.2.4 Period The fundamental period of a building, in the direction under consideration, shall be calculated in accordance with Eq. (4-5).

$$T = C_t h_n^\beta \quad (4-5)$$

where T = Fundamental period (seconds) in the direction under consideration;

- C_t = 0.035 for moment-resisting frame systems of steel (Building Types S1 and S1a);
- = 0.018 for moment-resisting frames of reinforced concrete (Building Type C1);
- = 0.030 for eccentrically braced steel frames (Building Types S2 and S2a);
- = 0.020 for all other framing systems;
- h_n = height (ft) above the base to the roof level;
- β = 0.80 for moment-resisting frame systems of steel (Building Types S1 and S1a);
- = 0.90 for moment-resisting frame systems of reinforced concrete (Building Type C1); and
- = 0.75 for all other framing systems.

Alternatively, for steel or reinforced-concrete moment frames of 12 stories or fewer, the fundamental period of the building may be calculated as follows:

$$T = 0.10n \quad (4-6)$$

where n = number of stories above the base.

C4.5.2.4 Period The values of C_t given in this standard are intended to be reasonable lower bound (not mean) values for structures, including the contribution of nonstructural elements. The value of T used in the evaluation should be as close as possible to, but less than, the true period of the structure.

4.5.3 Quick Checks for Strength and Stiffness Quick Checks shall be used to compute the stiffness and strength of building components. Quick Checks are triggered by evaluation statements in the checklists of Chapter 16 and are required to determine the compliance of certain building components. The seismic forces used in the Quick Checks shall be calculated in accordance with Section 4.5.2.

4.5.3.1 Story Drift for Moment Frames Eq. (4-7) shall be used to calculate the drift ratios of regular, multi-story, multi-bay moment frames with columns continuous above and below the story under consideration. The drift ratio is based on the deflection caused by flexural displacement of a representative column, including the effect of end rotation caused by bending of the representative beam.

$$D_r = \left(\frac{k_b + k_c}{k_b k_c} \right) \left(\frac{h}{12E} \right) V_c \quad (4-7)$$

where D_r = Drift ratio. Interstory displacement divided by story height,

- k_b = I/L for the representative beam;
- k_c = I/h for the representative column;
- h = Story height (in.);
- I = Moment of inertia (in.⁴);

- L = Beam length from center-to-center of adjacent columns (in.);
- E = Modulus of elasticity (kip/in.²); and
- V_c = Shear in the column (kip).

The column shear forces are calculated using the story shear forces in accordance with Section 4.5.2.2. For reinforced concrete frames, an effective cracked section moment of inertia equal to one-half of gross value shall be used.

Eq. (4-7) also may be used for the first floor of the frame if columns are fixed against rotation at the bottom. However, if columns are pinned at the bottom, the drift ratio shall be multiplied by 2.

For other configurations of frames, the Quick Check need not be performed; however, a Tier 2 evaluation, including calculation of the drift ratio, shall be completed based on principles of structural mechanics.

C4.5.3.1 Story Drift for Moment Frames Eq. (4-7) assumes that all of the columns in the frame have similar stiffness.

4.5.3.2 Shear Stress in Concrete Frame Columns The average shear stress, v_j^{avg} , in the columns of concrete frames shall be computed in accordance with Eq. (4-8).

$$v_j^{\text{avg}} = \frac{1}{M_s} \left(\frac{n_c}{n_c - n_f} \right) \left(\frac{V_j}{A_c} \right) \quad (4-8)$$

where n_c = Total number of columns;

n_f = Total number of frames in the direction of loading;

A_c = Summation of the cross-sectional area of all columns in the story under consideration;

V_j = Story shear computed in accordance with Section 4.5.2.2; and

M_s = System modification factor; M_s shall be taken as equal to 2.0 for buildings being evaluated to the Life Safety Performance Level and equal to 1.3 for buildings being evaluated to the Immediate Occupancy Performance Level.

C4.5.3.2 Shear Stress in Concrete Frame Columns Eq. (4-8) assumes that all of the columns in the frame have similar stiffness.

The inclusion of the term $[n_c/(n_c - n_f)]$ in Eq. (4-8) is based on the assumption that the end column carries half the load of a typical interior column. This equation is not theoretically correct for a one-bay frame and yields shear forces that are twice the correct force; however, because of the lack of redundancy in one-bay frames, this level of conservatism is considered appropriate.

4.5.3.3 Shear Stress in Shear Walls The average shear stress in shear walls, v_j^{avg} , shall be calculated in accordance with Eq. (4-9).

$$v_j^{\text{avg}} = \frac{1}{M_s} \left(\frac{V_j}{A_w} \right) \quad (4-9)$$

where V_j = Story shear at level j computed in accordance with Section 4.5.2.2.

A_w = Summation of the horizontal cross-sectional area of all shear walls in the direction of loading. Openings shall be taken into consideration where computing A_w . For masonry walls, the net area shall be used. For wood-framed walls, the length shall be used rather than the area.

M_s = System modification factor; M_s shall be taken from Table 4-9.

Table 4-9. M_s Factors for Shear Walls

Wall Type	Level of Performance	
	LS	IO
Reinforced concrete, precast concrete, wood, and reinforced masonry	4.0	2.0
Unreinforced masonry	1.5	1.0

Table 4-10. M_s Factors for Diagonal Braces

Brace Type	d/t^a	Level of Performance	
		LS	IO
Tube ^b	$<90/(F_{ye})^{1/2}$	6.0	2.5
	$>190/(F_{ye})^{1/2}$	3.0	1.5
Pipe ^b	$<1500/F_{ye}$	6.0	2.5
	$>6000/F_{ye}$	3.0	1.5
Tension-only		3.0	1.5
All others		6.0	2.5

^aDepth-to-thickness ratio.

^bInterpolation to be used for tubes and pipes.
 $F_{ye} = 1.25F_y$; expected yield stress.

4.5.3.4 Diagonal Bracing The average axial stress in diagonal bracing elements, f_j^{avg} , shall be calculated in accordance with Eq. (4-10).

$$f_j^{avg} = \frac{1}{M_s} \left(\frac{V_j}{sN_{br}} \right) \left(\frac{L_{br}}{A_{br}} \right) \quad (4-10)$$

where L_{br} = Average length of the braces (ft);

N_{br} = Number of braces in tension and compression if the braces are designed for compression; number of diagonal braces in tension if the braces are designed for tension only;

s = Average span length of braced spans (ft);

A_{br} = Average area of a diagonal brace (in.²);

V_j = Maximum story shear at each level (kip); and

M_s = System modification factor; M_s shall be taken from Table 4-10.

4.5.3.5 Precast Connections The strength of the connection in precast concrete moment frames shall be greater than the moment in the girder, M_{gj} , calculated in accordance with Eq. (4-11).

$$M_{gj} = \frac{V_j}{M_s} \left(\frac{1}{n_c - n_f} \right) \left(\frac{h}{2} \right) \quad (4-11)$$

Where n_c = Total number of columns;

n_f = Total number of frames in the direction of loading;

V_j = Story shear at the level directly below the connection under consideration;

h = Typical column story height; and

M_s = System modification factor taken as equal to 2.0 for buildings being evaluated to the Life Safety Performance Level and equal to 1.3 for buildings being evaluated to the Immediate Occupancy Performance Level.

C4.5.3.5 Precast Connections The term $[1/(n_c - n_f)]$ in Eq. (4-11) is based on the assumption that the end column carries half the load of a typical interior column.

4.5.3.6 Column Axial Stress Caused by Overturning The axial stress of columns in moment frames at the base subjected

to overturning forces, p_{ot} , shall be calculated in accordance with Eq. (4-12).

$$p_{ot} = \frac{1}{M_s} \left(\frac{2}{3} \right) \left(\frac{Vh_n}{Ln_f} \right) \left(\frac{1}{A_{col}} \right) \quad (4-12)$$

where n_f = Total number of frames in the direction of loading;

V = Pseudo seismic force;

h_n = Height (ft) above the base to the roof level;

L = Total length of the frame (ft);

M_s = System modification factor taken as equal to 2.0 for buildings being evaluated to the Life Safety Performance Level and equal to 1.3 for buildings being evaluated to the Immediate Occupancy Performance Level; and

A_{col} = Area of the end column of the frame.

C4.5.3.6 Column Axial Stress Caused by Overturning The 2/3 factor in Eq. (4-12) assumes a triangular force distribution with the resultant applied at 2/3 the height of the building.

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$

Where w_p = unit weight of the wall;

A_p = area of wall tributary to the connection;

ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and

S_{XS} = value specified in Section 4.5.2.3.

4.5.3.8 Prestressed Elements The average prestress in prestressed or post-tensioned elements, f_p , shall be calculated in accordance with Eq. (4-14).

$$f_p = \frac{f_{pe} n_p}{A_p} \quad (4-14)$$

where f_{pe} = Effective force of a prestressed strand;

n_p = Number of prestressed strands; and

A_p = Gross area of prestressed concrete elements.

C4.5.3.8 Prestressed Elements The average prestress is simply calculated as the effective force of a prestressed strand times the number of strands divided by the gross concrete area. In many cases, half-inch strands are used, which correspond to an effective force of 25 kip per strand.

4.5.3.9 Flexural Stress in Columns and Beams of Steel Moment Frames The average flexural stress in the columns and beams of steel frames at each level shall be computed in accordance with Eq. (4-15).

$$f_j^{avg} = V_j \frac{1}{M_s} \left(\frac{n_c}{n_c - n_f} \right) \left(\frac{h}{2} \right) \frac{1}{Z} \quad (4-15)$$

where n_c = Total number of frame columns at the level, j , under consideration.

n_f = Total number of frames in the direction of loading at the level, j , under consideration.

V_j = Story shear computed in accordance with Section 4.5.2.2.

h = Story height (in.).

Z = For columns, the sum of the plastic section moduli of all the frame columns at the level under consideration. For beams, it is the sum of the plastic section moduli of all the frame beams with moment-resisting connections. If a beam has moment-resisting connec-

tions at both ends, then the contribution of that beam to the sum is twice the plastic section modulus of that beam (in^3).

M_s = System modification factor; M_s shall be taken as equal to 8.0 for buildings being evaluated to the Life Safety Performance Level and equal to 3.0 for buildings being evaluated to the Immediate Occupancy Performance Level for columns and beams satisfying the checklist items for compactness and column axial stress. If the columns or beams do not satisfy the checklist statements for compactness and column axial stress for the Immediate Occupancy Performance Level, then this item must be marked noncompliant.

C4.5.3.9 Flexural Stress in Columns and Beams of Steel Moment Frames Eq. (4-15) assumes that all of the columns in the frame have similar stiffness.

The inclusion of the term $[n_c/(n_c - n_p)]$ in Eq. (4-15) is based on the assumption that the end column carries half the load of a typical interior column. This equation is not theoretically correct for a one-bay frame and yields forces that are twice the correct force. However, because of the lack of redundancy in the one-bay frame, this level of conservatism is considered appropriate. The equation may also be conservative when checking the top level of a frame.

7.4.1.3 Determination of Forces and Deformations for LSP

Forces and deformations in elements and components shall be calculated for the pseudo seismic force of Section 7.4.1.3.1, using component stiffnesses calculated in accordance with Chapters 8 through 12. Pseudo seismic forces shall be distributed throughout the building in accordance with Sections 7.4.1.3.2 through 7.4.1.3.4. Alternatively, for unreinforced masonry buildings in which the fundamental period is calculated using Eq. (7-20), pseudo seismic forces shall be permitted to be distributed in accordance with Section 7.4.1.3.5. Actions and deformations shall be modified to consider the effects of torsion in accordance with Section 7.2.3.2.

7.4.1.3.1 Pseudo Seismic Force for LSP The pseudo lateral force in a given horizontal direction of a building shall be determined using Eq. (7-21). This force shall be used to evaluate or retrofit the vertical elements of the seismic-force-resisting system.

$$V = C_1 C_2 C_m S_a W \tag{7-21}$$

where V = Pseudo lateral force; and

C_1 = Modification factor to relate expected maximum inelastic displacements to displacements calculated for linear elastic response. For fundamental periods less than 0.2 s, C_1 need not be taken as greater than the value at $T = 0.2$ s. For fundamental periods greater than 1.0 s, $C_1 = 1.0$.

$$C_1 = 1 + \frac{\mu_{\text{strength}} - 1}{aT^2} \tag{7-22}$$

where a = Site class factor;

- = 130 site Class A or B;
- = 90 site Class C;
- = 60 site Class D, E, or F;

μ_{strength} = Ratio of elastic strength demand to yield strength coefficient calculated in accordance with Eq. (7-31) with the elastic base shear capacity substituted for shear yield strength, V_y ;

T = Fundamental period of the building in the direction under consideration, calculated in accordance with Section 7.4.1.2, including modification for SSI effects of Section 7.2.7, if applicable;

C_2 = Modification factor to represent the effect of pinched hysteresis shape, cyclic stiffness degradation, and strength deterioration on maximum displacement response. For fundamental periods greater than 0.7 s, $C_2 = 1.0$.

$$C_2 = 1 + \frac{1}{800} \left(\frac{\mu_{\text{strength}} - 1}{T} \right)^2 \tag{7-23}$$

Alternately, it shall be permitted to use $C_1 C_2$ per Table 7-3, where m_{max} is the largest m -factor for all primary elements of the building in the direction under consideration.

C_m = Effective mass factor to account for higher modal mass participation effects obtained from Table 7-4.

C_m shall be taken as 1.0 if the fundamental period, T , is greater than 1.0 s;

S_a = response spectrum acceleration, at the fundamental period and damping ratio of the building in the direction under consideration. The value of S_a shall be obtained from the procedure specified in Section 2.4; and

W = effective seismic weight of the building, including the total dead load and applicable portions of other gravity loads listed below:

1. In areas used for storage, a minimum 25% of the floor live load shall be applicable. The live load shall be permitted to be reduced for tributary area as approved by the authority having jurisdiction. Floor live load in public garages and open parking structures is not applicable.
2. Where an allowance for partition load is included in the floor load design, the actual partition weight or a minimum weight of 10 lb/in.² of floor area, whichever is greater, shall be applicable.
3. Total operating weight of permanent equipment.
4. Where the flat roof snow load calculated in accordance with ASCE 7 exceeds 30 lb/ft², the effective snow load shall be taken as 20% of the snow load. Where the flat roof snow load is less than 30 lb/ft², the effective snow load shall be permitted to be zero.

C7.4.1.3.1 Pseudo Lateral Force for LSP Coefficient C_1 . This modification factor is used to account for the difference in maximum elastic and inelastic displacement amplitudes in structures with relatively stable and full hysteretic loops. The values of the coefficient are based on analytical and experimental investigations of the earthquake response of yielding structures. The quantity μ_{strength} is the ratio of the required elastic strength to the yield strength of the structure. Alternatively, μ_{strength} may be considered using:

$$\mu_{\text{strength}} = \frac{\text{DCR}_{\text{max}}}{1.5} C_m \geq 1.0 \tag{C7-3}$$

where DCR_{max} is the largest DCR computed for any primary component of a building in the direction of response under consideration, taking $C_1 = C_2 = C_m = 1.0$.

The expression above is obtained by substituting Eq. (7-17) into Eq. (7-31) and assuming that the elastic base shear capacity (fully yielded strength, V_y) is mobilized at a shear that is 1.5 times the shear at first yield (as indicated by the largest primary component DCR). The latter assumption is based on representative values for system overstrength. As is indicated in Fig. C12.1-1 of FEMA P-750 (2009c), the factor relating force level to fully

Table 7-3. Alternate Values for Modification Factors $C_1 C_2$

Fundamental Period	$m_{\text{max}} < 2$	$2 \leq m_{\text{max}} < 6$	$m_{\text{max}} \geq 6$
$T \leq 0.3$	1.1	1.4	1.8
$0.3 < T \leq 1.0$	1.0	1.1	1.2
$T > 1.0$	1.0	1.0	1.1

$C_1 C_2 C_m = 1.4 \rightarrow$ For Concrete & Masonry Shear Walls

Table 7-4. Values for Effective Mass Factor C_m

No. of Stories	Concrete Moment Frame	Concrete Shear Wall	Concrete Pier-Spandrel	Steel Moment Frame	Steel Concentrically Braced Frame	Steel Eccentrically Braced Frame	Other
1-2	1.0	1.0	1.0	1.0	1.0	1.0	1.0
3 or more	0.9	0.8	0.8	0.9	0.9	0.9	1.0

NOTE: C_m shall be taken as 1.0 if the fundamental period, T , in the direction of response under consideration is greater than 1.0 s.

The Type 2 curve depicted in Fig. 7-4 is representative of ductile behavior where there is an elastic range (points 0 to 1 on the curve) and a plastic range (points 1 to 3). The plastic range can have either a positive or negative post-elastic slope (points 1 to 3) followed by substantial loss of seismic-force-resisting capacity at point 3. Loss of gravity-load-resisting capacity takes place at the deformation associated with point 4. Primary component actions exhibiting this behavior shall be classified as deformation-controlled if the plastic range is such that $e \geq 2g$; otherwise, they shall be classified as force controlled. Secondary component actions exhibiting this behavior shall be classified as deformation controlled if $f \geq 2g$; otherwise, they shall be classified as force controlled.

The Type 3 curve depicted in Fig. 7-4 is representative of a brittle or nonductile behavior where there is an elastic range (points 0 to 1 on the curve) followed by loss of seismic-force-resisting capacity at point 3 and loss of gravity-load-resisting capacity at the deformation associated with point 4. Primary component actions exhibiting this behavior shall be classified as force controlled. Secondary component actions exhibiting this behavior shall be classified as deformation controlled if $f \geq 2g$; otherwise, they shall be classified as force controlled.

For nonlinear procedures, force-controlled components defined in Chapters 8 through 12 may be reclassified as Type 3 deformation-controlled components, provided the following criteria are met:

1. The component action being reclassified exhibits the Type 3 deformation-controlled performance defined in this section;
2. The gravity-load-resisting load path is not altered, or if it is altered, an alternate load path is provided to ensure local stability is maintained in accordance with the load combinations of Section 7.2.2 at the anticipated maximum displacements predicted by the analysis;
3. The total gravity load supported by all components that are reclassified from force controlled to deformation controlled does not exceed 5% of the total gravity load being supported at that story; and
4. All remaining deformation-controlled components meet the acceptance criteria to achieve the target performance level and all remaining force-controlled components are not overstressed.

Where overstrength of Type 3 components alters the expected mechanism in the building, the analysis shall be repeated with the affected Type 3 component strengths increased by the ratio Q_{CV}/Q_N , and all components shall be rechecked.

C7.5.1.2 Deformation-Controlled and Force-Controlled Actions

Acceptance criteria for primary components that exhibit Type 1 behavior typically are within the elastic or plastic ranges between points 0 and 2, depending on the performance level. Acceptance criteria for secondary components that exhibit Type 1 behavior can be within any of the performance ranges.

Acceptance criteria for primary and secondary components exhibiting Type 2 behavior are within the elastic or plastic ranges, depending on the performance level.

Acceptance criteria for primary and secondary components exhibiting Type 3 behavior are always within the elastic range.

Table C7-1 provides some examples of possible deformation- and force-controlled actions in common framing systems. Classification of deformation- or force-controlled actions are specified for foundation and framing components in Chapters 8 through 12.

Table C7-1. Examples of Possible Deformation-Controlled and Force-Controlled Actions

Component	Deformation-Controlled Action	Force-Controlled Action
Moment frames		
• Beams	Moment (M)	Shear (V)
• Columns	—	Axial load (P), V
• Joints	—	V^a
Shear walls	M, V	P
Braced frames		
• Braces	P	—
• Beams	—	P
• Columns	—	P
• Shear link	V	P, M
Connections	P, V, M^b	P, V, M
Diaphragms	M, V^c	P, V, M

^aShear may be a deformation-controlled action in steel moment frame construction.

^bAxial, shear, and moment may be deformation-controlled actions for certain steel and wood connections.

^cIf the diaphragm carries lateral loads from vertical-force-resisting elements above the diaphragm level, then M and V shall be considered force-controlled actions.

A given component may have a combination of both deformation- and force-controlled actions.

Classification as a deformation-controlled action is not up to the discretion of the user. Deformation-controlled actions have been defined in this standard by the designation of m -factors or nonlinear deformation capacities in Chapters 8 through 12. Additionally, there are specific provisions for nonlinear analyses when certain force-controlled actions may be reclassified as deformation controlled. Where such values are not designated and component testing justifying Type 1 or Type 2 behavior is absent, actions are to be taken as force controlled.

Figure C7-3 shows the generalized force versus deformation curves used throughout this standard to specify element modeling and acceptance criteria for deformation-controlled actions in any of the four basic material types. Linear response is depicted between point A (unloaded element) and an effective yield point B. The slope from point B to point C is typically a small percentage (0% to 10%) of the elastic slope and is included to represent phenomena such as strain hardening. Point C has an ordinate that represents the strength of the element and an abscissa value equal to the deformation at which significant strength degradation begins (line CD). Beyond point D, the element responds with substantially reduced strength to point E. At deformations greater than point F, the element seismic strength is essentially zero.

The sharp transition as shown on idealized curves in Fig. C7-3 between points C and D can result in computational difficulty and an inability to converge where it is used as modeling input in nonlinear computerized analysis software. For some types of suddenly degrading components (e.g., pre-Northridge connection fracture), this is reflective of the observed component behavior. However, to avoid this computational instability, a small slope (e.g., 10 vertical to 1 horizontal) may be provided to the segment of these curves between points C and D. Alternatively, the slope may be based on data from testing of comparable specimens. (e.g., for reinforced concrete components, it may be acceptable to connect points 2 and 3 for Type 1 components). See PEER/ATC 72-1 (2010) for additional guidance.

For some components, it is convenient to prescribe acceptance criteria in terms of deformation (such as θ or Δ), whereas for

C7.5.1.4 Material Properties Where calculations are used to determine expected or lower-bound strengths of components, expected or lower-bound material properties, respectively, shall be used.

7.5.1.5 Component Capacities

7.5.1.5.1 General Detailed criteria for calculation of individual component force and deformation capacities shall comply with the requirements in individual materials chapters as follows:

1. Foundations: Chapter 8;
2. Components composed of steel or cast iron: Chapter 9;
3. Components composed of reinforced concrete: Chapter 10;
4. Components composed of reinforced or unreinforced masonry: Chapter 11;
5. Components composed of timber, cold-formed steel light frame, gypsum, or plaster products: Chapter 12;
6. Nonstructural (architectural, mechanical, and electrical) components: Chapter 13; and
7. Seismic isolation systems and energy dissipation systems: Chapter 14.

Elements and components composed of combinations of materials are covered in the chapters associated with each material.

7.5.1.5.2 Linear Procedures If linear procedures are used, capacities for deformation-controlled actions shall be defined as the product of m -factors, α -factors, and expected strengths, Q_{CE} . Capacities for force-controlled actions shall be defined as lower-bound strengths, Q_{CL} , as summarized in Table 7-6.

7.5.1.5.3 Nonlinear Procedures If nonlinear procedures are used, component capacities for deformation-controlled actions shall be taken as permissible inelastic deformation limits. Component capacities for force-controlled actions shall be taken as lower-bound strengths, Q_{CL} , as summarized in Table 7-7.

Table 7-6. Calculation of Component Action Capacity: Linear Procedures

Parameter	Deformation Controlled	Force Controlled
Existing material strength	Expected mean value with allowance for strain-hardening	Lower-bound value (approximately mean value 1σ level)
Existing action capacity	κQ_{CE}	κQ_{CL}
New material strength	Expected material strength	Specified material strength
New action capacity	Q_{CE}	Q_{CL}

Table 7-7. Calculation of Component Action Capacity: Nonlinear Procedures

Parameter	Deformation Controlled	Force Controlled
Deformation capacity (existing component)	$\kappa \times$ Deformation limit	N/A
Deformation capacity (new component)	Deformation limit	N/A
Strength capacity (existing component)	N/A	$\kappa \times Q_{CL}$
Strength capacity (new component)	N/A	Q_{CL}

7.5.2 Linear Procedures

7.5.2.1 Forces and Deformations Component forces and deformations shall be calculated in accordance with linear analysis procedures of Sections 7.4.1 or 7.4.2.

7.5.2.1.1 Deformation-Controlled Actions for LSP or LDP Deformation-controlled actions, Q_{UD} , shall be calculated in accordance with Eq. (7-34):

$$Q_{UD} = Q_G + Q_E \quad (7-34)$$

where Q_E = Action caused by the response to the selected Seismic Hazard Level calculated using either Section 7.4.1 or Section 7.4.2;

Q_G = Action caused by gravity loads as defined in Section 7.2.2; and

Q_{UD} = Deformation-controlled action caused by gravity loads and earthquake forces.

C7.5.2.1.1 Deformation-Controlled Actions for LSP or LDP Because of possible anticipated nonlinear response of the structure, the actions as represented by Eq. (7-34) may exceed the actual strength of the component to resist these actions. The acceptance criteria of Section 7.5.2.2.1 take this overload into account through use of a factor, m , that is an indirect measure of the nonlinear deformation capacity of the component.

7.5.2.1.2 Force-Controlled Actions for LSP or LDP Force-controlled actions, Q_{UF} , shall be calculated using one of the following methods:

1. Q_{UF} shall be taken as the maximum action that can be developed in a component based on a limit-state analysis considering the expected strength of the components delivering force to the component under consideration, or the maximum action developed in the component as limited by the nonlinear response of the building.
2. Alternatively, Q_{UF} shall be calculated in accordance with Eq. (7-35).

$$Q_{UF} = Q_G \pm \frac{Q_E}{C_1 C_2 J} \quad (7-35)$$

where Q_{UF} = Force-controlled action caused by gravity loads in combination with earthquake forces; and

J = Force-delivery reduction factor, greater than or equal to 1.0, taken as the smallest demand capacity ratio (DCR) of the components in the load path delivering force to the component in question, calculated in accordance with Eq. (7-16).

Alternatively, values of J equal to 2.0 for a high level of seismicity, 1.5 for a moderate level of seismicity, and 1.0 for a low level of seismicity shall be permitted where not based on calculated DCRs. J shall be taken as 1.0 for the Immediate Occupancy Structural Performance Level.

In any case where the forces contributing to Q_{UF} are delivered by components of the seismic-force-resisting system that remain elastic, J shall be taken as 1.0.

C7.5.2.1.2 Force-Controlled Actions for LSP or LDP The basic approach for calculating force-controlled actions for evaluation or retrofit differs from that used for deformation-controlled actions because nonlinear deformations associated with force-controlled actions are not permitted. Therefore, force demands for force-controlled actions should not exceed the force capacity (strength).

Ideally, an inelastic mechanism for the structure is identified, and the force-controlled actions, Q_{UF} , for evaluation or retrofit are determined by limit analysis using that mechanism. This approach always produces a conservative estimate of the actions, even if an incorrect mechanism is selected. Where it is not possible to use limit (or plastic) analysis, or in cases where forces do not produce significant nonlinear response in the building, it is acceptable to determine the force-controlled actions for evaluation or retrofit using Eq. (7-35).

Coefficients C_1 and C_2 were introduced in Eq. (7-21) to amplify the base shear to achieve a better estimate of the maximum displacements expected for buildings responding in the inelastic range. Displacement amplifiers, C_1 and C_2 , are divided out of Eq. (7-35) when seeking an estimate of the force level present in a component where the building is responding inelastically.

Because J is included for force-controlled actions, it may appear to be more advantageous to treat an action as force controlled where m -factors are less than J . However, proper application of force-controlled criteria requires a limit state analysis of demand and lower-bound calculation of capacity that yields a reliable result whether an action is treated as force or deformation controlled.

7.5.2.2 Acceptance Criteria for Linear Procedures

7.5.2.2.1 Acceptance Criteria for Deformation-Controlled Actions for LSP or LDP Deformation-controlled actions in primary and secondary components shall satisfy Eq. (7-36).

$$m\kappa Q_{CE} > Q_{UD} \quad (7-36)$$

where m = Component capacity modification factor to account for expected ductility associated with this action at the selected Structural Performance Level. m -factors are specified in Chapters 8 through 12 and 14;

Q_{CE} = Expected strength of component deformation-controlled action of an element at the deformation level under consideration. Q_{CE} , the expected strength, shall be determined considering all coexisting actions on the component under the loading condition by procedures specified in Chapters 8 through 14; and

κ = Knowledge factor defined in Section 6.2.4.

7.5.2.2.2 Acceptance Criteria for Force-Controlled Actions for LSP or LDP Force-controlled actions in primary and secondary components shall satisfy Eq. (7-37):

$$\kappa Q_{CL} > Q_{UF} \quad (7-37)$$

where Q_{CL} = Lower-bound strength of a force-controlled action of an element at the deformation level under consideration. Q_{CL} , the lower-bound strength, shall be determined considering all coexisting actions on the component under the loading condition by procedures specified in Chapters 8 through 12 and 14.

7.5.2.2.3 Verification of Analysis Assumptions for LSP or LDP In addition to the requirements in Section 7.2.14, the following verification of analysis assumptions shall be made.

Where moments caused by gravity loads in horizontally spanning primary components exceed 75% of the expected moment strength at any location, the possibility for inelastic flexural action at locations other than member ends shall be specifically investigated by comparing flexural actions with expected member strengths. Where linear procedures are used, formation of flexural plastic hinges away from member ends shall not be permitted.

7.5.3 Nonlinear Procedures

7.5.3.1 Forces and Deformations Component forces and deformations shall be calculated in accordance with nonlinear analysis procedures of Sections 7.4.3 or 7.4.4.

7.5.3.2 Acceptance Criteria for Nonlinear Procedures

7.5.3.2.1 Acceptance Criteria for Deformation-Controlled Actions for NSP or NDP Primary and secondary components shall have expected deformation capacities not less than maximum deformation demands calculated at target displacements. Primary and secondary component demands shall be within the acceptance criteria for nonlinear components at the selected Structural Performance Level. Expected deformation capacities shall be determined considering all coexisting forces and deformations in accordance with Chapters 8 through 14.

C7.5.3.2.1 Acceptance Criteria for Deformation-Controlled Actions for NSP or NDP Where all components are explicitly modeled with full backbone curves, the NSP or NDP can be used to evaluate the full contribution of all components to the seismic force resistance of the structure as they degrade to residual strength values. Where degradation is explicitly evaluated in the analysis, components can be relied upon for lateral-force resistance out to the secondary component limits of response.

Studies on the effects of different types of strength degradation are presented in FEMA 440 (2005). As components degrade, the post-yield slope of the force–displacement curve becomes negative. The strength ratio, μ_{max} , limits the extent of degradation based on the degree of negative post-yield slope.

7.5.3.2.2 Acceptance Criteria for Force-Controlled Actions for NSP or NDP Primary and secondary components shall have lower-bound strengths not less than the maximum analysis forces. Lower-bound strengths shall be determined considering all coexisting forces and deformations by procedures specified in Chapters 8 through 12 and 14.

7.5.3.2.3 Verification of Analysis Assumptions for NSP or NDP In addition to the requirements in Section 7.2.14, the following verification of analysis assumptions shall be made:

Flexural plastic hinges shall not form away from component ends unless they are explicitly accounted for in modeling and analysis.

7.6 ALTERNATIVE MODELING PARAMETERS AND ACCEPTANCE CRITERIA

It shall be permitted to derive required parameters and acceptance criteria using the experimentally obtained cyclic response characteristics of a subassembly, determined in accordance with this section. Where relevant data on the inelastic force–deformation behavior for a structural subassembly are not available, such data shall be obtained from experiments consisting of physical tests of representative subassemblies as specified in this section. Approved independent review of this process shall be conducted.

C7.6 ALTERNATIVE MODELING PARAMETERS AND ACCEPTANCE CRITERIA

This section provides guidance for developing appropriate data to evaluate construction materials and detailing systems not specifically addressed by this standard. This standard specifies stiffnesses, m -factors, strengths, and deformation capacities for a wide range of components. To the extent practical, this standard

unless a larger or smaller number of deformation cycles is determined considering earthquake duration and dynamic properties of the structure.

C10.3.2.1 General In this standard, actions are classified as either deformation controlled or force controlled. Actions are considered to be deformation controlled where the component behavior is well documented by test results. Where linear or nonlinear acceptance criteria are tabulated in this chapter, the committee has judged the action to be deformation controlled and expected material properties should be used. Where such acceptance criteria are not specified, the action should be assumed force controlled, thereby requiring the use of lower-bound material properties, or the design professional may opt to perform testing to validate the classification of deformation controlled. Section 7.6 provides guidance on procedures to be followed during testing, and Section 7.5.1.2 provides a methodology based on the test data to distinguish force-controlled from deformation-controlled actions. Further guidance on the testing of moment-frame components can be found in ACI 374.1.

In some cases, including short-period buildings and those subjected to a long-duration design earthquake, a building may be expected to be subjected to additional cycles to the design deformation levels beyond the three cycles recommended in Section 10.3.2.1. The increased number of cycles may lead to reductions in resistance and deformation capacity. The effects on strength and deformation capacity of additional deformation cycles should be considered in design.

10.3.2.2 Deformation-Controlled Actions Strengths used for deformation-controlled actions shall be taken as equal to expected strengths Q_{CE} obtained experimentally or calculated using accepted principles of mechanics. Expected strength is defined as the mean maximum resistance expected over the range of deformations to which a concrete component is likely to be subjected. Where calculations are used to define expected strength, expected material properties shall be used. Unless specified in this standard, other procedures specified in ACI 318 to calculate design strengths shall be permitted, except that the strength reduction factor ϕ shall be taken equal to unity. Deformation capacities for acceptance of deformation-controlled actions calculated by nonlinear procedures shall be as specified in Sections 10.4 through 10.12. For components constructed of lightweight concrete, Q_{CE} shall be modified in accordance with ACI 318 procedures for lightweight concrete.

C10.3.2.2 Deformation-Controlled Actions Expected yield strength of reinforcing steel, as specified in Section 10.2.2.1.2, includes material overstrength considerations.

10.3.2.3 Force-Controlled Actions Strengths used for force-controlled actions shall be taken as lower-bound strengths Q_{CL} , obtained experimentally or calculated using established principles of mechanics. Lower-bound strength is defined as the mean less one standard deviation of resistance expected over the range of deformations and loading cycles to which the concrete component is likely to be subjected. Where calculations are used to define lower-bound strengths, lower-bound estimates of material properties shall be used. Unless other procedures are specified in this standard, procedures specified in ACI 318 to calculate design strengths shall be permitted, except that the strength reduction factor ϕ shall be taken equal to unity. For components constructed of lightweight concrete, Q_{CL} shall be modified in accordance with ACI 318 procedures for lightweight concrete.

10.3.2.4 Component Ductility Demand Classification Table 10-6 provides classification of component ductility demands as

Table 10-6. Component Ductility Demand Classification

Maximum Value of DCR or Displacement Ductility	Descriptor
<2	Low ductility demand
2 to 4	Moderate ductility demand
>4	High ductility demand

low, moderate, or high based on the maximum value of the demand–capacity ratio (DCR) defined in Section 7.3.1.1 for linear procedures or the calculated displacement ductility for nonlinear procedures.

10.3.3 Flexure and Axial Loads Flexural strength of members with and without axial loads shall be calculated according to ACI 318 or by other demonstrated rational methods, such as sectional analysis using appropriate concrete and steel constitutive models. Deformation capacity of members with and without axial loads shall be calculated considering shear, flexure, and reinforcement slip deformations, or based on acceptance criteria given in this standard. Strengths and deformation capacities of components with monolithic flanges shall be calculated considering concrete and developed longitudinal reinforcement within the effective flange width, as defined in Section 10.3.1.3.

Strength and deformation capacities shall be determined based on the available development of longitudinal reinforcement. Where longitudinal reinforcement has embedment or development length that is insufficient for reinforcement strength development, flexural strength shall be calculated based on limiting stress capacity of the embedded bar as defined in Section 10.3.5.

Where flexural deformation capacities are calculated from basic principles of mechanics, reductions in deformation capacity caused by applied shear shall be considered. Where using analytical models for flexural deformability that do not directly consider effect of shear and design shear equals or exceeds $6\sqrt{f'_c}A_w$, lb/in.² ($0.5\sqrt{f'_c}A_w$, MPa), the design value shall not exceed 80% of the value calculated using the analytical model.

For concrete columns under combined axial load and biaxial bending, the combined strength shall be evaluated considering biaxial bending. When using linear procedures, the design axial load P_{UF} shall be calculated as a force controlled action per Section 7.5.2. The design moments M_{UD} should be calculated about each of two orthogonal axes. Combined strength shall be based on principles of mechanics with applied bending moments calculated as $M_{UDx}/(m_s\kappa)$ and $M_{UDy}/(m_s\kappa)$ about the x- and y-axes, respectively. Acceptance shall be based on the applied bending moments lying within the expected strength envelope calculated at an axial load level of P_{UF} .

C10.3.3 Flexure and Axial Loads Laboratory tests indicate that flexural deformability may be reduced as coexisting shear forces increase. As flexural ductility demands increase, shear capacity decreases, which may result in a shear failure before theoretical flexural deformation capacities are reached. Use caution where flexural deformation capacities are determined by calculation. FEMA 306 (1998b) (Section 5.2) is a resource for guidance on the interaction between shear and flexure.

The combined strength under uniaxial or biaxial bending with axial load is difficult to generalize in a closed-form solution, given the range of column section geometries encountered. For a particular class of rectangular column sections, closed-form solutions based on section capacities about the principal axes have been developed that provide excellent agreement when compared with a more generalized analysis (Hsu 1988, Furlong

Table 9-4. (Continued)

Component/Action	<i>m</i> -Factors for Linear Procedures ^a				
	IO	Primary		Secondary	
		LS	CP	LS	CP
Composite Top and Clip Angle Bottom ⁱ					
a. Failure of deck reinforcement	1.25	2	3	4	6
b. Local flange yielding and web crippling of column	1.5	4	6	5	7
c. Yield of bottom flange angle	1.5	4	6	6	7
d. Tensile yield of rivets or bolts at column flange	1.25	1.5	2.5	2.5	3.5
e. Shear yield of beam flange connections	1.25	2.5	3.5	3.5	4.5
Shear connection with slab ^j	2.4–0.011 d_{bg}	—	—	13.0–0.290 d_{bg}	17.0–0.387 d_{bg}
Shear connection without slab ^j	8.9–0.193 d_{bg}	—	—	13.0–0.290 d_{bg}	17.0–0.387 d_{bg}
Eccentrically Braced Frame (EBF) Link Beam^{k,l}					
a. $e \leq \frac{1.6 M_{CE}}{V_{CE}}$	1.5	9	13	13	15
b. $e \geq \frac{2.6 M_{CE}}{V_{CE}}$	Same as for beams				
c. $\frac{1.6 M_{CE}}{V_{CE}} < e < \frac{2.6 M_{CE}}{V_{CE}}$	Linear interpolation shall be used				
Braces in Compression (except EBF braces)					
a. Slender ^m $\frac{KI}{r} \geq 4.2\sqrt{E/F_y}$					
1. <i>W</i> , <i>I</i> , 2 <i>L</i> in-plane ⁿ , 2 <i>C</i> in-plane ⁿ	1.25	6	8	7	9
2. 2 <i>L</i> out-of-plane ⁿ , 2 <i>C</i> out-of-plane ⁿ	1.25	5	7	6	8
3. HSS, pipes, tubes, <i>L</i>	1.25	5	7	6	8
b. Stocky ^{m,o} $\frac{KI}{r} \leq 2.1\sqrt{E/F_y}$					
1. <i>W</i> , <i>I</i> , 2 <i>L</i> in-plane ⁿ , 2 <i>C</i> in-plane ⁿ	1.25	5	7	6	8
2. 2 <i>L</i> out-of-plane ⁿ , 2 <i>C</i> out-of-plane ⁿ	1.25	4	6	5	7
3. HSS, pipes, tubes	1.25	4	6	5	7
c. Intermediate	Linear interpolation between the values for slender and stocky braces (after application of all applicable modifiers) shall be used.				
Braces in Tension (except EBF braces)^p	1.25	5 ^{q,r}	7 ^{q,r}	8 ^{q,r}	10 ^{q,r}
Buckling-Restrained Braces^s	2.3	5.6	7.5	7.5	10
Beams, Columns in Tension (except EBF Beams, Columns)	1.25	3	5	6	7
Steel Plate Shear Walls^t	1.5	8	12	12	14
Diaphragm Components					
Diaphragm shear yielding or panel or plate buckling	1.25	2	3	2	3
Diaphragm chords and collectors—Full lateral support	1.25	6	8	6	8
Diaphragm chords and collectors—Limited lateral support	1.25	2	3	2	3

m-factors for flexible steel deck diaphragm shear

^aColumns in moment or braced frames shall be permitted to be designed for the maximum force delivered by connecting members. For rectangular or square columns, replace $b/2t_f$ with b/t , replace 52 with 110, and replace 65 with 190.

^bColumns with $P/P_{CL} > 0.5$ shall be considered force controlled.

^c $m = 9(1 - 5/3 P/P_{CL})$ in the plane of bending.

^d $m = 12(1 - 5/3 P/P_{CL})$ in the plane of bending.

^e $m = 15(1 - 5/3 P/P_{CL})$ in the plane of bending.

^f $m = 18(1 - 5/3 P/P_{CL})$ in the plane of bending.

^gTabulated values shall be modified as indicated in Section 9.4.2.4.2, Item 4.

^h d is the beam depth; d_{bg} is the depth of the bolt group.

ⁱWeb plate or stiffened seat shall be considered to carry shear. Without shear connection, action shall not be classified as secondary. If $d_b > 18$ in., multiply m -factors by $18/d_b$, but values need not be less than 1.0.

^jFor high-strength bolts, divide values by 2.0, but values need not be less than 1.25.

^kValues are for link beams with three or more web stiffeners. If no stiffeners, divide values by 2.0, but values need not be less than 1.25. Linear interpolation shall be used for one or two stiffeners.

^lAssumes ductile detailing for flexural link, in accordance with AISC 341.

^mIn addition to consideration of connection capacity in accordance with Section 9.5.2.4.1, values for braces shall be modified for connection robustness as follows: Where brace connections do not satisfy the requirements of AISC 341, F2.6, the acceptance criteria shall be multiplied by 0.8.

ⁿStitches for built-up members: Where the stitches for built-up braces do not satisfy the requirements of AISC 341, F2.5b, the acceptance criteria shall be multiplied by 0.5.

^oSection compactness: Acceptance criteria applies to brace sections that are concrete-filled or seismically compact according to Table D1.1 of AISC 341 for highly ductile members. Where the brace section is noncompact according to Table B4.1 of AISC 360, the acceptance criteria shall be multiplied by 0.5. For intermediate compactness conditions, the acceptance criteria shall be multiplied by a value determined by linear interpolation between the seismically compact and the noncompact cases.

^pFor tension-only bracing, m -factors shall be divided by 2.0, but need not be less than 1.25.

^qFor 2*L*, HSS, pipe, and single angle, m -factors shall be multiplied by 0.8.

^rIn addition to consideration of connection capacity in accordance with Section 9.5.2.4.1, values for braces shall be modified for connection robustness as follows: Where brace connections do not satisfy the requirements of AISC 341, Section F2.6, the acceptance criteria shall be multiplied by 0.8.

^sFor 2*L*, HSS, pipe, and single angle, m -factors shall be multiplied by 0.7.

^tMaximum strain of the buckling-restrained brace (BRB) core shall not exceed 2.5%.

^uIf testing to demonstrate compliance with Section 9.5.4.4.2 is not available, the acceptance criteria shall be multiplied by 0.7.

^vApplicable if stiffeners, or concrete backing, is provided to prevent buckling.

^wRegardless of the modifiers applied, m need never be taken less than 1.0.

Table 10-13. Numerical Acceptance Criteria for Linear Procedures—Reinforced Concrete Beams

Conditions			m-Factors ^d				
			Performance Level				
			Component Type				
			Primary		Secondary		
		IO	LS	CP	LS	CP	
Condition i. Beams controlled by flexure ^b							
$\rho - \rho'$	Transverse reinforcement ^c	$\frac{V}{b_w d \sqrt{f'_c}}$					
ρ_{hall}							
≤ 0.0	C	≤ 3 (0.25)	3	6	7	6	10
≤ 0.0	C	≥ 6 (0.5)	2	3	4	3	5
≥ 0.5	C	≤ 3 (0.25)	2	3	4	3	5
≥ 0.5	C	≥ 6 (0.5)	2	2	3	2	4
≤ 0.0	NC	≤ 3 (0.25)	2	3	4	3	5
≤ 0.0	NC	≥ 6 (0.5)	1.25	2	3	2	4
≥ 0.5	NC	≤ 3 (0.25)	2	3	3	3	4
≥ 0.5	NC	≥ 6 (0.5)	1.25	2	2	2	3
Condition ii. Beams controlled by shear ^b							
Stirrup spacing $\leq d/2$			1.25	1.5	1.75	3	4
Stirrup spacing $> d/2$			1.25	1.5	1.75	2	3
Condition iii. Beams controlled by inadequate development or splicing along the span ^b							
Stirrup spacing $\leq d/2$			1.25	1.5			4
Stirrup spacing $> d/2$			1.25	1.5			3
Condition iv. Beams controlled by inadequate embedment into beam-column joint ^b			2	2	3	3	4

NOTE: f'_c in lb/in.² (MPa) units.

^aValues between those listed in the table should be determined by linear interpolation.

^bWhere more than one of conditions i, ii, iii, and iv occurs for a given component, use the minimum appropriate numerical value from the table.

^c"C" and "NC" are abbreviations for conforming and nonconforming transverse reinforcement. Transverse reinforcement is conforming if, within the flexural plastic hinge region, hoops are spaced at $\leq d/3$, and if, for components of moderate and high ductility demand, the strength provided by the hoops (V_t) is at least 3/4 of the design shear. Otherwise, the transverse reinforcement is considered nonconforming.

^d V is the design shear force calculated using limit-state analysis procedures in accordance with Section 10.4.2.4.1.

2. Posttensioning existing beams, columns, or joints using external posttensioning reinforcement. Posttensioned reinforcement should be unbonded within a distance equal to twice the effective depth from sections where inelastic action is expected. Anchorages should be located away from regions where inelastic action is anticipated and should be designed with consideration of possible force variations from seismic forces;
3. Modifying the element by selective material removal from the existing element. Examples include (a) where nonstructural components interfere with the frame, eliminating this interference by removing or separating the nonstructural component from the frame; (b) weakening from concrete removal or severing longitudinal reinforcement to change the response from a nonductile to a more ductile mode, for example, weakening beams to promote formation of a strong-column, weak-beam system; and (c) segmenting walls to change stiffness and strength;
4. Improving deficient existing reinforcement details. Removal of cover concrete to modify existing reinforcement details should avoid damage to core concrete and the bond between existing reinforcement and core concrete. New cover concrete should be designed and constructed to achieve fully composite action with the existing materials (FEMA 547 Sections 12.4.4, 12.4.5, and 12.4.6);
5. Changing the building system to reduce demands on the existing elements. Examples include addition of supplementary seismic-force-resisting elements, such as walls or buttresses, seismic isolation, and mass reduction (FEMA 547 Chapter 24); and
6. Changing the frame element to a shear wall, infilled frame, or braced frame element by adding new material. Connections between new and existing materials should be designed to transfer the anticipated forces based on the design-load combinations. Where the existing concrete frame columns and beams act as boundary components and collectors for the new shear wall or braced frame, these should be checked for adequacy, considering strength, reinforcement development, and deformability. Diaphragms, including ties and collectors, should be evaluated and if necessary, rehabilitated to ensure a complete load path to the new shear wall or braced frame element (FEMA 547 Sections 12.4.1 and 12.4.2).

10.4.3 Posttensioned Concrete Beam-Column Moment Frames

10.4.3.1 General The analytical model for a posttensioned concrete beam-column frame element shall be established as specified in Section 10.4.2.1 for reinforced concrete beam-

TABLE 28 – ALLOWABLE DIAPHRAGM STRENGTH, q (plf), AND FLEXIBILITY FACTORS, F, FOR TYPE HSB®-36 DECK ATTACHED WITH WELDS TO SUPPORTS AND SIDELAPS FASTENED WITH BUTTON PUNCHES (BP) OR 1½" TOP SEAM WELDS (TSW) AT SIDELAPS^{1,2,3,4,5,6,7,8}

DECK GAGE	SIDELAP ATTACHMENT	SPAN (ft.-in.)									
		4'-0"	5'-0"	6'-0"	7'-0"	8'-0"	9'-0"	10'-0"	11'-0"	12'-0"	
36/4 ARC SPOT AND ARC SEAM WELD PATTERN AT SUPPORTS											
22	BP @ 24"	q	282	234	190	169	144	135	121	-	-
		F	-1.3+267R	4.2+212R	9.1+174R	12.6+148R	16.3+127R	18.9+112R	22.1+98R	-	-
	BP @ 12"	q	318	262	226	199	180	167	157	-	-
		F	-2.3+267R	3.1+212R	7.2+175R	10.5+149R	13.3+129R	15.7+114R	17.9+101R	-	-
	TSW @ 24"	q	628	649	562	588	526	552	505	-	-
		F	-9.4+271R	-6.3+217R	-3.5+181R	-2.2+155R	-0.5+135R	0.1+120R	1.2+108R	-	-
	TSW @ 18"	q	763	756	663	673	681	622	633	-	-
		F	-10.2+271R	-6.9+217R	-4.2+181R	-2.8+155R	-1.7+136R	-0.4+121R	0.2+108R	-	-
	TSW @ 12"	q	871	846	828	815	805	798	791	-	-
		F	-10.7+272R	-7.3+217R	-5.1+181R	-3.5+155R	-2.3+136R	-1.3+121R	-0.6+109R	-	-
	TSW @ 6"	q	1117	1107	1101	1096	1092	1089	1001	-	-
		F	-11.6+272R	-8.2+217R	-6+181R	-4.4+155R	-3.2+136R	-2.3+121R	-1.5+109R	-	-
20	BP @ 24"	q	403	336	275	246	211	195	175	169	155
		F	3.1+167R	7.2+132R	11.1+108R	13.8+91R	16.9+78R	19+68R	21.7+59R	23.4+53R	25.8+47R
	BP @ 12"	q	454	378	326	290	262	241	227	216	206
		F	2.2+168R	6.2+133R	9.3+109R	11.9+93R	14.2+80R	16.1+70R	17.8+62R	19.4+55R	20.8+50R
	TSW @ 24"	q	824	846	733	764	685	715	654	683	634
		F	-4.2+171R	-2.3+137R	-0.4+114R	0.3+98R	1.5+86R	1.9+76R	2.7+68R	2.8+62R	3.4+57R
	TSW @ 18"	q	993	981	861	872	879	804	818	829	774
		F	-5+172R	-2.9+137R	-1.1+114R	-0.2+98R	0.5+86R	1.4+76R	1.8+69R	2.1+62R	2.6+57R
	TSW @ 12"	q	1127	1093	1069	1051	1037	1026	1018	1010	912
		F	-5.5+172R	-3.3+137R	-1.9+115R	-0.8+98R	0+86R	0.6+76R	1+69R	1.4+62R	1.8+57R
	TSW @ 6"	q	1435	1422	1412	1406	1400	1396	1313	1085	912
		F	-6.2+172R	-4.1+138R	-2.7+115R	-1.7+98R	-0.9+86R	-0.3+76R	0.1+69R	0.5+63R	0.8+57R
18	BP @ 24"	q	704	592	487	438	379	353	314	300	275
		F	6.3+80R	9.1+63R	11.9+51R	13.9+42R	16.3+35R	17.8+30R	20+26R	21.3+22R	23.3+19R
	BP @ 12"	q	794	666	579	517	470	434	405	383	366
		F	5.5+81R	8.2+63R	10.4+52R	12.2+43R	13.9+37R	15.3+32R	16.7+28R	17.9+24R	19+22R
	TSW @ 24"	q	1272	1293	1121	1160	1040	1081	989	1028	955
		F	0+84R	0.8+67R	1.9+56R	2.2+48R	2.9+42R	3+37R	3.5+33R	3.5+30R	3.9+28R
	TSW @ 18"	q	1513	1486	1306	1316	1323	1210	1227	1241	1160
		F	-0.7+84R	0.3+67R	1.3+56R	1.7+48R	2+42R	2.6+37R	2.7+33R	2.9+30R	3.2+28R
	TSW @ 12"	q	1705	1648	1607	1577	1554	1535	1520	1508	1394
		F	-1.1+84R	-0.1+67R	0.7+56R	1.2+48R	1.6+42R	1.9+37R	2.1+34R	2.3+30R	2.5+28R
	TSW @ 6"	q	2150	2127	2111	2099	2090	2083	2007	1659	1394
		F	-1.8+84R	-0.8+67R	-0.1+56R	0.4+48R	0.8+42R	1.1+37R	1.3+34R	1.5+31R	1.7+28R
16	BP @ 24"	q	912	778	641	584	506	477	425	408	371
		F	7.1+44R	9.2+34R	11.5+27R	13.1+22R	15.1+18R	16.4+15R	18.3+12R	19.4+10R	21.2+8R
	BP @ 12"	q	1041	893	784	707	649	604	568	538	514
		F	6.4+45R	8.4+35R	10.1+28R	11.6+23R	13+19R	14.2+16R	15.3+14R	16.3+12R	17.3+10R
	TSW @ 24"	q	1643	1679	1460	1515	1361	1417	1299	1352	1257
		F	1.4+48R	1.8+38R	2.6+32R	2.7+27R	3.2+24R	3.2+21R	3.6+19R	3.5+17R	3.8+16R
	TSW @ 18"	q	1957	1929	1702	1718	1731	1586	1610	1630	1525
		F	0.8+48R	1.3+38R	2.1+32R	2.3+27R	2.4+24R	2.8+21R	2.9+19R	2.9+17R	3.2+16R
	TSW @ 12"	q	2203	2136	2088	2053	2023	2004	1986	1971	1941
		F	0.4+48R	1+38R	1.5+32R	1.8+27R	2+24R	2.2+21R	2.3+19R	2.4+17R	2.5+16R
	TSW @ 6"	q	2753	2727	2710	2696	2683	2678	2671	2310	1941
		F	-0.2+48R	0.4+38R	0.8+32R	1.1+27R	1.3+24R	1.5+21R	1.6+19R	1.7+17R	1.8+16R

See Page 107 for footnotes.


(continued)

General Notes (Cont'd.)

Sidelap Deck-to-Deck Panel Attachments Parallel to the Flutes:

- 16. Provisions of specific UL Fire-Rated Assemblies may reduce the maximum allowable sidelap fastener spacing.
- 17. Deck panel side seams (sidelaps) may be connected with the Verco PunchLok II VSC2 connections, welds, screws, or button punches, as illustrated in Figure 1 and as indicated in the evaluation report.

FIGURE 1 - SIDELAP OPTIONS



Diaphragm Shear and Flexibility:

- 18. The shear strength and flexibility factors for roof decks and FORMLOK decks without concrete fill listed in this report are based on an $F_u = 62$ ksi, and a continuous 3-span condition for span lengths 4 feet and greater. For span lengths less than 4 feet, the allowable diaphragm shear values are based on a sheet length of 12 feet or a maximum of 7 spans. Deck panels longer than 12 feet or with more than 7 spans may be used with the tabulated values.
- 19. The allowable values for composite decks shown in the tables are applicable to either phosphatized/painted or galvanized decks. The allowable values shown for roof deck panels are applicable to either painted, mill-finished, or galvanized decks.
- 20. The allowable diaphragm shear strength listed in the tables are in pounds per linear foot. The flexibility factors listed in the tables are in micro inches a diaphragm web will deflect in a span of 1 ft under a shear load of 1 lb/ft.
- 21. Where individual panels are cut, the partial panel shall be fastened in a manner to fully transfer the shears at the point of the diaphragm to the adjacent full panels for the values specified in the tables.
- 22. Verco's published allowable diaphragm shear strength tables (except tables 47 and 48) utilize the ASD factors of safety for Earthquake loading from AISI S100, Table D5, excerpt below.
 - a. To convert from Earthquake loading to Wind loading, utilizing ASD, the published allowable diaphragm shear strength may be multiplied by Ω_d (Earthquake), and then divided by Ω_d (Wind):

As an example:

Welds: $3.00/2.35 = 1.27$

Mechanical Fasteners: $2.5/2.35 = 1.06$

- b. To convert from ASD to LRFD for each connection type, the published allowable diaphragm shear values may be multiplied by the applicable conversion factor, $C = \Omega_d \times \Phi_d$

The following examples are for Earthquake loading:

For welds: $C_{WELD} = 3.00 \times 0.55 = 1.65$

For mechanical fasteners: $C_{MECHANICAL\ FASTENER} = 2.5 \times 0.65 = 1.625$

For deck panel buckling*: $C_{BUCKLING} = 2.00 \times 0.80 = 1.60$

* The shaded areas in the allowable diaphragm shear tables indicate where buckling is the limit state rather than the connections.

AISI S100 TABLE D5 - SAFETY FACTORS AND RESISTANCE FACTORS FOR DIAPHRAGMS

Load Type or Combinations Including	Connection Type ¹	Limit State					
		Connection Related			Panel Buckling ²		
		USA and Mexico		Canada	USA and Mexico		Canada
		Ω_d (ASD)	Φ_d (LRFD)	Φ_d (LSD)	Ω_d (ASD)	Φ_d (LRFD)	Φ_d (LSD)
Earthquake	Welds	3.00	0.55	0.50	2.00	0.80	0.75
	Screws	2.50	0.65	0.60			
Wind	Welds	2.35	0.70	0.65			
	Screws	2.35	0.70	0.65			
All Others	Welds	2.65	0.60	0.55			
	Screws	2.50	0.65	0.60			

¹ For mechanical fasteners - such as Power Actuated Fasteners or Forced Entry Fasteners, the factors of safety for screws may be used.

² Panel buckling is considered out-of-plane deck buckling and not local buckling at fasteners.

USGS Design Maps Summary Report

User-Specified Input

Report Title Willamete River WTP
Wed September 6, 2017 20:16:49 UTC

Building Code Reference Document ASCE 41-13 Retrofit Standard, BSE-1E
(which utilizes USGS hazard data available in 2008)



Site Coordinates 45.295°N, 122.783°W

Site Soil Classification Site Class E – “Soft Clay Soil”



USGS-Provided Output

$S_{S,20/50}$	0.283 g	$S_{XS,BSE-1E}$	0.611 g
$S_{1,20/50}$	0.107 g	$S_{X1,BSE-1E}$	0.372 g



Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.


Design Maps Detailed Report

ASCE 41-13 Retrofit Standard, BSE-1E (45.295°N, 122.783°W)

Site Class E – “Soft Clay Soil”

Section 2.4.1 – General Procedure for Hazard Due to Ground Shaking

20%/50-year maximum direction spectral response acceleration for 0.2s and 1.0s periods, respectively:

From Section 2.4.1.4

$$S_{S,20/50} = 0.283 \text{ g}$$

From Section 2.4.1.4

$$S_{S,20/50} = 0.107 \text{ g}$$

Section 2.4.1.6 – Adjustment for Site Class

The authority having jurisdiction (not the USGS), site-specific geotechnical data, and/or the default has classified the site as Site Class E, based on the site soil properties in accordance with Section 2.4.1.6.1.

SITE CLASS	SOIL PROFILE NAME	Soil shear wave velocity, \bar{v}_s (ft/s)	Standard penetration resistance, \bar{N}	Soil undrained shear strength, \bar{s}_{ur} (psf)
A	Hard rock	$\bar{v}_s > 5,000$	N/A	N/A
B	Rock	$2,500 < \bar{v}_s \leq 5,000$	N/A	N/A
C	Very dense soil and soft rock	$1,200 < \bar{v}_s \leq 2,500$	$\bar{N} > 50$	>2,000 psf
D	Stiff soil profile	$600 \leq \bar{v}_s < 1,200$	$15 \leq \bar{N} \leq 50$	1,000 to 2,000 psf
E	Stiff soil profile	$\bar{v}_s < 600$	$\bar{N} < 15$	<1,000 psf
E	—	Any profile with more than 10 ft of soil having the characteristics: <ol style="list-style-type: none"> 1. Plasticity index $PI > 20$, 2. Moisture content $w \geq 40\%$, and 3. Undrained shear strength $\bar{s}_u < 500$ psf 		
F	—	Any profile containing soils having one or more of the following characteristics: <ol style="list-style-type: none"> 1. Soils vulnerable to potential failure or collapse under seismic loading such as liquefiable soils, quick and highly sensitive clays, collapsible weakly cemented soils. 2. Peats and/or highly organic clays ($H > 10$ feet of peat and/or highly organic clay where H = thickness of soil) 3. Very high plasticity clays ($H > 25$ feet with plasticity index $PI > 75$) 4. Very thick soft/medium stiff clays ($H > 120$ feet) 		

For SI: 1ft/s = 0.3048 m/s 1lb/ft² = 0.0479 kN/m²

Table 2-3. Values of F_a as a Function of Site Class and Mapped Short-Period Spectral Response Acceleration S_s

Site Class	Mapped Spectral Acceleration at Short-Period S_s				
	$S_s \leq 0.25$	$S_s = 0.50$	$S_s = 0.75$	$S_s = 1.00$	$S_s \geq 1.25$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	Site-specific geotechnical and dynamic site response analyses shall be performed				

Note: Use straight-line interpolation for intermediate values of S_s

For Site Class = E and $S_s = 0.283$ g, $F_a = 2.394$

Table 2-4. Values of F_v as a Function of Site Class and Mapped Spectral Response Acceleration at 1 s Period S_1

Site Class	Mapped Spectral Acceleration at 1 s Period S_1				
	$S_1 \leq 0.10$	$S_1 = 0.20$	$S_1 = 0.30$	$S_1 = 0.40$	$S_1 \geq 0.50$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.7	1.6	1.5	1.4	1.3
D	2.4	2.0	1.8	1.6	1.5
E	3.5	3.2	2.8	2.4	2.4
F	Site-specific geotechnical and dynamic site response analyses shall be performed				

Note: Use straight-line interpolation for intermediate values of S_1

For Site Class = E and $S_1 = 0.107$ g, $F_v = 3.479$

Provided as a reference for
Equation (2-4):

$$F_a S_{S,20/50} = 2.394 \times 0.283 \text{ g} = 0.678 \text{ g}$$

Provided as a reference for
Equation (2-5):

$$F_v S_{1,20/50} = 3.479 \times 0.107 \text{ g} = 0.372 \text{ g}$$

Provided as a reference for
Equation (2-4):

$$S_{X_S, BSE-1N} = \frac{2}{3} \times S_{X_S, BSE-2N} = \frac{2}{3} \times F_a S_{S, BSE-2N} = 0.611 \text{ g}$$

Provided as a reference for
Equation (2-5):


$$S_{X_1, BSE-1N} = \frac{2}{3} \times S_{X_1, BSE-2N} = \frac{2}{3} \times F_v S_{1, BSE-2N} = 0.656 \text{ g}$$

Equation (2-4): $S_{X_S, BSE-1E} = \text{MIN}[F_a S_{S,20/50}, S_{X_S, BSE-1N}] = \text{MIN}[0.678\text{g}, 0.611\text{g}] = 0.611\text{g}$

Equation (2-5): $S_{X_1, BSE-1E} = \text{MIN}[F_v S_{S,20/50}, S_{X_1, BSE-1N}] = \text{MIN}[0.372\text{g}, 0.656\text{g}] = 0.372\text{g}$


Section 2.4.1.7.1 — General Horizontal Response Spectrum

Figure 2-1. General Horizontal Response Spectrum



Section 2.4.1.7.2 — General Vertical Response Spectrum

The General Vertical Response Spectrum is determined by multiplying the General Horizontal Response Spectrum by $\frac{2}{3}$.



USGS Design Maps Summary Report

User-Specified Input

Report Title Willamete River WTP
Wed September 6, 2017 20:41:26 UTC

Building Code Reference Document ASCE 41-13 Retrofit Standard, BSE-1N
(which utilizes USGS hazard data available in 2008)

Site Coordinates 45.295°N, 122.783°W



Site Soil Classification Site Class E – "Soft Clay Soil"



USGS-Provided Output

$S_{XS,BSE-1N}$ 0.611 g

$S_{X1,BSE-1N}$ 0.656 g



Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.


Design Maps Detailed Report

ASCE 41-13 Retrofit Standard, BSE-1N (45.295°N, 122.783°W)

Site Class E – “Soft Clay Soil”

Section 2.4.1 – General Procedure for Hazard Due to Ground Shaking

Provided as a reference for Equation (2-4) and Equation (2-5), respectively:

From Section 2.4.1.1

$$S_{S,BSE-2N} = 0.924 \text{ g}$$

From Section 2.4.1.1

$$S_{1,BSE-2N} = 0.410 \text{ g}$$

Section 2.4.1.6 – Adjustment for Site Class

The authority having jurisdiction (not the USGS), site-specific geotechnical data, and/or the default has classified the site as Site Class E, based on the site soil properties in accordance with Section 2.4.1.6.1.

SITE CLASS	SOIL PROFILE NAME	Soil shear wave velocity, \bar{v}_s, (ft/s)	Standard penetration resistance, \bar{N}	Soil undrained shear strength, \bar{s}_u, (psf)
A	Hard rock	$\bar{v}_s > 5,000$	N/A	N/A
B	Rock	$2,500 < \bar{v}_s \leq 5,000$	N/A	N/A
C	Very dense soil and soft rock	$1,200 < \bar{v}_s \leq 2,500$	$\bar{N} > 50$	$> 2,000$ psf
D	Stiff soil profile	$600 \leq \bar{v}_s < 1,200$	$15 \leq \bar{N} \leq 50$	1,000 to 2,000 psf
E	Stiff soil profile	$\bar{v}_s < 600$	$\bar{N} < 15$	$< 1,000$ psf
E	—	Any profile with more than 10 ft of soil having the characteristics: <ol style="list-style-type: none"> 1. Plasticity index $PI > 20$, 2. Moisture content $w \geq 40\%$, and 3. Undrained shear strength $\bar{s}_u < 500$ psf 		
F	—	Any profile containing soils having one or more of the following characteristics: <ol style="list-style-type: none"> 1. Soils vulnerable to potential failure or collapse under seismic loading such as liquefiable soils, quick and highly sensitive clays, collapsible weakly cemented soils. 2. Peats and/or highly organic clays ($H > 10$ feet of peat and/or highly organic clay where H = thickness of soil) 3. Very high plasticity clays ($H > 25$ feet with plasticity index $PI > 75$) 4. Very thick soft/medium stiff clays ($H > 120$ feet) 		

For SI: 1ft/s = 0.3048 m/s 1lb/ft² = 0.0479 kN/m²

Table 2-3. Values of F_a as a Function of Site Class and Mapped Short-Period Spectral Response Acceleration S_s

Site Class	Mapped Spectral Acceleration at Short-Period S_s				
	$S_s \leq 0.25$	$S_s = 0.50$	$S_s = 0.75$	$S_s = 1.00$	$S_s \geq 1.25$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	Site-specific geotechnical and dynamic site response analyses shall be performed				

Note: Use straight-line interpolation for intermediate values of S_s

For Site Class = E and $S_s = 0.924$ g, $F_a = 0.992$

Table 2-4. Values of F_v as a Function of Site Class and Mapped Spectral Response Acceleration at 1 s Period S_1

Site Class	Mapped Spectral Acceleration at 1 s Period S_1				
	$S_1 \leq 0.10$	$S_1 = 0.20$	$S_1 = 0.30$	$S_1 = 0.40$	$S_1 \geq 0.50$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.7	1.6	1.5	1.4	1.3
D	2.4	2.0	1.8	1.6	1.5
E	3.5	3.2	2.8	2.4	2.4
F	Site-specific geotechnical and dynamic site response analyses shall be performed				

Note: Use straight-line interpolation for intermediate values of S_1

For Site Class = E and $S_1 = 0.410$ g, $F_v = 2.400$

Provided as a reference for Equation (2-4):

$$S_{XS,BSE-2N} = F_a S_{S,BSE-2N} = 0.992 \times 0.924 \text{ g} = 0.916 \text{ g}$$

Provided as a reference for Equation (2-5):

$$S_{X1,BSE-2N} = F_v S_{1,BSE-2N} = 2.400 \times 0.410 \text{ g} = 0.985 \text{ g}$$

Equation (2-4):


$$S_{XS,BSE-1N} = \frac{2}{3} \times S_{XS,BSE-2N} = \frac{2}{3} \times 0.916 \text{ g} = 0.611 \text{ g}$$

Equation (2-5):

$$S_{X1,BSE-1N} = \frac{2}{3} \times S_{X1,BSE-2N} = \frac{2}{3} \times 0.985 \text{ g} = 0.657 \text{ g}$$


Section 2.4.1.7.1 — General Horizontal Response Spectrum

Figure 2-1. General Horizontal Response Spectrum



Section 2.4.1.7.2 — General Vertical Response Spectrum

The General Vertical Response Spectrum is determined by multiplying the General Horizontal Response Spectrum by $\frac{2}{3}$.



ACI 350 - EXISTING CONCRETE STRUCTURES
CRITERIA & PARAMETERS

CODE

$$U = 1.4(D + F) \quad (9-1)$$

$$U = 1.2(D + F + T) + 1.6(L + H) \quad (9-2)$$

$$+ 0.5(L_r \text{ or } S \text{ or } R)$$

$$U = 1.2D + 1.6(L_r \text{ or } S \text{ or } R) + (1.0L \text{ or } 0.8W) \quad (9-3)$$

$$U = 1.2D + 1.6W + 1.0L + 0.5(L_r \text{ or } S \text{ or } R) \quad (9-4)$$

$$U = 1.2D + 1.2F + 1.0E + 1.6H + 1.0L + 0.2S \quad (9-5)$$

$$U = 0.9D + 1.2F + 1.6W + 1.6H \quad (9-6)$$

$$U = 0.9D + 1.2F + 1.0E + 1.6H \quad (9-7)$$

except as follows.

(a) The load factor on L in Eq. (9-3) to (9-5) shall be permitted to be reduced to 0.5 where it can be justified that no greater than 50 percent of the design live load is expected to be present during normal operating conditions. Reduction of the load factor shall not be permitted in areas occupied as places of public assembly, and areas where the live load L is greater than 100 lb/ft²;

(b) Where wind load W has not been reduced by a directionality factor, it shall be permitted to use $1.3W$ in place of $1.6W$ in Eq. (9-4) and (9-6);

(c) Where earthquake load E is based on service-level seismic forces, $1.4E$ shall be used in place of $1.0E$ in Eq. (9-5) and (9-7);

(d) The load factor on H shall be reduced to 0.6 where H reduces the effect of D , L , or F . Earth pressure shall be permitted to be used to reduce other load effects only if investigation and analysis shows that structure movement and soil characteristics are appropriate to develop that pressure;

(e) Both the full value and the zero value of L and F shall be used in the above load combinations to determine the most severe condition.

9.2.2 — If resistance to impact effects is taken into account in design, such effects shall be included with live load L .

9.2.3 — Estimations of differential settlement, creep, shrinkage, expansion of shrinkage-compensating concrete, or temperature change shall be based on a realistic assessment of such effects occurring in service.

9.2.4 — For a structure in a flood zone, the flood load and load combinations of ASCE 7 shall be used.

9.2.5 — For post-tensioned anchorage zone design, a load factor of 1.2 shall be applied to the maximum prestressing steel jacking force.

COMMENTARY

be applied to H as noted, and the magnitude of earth pressure used should be developed conservatively by a geotechnical engineer.

Both L and F are considered to be transient loads, so designs must consider the effects for such loads being present or absent.

R9.2.2 — If the live load is applied rapidly, as may be the case for vehicle loads, cranes, etc., impact effects should be considered. In all equations, substitute ($L + \text{impact}$) for L when impact should be considered.

R9.2.3 — The designer should consider the effects of differential settlement, creep, shrinkage, temperature, and shrinkage-compensating concrete. The term realistic assessment is used to indicate that the most probable values rather than the upper bound values of the variables should be used.

R9.2.4 — Areas subject to flooding are defined by flood hazard maps, usually maintained by local governmental jurisdictions.

R9.2.5 — The load factor of 1.2 applied to the maximum tendon jacking force results in a design load of about 113 percent of the specified prestressing steel yield strength, but

CODE

9.2.6 — Required strength U for other than compression-controlled sections, as defined in 10.3.3, shall be multiplied by the following environmental durability factor (S_d) in portions of an environmental engineering concrete structure where durability, liquid-tightness, or similar serviceability are considerations. In the case of shear design, this factor is applied to the excess shear strength carried by shear reinforcement only. This durability factor shall not be used for designs using service loads and permissible service load stresses. For applicable use of the environmental durability factor (S_d) in conjunction with load combinations that include earthquake loads, see Section 21.2.1.8.

$$S_d = \frac{\phi f_y}{\gamma f_s} \geq 1.0 \quad (9-8)$$

where $\gamma = \frac{\text{factored load}}{\text{unfactored load}}$

and where f_s is the permissible tensile stress in reinforcement as given below:

9.2.6.1 — Flexural stress: See 10.6.4.

9.2.6.2 — Direct and hoop tensile stress in normal environmental exposures

$$f_s = 20,000 \text{ psi}$$

9.2.6.3 — Direct and hoop tensile stress in severe environmental exposures

$$f_s = 17,000 \text{ psi}$$

9.2.6.4 — Shear stress carried by shear reinforcement in normal environmental exposures

$$f_s = 24,000 \text{ psi}$$

9.2.6.5 — Shear stress carried by shear reinforcement in severe environmental exposures

$$f_s = 20,000 \text{ psi}$$

COMMENTARY

not more than 96 percent of the nominal ultimate strength of the prestressing steel. This compares well with the maximum attainable jacking force, which is limited by the anchor efficiency factor.

R9.2.6 — In environmental engineering concrete structures, durability and long-term service life are paramount. The resulting stresses in nonprestressed reinforcement using normal building code load factors are higher than would be desirable in environmental engineering concrete structures. The intent of the environmental durability factor is to reduce the effective stress in nonprestressed reinforcement under service load conditions, such that stress levels are considered to be in an acceptable range for control of cracking. The environmental durability factor in Eq. (9-8) will vary with individual load combinations and with applicable ϕ factors (for example, flexure versus shear). As a conservative simplification, the ϕ factor may be taken as the maximum ϕ factor (0.90) in Eq. (9-8).

The limitation of $S_d \geq 1.0$ is to ensure that the strength requirements of 318 are always met as a minimum regardless of crack control considerations. This limitation will likely control where bars of relatively low yield strength are used.

In effect, for tension-controlled sections and shear strength contributed by reinforcement, Eq. (9-8) eliminates the effects of code-prescribed load factors and ϕ factors and applies an effective load factor equal to f_y/f_s with ϕ factors set to 1.0. Thus, where the environmental durability factor is applicable in these types of sections, the following design procedure will achieve the same results:

1. Multiply the unfactored loads by a uniform load factor equal to f_y/f_s (≥ 1.0);
2. Use a value of 1.0 for applicable design ϕ factors.

The normal load factors would still be applicable to some design conditions, such as shear strength from concrete and compression-controlled members.

R9.2.6.1 — Required flexural strength $\geq S_d U$.


R9.2.6.2 and R9.2.6.3 — Required strength in direct and hoop tension $\geq S_d U$.

Some designers prefer to use a maximum steel stress equal to 14,000 psi for hoop tension. This practice is based on an earlier version of the PCA publication, "Circular Concrete Tanks without Prestressing."^{9.7}


R9.2.6.4 and R9.2.6.5 — Shear stress carried by the shear reinforcing is defined as the excess shear strength required in addition to the design shear strength provided by the concrete ϕV_c

$$\phi V_s \geq S_d (V_u - \phi V_c)$$

TOTAL LATERAL PRESSURE




STATIC BACKFILL COMPONENT




$$P_R = [\text{PRESSURE VALUE}] \times \frac{H}{2}$$

STATIC SURCHARGE COMPONENT



$$P_R = [\text{PRESSURE VALUE}] \times H$$

SEISMIC BACKFILL COMPONENT



$$P_R = [\text{PRESSURE VALUE}] \times \frac{H}{2}$$

WILSONVILLE WATER TREATMENT PLANT
WILSONVILLE, OREGON

**LATERAL PRESSURE
DISTRIBUTION AND
RESULTANT LOCATION**



SQUIER ASSOCIATES

FIGURE 6

USGS Design Maps Summary Report

User-Specified Input

Report Title Willamete River WTP
Wed September 6, 2017 20:19:38 UTC

Building Code Reference Document ASCE 7-10 Standard
(which utilizes USGS hazard data available in 2008)

Site Coordinates 45.295°N, 122.783°W

Site Soil Classification Site Class E – “Soft Clay Soil”


Risk Category I/II/III



USGS-Provided Output

$S_s = 0.924 \text{ g}$	$S_{MS} = 0.916 \text{ g}$	$S_{DS} = 0.611 \text{ g}$
$S_1 = 0.410 \text{ g}$	$S_{M1} = 0.985 \text{ g}$	$S_{D1} = 0.656 \text{ g}$

For information on how the S_s and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the “2009 NEHRP” building code reference document.



For PGA_M , T_L , C_{RS} , and C_{R1} values, please [view the detailed report](#).


Design Maps Detailed Report

ASCE 7-10 Standard (45.295°N, 122.783°W)

Site Class E – “Soft Clay Soil”, Risk Category I/II/III

Section 11.4.1 — Mapped Acceleration Parameters

Note: Ground motion values provided below are for the direction of maximum horizontal spectral response acceleration. They have been converted from corresponding geometric mean ground motions computed by the USGS by applying factors of 1.1 (to obtain S_s) and 1.3 (to obtain S_1). Maps in the 2010 ASCE-7 Standard are provided for Site Class B. Adjustments for other Site Classes are made, as needed, in Section 11.4.3.

From [Figure 22-1](#) ^[1]

$S_s = 0.924 \text{ g}$

From [Figure 22-2](#) ^[2]

$S_1 = 0.410 \text{ g}$

Section 11.4.2 — Site Class

The authority having jurisdiction (not the USGS), site-specific geotechnical data, and/or the default has classified the site as Site Class E, based on the site soil properties in accordance with Chapter 20.

Table 20.3–1 Site Classification

Site Class	\bar{v}_s	\bar{N} or \bar{N}_{ch}	\bar{s}_u
A. Hard Rock	>5,000 ft/s	N/A	N/A
B. Rock	2,500 to 5,000 ft/s	N/A	N/A
C. Very dense soil and soft rock	1,200 to 2,500 ft/s	>50	>2,000 psf
D. Stiff Soil	600 to 1,200 ft/s	15 to 50	1,000 to 2,000 psf
E. Soft clay soil	<600 ft/s	<15	<1,000 psf
Any profile with more than 10 ft of soil having the characteristics: <ul style="list-style-type: none"> • Plasticity index $PI > 20$, • Moisture content $w \geq 40\%$, and • Undrained shear strength $\bar{s}_u < 500$ psf 			
F. Soils requiring site response analysis in accordance with Section 21.1	See Section 20.3.1		

For SI: 1ft/s = 0.3048 m/s 1lb/ft² = 0.0479 kN/m²

Section 11.4.3 — Site Coefficients and Risk-Targeted Maximum Considered Earthquake (MCE_R) Spectral Response Acceleration Parameters

Table 11.4-1: Site Coefficient F_a

Site Class	Mapped MCE _R Spectral Response Acceleration Parameter at Short Period				
	$S_s \leq 0.25$	$S_s = 0.50$	$S_s = 0.75$	$S_s = 1.00$	$S_s \geq 1.25$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of S_s

For Site Class = E and $S_s = 0.924$ g, $F_a = 0.992$

Table 11.4-2: Site Coefficient F_v

Site Class	Mapped MCE _R Spectral Response Acceleration Parameter at 1-s Period				
	$S_1 \leq 0.10$	$S_1 = 0.20$	$S_1 = 0.30$	$S_1 = 0.40$	$S_1 \geq 0.50$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.7	1.6	1.5	1.4	1.3
D	2.4	2.0	1.8	1.6	1.5
E	3.5	3.2	2.8	2.4	2.4
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of S_1

For Site Class = E and $S_1 = 0.410$ g, $F_v = 2.400$

Equation (11.4-1): $S_{MS} = F_a S_s = 0.992 \times 0.924 = 0.916 \text{ g}$

Equation (11.4-2): $S_{M1} = F_v S_1 = 2.400 \times 0.410 = 0.985 \text{ g}$

Section 11.4.4 — Design Spectral Acceleration Parameters


Equation (11.4-3): $S_{DS} = \frac{2}{3} S_{MS} = \frac{2}{3} \times 0.916 = 0.611 \text{ g}$

Equation (11.4-4): $S_{D1} = \frac{2}{3} S_{M1} = \frac{2}{3} \times 0.985 = 0.656 \text{ g}$

Section 11.4.5 — Design Response Spectrum


From [Figure 22-12](#)^[3] $T_L = 16 \text{ seconds}$

Figure 11.4-1: Design Response Spectrum



Section 11.4.6 — Risk-Targeted Maximum Considered Earthquake (MCE_R) Response Spectrum

The MCE_R Response Spectrum is determined by multiplying the design response spectrum above by 1.5.



Section 11.8.3 — Additional Geotechnical Investigation Report Requirements for Seismic Design Categories D through F

From [Figure 22-7](#) ^[4]

$$PGA = 0.406$$

Equation (11.8-1):

$$PGA_M = F_{PGA}PGA = 0.900 \times 0.406 = 0.366 \text{ g}$$

Table 11.8-1: Site Coefficient F_{PGA}

Site Class	Mapped MCE Geometric Mean Peak Ground Acceleration, PGA				
	PGA ≤ 0.10	PGA = 0.20	PGA = 0.30	PGA = 0.40	PGA ≥ 0.50
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of PGA

For Site Class = E and PGA = 0.406 g, $F_{PGA} = 0.900$

Section 21.2.1.1 — Method 1 (from Chapter 21 – Site-Specific Ground Motion Procedures for Seismic Design)

From [Figure 22-17](#) ^[5]

$$C_{RS} = 0.898$$

From [Figure 22-18](#) ^[6]

$$C_{R1} = 0.871$$

Section 11.6 — Seismic Design Category

Table 11.6-1 Seismic Design Category Based on Short Period Response Acceleration Parameter

VALUE OF S_{DS}	RISK CATEGORY		
	I or II	III	IV
$S_{DS} < 0.167g$	A	A	A
$0.167g \leq S_{DS} < 0.33g$	B	B	C
$0.33g \leq S_{DS} < 0.50g$	C	C	D
$0.50g \leq S_{DS}$	D	D	D

For Risk Category = I and $S_{DS} = 0.611 g$, Seismic Design Category = D

Table 11.6-2 Seismic Design Category Based on 1-S Period Response Acceleration Parameter

VALUE OF S_{D1}	RISK CATEGORY		
	I or II	III	IV
$S_{D1} < 0.067g$	A	A	A
$0.067g \leq S_{D1} < 0.133g$	B	B	C
$0.133g \leq S_{D1} < 0.20g$	C	C	D
$0.20g \leq S_{D1}$	D	D	D

For Risk Category = I and $S_{D1} = 0.656 g$, Seismic Design Category = D

Note: When S_1 is greater than or equal to 0.75g, the Seismic Design Category is **E** for buildings in Risk Categories I, II, and III, and **F** for those in Risk Category IV, irrespective of the above.

Seismic Design Category \equiv "the more severe design category in accordance with Table 11.6-1 or 11.6-2" = D

Note: See Section 11.6 for alternative approaches to calculating Seismic Design Category.

References

1. *Figure 22-1:*
https://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-1.pdf
2. *Figure 22-2:*
https://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-2.pdf
3. *Figure 22-12:*
https://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-12.pdf
4. *Figure 22-7:*
https://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-7.pdf
5. *Figure 22-17:*
https://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-17.pdf
6. *Figure 22-18:*
https://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-18.pdf

Area 4 - ActiFlo Building
ASCE 41 Evaluation



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Seismic

SEISMIC HAZARD LEVEL & BASIC PERFORMANCE OBJECTIVE

Note: **4.1.2 Seismic Hazard Level** The Seismic Hazard Level for the Tier 1 screening shall be BSE-1E per Table 2-1 for the Basic Performance Objective for Existing Buildings (BPOE).

Table 2-1. Basic Performance Objective for Existing Buildings (BPOE)

Risk Category	Tier 1*	Tier 2*	Tier 3	
	BSE-1E	BSE-1E	BSE-1E	BSE-2E
I & II	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Collapse Prevention Structural Performance Nonstructural Performance Not Considered (5-D)
III	See footnote b for Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Limited Safety Structural Performance Nonstructural Performance Not Considered (4-D)
IV	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Life Safety Structural Performance Nonstructural Performance Not Considered (3-D)

*For Tier 1 and 2 assessments, seismic performance for the BSE-2E is not explicitly evaluated.
 *For Risk Category III, the Tier 1 screening checklists shall be based on the Life Safety Performance Level (S-3), except that checklist statements using the Quick Check procedures of Section 4.5.5 shall be based on MS-factors and other limits that are an average of the values for Life Safety and Immediate Occupancy.

BUILDING PERIOD (SECTION 4.5.2.4)

building height, h_n = 11.00 ft
 building period adjustment factor, C_t = 0.020
 effective viscous damping ratio, β = 0.75
 fundamental building period, T = 0.121 sec

SEISMIC PARAMETERS

Building Type = RM1 Table 3-1
 modification factor, C = 1.00 Table 4-8

Table 4-8. Modification Factor, C

Building Type*	Number of Stories			
	1	2	3	≥4
Wood (W1, W1a, W2)	1.3	1.1	1.0	1.0
Moment frame (S1, S3, C1, PC2a)	1.3	1.1	1.0	1.0
Shear wall (S4, S5, C2, C3, PC1a, PC2, RM2, URMa)	1.4	1.2	1.1	1.0
Braced frame (S2)	1.3	1.1	1.0	1.0
Unreinforced masonry (URM)	1.0	1.0	1.0	1.0
Flexible diaphragms (S1a, S2a, S5a, C2a, C3a, PC1, RMI)	1.0	1.0	1.0	1.0

*Defined in Table 3-1.

spectral acceleration at 1-sec for BSE-1E, S_{x1} = 0.372 g USGS Seismic Map
 spectral acceleration at short period for BSE-1E, S_{xs} = 0.611 g USGS Seismic Map
 spectral acceleration, S_a = 0.611 g $S_a = \frac{S_{x1}}{T}$ but S_a shall not exceed S_{xs} .
 base shear coefficient, V = 0.611 W Eq 4-1

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Building Weight & Base Shear

DEAD LOAD (Seismic Weight)

Roof Weight

Roofing	=	5.00	psf
Metal Roof Deck	=	3.00	psf
Steel Joist	=	7.00	psf
Miscellaneous (MEP)	=	5.00	psf
Total =			20.00 psf

Roof Length	=	19.33	ft
Roof Width	=	18.67	ft

Total Roof Weight = 7.22 kips

	UW (in)	Trib Ht (ft)	Length (ft)		
Parapet Wall	84.00	1.00	58.66	=	4.93 kips
Wall Below	84.00	5.50	58.66	=	27.10 kips

Roof Seismic Weight = 39.25 kips

Seismic Weight & Base Shear

Base Shear Coefficient	=	0.611	g
Total Seismic Weight	=	39	kips
Design Base Shear	=	24	kips

LIVE LOAD

Roof Live Load	=	20.0	psf
----------------	---	------	-----

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Shear Stress

SEISMIC LOAD VERTICAL DISTRIBUTION

Wall Shear Stress Check

4.5.3.3 Shear Stress in Shear Walls The average shear stress in shear walls, v_j^{avg} , shall be calculated in accordance with Eq. (4-9).

$$v_j^{avg} = \frac{1}{M_s} \left(\frac{V_j}{A_w} \right) \quad (4-9)$$

where V_j = Story shear at level j computed in accordance with Section 4.5.2.2.

A_w = Summation of the horizontal cross-sectional area of all shear walls in the direction of loading. Openings shall be taken into consideration when computing A_w . For masonry walls, the net area shall be used. For wood-framed walls, the length shall be used rather than the area.

M_s = System modification factor; M_s shall be taken from Table 4-9.

$V_{s,allow} = 70$ psi
 $M_s = 3.0$ <-- Damage Control (between "LS" & "IO")

	t_{wall} (in)	$L_{net, wall}$ (ft)	A_{wall} (in ²)	V (kips)	V_{shear} (psi)	
Walls in NS-Dir	7.63	40.00	3660	24.00	2.19	<= OK
Walls in EW-Dir	7.63	31.99	2927	24.00	2.73	<= OK


Table 4-9. M_s Factors for Shear Walls

Wall Type	Level of Performance	
	LS	IO
Reinforced concrete, precast concrete, wood, and reinforced masonry	4.0	2.0
Unreinforced masonry	1.5	1.0

Table 4-10. M_s Factors for Diagonal Braces

Brace Type	d/t^*	Level of Performance	
		LS	IO
Tube ^b	$< 90/(F_y)^{1/2}$	6.0	2.5
	$> 190/(F_y)^{1/2}$	3.0	1.5
Pipe ^b	$< 1500/F_{ye}$	6.0	2.5
	$> 6000/F_{ye}$	3.0	1.5
Tension-only		3.0	1.5
All others		6.0	2.5

*Depth-to-thickness ratio.
^bInterpolation to be used for tubes and pipes.
 $F_{ye} = 1.25F_y$; expected yield stress.



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Transverse Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1
 seismic modification factors, $C_1 C_2 = 1.40$ per Table 7-3
 effective mass factor, $C_m = 1.00$ per Table 7-4
 diaphragm shear, m_1 -factor = 1.625 per Table 9-4 (between "IO" & "LS")
 diaphragm chord, m_2 -factor = 3.625 per Table 9-4 (between "IO" & "LS")
 force-delivery reduction factor, $J = 2.00$ per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} = 18.67$ ft
 diaphragm depth, $L_{diaph} = 19.33$ ft
 spectral acceleration, $S_a = 0.611$ g
 building seismic weight, $W = 39$ kips
 pseudo seismic force, $V = F_d = C_1 C_2 C_m S_a W = 33$ kips
 diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) = 863$ plf
 allowable diaphragm shear = 1069 plf per IAPMO-ER #0217
 conversion factor for strength design, $C_{buckling} = 1.60$ per IAPMO-ER #0217
 diaph shear capacity, $Q_{CE} = 1710$ plf
 $m_1 * K * Q_{CE} = 2779$ plf


Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) = 4028$ lbs
 strength reduction factor, $\phi = 1.00$
 Number of Bars = 4 bars
 Bar Size = $\#4$
 Yield Stress $f_y = 60,000$ psi
 $A_{s,total} = 0.80$ in²
 Tensile Capacity at Opng, $\phi T_n = 48000$ lbs
 $m_2 * K * Q_{CE} = 174000$ lbs

Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, $d_b = 0.750$ in
 anchorage spacing, $s = 24.00$ in
 anchor bolt effective embed, $l_b = 3.50$ in





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Transverse Direction

anchor bolt yield stress, $f_y = 36.00$ ksi
 masonry compressive strength, $f_m = 1500$ psi

anchor bolt shear, $Q_E = V_{bolt} = (V / 2L_{diaph}) * (s/12) = 1726$ lbs /bolt
 $Q_{UF} = Q_E / (J * C_1 * C_2) = 616$ lbs /bolt

projected area of anchor bolt shear, $A_{pv} = 38.48$ in² lbs /bolt
 projected area of anchor bolt tension, $A_{pt} = 76.97$ in² lbs /bolt
 cross section area of anchor bolt, $A_b = 0.44$ in² lbs /bolt

strength reduction factor, $\phi = 1.00$

$KQ_{CL} = K\phi B_{vnb} = K * \phi * 4 * A_{pv} * (f'_m)^{0.5} = 5962$ lbs /bolt masonry breakout
 $KQ_{CL} = K\phi B_{vnpri} = K * \phi * 1050 * (f'_m * A_b)^{1/4} = 5327$ lbs /bolt masonry crushing
 $KQ_{CL} = K\phi B_{vnpry} = K * \phi * 8 * A_{pt} * (f'_m)^{0.5} = 23848$ lbs /bolt anchor bolt pryout
 $KQ_{CL} = K\phi B_{vns} = K * \phi * 0.6 * A_b * f_y = 15904$ lbs /bolt steel yielding

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

effective puddle weld diameter = 0.500 in
 puddle weld spacing = 12.00 in

puddle weld shear, $Q_E = V_{bolt} = (V / 2L_{diaph}) * (s/12) = 863$ lbs /weld
 $Q_{UF} = Q_E / (J * C_1 * C_2) = 308$ lbs /weld

allowable strength of weld = 1257 lbs /weld
 conversion factor for strength design, $C_{WELD} = 1.65$ per IAPMO-ER #0217
 $KQ_{CL} = 2074$ lbs /weld

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

demand capacity ratio, DCR = 0.31 <-- **OK** diaphragm shear
demand capacity ratio, DCR = 0.02 <-- **OK** diaphragm chord
demand capacity ratio, DCR = 0.10 <-- **OK** masonry breakout
demand capacity ratio, DCR = 0.12 <-- **OK** masonry crushing
demand capacity ratio, DCR = 0.03 <-- **OK** anchor bolt pryout
demand capacity ratio, DCR = 0.04 <-- **OK** steel yielding
demand capacity ratio, DCR = 0.15 <-- **OK** puddle weld strength

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Longitudinal Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1
 seismic modification factors, $C_1 C_2 = 1.40$ per Table 7-3
 effective mass factor, $C_m = 1.00$ per Table 7-4
 diaphragm shear, m_1 -factor = 1.625 per Table 9-4 (between "IO" & "LS")
 diaphragm chord, m_2 -factor = 3.625 per Table 9-4 (between "IO" & "LS")
 force-delivery reduction factor, $J = 2.00$ per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} = 19.33$ ft
 diaphragm depth, $L_{diaph} = 18.67$ ft
 spectral acceleration, $S_a = 0.611$ g
 building seismic weight, $W = 39$ kips
 pseudo seismic force, $V = F_d = C_1 C_2 C_m S_a W = 33$ kips
 diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) = 893$ plf
 allowable diaphragm shear = 1069 plf per IAPMO-ER #0217
 conversion factor for strength design, $C_{buckling} = 1.60$ per IAPMO-ER #0217
 diaph shear capacity, $Q_{CE} = 1710$ plf
 $m_1 * K * Q_{CE} = 2779$ plf


Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) = 4317$ lbs
 strength reduction factor, $\phi = 1.00$
 Number of Bars = 4 bars
 Bar Size = $\#4$
 Yield Stress $f_y = 60,000$ psi
 $A_{s,total} = 0.80$ in²
 Tensile Capacity at Opng, $\phi T_n = 48000$ lbs
 $m_2 * K * Q_{CE} = 174000$ lbs

Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, $d_b = 0.750$ in
 anchorage spacing, $s = 24.00$ in
 anchor bolt effective embed, $l_b = 3.50$ in



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Longitudinal Direction

anchor bolt yield stress, $f_y = 36.00$ ksi
 masonry compressive strength, $f_m = 1500$ psi

anchor bolt shear, $Q_E = V_{\text{bolt}} = (V / 2L_{\text{diaph}}) * (s/12) = 1787$ lbs /bolt
 $Q_{UF} = Q_E / (J * C_1 * C_2) = 638$ lbs /bolt

projected area of anchor bolt shear, $A_{pv} = 38.48$ in² lbs /bolt
 projected area of anchor bolt tension, $A_{pt} = 76.97$ in² lbs /bolt
 cross section area of anchor bolt, $A_b = 0.44$ in² lbs /bolt

strength reduction factor, $\phi = 1.00$

$KQ_{CL} = K\phi B_{vnb} = K*\phi*4*A_{pv}*(f'_m)^{0.5} = 5962$ lbs /bolt **OK** masonry breakout
 $KQ_{CL} = K\phi B_{vnpny} = K*\phi*1050*(f'_m*A_b)^{1/4} = 5327$ lbs /bolt **OK** masonry crushing
 $KQ_{CL} = K\phi B_{vnpry} = K*\phi*8*A_{pt}*(f'_m)^{0.5} = 23848$ lbs /bolt **OK** anchor bolt pryout
 $KQ_{CL} = K\phi B_{vns} = K*\phi*0.6*A_b*f_y = 15904$ lbs /bolt **OK** steel yielding

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

effective puddle weld diameter = 0.500 in
 puddle weld spacing = 12.00 in

puddle weld shear, $Q_E = V_{\text{bolt}} = (V / 2L_{\text{diaph}}) * (s/12) = 893$ lbs /weld
 $Q_{UF} = Q_E / (J * C_1 * C_2) = 319$ lbs /weld

allowable strength of weld = 1257 lbs /weld
 conversion factor for strength design, $C_{WELD} = 1.65$ per IAPMO-ER #0217
 $KQ_{CL} = 2074$ lbs /weld

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

demand capacity ratio, DCR = 0.32 <-- **OK** diaphragm shear
demand capacity ratio, DCR = 0.02 <-- **OK** diaphragm chord
demand capacity ratio, DCR = 0.11 <-- **OK** masonry breakout
demand capacity ratio, DCR = 0.12 <-- **OK** masonry crushing
demand capacity ratio, DCR = 0.03 <-- **OK** anchor bolt pryout
demand capacity ratio, DCR = 0.04 <-- **OK** steel yielding
demand capacity ratio, DCR = 0.15 <-- **OK** puddle weld strength

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Joist Supports

WALL ANCHORAGE FORCE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$


Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall height to diaphragm, h_w = 11.00 ft
- parapet height, h_p = 1.00 ft
- unit weight of wall, w_p = 84.00 psf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- beam spacing = 6.22 ft
- wall out-of-plane load = 500 lbs/ ft
- wall anchorage force, T_c = 3114 lbs

<-- Damage Control (between "LS" & "IO")

Masonry & Steel Strength

- number of anchor bolts = 2
- anchor bolt size = 0.625 in
- anchor bolt embed = 6.00 in
- anchor bolt edge distance = 3.81 in
- anchorage spacing = 6.00 in
- anchor bolt yield stress, f_y = 36.00 ksi
- masonry compressive strength, f_m = 1500 psi
- projected area of anchor bolt shear, A_{pv} = 46 in²
- projected area of anchor bolt tension, A_{pt} = 137 in²
- cross section area of anchor bolt, A_b = 0.31 in²



- $\phi B_{vnb} = 1.0 \cdot 4 \cdot A_{pv} \cdot (f_m)^{0.5} = 7,074$ lbs
- $\phi B_{vnpry} = 1.0 \cdot 1050 \cdot (f_m \cdot A_b)^{1/4} = 9,726$ lbs
- $\phi B_{vnpry} = 1.0 \cdot 8 \cdot A_{pt} \cdot (f_m)^{0.5} = 42,525$ lbs
- $\phi B_{vns} = 1.0 \cdot 0.6 \cdot A_b \cdot f_y = 13,254$ lbs

- masonry breakout
- masonry crushing
- anchor bolt pryout
- steel yielding

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

- demand capacity ratio, DCR = 0.44 <-- **OK** masonry breakout
- demand capacity ratio, DCR = 0.32 <-- **OK** masonry crushing
- demand capacity ratio, DCR = 0.07 <-- **OK** anchor bolt pryout
- demand capacity ratio, DCR = 0.23 <-- **OK** steel yielding

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

WALL ANCHORAGE FORCE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$


Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall height to diaphragm, h_w = 11.00 ft
- parapet height, h_p = 1.00 ft
- unit weight of wall, w_p = 84.00 psf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- anchor bolts spacing = 24.00 in
- wall out-of-plane load = 500 lbs/ ft
- wall anchorage force, T_c = 1001 lbs /bolt

<-- Damage Control (between "LS" & "IO")

Masonry & Steel Strength

- anchor bolt size = 0.750 in
- anchor bolt embed = 3.50 in
- anchor bolt edge distance = 3.81 in
- anchorage spacing = 6.00 in
- anchor bolt yield stress, f_y = 36.00 ksi
- masonry compressive strength, f_m = 1500 psi
- projected area of anchor bolt tension, A_{pt} = 38 in²
- cross section area of anchor bolt, A_b = 0.44 in²



$$\phi B_{vnp} = 1.0 \cdot 4 \cdot A_{pt} \cdot (f'_m)^{0.5} = 5,962 \text{ lbs}$$

$$\phi B_{vns} = 1.0 \cdot A_b \cdot f_y = 15,904 \text{ lbs}$$

anchor bolt pryout
 steel yielding

Ledger Angle

- yield strength, f_y = 36,000 psi
- ledger angle thick, t = 0.31 in
- moment arm, I_{arm} = 1.19 in
- effective width, b = 3.00 in
- section modulus, S = 0.0488 in³

distance from top of ledger to center of AB

shear stress = 1,068 psi

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

moment = 1,191 lb-in
 flexural stress = 24,391 psi

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.17	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.06	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.03	<--	<u>OK</u>	ledger shear
<u>demand capacity ratio, DCR =</u>	0.68	<--	<u>OK</u>	ledger flexural

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck


STEEL DECK PROPERTIES (ASTM A653, Grade 33)

Modulus of Elasticity, E = 29500 ksi

Yield Strength, F_y = 38 ksi

Ultimate Strength, F_u = 52 ksi

PLB™-36
HSB®-36



Steel Deck = HSB-36

Gage = 20

Deck Span, L = 5.67 ft

Gage	Weight		Section Properties per ft (m) of width		
	Galv psf N/m ²	Painted psf N/m ²	I in. ⁴ mm ⁴	+ S in. ³ mm ³	- S in. ³ mm ³
22	1.9	1.8	0.175	0.187	0.198
	91.0	86.2	238,978	10,054	10,645
20	2.3	2.2	0.216	0.235	0.248
	110.1	105.3	294,967	12,634	13,333
18	2.9	2.8	0.302	0.322	0.335
	138.9	134.1	412,408	17,312	18,011
16	3.5	3.4	0.377	0.411	0.417
	167.6	162.8	514,827	22,097	22,419

DESIGN LOAD (Service Level)

Roof Load, w = 30 psf --- steel deck gravity

Wall Out-of-Plane Load, F = 500 lb/ft --- deck axial load

Design Flexural Moment :

Neutral Axis, y_b = 0.919 in

M_{roof} = 1.447 kip-in /ft --- moment due to gravity load = w * L² / 8

M_{ecc} = 0.328 kip-in /ft --- moment due to wall out-of-plane = (F/1.4) * y_b

M_{total} = 1.775 kip-in /ft

ARC-SPOT WELD (WALL OUT-OF-PLANE)

Effective Weld Size Dia, d_e = 1/2 in

Weld Pattern = 5 per 36/sheet

Allowable Weld Capacity = 2.10 kip/ft <= OK

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

Allowable shear strength for 1/2" effective diameter puddle welds.



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE COMPRESSION

Effective Length Factor, $K = 1.00$
 Deck Thickness, $t = 0.0359$ in
 Width of Top Flange, $w = 3.50$ in
 Gross Section Area, $A_g = 0.599$ in²/ft
 radius of gyration, $r = 0.601$ in
 $KL/r = 113$
 $\lambda_c = 1.29$
 $F_n = 18.85$ ksi

Effective Width of Top & Bottom Flange Under Compression
(Assume Bottom Flange Fully Effective)

$\Omega_c = 1.8$ --- factor of safety
 $k = 4$ k = Plate buckling coefficient
 = 4 for stiffened elements supported by a web on each longitudinal edge.
 Values for different types of elements are given in the applicable sections.
 Poisson's Ratio = 0.300
 $F_{cr} = 11.22$
 $\lambda = 1.296$
 $\rho = 0.641$
 Effective Flange Width, $b = 2.242$ in --- effective flange width = ρw
 Effective Section Area, $A_e = 0.554$ in²/ft --- effective section area
 $P_n / \Omega_c = 5.80$ kip /ft **<= OK** --- $A_e * F_n / \Omega_c$

STEEL DECK ALLOWABLE TENSION

Gross Section Area, $A_g = 0.599$ in²/ft
 $\Omega_{T1} = 1.67$
 $T_{n1} / \Omega_{T1} = 13.63$ kip /ft **<= OK** --- $A_g * F_y / \Omega_{T1}$
 $\Omega_{T2} = 2.00$
 $T_{n2} / \Omega_{T2} = 15.57$ kip /ft **<= OK** --- $A_g * F_u / \Omega_{T2}$

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET
 CHKD BY DESCRIPTION Area 4 - ActiFlo JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE BENDING

$$\Omega_b = 1.67$$

$$S_+ = 0.235 \text{ in}^3/\text{ft} \quad \text{--- positive section modulus}$$

$$\frac{M_n}{\Omega_b} = 5.35 \text{ kip-in /ft} \quad \leq \text{OK} \quad \text{--- } S_+ * F_y / \Omega_b$$

COMBINED LOAD INTERACTION

Bending-Tension Interaction:


$$\text{DCR} = 0.369 \quad \leq \text{OK}$$

Bending-Compression Interaction:

$$\text{DCR} = 0.418 \quad \leq \text{OK}$$

Area 4 - ActiFlo Concrete Structure
ACI 350 Evaluation

WALL IDENTIFICATION



<p>REVISIONS</p> <table border="1"> <tr> <th>NO.</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> <tr> <td>1</td> <td></td> <td>RECORD DRAWING</td> </tr> </table>	NO.	DATE	DESCRIPTION	1		RECORD DRAWING	<p>SCALE: 3/8"=1'-0"</p> <p>WARNING: IF THIS SPACE DOES NOT SCALE, THEN DRAWING IS NOT TO SCALE.</p>	<p>DESIGNED BY: B. CROOK</p> <p>DRAWN BY: B. CROOK</p> <p>CHECKED BY:</p>	<p>SENT BY:</p> <p>DATE:</p> <p>DATE:</p>	<p>FOUNDATION PLAN</p>	<p>PORTLAND OREGON</p> <p>MWH</p> <p>MONTGOMERY WATSON HARZA</p>	<p>City of WILSONVILLE</p> <p>in OREGON</p>	<p>WILLETTE RINE ACTIVE FOUNDATIONAL STRUTURAL</p> <p>CITY OF WILSONVILLE</p> <p>FOUNDATION PLAN</p>	<p>SHEET 4S-01</p>
NO.	DATE	DESCRIPTION												
1		RECORD DRAWING												

RECORD DRAWING

This record drawing has been prepared, entirely or in part, by a registered professional engineer or architect. It is not to be used for any other project or for any other purpose without the written consent of the engineer or architect. It is not to be incorporated into any other drawing without the written consent of the engineer or architect.

NOTES:

- 3'-6" WALL EXTENSION STARTS AT EL. 142.00 AND CONTINUES TO EL. 154.00. FOR REF. AND SEE SEC C/4S-5 AND SEC D/4S-6.

SEE AREA 5: DRAWINGS

EXP. JET - SEE S-109 (SUM)

REV	DATE BY	RECORD DRAWING DESCRIPTION	SCALE	WARNING	DESIGNED BY	CHECKED BY	SUBMITTED BY	LICENSE NO.	DATE
1			3/8"=1'-0"	IF THIS DATE DOES NOT TO SCALE	B. CROOK	B. CROOK			




Portland Oregon

City of **WILSONVILLE** in OREGON



WILMETTE REGIONAL WATER TREATMENT PLANT
ACFEF1010001
STRUCTURAL SECTION

SHEET 4S-03



SECTION A
4S-01
4S-02

NOTE:
CORNER FILLETS
USE #5012 WITH WIRE
FABRIC NEAR SURFACE

RECORD DRAWING
This record drawing has been prepared for the City of Wilsonville and is the property of the City of Wilsonville. It is not to be used for any other purpose without the written consent of the City of Wilsonville. The engineer and architect accept no responsibility for any errors or omissions which may have been incorporated into the document.

REV	DATE BY	DESCRIPTION
R	10/20/08	RECORD DRAWING

SCALE
3/8"=1'-0"

WARNING
IF THIS DRAWING DOES NOT SCALE THEN THIS DRAWING IS NOT TO SCALE

DESIGNED BY: B. CROOK
CHECKED BY: B. CROOK

SUBMITTED BY:

LICENSE NO.:
DATE:



Portland Oregon




WILSONVILLE
CITY OF WILSONVILLE
WATER TREATMENT PLANT
STRUCTURAL SECTION

SHEET
4S-05

SECTION	C
	4S-01
	4S-02


RECORD DRAWING
This record drawing is prepared in accordance with the provisions of the Oregon Building Code, and is intended to be used for the purpose of providing information to the contractor and other interested parties. It is not intended to be used for any other purpose, and any use for other purposes is at the user's risk. The user is responsible for verifying the accuracy of the information contained herein, and for incorporating any changes which may have been incorporated into the document as a result of the construction process.



BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = **1** ft
 tank inside length in direction of seismic, L = **19** ft
 tank wall thickness, t_w = **16** inch
 wall height to underside of roof, H_w = **20.67** ft
 liquid height, H_L = **19** ft
 liquid specific gravity = **1**
 liquid density, γ_L = (sp.gr.) * γ_w = **0.0624** k/ft³
 acceleration due to gravity, g = **32.17** ft/sec²
 liquid mass density, ρ_L = γ_L / g = **0.00194** k-sec²/ft⁴



WALL SECTION
(wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = **15.5** ft
 groundwater ht. above foundation base = **0** ft
 dry soil lateral pressure = **0.055** k/ft³
 saturated soil lateral pressure = **0** k/ft³
 dry soil unit weight = **0.11** k/ft³
 live load lateral surcharge = **0.100** ksf
 0
 concrete strength, f' _c = **4** ksi
 concrete density, γ_c = **0.150** k/ft³
 concrete modulus of elasticity, E_c = **3605.0** ksi
 concrete mass density, ρ_c = γ_c / g = **0.004663** k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = **0.611** *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = **0.656** *g

Structure Risk Category = **3**
 Importance factor, I = **1.25**
 Response modification factor, R_{wi} = **2.29**
 Response modification factor, R_{wc} = **1.39**



WALL PLAN

Load Cases:

- case 1 = water
- case 2 = water + water seismic + wall seismic
- case 3 = soil + lateral surcharge
- case 4 = soil + soil seismic + wall seismic

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures

Weights:

$$\begin{aligned}
 \text{unit 1-ft width wall mass, } W_w &= (16/12) * (20.67) * 0.15 = 4.13 \text{ kip} \\
 \text{wall c.g. relative to base, } h_w &= 20.67 / 2 = 10.335 \text{ ft}
 \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (19) * (1) * (19) * 32.17 = 22.53 \text{ kip}$$

Seismic:1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.12850 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.28267 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 8.537 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = Ec * (tw * Hw/h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 1600.23 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (1600.23 / (0.1285 + 0.2827))^{1/2} = 62.3846 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 62.3846 = 0.1007 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (1)))^{1/2} = 10.0644$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 10.0644 / (19)^{1/2} = 2.3089 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 2.3089 = 2.7213 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * S_d1 / T_c = 0.362 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.8453$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures



L = 19 ft
 B = 1 ft
 H_L = 19 ft
 W_L = 22.53 kip

L / H_L = 1.00000
 H_L / L = 1.00000

3). lateral fluid impulsive force: Dynamic Model

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 22.53 * (\tanh(0.866 * (1)) / 0.866 * (1)) = 18.19 \text{ kip}$$

W_i = equivalent mass of the impulsive component of liquid.

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 19 * (0.5 - 0.09375 * (1)) = 7.719 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * \left\{ \frac{(0.866 * L/H_L)}{2 * \tanh(0.866 * L/H_L)} - 1/8 \right\} = 9.389 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.29) * 18.19 = 6.1 \text{ kip}$$

4). lateral fluid convective force:

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh\left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 22.53 * (0.264 * (1) * \tanh(3.16 * (1))) = 5.93 \text{ kip}$$

W_c = equivalent mass of the convective component of liquid.

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L} \right) \right) - 1}{3.16 \left(\frac{H_L}{L} \right) \sinh\left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 13.477 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L} \right) \right) - 2.01}{3.16 \left(\frac{H_L}{L} \right) \sinh\left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 13.993 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.3616 * 1.25 / 1.39) * 5.93 = 1.9 \text{ kip}$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 4.13$ kip
 wall c.g. relative to base, $h_w = 10.335$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \epsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.8453 / 2.29) * 4.13 = 1.16 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (19 / 2) * (0.3616 / 1.4 * 1.25) = 3.07 \text{ ft}$$

Wave height is greater than the freeboard of 1.67-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_t = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 6.10$ kip
 $h_i = 7.719$ ft
 at $y = H_L$, $p_{iy} = 0.070$ ksf
 at base $y = 0$, $p_{iy} = 0.251$ ksf

convective:

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 1.90$ kip
 $h_c = 13.477$ ft
 at $y = H_L$, $p_{cy} = 0.113$ ksf
 at base $y = 0$, $p_{cy} = -0.013$ ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.290$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2819 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.056$ ksf
 at base $y = 0$, $p_{wy} = 0.056$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.186$ ksf

combine the effects of the dynamic pressures on the wall:


$$p_y = \sqrt{(p_{vy} + p_{wy})^2 + p_{cy}^2 + p_{vy}^2} =$$

at $y = H_w$, $p_y = 0.170$ ksf
 at base $y = 0$, $p_y = 0.422$ ksf



9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.67$ ft
 liquid height, $H_L = 19$ ft



BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 20.67 ft
 soil height above top of base = 15.5 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.8525 ksf
 unfactored soil, q3 = 0.0000 ksf



equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.8525 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **4.08** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **10.33** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0003 ksf
 equivalent soil seismic, q9 = 0.5261 ksf
 wall seismic (see wall page 5), q10 = 0.0564 ksf
 equivalent soil seismic, q11 = q9 = 0.5261 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.5258 ksf

unfactored equivalent soil seismic, q8 = 0.0003 / 1.4 = 0.0002 ksf
 unfactored equivalent soil seismic, q9 = 0.5261 / 1.4 = 0.3758 ksf
 unfactored wall seismic, q10 = 0.0564 / 1.4 = 0.0403 ksf
 unfactored equivalent soil seismic, q11 = 0.5261 / 1.4 = 0.3758 ksf
 unfactored equivalent soil seismic, q12 = -0.5258 / 1.4 = -0.3756 ksf


BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 1&3 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.67 ft
 water depth = 19 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.67 ft
 water depth = 19 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.67 ft
 soil height on wall = 15.5 ft

equivalent static soil & surcharge loadings...

LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.853 ksf
 unfactored soil, q3 = 0.000 ksf




equivalent soil loadings:

unfactored q5 = 0.100 ksf
 unfactored q6 = 0.853 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)

equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.67 ft
 soil height on wall = 15.5 ft




unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.376 ksf
 unfactored equivalent soil seismic, q10 = 0.040 ksf
 unfactored equivalent soil seismic, q11 = 0.376 ksf
 unfactored equivalent soil seismic, q12 = -0.376 ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = **1** ft
 tank inside length in direction of seismic, L = **9** ft
 tank wall thickness, t_w = **12** inch
 wall height to underside of roof, H_w = **20.67** ft
 liquid height, H_L = **19** ft
 liquid specific gravity = **1**
 liquid density, γ_L = (sp.gr.) * γ_w = **0.0624** k/ft³
 acceleration due to gravity, g = **32.17** ft/sec²
 liquid mass density, ρ_L = γ_L / g = **0.00194** k-sec²/ft⁴



WALL SECTION
 (wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = **0** ft
 groundwater ht. above foundation base = **0** ft
 dry soil lateral pressure = **0.055** k/ft³
 saturated soil lateral pressure = **0** k/ft³
 dry soil unit weight = **0.11** k/ft³
 live load lateral surcharge = **0.100** ksf
 0
 concrete strength, f' _c = **4** ksi
 concrete density, γ_c = **0.150** k/ft³
 concrete modulus of elasticity, E_c = **3605.0** ksi
 concrete mass density, ρ_c = γ_c / g = **0.004663** k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = **0.611** *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = **0.656** *g

Structure Risk Category = **3**
 Importance factor, I = **1.25**
 Response modification factor, R_{wi} = **2.44**
 Response modification factor, R_{wc} = **1.23**



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

Weights:

$$\begin{aligned}
 \text{unit 1-ft width wall mass, } W_w &= (12/12) * (20.67) * 0.15 = 3.10 \text{ kip} \\
 \text{wall c.g. relative to base, } h_w &= 20.67 / 2 = 10.335 \text{ ft}
 \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (9) * (1) * (19) * 32.17 = 10.67 \text{ kip}$$

Seismic:1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.09638 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.15714 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 9.294 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = E_c * (t_w * H_w / h)^3 / (12 * (4 * H_w - h) * (H_w - h)^2) = 601.30 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (601.3 / (0.0964 + 0.1571))^{1/2} = 48.7012 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 48.7012 = 0.1290 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (2.1111)))^{1/2} = 10.0825$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 10.0825 / (9)^{1/2} = 3.3608 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 3.3608 = 1.8695 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * S_d1 / T_c = 0.526 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.9340$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures



L = 9 ft
 B = 1 ft
 H_L = 19 ft
 W_L = 10.67 kip

L / H_L = 0.47368
 H_L / L = 2.11111

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 10.67 * (\tanh(0.866 * 0.4737)) / 0.866 * (0.4737) = 10.11 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 19 * (0.5 - 0.09375 * (0.4737)) = 8.656 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * 0.45 = 8.55 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.44) * 10.11 = 3.2 \text{ kip}$$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 10.67 * (0.264 * (0.4737) * \tanh(3.16 * (2.1111))) = 1.33 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 16.159 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 16.166 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.5263 * 1.25 / 1.23) * 1.33 = 0.7 \text{ kip}$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.10$ kip
 wall c.g. relative to base, $h_w = 10.335$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \epsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.934 / 2.44) * 3.1 = 0.91 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (9 / 2) * (0.5263 / 1.4 * 1.25) = 2.11 \text{ ft}$$

Wave height is greater than the freeboard of 1.67-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_t = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 3.20$ kip
 $h_i = 8.656$ ft
 at $y = H_L$, $p_{iy} = 0.062$ ksf
 at base $y = 0$, $p_{iy} = 0.107$ ksf

convective:

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 0.70$ kip
 $h_c = 16.159$ ft
 at $y = H_L$, $p_{cy} = 0.057$ ksf
 at base $y = 0$, $p_{cy} = -0.020$ ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.290$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2924 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.044$ ksf
 at base $y = 0$, $p_{wy} = 0.044$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.186$ ksf

combine the effects of the dynamic pressures on the wall:




$$p_y = \sqrt{(p_{vy} + p_{wy})^2 + p_{cy}^2 + p_{vy}^2} =$$

at $y = H_w$, $p_y = 0.120$ ksf
 at base $y = 0$, $p_y = 0.327$ ksf



9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.67$ ft
 liquid height, $H_L = 19$ ft



BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 20.67 ft
 soil height above top of base = 0 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.0000 ksf
 unfactored soil, q3 = 0.0000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.0000 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = 0 k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = 0 ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.0000 ksf
 wall seismic (see wall page 5), q10 = 0.0439 ksf
 equivalent soil seismic, q11 = q8 - q9 = 0.0000 ksf
 equivalent soil seismic, q12 = q9 = 0.0000 ksf

unfactored equivalent soil seismic, $q8 = 0 / 1.4 = 0.0000$ ksf
 unfactored equivalent soil seismic, $q9 = 0 / 1.4 = 0.0000$ ksf
 unfactored wall seismic, $q10 = 0.0439 / 1.4 = 0.0313$ ksf
 unfactored equivalent soil seismic, $q11 = 0 / 1.4 = 0.0000$ ksf
 unfactored equivalent soil seismic, $q12 = 0 / 1.4 = 0.0000$ ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.67 ft
 water depth = 19 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.67 ft
 water depth = 19 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.67 ft
 soil height on wall = 0 ft

equivalent static soil & surcharge loadings...

LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.000 ksf
 unfactored soil, q3 = 0.000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.000 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)

equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.67 ft
 soil height on wall = 0 ft




unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.000 ksf
 unfactored equivalent soil seismic, q10 = 0.031 ksf
 unfactored equivalent soil seismic, q11 = 0.000 ksf
 unfactored equivalent soil seismic, q12 = 0.000 ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = **1** ft
 tank inside length in direction of seismic, L = **5** ft
 tank wall thickness, t_w = **12** inch
 wall height to underside of roof, H_w = **20.67** ft
 liquid height, H_L = **19** ft
 liquid specific gravity = **1**
 liquid density, γ_L = (sp.gr.) * γ_w = **0.0624** k/ft³
 acceleration due to gravity, g = **32.17** ft/sec²
 liquid mass density, ρ_L = γ_L / g = **0.00194** k-sec²/ft⁴



WALL SECTION
 (wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = **15.5** ft
 groundwater ht. above foundation base = **0** ft
 dry soil lateral pressure = **0.055** k/ft³
 saturated soil lateral pressure = **0** k/ft³
 dry soil unit weight = **0.11** k/ft³
 live load lateral surcharge = **0.100** ksf
 0
 concrete strength, f' _c = **4** ksi
 concrete density, γ_c = **0.150** k/ft³
 concrete modulus of elasticity, E_c = **3605.0** ksi
 concrete mass density, ρ_c = γ_c / g = **0.004663** k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = **0.611** *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = **0.656** *g

Structure Risk Category = **3**
 Importance factor, I = **1.25**
 Response modification factor, R_{wi} = **2.5**
 Response modification factor, R_{wc} = **1**



WALL PLAN

Load Cases:

- case 1 = water
- case 2 = water + water seismic + wall seismic
- case 3 = soil + lateral surcharge
- case 4 = soil + soil seismic + wall seismic

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (12/12) * (20.67) * 0.15 = 3.10 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 20.67 / 2 = 10.335 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (5) * (1) * (19) * 32.17 = 5.93 \text{ kip}$$

Seismic:1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.09638 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.09058 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 9.703 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = E_c * (t_w * H_w / h)^3 / (12 * (4 * H_w - h) * (H_w - h)^2) = 571.75 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (571.75 / (0.0964 + 0.0906))^{1/2} = 55.3006 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 55.3006 = 0.1136 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (3.8)))^{1/2} = 10.0825$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 10.0825 / (5)^{1/2} = 4.5090 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 4.509 = 1.3935 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * S_{d1} / T_c = 0.706 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.9718$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures



L = 5 ft
 B = 1 ft
 H_L = 19 ft
 W_L = 5.93 kip

L / H_L = 0.26316
 H_L / L = 3.80000

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 5.93 * (\tanh(0.866 * 0.2632)) / 0.866 * (0.2632) = 5.83 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 19 * (0.5 - 0.09375 * (0.2632)) = 9.031 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * 0.45 = 8.55 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.5) * 5.83 = 1.8 \text{ kip}$$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 5.93 * (0.264 * (0.2632) * \tanh(3.16 * (3.8))) = 0.41 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 1}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 17.418 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 2.01}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 17.418 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.7062 * 1.25 / 1) * 0.41 = 0.4 \text{ kip}$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.10$ kip
 wall c.g. relative to base, $h_w = 10.335$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \epsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.9718 / 2.5) * 3.1 = 0.92 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (5 / 2) * (0.7062 / 1.4 * 1.25) = 1.58 \text{ ft}$$


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_t = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 1.80$ kip
 $h_i = 9.031$ ft
 at $y = H_L$, $p_{iy} = 0.040$ ksf
 at base $y = 0$, $p_{iy} = 0.054$ ksf

convective:

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 0.40$ kip
 $h_c = 17.418$ ft
 at $y = H_L$, $p_{cy} = 0.037$ ksf
 at base $y = 0$, $p_{cy} = -0.016$ ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.290$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2969 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.045$ ksf
 at base $y = 0$, $p_{wy} = 0.045$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.186$ ksf

combine the effects of the dynamic pressures on the wall:


$$p_y = \sqrt{(p_{vy} + p_{wy})^2 + p_{cy}^2 + p_{vy}^2} =$$

at $y = H_w$, $p_y = 0.093$ ksf
 at base $y = 0$, $p_y = 0.307$ ksf



9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.67$ ft
 liquid height, $H_L = 19$ ft



BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 20.67 ft
 soil height above top of base = 15.5 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.8525 ksf
 unfactored soil, q3 = 0.0000 ksf



equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.8525 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **4.08** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **10.33** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0003 ksf
 equivalent soil seismic, q9 = 0.5261 ksf
 wall seismic (see wall page 5), q10 = 0.0445 ksf
 equivalent soil seismic, q11 = q9 = 0.5261 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.5258 ksf

unfactored equivalent soil seismic, q8 = 0.0003 / 1.4 = 0.0002 ksf
 unfactored equivalent soil seismic, q9 = 0.5261 / 1.4 = 0.3758 ksf
 unfactored wall seismic, q10 = 0.0445 / 1.4 = 0.0318 ksf
 unfactored equivalent soil seismic, q11 = 0.5261 / 1.4 = 0.3758 ksf
 unfactored equivalent soil seismic, q12 = -0.5258 / 1.4 = -0.3756 ksf


BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.67 ft
 water depth = 19 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.67 ft
 water depth = 19 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.67 ft
 soil height on wall = 15.5 ft

equivalent static soil & surcharge loadings...

LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.853 ksf
 unfactored soil, q3 = 0.000 ksf




equivalent soil loadings:

unfactored q5 = 0.100 ksf
 unfactored q6 = 0.853 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)

equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.67 ft
 soil height on wall = 15.5 ft




unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.376 ksf
 unfactored equivalent soil seismic, q10 = 0.032 ksf
 unfactored equivalent soil seismic, q11 = 0.376 ksf
 unfactored equivalent soil seismic, q12 = -0.376 ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = **1** ft
 tank inside length in direction of seismic, L = **36** ft
 tank wall thickness, t_w = **12** inch
 wall height to underside of roof, H_w = **20.67** ft
 liquid height, H_L = **19** ft
 liquid specific gravity = **1**
 liquid density, γ_L = (sp.gr.) * γ_w = **0.0624** k/ft³
 acceleration due to gravity, g = **32.17** ft/sec²
 liquid mass density, ρ_L = γ_L / g = **0.00194** k-sec²/ft⁴



WALL SECTION
 (wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = **0** ft
 groundwater ht. above foundation base = **0** ft
 dry soil lateral pressure = **0.055** k/ft³
 saturated soil lateral pressure = **0** k/ft³
 dry soil unit weight = **0.11** k/ft³
 live load lateral surcharge = **0.100** ksf
 0
 concrete strength, f' _c = **4** ksi
 concrete density, γ_c = **0.150** k/ft³
 concrete modulus of elasticity, E_c = **3605.0** ksi
 concrete mass density, ρ_c = γ_c / g = **0.004663** k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = **0.611** *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = **0.656** *g

Structure Risk Category = **3**
 Importance factor, I = **1.25**
 Response modification factor, R_{wi} = **2.37**
 Response modification factor, R_{wc} = **1.07**



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (12/12) * (20.67) * 0.15 = 3.10 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 20.67 / 2 = 10.335 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (36) * (1) * (19) * 32.17 = 42.68 \text{ kip}$$

Seismic:1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.09638 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.37505 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 7.781 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = E_c * (t_w * H_w / h)^3 / (12 * (4 * H_w - h) * (H_w - h)^2) = 782.11 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (782.11 / (0.0964 + 0.3751))^{1/2} = 40.7310 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 40.731 = 0.1543 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.5278)))^{1/2} = 9.7298$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 9.7298 / (36)^{1/2} = 1.6216 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 1.6216 = 3.8746 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * S_{d1} / T_c = 0.254 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.7137$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures



L = 36 ft
 B = 1 ft
 H_L = 19 ft
 W_L = 42.68 kip
 L / H_L = 1.89474
 H_L / L = 0.52778

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 42.68 * (\tanh(0.866 * (1.8947)) / 0.866 * (1.8947)) = 24.13 \text{ kip}$$

h_i (EBP) = H_L * 0.375 = 19 * 0.375 = 7.125 ft
 h_i (IBP) = H_L * {{{(0.866*L/H_L)/(2*tanh(0.866*L/H_L))} - 1/8} = 14.43 ft
 impulsive force, P_i = $\left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.37) * 24.13 = 7.8 \text{ kip}$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 42.68 * (0.264 * (1.8947) * \tanh(3.16 * (0.5278))) = 19.88 \text{ kip}$$

$$h_{c (EBP)} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 1}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 11.224 \text{ ft}$$

$$h_{c (IBP)} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 2.01}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 15.726 \text{ ft}$$

convective force, P_c = $\left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.254 * 1.25 / 1.07) * 19.88 = 5.9 \text{ kip}$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.10$ kip
 wall c.g. relative to base, $h_w = 10.335$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \epsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.7137 / 2.37) * 3.1 = 0.71 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (36 / 2) * (0.254 / 1.4 * 1.25) = 4.08 \text{ ft}$$

Wave height is greater than the freeboard of 1.67-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_t = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 7.80$ kip
 $h_i = 7.125$ ft
 at $y = H_L$, $p_{iy} = 0.051$ ksf
 at base $y = 0$, $p_{iy} = 0.359$ ksf

convective:

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 5.90$ kip
 $h_c = 11.224$ ft
 at $y = H_L$, $p_{cy} = 0.240$ ksf
 at base $y = 0$, $p_{cy} = 0.071$ ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.290$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2300 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.034$ ksf
 at base $y = 0$, $p_{wy} = 0.034$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.186$ ksf

combine the effects of the dynamic pressures on the wall:




$$p_y = \sqrt{(p_{vy} + p_{wy})^2 + p_{cy}^2 + p_{vy}^2} =$$

at $y = H_w$, $p_y = 0.255$ ksf
 at base $y = 0$, $p_y = 0.494$ ksf



9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.67$ ft
 liquid height, $H_L = 19$ ft



BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 20.67 ft
 soil height above top of base = 0 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.0000 ksf
 unfactored soil, q3 = 0.0000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.0000 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = 0 k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = 0 ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.0000 ksf
 wall seismic (see wall page 5), q10 = 0.0345 ksf
 equivalent soil seismic, q11 = q8 - q9 = 0.0000 ksf
 equivalent soil seismic, q12 = q9 = 0.0000 ksf

unfactored equivalent soil seismic, q8 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q9 = 0 / 1.4 = 0.0000 ksf
 unfactored wall seismic, q10 = 0.0345 / 1.4 = 0.0246 ksf
 unfactored equivalent soil seismic, q11 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q12 = 0 / 1.4 = 0.0000 ksf


BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 5 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.67 ft
 water depth = 19 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.67 ft
 water depth = 19 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.67 ft
 soil height on wall = 0 ft

equivalent static soil & surcharge loadings...

LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.000 ksf
 unfactored soil, q3 = 0.000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.000 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)

equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.67 ft
 soil height on wall = 0 ft




unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.000 ksf
 unfactored equivalent soil seismic, q10 = 0.025 ksf
 unfactored equivalent soil seismic, q11 = 0.000 ksf
 unfactored equivalent soil seismic, q12 = 0.000 ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = **1** ft
 tank inside length in direction of seismic, L = **31** ft
 tank wall thickness, t_w = **14** inch
 wall height to underside of roof, H_w = **20.67** ft
 liquid height, H_L = **19** ft
 liquid specific gravity = **1**
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = **32.17** ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION
 (wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = **0** ft
 groundwater ht. above foundation base = **0** ft
 dry soil lateral pressure = **0.055** k/ft³
 saturated soil lateral pressure = **0** k/ft³
 dry soil unit weight = **0.11** k/ft³
 live load lateral surcharge = **0.100** ksf
 concrete strength, $f'_c = 4$ ksi
 concrete density, $\gamma_c = 0.150$ k/ft³
 concrete modulus of elasticity, $E_c = 3605.0$ ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = **3**
 Importance factor, I = **1.25**
 Response modification factor, $R_w = 2.37$
 Response modification factor, $R_{wc} = 1.08$



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures

Weights:

$$\begin{aligned}
 \text{unit 1-ft width wall mass, } W_w &= (14/12) * (20.67) * 0.15 = 3.62 \text{ kip} \\
 \text{wall c.g. relative to base, } h_w &= 20.67 / 2 = 10.335 \text{ ft}
 \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (31) * (1) * (19) * 32.17 = 36.75 \text{ kip}$$

Seismic:1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.11244 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.35907 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 7.89 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = Ec * (tw * Hw/h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 1213.37 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (1213.37 / (0.1124 + 0.3591))^{1/2} = 50.7285 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 50.7285 = 0.1239 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.6129)))^{1/2} = 9.8751$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 9.8751 / (31)^{1/2} = 1.7736 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 1.7736 = 3.5426 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * S_{d1} / T_c = 0.278 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.7499$$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures



L = 31 ft
 B = 1 ft
 H_L = 19 ft
 W_L = 36.75 kip

L / H_L = 1.63158
 H_L / L = 0.61290

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 36.75 * (\tanh(0.866 * (1.6316)) / 0.866 * (1.6316)) = 23.1 \text{ kip}$$

h_i (EBP) = H_L * 0.375 = 19 * 0.375 = 7.125 ft
 h_i (IBP) = H_L * {{{(0.866*L/H_L)/(2*tanh(0.866*L/H_L))} - 1/8} = 12.739 ft
 impulsive force, P_i = $\left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.37) * 23.1 = 7.4 \text{ kip}$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 36.75 * (0.264 * (1.6316) * \tanh(3.16 * (0.6129))) = 15.18 \text{ kip}$$

$$h_{c (EBP)} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 1}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 11.662 \text{ ft}$$

$$h_{c (IBP)} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 2.01}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 14.58 \text{ ft}$$

convective force, P_c = $\left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.2778 * 1.25 / 1.08) * 15.18 = 4.9 \text{ kip}$

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.62$ kip
 wall c.g. relative to base, $h_w = 10.335$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \epsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.7499 / 2.37) * 3.62 = 0.87 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (31 / 2) * (0.2778 / 1.4 * 1.25) = 3.84 \text{ ft}$$

Wave height is greater than the freeboard of 1.67-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_t = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 7.40$ kip
 $h_i = 7.125$ ft
 at $y = H_L$, $p_{iy} = 0.049$ ksf
 at base $y = 0$, $p_{iy} = 0.341$ ksf

convective:

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 4.90$ kip
 $h_c = 11.662$ ft
 at $y = H_L$, $p_{cy} = 0.217$ ksf
 at base $y = 0$, $p_{cy} = 0.041$ ksf

BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.290$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2417 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.042$ ksf
 at base $y = 0$, $p_{wy} = 0.042$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.186$ ksf

combine the effects of the dynamic pressures on the wall:




$$p_y = \sqrt{(p_{vy} + p_{wy})^2 + p_{cy}^2 + p_{vy}^2} =$$

at $y = H_w$, $p_y = 0.235$ ksf
 at base $y = 0$, $p_y = 0.482$ ksf



9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.67$ ft
 liquid height, $H_L = 19$ ft



BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 20.67 ft
 soil height above top of base = 0 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.0000 ksf
 unfactored soil, q3 = 0.0000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.0000 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **0** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **0** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.0000 ksf
 wall seismic (see wall page 5), q10 = 0.0423 ksf
 equivalent soil seismic, q11 = q8 - q9 = 0.0000 ksf
 equivalent soil seismic, q12 = q9 = 0.0000 ksf

unfactored equivalent soil seismic, q8 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q9 = 0 / 1.4 = 0.0000 ksf
 unfactored wall seismic, q10 = 0.0423 / 1.4 = 0.0302 ksf
 unfactored equivalent soil seismic, q11 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q12 = 0 / 1.4 = 0.0000 ksf


BY: C.Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.67 ft
 water depth = 19 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.67 ft
 water depth = 19 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.67 ft
 soil height on wall = 0 ft

equivalent static soil & surcharge loadings...

LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.000 ksf
 unfactored soil, q3 = 0.000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.000 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)

equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.67 ft
 soil height on wall = 0 ft



unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.000 ksf
 unfactored equivalent soil seismic, q10 = 0.030 ksf
 unfactored equivalent soil seismic, q11 = 0.000 ksf
 unfactored equivalent soil seismic, q12 = 0.000 ksf

**Area 4 - Actifio™
Wall 1 - Moment & Shear**

		Horizontal Span						
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR	SQX_u (psi)	SQ_{Q_n} (psi)	DCR
1.4F	1.61	11.90	19.16	47.00	0.41	62	126	0.49
1.2F+1.4E	1.00	14.50	14.50	47.00	0.31	77	126	0.61
1.6(H+L)	1.41	9.80	13.82	47.00	0.29	50	126	0.40
1.6H+1.4E	1.00	13.20	13.20	47.00	0.28	70	126	0.55

		Vertical Span (Mid-Height)						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_{Q_n} (psi)	DCR
1.4F	1.61	7.00	11.27	20.50	0.55	0	126	0.00
1.2F+1.4E	1.00	8.40	8.40	20.50	0.41	0	126	0.00
1.6(H+L)	1.41	5.96	8.40	20.50	0.41	0	126	0.00
1.6H+1.4E	1.00	7.50	7.50	20.50	0.37	0	126	0.00

		Vertical Span (Bottom)						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_{Q_n} (psi)	DCR
1.4F	1.61	17.40	28.01	51.00	0.55	62	126	0.49
1.2F+1.4E	1.00	20.70	20.70	51.00	0.41	76	126	0.60
1.6(H+L)	1.41	14.10	19.88	51.00	0.39	52	126	0.41
1.6H+1.4E	1.00	17.80	17.80	51.00	0.35	69	126	0.54



Software licensed to Carollo Engineers


Job Title Area 4 - ActiFlo

Load Case: 1.4H

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1				
Ref					
By	CC	Date	04-Aug-17	Chd	
File	Wall 1.std	Date/Time	09-Aug-2017 14:52		

- MX (local)
- lb-in/in
- <= -11.9 E3
- 10.7 E3
- 9456
- 8228
- 7001
- 5773
- 4546
- 3318
- 2091
- 863
- 364
- 1592
- 2820
- 4047
- 5275
- 6502
- >= 7730



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1,2F+1,4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1				
Ref					
By	CC	Date	04-Aug-17	Chd	
File	Wall 1.std		Date/Time	09-Sep-2017 08:15	

- MX (local)
- lb-in/in
- <= -14.5 E3
- 13 E3
- 11.5 E3
- 10 E3
- 8499
- 6992
- 5485
- 3978
- 2470
- 963
- 544
- 2051
- 3558
- 5066
- 6573
- 8080
- >= 9587





Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC


Date 04-Aug-17

Chd

File Wall 1.std

Date/Time 09-Aug-2017 14:52

- MX (local)
- lb-in/in
- <= -9785
- 8781
- 7778
- 6774
- 5771
- 4767
- 3764
- 2760
- 1757
- 754
- 250
- 1253
- 2257
- 3260
- 4264
- 5267
- >= 6271



Load 3



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall	1
-----------	---

Ref	
-----	--

By	CC	Date	04-Aug-17	Chd	
----	----	------	-----------	-----	--

File	Wall 1.std	Date/Time	09-Aug-2017 14:52
------	------------	-----------	-------------------

- MX (local)
- lb-in/in
- <= -13.2 E3
- 11.8 E3
- 10.4 E3
- 9059
- 7691
- 6323
- 4955
- 3587
- 2219
- 851
- 517
- 1885
- 3253
- 4621
- 5989
- 7357
- >= 8725



Load 4



Software licensed to Carollo Engineers


Job Title Area 4 - ActiFlo

Load Case: 1.4H

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1	Ref			
By	CC	Date	04-Aug-17	Chd	
File	Wall 1.std	Date/Time	09-Aug-2017 14:52		

- MY (local)
 lb-in/in
- <= -17.4 E3
 - 15.9 E3
 - 14.3 E3
 - 12.8 E3
 - 11.3 E3
 - 9.764
 - 8.236
 - 6.709
 - 5.181
 - 3.653
 - 2.125
 - 597
 - 931
 - 2459
 - 3986
 - 5514
 - >= 7042



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1	Ref			
By	CC	Date	04-Aug-17	Chd	
File	Wall 1.std	Date/Time	09-Sep-2017 08:15		

- MY (local)
- lb-in/in
- <= -20.7 E3
- 18.8 E3
- 17 E3
- 15.2 E3
- 13.4 E3
- 11.6 E3
- 9.766
- 7.949
- 6.132
- 4.315
- 2.498
- 681
- 1135
- 2952
- 4769
- 6586
- >= 8403



Load 2



Software licensed to Carollo Engineers


Job Title Area 4 - ActiFlo

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1				
Ref					
By	CC	Date	04-Aug-17	Chd	
File	Wall 1.std	Date/Time	09-Aug-2017 14:52		

- MY (local)
- lb-in/in
- <= -14.1 E3
- 12.9 E3
- 11.6 E3
- 10.4 E3
- 9.096
- 7.841
- 6.586
- 5.331
- 4.076
- 2.821
- 1.566
- .311
- 944
- 2199
- 3454
- 4709
- >= 5964



Load 3



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 1	
-------------	--

Ref	
-----	--

By CC	Date 04-Aug-17	Chd
-------	----------------	-----

File Wall 1.std	Date/Time 09-Aug-2017 14:52
-----------------	-----------------------------

- MY (local)
- lb-in/in
- <= -17.8 E3
- 16.3 E3
- 14.7 E3
- 13.1 E3
- 11.5 E3
- 9.911
- 8.325
- 6.739
- 5.154
- 3.568
- 1.982
- 396
- 1190
- 2775
- 4361
- 5947
- >= 7533



Load 4



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4H

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall 1


Ref	
-----	--

By	CC	Date	04-Aug-17	Chd	
----	----	------	-----------	-----	--

File	Wall 1.std	Date/Time	09-Aug-2017 14:52
------	------------	-----------	-------------------

SQX (local)
psi

- <= -58.3
- 50.7
- 43.2
- 35.7
- 28.2
- 20.7
- 13.2
- 5.67
- 1.84
- 9.35
- 16.9
- 24.4
- 31.9
- 39.4
- 46.9
- 54.4
- >= 61.9



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


PartWall 1

Ref

By CC Date 04-Aug-17 Chd

File Wall 1.std Date/Time 09-Sep-2017 08:15

- SQX (local)
psi
- <= -69.8
 - 60.7
 - 51.5
 - 42.4
 - 33.2
 - 24.1
 - 14.9
 - 5.75
 - 3.41
 - 12.6
 - 21.7
 - 30.9
 - 40
 - 49.2
 - 58.3
 - 67.5
 - >= 76.7



Load 2



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 102

Rev

Part/Wall 1

Ref

By CC

Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 09-Aug-2017 14:52

SQX (local)

psi

- <= -48.5
- 42.3
- 36.1
- 30
- 23.8
- 17.6
- 11.4
- 5.23
- 0.954
- 7.14
- 13.3
- 19.5
- 25.7
- 31.9
- 38.1
- 44.2
- >= 50.4



Load 3



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall	1
-----------	---


Ref	
-----	--

By	CC	Date	04-Aug-17	Chd	
----	----	------	-----------	-----	--

File	Wall 1.std	Date/Time	09-Aug-2017 14:52
------	------------	-----------	-------------------

SQX (local)
psi

<= -62.3
-54.1
-45.8
-37.6
-29.3
-21.1
-12.8
-4.56
3.69
11.9
20.2
28.4
36.7
45
53.2
61.5
>= 69.7



Load 4



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4H

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 104

Rev

Part/Wall 1

Ref

By CC

Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 09-Aug-2017 14:52

SQY (local)

psi

- <= -62.4
- 54.8
- 47.2
- 39.6
- 32
- 24.4
- 16.8
- 9.21
- 1.61
- 6
- 13.6
- 21.2
- 28.8
- 36.4
- 44
- 51.6
- >= 59.2



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1	Ref			
By	CC	Date	04-Aug-17	Chd	
File	Wall 1.std	Date/Time	09-Sep-2017 08:15		

- SQY (local)
psi
- <= -76.1
 - 66.8
 - 57.6
 - 48.3
 - 39
 - 29.8
 - 20.5
 - 11.2
 - 1.97
 - 7.3
 - 16.6
 - 25.8
 - 35.1
 - 44.4
 - 53.6
 - 62.9
 - >= 72.2



Load 2



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 106

Part/Wall 1

Ref

By CC

Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 09-Aug-2017 14:52

SQY (local)

psi

- <= -51.5
- 45.3
- 39
- 32.8
- 26.5
- 20.3
- 14
- 7.76
- 1.5
- 4.75
- 11
- 17.3
- 23.5
- 29.8
- 36
- 42.3
- >= 48.5



Load 3



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall	1
-----------	---

Ref	
-----	--

By	CC	Date	04-Aug-17	Chd	
----	----	------	-----------	-----	--

File	Wall 1.std	Date/Time	09-Aug-2017 14:52
------	------------	-----------	-------------------

- SQY (local)
psi
- <= -68.5
 - 60.2
 - 51.9
 - 43.5
 - 35.2
 - 26.9
 - 18.5
 - 10.2
 - 1.88
 - 6.45
 - 14.8
 - 23.1
 - 31.4
 - 39.8
 - 48.1
 - 56.4
 - >= 64.8



Load 4

**Area 4 - Actiflo™
Wall 2 - Moment & Shear**

		Horizontal Span							
		S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (Kip)	V_n (Kip)	DCR
1.4E (Water 2-Sides)	1.4F	1.61	9.44	15.19	24.50	0.62	5.58	14.51	0.38
	1.2F+1.4E	1.00	11.39	11.39	24.50	0.46	6.71	14.51	0.46
		1.00	2.57	2.57	24.50	0.10	1.49	14.51	0.10

		Vertical Span (Mid-Height)							
		S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (Kip)	V_n (Kip)	DCR
1.4E (Water 2-Sides)	1.4F	1.61	2.44	3.92	24.50	0.16	0.00	14.51	0.00
	1.2F+1.4E	1.00	3.10	3.10	24.50	0.13	0.00	14.51	0.00
		1.00	0.55	0.55	24.50	0.02	0.00	14.51	0.00

		Vertical Span (Bottom)							
		S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (Kip)	V_n (Kip)	DCR
1.4E (Water 2-Sides)	1.4F	1.61	15.11	24.33	24.50	0.99	7.45	14.51	0.51
	1.2F+1.4E	1.00	10.80	10.80	24.50	0.44	8.47	14.51	0.58
		1.00	1.90	1.90	24.50	0.08	1.39	14.51	0.10


<- OK
<- OK
<- OK

<- OK
<- OK
<- OK


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 6 =$ **12** ft
 plate dimension, a = **6** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.2903



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft) ...only for custom loads 100 or 400	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number			for moment	for shear
A	400	19.000	1.186	2.25	1.4
B					
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$ ", and triangular load height $\geq b / 6$ ".
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

M _x - Moment Summary													
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186								Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft		M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}		
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x/a	y/b	A	B	C	D	A	B	C	D				
0	1	0.0000				0.00				0.00	0.00	0.00	0.36
0	0.8	0.0042				2.11				2.11	4.75	0.12	0.36
0	0.6	0.0089				4.53				4.53	10.18	0.26	0.36
0	0.4	0.0133				6.74				6.74	15.16	0.39	0.36
0	0.2	0.0115				5.85				5.85	13.17	0.33	0.36
0	0	0.0000				0.00				0.00	0.00	0.00	0.36
0.2	0	0.0005				0.27				0.27	0.60	0.01	0.36
0.4	0	0.0013				0.64				0.64	1.45	0.04	0.36
0.6	0	0.0020				1.00				1.00	2.26	0.06	0.36
0.8	0	0.0025				1.27				1.27	2.86	0.07	0.36
1	0	0.0026				1.34				1.34	3.01	0.07	0.36
1	0.2	-0.0051				-2.61				-2.61	-5.87	-0.15	-0.36
1	0.4	-0.0065				-3.30				-3.30	-7.42	-0.19	-0.36
1	0.6	-0.0045				-2.29				-2.29	-5.16	-0.13	-0.36
1	0.8	-0.0021				-1.09				-1.09	-2.45	-0.06	-0.36
1	1	0.0000				0.00				0.00	0.00	0.00	0.36
0.8	1	0.0000				0.00				0.00	0.00	0.00	0.36
0.8	0.8	-0.0018				-0.93				-0.93	-2.10	-0.05	-0.36
0.8	0.6	-0.0040				-2.03				-2.03	-4.57	-0.11	-0.36
0.8	0.4	-0.0059				-2.97				-2.97	-6.68	-0.17	-0.36
0.8	0.2	-0.0048				-2.41				-2.41	-5.42	-0.14	-0.36

max negative moment, M_{ux}(-) = -7.42 ft-k/ft

max positive moment, M_{ux}(+) = 15.16 ft-k/ft

max negative steel req'd, A_s(-) = -0.19 in²/ft

max positive steel req'd, A_s(+) = 0.39 in²/ft

minimum steel req'd = -0.36 in²/ft

minimum steel req'd = 0.36 in²/ft

Use

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

M _y - Moment Summary													
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186								Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000				0.00				0.00	0.00	0.00	0.36
0	0.8	0.0008				0.41				0.41	0.91	0.02	0.36
0	0.6	0.0018				0.89				0.89	2.00	0.05	0.36
0	0.4	0.0027				1.35				1.35	3.04	0.07	0.36
0	0.2	0.0023				1.16				1.16	2.62	0.06	0.36
0	0	0.0000				0.00				0.00	0.00	0.00	0.36
0.2	0	0.0026				1.30				1.30	2.92	0.07	0.36
0.4	0	0.0065				3.31				3.31	7.45	0.18	0.36
0.6	0	0.0101				5.10				5.10	11.48	0.27	0.37
0.8	0	0.0124				6.31				6.31	14.19	0.34	0.38
1	0	0.0133				6.71				6.71	15.11	0.36	0.38
1	0.2	-0.0039				-1.97				-1.97	-4.44	-0.10	-0.36
1	0.4	-0.0031				-1.56				-1.56	-3.51	-0.08	-0.36
1	0.6	-0.0013				-0.65				-0.65	-1.45	-0.03	-0.36
1	0.8	-0.0004				-0.18				-0.18	-0.41	-0.01	-0.36
1	1	0.0000				0.00				0.00	0.00	0.00	0.36
1	0.4	-0.0031				-1.56				-1.56	-3.51	-0.08	-0.36
0.8	0.4	-0.0028				-1.43				-1.43	-3.22	-0.08	-0.36
0.6	0.4	-0.0020				-1.04				-1.04	-2.33	-0.05	-0.36
0.4	0.4	-0.0008				-0.40				-0.40	-0.91	-0.02	-0.36
0.2	0.4	0.0008				0.42				0.42	0.96	0.02	0.36

max negative moment, M_{uy}(-) = -4.44 ft-k/ft
 max negative steel req'd, A_s(-) = -0.10 in²/ft
 minimum steel req'd = -0.36 in²/ft

max positive moment, M_{uy}(+) = 15.11 ft-k/ft
 max positive steel req'd, A_s(+) = 0.36 in²/ft
 minimum steel req'd = 0.38 in²/ft

Use

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

Shear Summary												
a = 6 b = 20.67 a / b = 0.2903		Loads: q , or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V	V _u	φV _c
x / a	y / b	A	B	C	D	A	B	C	D	k/ft	k/ft	k/ft
0	1	-0.0075				-0.18				-0.18	-0.26	10.81
0	0.8	0.0411				1.01				1.01	1.41	10.81
0	0.6	0.0958				2.35				2.35	3.29	10.81
0	0.4	0.1626				3.99				3.99	5.58	10.81
0	0.2	0.1582				3.88				3.88	5.43	10.81
0	0.00	0.0249				0.61				0.61	0.85	10.81
0.2	0	0.0372				0.91				0.91	1.28	10.81
0.4	0	0.1199				2.94				2.94	4.12	10.81
0.6	0	0.1756				4.31				4.31	6.03	10.81
0.8	0	0.2071				5.08				5.08	7.11	10.81
1	0	0.2171				5.32				5.32	7.45	10.81
0.2	1	-0.0129				-0.32				-0.32	-0.44	10.81
0.4	1	0.0029				0.07				0.07	0.10	10.81
0.6	1	0.0143				0.35				0.35	0.49	10.81
0.8	1	0.0212				0.52				0.52	0.73	10.81
1	1	0.0235				0.58				0.58	0.81	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 7.45 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 6 = 12$ ft
 plate dimension, a = **6** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.2903



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	19.000	1.186	1.2	1.2
B	100	19.000	0.121	1.4	1.4
C	400	19.000	0.181	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$ ", and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

M _x - Moment Summary													
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186	0.121	0.181						Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0	0.8	0.0042	0.0161	0.0042		2.11	0.83	0.32		3.26	4.15	0.10	0.36
0	0.6	0.0089	0.0249	0.0089		4.53	1.29	0.69		6.51	8.20	0.21	0.36
0	0.4	0.0133	0.0258	0.0133		6.74	1.33	1.03		9.10	11.39	0.29	0.36
0	0.2	0.0115	0.0166	0.0115		5.85	0.86	0.89		7.60	9.47	0.24	0.36
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.2	0	0.0005	0.0007	0.0005		0.27	0.03	0.04		0.34	0.42	0.01	0.36
0.4	0	0.0013	0.0017	0.0013		0.64	0.09	0.10		0.83	1.03	0.03	0.36
0.6	0	0.0020	0.0027	0.0020		1.00	0.14	0.15		1.30	1.61	0.04	0.36
0.8	0	0.0025	0.0034	0.0025		1.27	0.17	0.19		1.64	2.04	0.05	0.36
1	0	0.0026	0.0036	0.0026		1.34	0.19	0.20		1.73	2.15	0.05	0.36
1	0.2	-0.0051	-0.0078	-0.0051		-2.61	-0.40	-0.40		-3.41	-4.25	-0.11	-0.36
1	0.4	-0.0065	-0.0128	-0.0065		-3.30	-0.66	-0.50		-4.46	-5.59	-0.14	-0.36
1	0.6	-0.0045	-0.0124	-0.0045		-2.29	-0.64	-0.35		-3.28	-4.14	-0.10	-0.36
1	0.8	-0.0021	-0.0080	-0.0021		-1.09	-0.41	-0.17		-1.66	-2.11	-0.05	-0.36
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.8	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.8	0.8	-0.0018	-0.0072	-0.0018		-0.93	-0.37	-0.14		-1.45	-1.84	-0.05	-0.36
0.8	0.6	-0.0040	-0.0111	-0.0040		-2.03	-0.57	-0.31		-2.92	-3.68	-0.09	-0.36
0.8	0.4	-0.0059	-0.0114	-0.0059		-2.97	-0.59	-0.45		-4.01	-5.02	-0.13	-0.36
0.8	0.2	-0.0048	-0.0070	-0.0048		-2.41	-0.36	-0.37		-3.14	-3.91	-0.10	-0.36

max negative moment, M_{ux}(-) = -5.59 ft-k/ft

max negative steel req'd, A_s(-) = -0.14 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 11.39 ft-k/ft

max positive steel req'd, A_s(+) = 0.29 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

M _y - Moment Summary													
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186	0.121	0.181						Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0	0.8	0.0008	0.0032	0.0008		0.41	0.17	0.06		0.63	0.80	0.02	0.36
0	0.6	0.0018	0.0050	0.0018		0.89	0.26	0.14		1.28	1.62	0.04	0.36
0	0.4	0.0027	0.0052	0.0027		1.35	0.27	0.21		1.82	2.28	0.05	0.36
0	0.2	0.0023	0.0033	0.0023		1.16	0.17	0.18		1.51	1.88	0.04	0.36
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.2	0	0.0026	0.0032	0.0026		1.30	0.17	0.20		1.66	2.07	0.05	0.36
0.4	0	0.0065	0.0084	0.0065		3.31	0.44	0.51		4.25	5.29	0.12	0.36
0.6	0	0.0101	0.0135	0.0101		5.10	0.70	0.78		6.58	8.19	0.19	0.36
0.8	0	0.0124	0.0169	0.0124		6.31	0.87	0.96		8.14	10.14	0.24	0.36
1	0	0.0133	0.0181	0.0133		6.71	0.94	1.02		8.67	10.80	0.26	0.36
1	0.2	-0.0039	-0.0042	-0.0039		-1.97	-0.22	-0.30		-2.49	-3.10	-0.07	-0.36
1	0.4	-0.0031	-0.0055	-0.0031		-1.56	-0.28	-0.24		-2.08	-2.60	-0.06	-0.36
1	0.6	-0.0013	-0.0049	-0.0013		-0.65	-0.25	-0.10		-1.00	-1.27	-0.03	-0.36
1	0.8	-0.0004	-0.0035	-0.0004		-0.18	-0.18	-0.03		-0.39	-0.51	-0.01	-0.36
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
1	0.4	-0.0031	-0.0055	-0.0031		-1.56	-0.28	-0.24		-2.08	-2.60	-0.06	-0.36
0.8	0.4	-0.0028	-0.0050	-0.0028		-1.43	-0.26	-0.22		-1.91	-2.38	-0.06	-0.36
0.6	0.4	-0.0020	-0.0035	-0.0020		-1.04	-0.18	-0.16		-1.38	-1.72	-0.04	-0.36
0.4	0.4	-0.0008	-0.0013	-0.0008		-0.40	-0.06	-0.06		-0.53	-0.66	-0.02	-0.36
0.2	0.4	0.0008	0.0017	0.0008		0.42	0.09	0.06		0.58	0.72	0.02	0.36

max negative moment, M_{uy}(-) = -3.10 ft-k/ft

max negative steel req'd, A_s(-) = -0.07 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 10.80 ft-k/ft

max positive steel req'd, A_s(+) = 0.26 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

Shear Summary												
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY		
		1.186	0.121	0.181						Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		24.515	2.501	3.741								
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	-0.0075	-0.0177	-0.0075		-0.18	-0.04	-0.03		-0.26	-0.32	10.81
0	0.8	0.0411	0.1937	0.0411		1.01	0.48	0.15		1.65	2.10	10.81
0	0.6	0.0958	0.2893	0.0958		2.35	0.72	0.36		3.43	4.33	10.81
0	0.4	0.1626	0.3071	0.1626		3.99	0.77	0.61		5.36	6.71	10.81
0	0.2	0.1582	0.2068	0.1582		3.88	0.52	0.59		4.99	6.20	10.81
0	0.00	0.0249	0.0202	0.0249		0.61	0.05	0.09		0.75	0.93	10.81
0.2	0	0.0372	0.0256	0.0372		0.91	0.06	0.14		1.11	1.38	10.81
0.4	0	0.1199	0.1314	0.1199		2.94	0.33	0.45		3.72	4.62	10.81
0.6	0	0.1756	0.2087	0.1756		4.31	0.52	0.66		5.48	6.82	10.81
0.8	0	0.2071	0.2544	0.2071		5.08	0.64	0.77		6.49	8.07	10.81
1	0	0.2171	0.2694	0.2171		5.32	0.67	0.81		6.81	8.47	10.81
0.2	1	-0.0129	0.0078	-0.0129		-0.32	0.02	-0.05		-0.34	-0.42	10.81
0.4	1	0.0029	0.0702	0.0029		0.07	0.18	0.01		0.26	0.35	10.81
0.6	1	0.0143	0.1314	0.0143		0.35	0.33	0.05		0.73	0.96	10.81
0.8	1	0.0212	0.1369	0.0212		0.52	0.34	0.08		0.94	1.21	10.81
1	1	0.0235	0.1448	0.0235		0.58	0.36	0.09		1.03	1.32	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 8.47 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 6 = 12$ ft
 plate dimension, a = **6** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.2903



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	100	19.000	0.145	1.4	1.4
B	400	19.000	0.042	1.4	1.4
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

M _x - Moment Summary													
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.145	0.042							Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0161	0.0042			1.00	0.07			1.07	1.50	0.04	0.36
0	0.6	0.0249	0.0089			1.54	0.16			1.70	2.39	0.06	0.36
0	0.4	0.0258	0.0133			1.60	0.24			1.84	2.57	0.06	0.36
0	0.2	0.0166	0.0115			1.03	0.21			1.24	1.73	0.04	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0007	0.0005			0.04	0.01			0.05	0.07	0.00	0.36
0.4	0	0.0017	0.0013			0.11	0.02			0.13	0.18	0.00	0.36
0.6	0	0.0027	0.0020			0.17	0.04			0.20	0.28	0.01	0.36
0.8	0	0.0034	0.0025			0.21	0.05			0.25	0.36	0.01	0.36
1	0	0.0036	0.0026			0.22	0.05			0.27	0.38	0.01	0.36
1	0.2	-0.0078	-0.0051			-0.48	-0.09			-0.57	-0.80	-0.02	-0.36
1	0.4	-0.0128	-0.0065			-0.79	-0.12			-0.91	-1.27	-0.03	-0.36
1	0.6	-0.0124	-0.0045			-0.77	-0.08			-0.85	-1.19	-0.03	-0.36
1	0.8	-0.0080	-0.0021			-0.49	-0.04			-0.53	-0.75	-0.02	-0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.8	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.8	0.8	-0.0072	-0.0018			-0.44	-0.03			-0.48	-0.67	-0.02	-0.36
0.8	0.6	-0.0111	-0.0040			-0.69	-0.07			-0.76	-1.06	-0.03	-0.36
0.8	0.4	-0.0114	-0.0059			-0.71	-0.11			-0.81	-1.14	-0.03	-0.36
0.8	0.2	-0.0070	-0.0048			-0.43	-0.09			-0.52	-0.73	-0.02	-0.36

max negative moment, M_{ux}(-) = -1.27 ft-k/ft

max negative steel req'd, A_s(-) = -0.03 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 2.57 ft-k/ft

max positive steel req'd, A_s(+) = 0.06 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

M _y - Moment Summary													
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.145	0.042							Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0032	0.0008			0.20	0.01			0.21	0.30	0.01	0.36
0	0.6	0.0050	0.0018			0.31	0.03			0.34	0.47	0.01	0.36
0	0.4	0.0052	0.0027			0.32	0.05			0.37	0.51	0.01	0.36
0	0.2	0.0033	0.0023			0.21	0.04			0.25	0.35	0.01	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0032	0.0026			0.20	0.05			0.24	0.34	0.01	0.36
0.4	0	0.0084	0.0065			0.52	0.12			0.64	0.90	0.02	0.36
0.6	0	0.0135	0.0101			0.84	0.18			1.02	1.42	0.03	0.36
0.8	0	0.0169	0.0124			1.05	0.22			1.27	1.78	0.04	0.36
1	0	0.0181	0.0133			1.12	0.24			1.36	1.90	0.04	0.36
1	0.2	-0.0042	-0.0039			-0.26	-0.07			-0.33	-0.46	-0.01	-0.36
1	0.4	-0.0055	-0.0031			-0.34	-0.06			-0.39	-0.55	-0.01	-0.36
1	0.6	-0.0049	-0.0013			-0.30	-0.02			-0.33	-0.46	-0.01	-0.36
1	0.8	-0.0035	-0.0004			-0.22	-0.01			-0.22	-0.31	-0.01	-0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
1	0.4	-0.0055	-0.0031			-0.34	-0.06			-0.39	-0.55	-0.01	-0.36
0.8	0.4	-0.0050	-0.0028			-0.31	-0.05			-0.36	-0.51	-0.01	-0.36
0.6	0.4	-0.0035	-0.0020			-0.22	-0.04			-0.26	-0.36	-0.01	-0.36
0.4	0.4	-0.0013	-0.0008			-0.08	-0.01			-0.09	-0.13	0.00	-0.36
0.2	0.4	0.0017	0.0008			0.10	0.02			0.12	0.17	0.00	0.36

max negative moment, M_{uy}(-) = -0.55 ft-k/ft

max negative steel req'd, A_s(-) = -0.01 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 1.90 ft-k/ft

max positive steel req'd, A_s(+) = 0.04 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willemetter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

Shear Summary												
a = 6 b = 20.67 a / b = 0.2903		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	-0.0177	-0.0075			-0.05	-0.01			-0.06	-0.08	10.81
0	0.8	0.1937	0.0411			0.58	0.04			0.62	0.86	10.81
0	0.6	0.2893	0.0958			0.87	0.08			0.95	1.33	10.81
0	0.4	0.3071	0.1626			0.92	0.14			1.06	1.49	10.81
0	0.2	0.2068	0.1582			0.62	0.14			0.76	1.06	10.81
0	0.00	0.0202	0.0249			0.06	0.02			0.08	0.11	10.81
0.2	0	0.0256	0.0372			0.08	0.03			0.11	0.15	10.81
0.4	0	0.1314	0.1199			0.39	0.10			0.50	0.70	10.81
0.6	0	0.2087	0.1756			0.63	0.15			0.78	1.09	10.81
0.8	0	0.2544	0.2071			0.76	0.18			0.94	1.32	10.81
1	0	0.2694	0.2171			0.81	0.19			1.00	1.39	10.81
0.2	1	0.0078	-0.0129			0.02	-0.01			0.01	0.02	10.81
0.4	1	0.0702	0.0029			0.21	0.00			0.21	0.30	10.81
0.6	1	0.1314	0.0143			0.39	0.01			0.41	0.57	10.81
0.8	1	0.1369	0.0212			0.41	0.02			0.43	0.60	10.81
1	1	0.1448	0.0235			0.43	0.02			0.45	0.64	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 1.49 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

**Area 4 - Actiflo™
Wall 3 - Moment & Shear**

		Horizontal Span							
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	SQX_u (psi)	SQ_n (psi)	DCR	
1.4E (Water 2-Sides)	1.4F	1.61	19.10	30.75	47.00	0.65	96	126	0.76
	1.2F+1.4E	1.00	23.90	23.90	47.00	0.51	137	126	1.08
	1.00	15.10	15.10	47.00	0.32	109	126	0.86	

		Vertical Span (Mid-Height)							
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR	
1.4E (Water 2-Sides)	1.4F	1.61	13.60	21.90	20.50	1.07	0	126	0.00
	1.2F+1.4E	1.00	16.80	16.80	20.50	0.82	0	126	0.00
	1.00	10.70	10.70	20.50	0.52	0	126	0.00	

		Vertical Span (Bottom)							
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR	
1.4E (Water 2-Sides)	1.4F	1.61	31.40	50.55	51.00	0.99	64	126	0.50
	1.2F+1.4E	1.00	38.20	38.20	51.00	0.75	86	126	0.68
	1.00	22.50	22.50	51.00	0.44	68	126	0.53	

<- OK
 <- OK
 <- OK

<- NG
 <- OK
 <- OK



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By Date 04-Aug-17

Chd


File Wall 3.std

Date/Time 09-Aug-2017 15:20

MX (local)

lb-in/in

- <= -19.1 E3
- 17.4 E3
- 15.7 E3
- 14 E3
- 12.3 E3
- 10.5 E3
- 8.827
- 7.110
- 5.393
- 3.676
- 1.960
- 243
- 1474
- 3191
- 4907
- 6624
- >= 8341



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	3				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 3.std	Date/Time	09-Sep-2017 10:11		

- MX (local)
lb-in/in
- <= -23.9 E3
 - 21.7 E3
 - 19.5 E3
 - 17.3 E3
 - 15.1 E3
 - 12.9 E3
 - 10.7 E3
 - 8.498
 - 6.294
 - 4.089
 - 1.884
 - 321
 - 2526
 - 4731
 - 6936
 - 9141
 - >= 11.3 E3





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	3				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 3.std	Date/Time	09-Sep-2017 10:11		

- MX (local)
lb-in/in
- <= -15.1 E3
 - 13.6 E3
 - 12.1 E3
 - 10.6 E3
 - 9139
 - 7645
 - 6151
 - 4657
 - 3162
 - 1668
 - 174
 - 1320
 - 2815
 - 4309
 - 5803
 - 7297
 - >= 8792



Load 3



Software licensed to Carollo Engineers


Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	3				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 3.std	Date/Time	09-Aug-2017 15:20		

- MY (local)
lb-in/in
- <= -31.4 E3
 - 28.6 E3
 - 25.8 E3
 - 23 E3
 - 20.2 E3
 - 17.3 E3
 - 14.5 E3
 - 11.7 E3
 - 8.920
 - 6.110
 - 3.301
 - 4.91
 - 2.318
 - 5.128
 - 7.937
 - 10.7 E3
 - >= 13.6 E3



Load 1




Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	3	Ref			
By		Date	04-Aug-17	Chd	
File	Wall 3.std	Date/Time	09-Sep-2017 10:11		





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 3

Ref

By Date 04-Aug-17 Chd Date/Time 09-Sep-2017 10:11

File Wall 3.std

- MY (local)
lb-in/in
- <= -22.5 E3
 - 20.5 E3
 - 18.4 E3
 - 16.3 E3
 - 14.2 E3
 - 12.1 E3
 - 10.1 E3
 - 7.986
 - 5.907
 - 3.829
 - 1.750
 - 329
 - 2408
 - 4486
 - 6565
 - 8644
 - >= 10.7 E3





Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 3

Ref

By Date 04-Aug-17

Chd


File Wall 3.std

Date/Time 09-Aug-2017 15:20

SQX (local)

psi

- <= -95.6
- 83.6
- 71.7
- 59.7
- 47.7
- 35.8
- 23.8
- 11.8
- 0.150
- 12.1
- 24.1
- 36.1
- 48
- 60
- 72
- 83.9
- >= 95.9



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall	3
-----------	---

Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 3.std	Date/Time	09-Sep-2017 10:11
------	------------	-----------	-------------------

- SQX (local)
psi
- <= -134
 - 117
 - 99.8
 - 82.9
 - 66
 - 49.1
 - 32.2
 - 15.3
 - 1.57
 - 18.5
 - 35.3
 - 52.2
 - 69.1
 - 86
 - 103
 - 120
 - >= 137



Load 2



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall	3
-----------	---


Ref	
-----	--

By		Date	04-Aug-17	Chd	
----	--	------	-----------	-----	--

File	Wall 3.std	Date/Time	09-Sep-2017 10:11
------	------------	-----------	-------------------

SQX (local)
psi

<= -103
-90
-76.7
-63.4
-50.2
-36.9
-23.6
-10.4
2.88
16.1
29.4
42.7
55.9
69.2
82.5
95.7
>= 109





Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 3	
-------------	--

Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 3.std	Date/Time	09-Aug-2017 15:20
------	------------	-----------	-------------------

- SQY (local)
psi
- <= -62.5
 - 54.7
 - 46.8
 - 38.9
 - 31
 - 23.1
 - 15.2
 - 7.36
 - 0.528
 - 8.41
 - 16.3
 - 24.2
 - 32.1
 - 39.9
 - 47.8
 - 55.7
 - >= 63.6



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No

10721A.10

Sheet No

1

Rev

Part/Wall 3

Ref

By

Date 04-Aug-17

Chd


File Wall 3.std

Date/Time 09-Sep-2017 10:11

SQY (local)

psi

- <= -85.7
- 75.5
- 65.3
- 55.1
- 44.9
- 34.7
- 24.5
- 14.3
- 4.06
- 6.14
- 16.3
- 26.5
- 36.7
- 46.9
- 57.1
- 67.3
- >= 77.5



Load 2



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	3				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 3.std	Date/Time	09-Sep-2017 10:11		

- SQY (local)
psi
- <= -67.6
 - 60.4
 - 53.3
 - 46.1
 - 39
 - 31.9
 - 24.7
 - 17.6
 - 10.4
 - 3.28
 - 3.86
 - 11
 - 18.2
 - 25.3
 - 32.4
 - 39.6
 - >= 46.7



Area 4 - Actiflo™
Wall 4 - Moment & Shear

		Horizontal Span - Outside Face				
	S _d	M _{ux} (k-ft)	S _d *M _{ux} (k-ft)	M _n (k-ft)	DCR	
1.0F-0.6H	1.00	3.10	3.10	18.50	0.17	
1.0F+1.4E-0.6H	1.00	4.23	4.23	18.50	0.23	
1.6(H+L)	1.41	14.75	20.80	18.50	1.12	
1.6H+1.4E	1.00	11.79	11.79	18.50	0.64	
				V _u (kip)	V _n (kip)	DCR
1.0F-0.6H	1.00			0.00	14.51	0.00
1.0F+1.4E-0.6H	1.00			0.00	14.51	0.00
1.6(H+L)	1.41			6.88	14.51	0.47
1.6H+1.4E	1.00			5.57	14.51	0.38

		Vertical Span (Mid-Height) - Outside Face				
	S _d	M _{uy} (k-ft)	S _d *M _{uy} (k-ft)	M _n (k-ft)	DCR	
1.0F-0.6H	1.00	7.63	7.63	27.50	0.28	
1.0F+1.4E-0.6H	1.00	10.39	10.39	27.50	0.38	
				V _u (kip)	V _n (kip)	DCR
1.0F-0.6H	1.00			0.00	14.51	0.00
1.0F+1.4E-0.6H	1.00			0.00	14.51	0.00

		Vertical Span (Bottom) - Outside Face				
	S _d	M _{uy} (k-ft)	S _d *M _{uy} (k-ft)	M _n (k-ft)	DCR	
1.6(H+L)	1.41	31.34	44.20	51.50	0.86	
1.6H+1.4E	1.00	25.87	25.87	51.50	0.50	
				V _u (kip)	V _n (kip)	DCR
1.6(H+L)	1.41			11.13	14.51	0.77
1.6H+1.4E	1.00			9.59	14.51	0.66

		Horizontal Span - Inside Face				
	S _d	M _{ux} (k-ft)	S _d *M _{ux} (k-ft)	M _n (k-ft)	DCR	
1.0F-0.6H	1.00	8.95	8.95	13.00	0.69	
1.0F+1.4E-0.6H	1.00	12.25	12.25	13.00	0.94	
1.6(H+L)	1.41	4.67	6.59	13.00	0.51	
1.6H+1.4E	1.00	3.68	3.68	13.00	0.28	
				V _u (kip)	V _n (kip)	DCR
1.0F-0.6H	1.00			3.85	14.51	0.27
1.0F+1.4E-0.6H	1.00			5.37	14.51	0.37
1.6(H+L)	1.41			0.00	14.51	0.00
1.6H+1.4E	1.00			0.00	14.51	0.00


		Vertical Span (Mid-Height) - Inside Face				
	S _d	M _{uy} (k-ft)	S _d *M _{uy} (k-ft)	M _n (k-ft)	DCR	
1.6(H+L)	1.41	12.45	17.55	35.00	0.50	
1.6H+1.4E	1.00	10.06	10.06	35.00	0.29	
				V _u (kip)	V _n (kip)	DCR
1.6(H+L)	1.41			0.00	14.51	0.00
1.6H+1.4E	1.00			0.00	14.51	0.00

		Vertical Span (Bottom) - Inside Face				
	S _d	M _{uy} (k-ft)	S _d *M _{uy} (k-ft)	M _n (k-ft)	DCR	
1.0F-0.6H	1.00	17.63	17.63	66.00	0.27	
1.0F+1.4E-0.6H	1.00	24.61	24.61	66.00	0.37	
				V _u (kip)	V _n (kip)	DCR
1.0F-0.6H	1.00			5.77	14.51	0.40
1.0F+1.4E-0.6H	1.00			8.16	14.51	0.56


BY: C. Che DATE: Aug-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrostatic - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 19.67 = 39.34$ ft
 plate dimension, a = **19.67** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.9516



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	19.000	1.186	1	1
B	400	15.500	-0.853	0.6	0.6
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrostatic - Soil Static

M _x - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186	-0.853							Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		506.717	-364.443										
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0149	0.0095			7.54	-3.47			4.07	5.46	0.14	0.36
0	0.6	0.0252	0.0174			12.75	-6.34			6.41	8.95	0.23	0.36
0	0.4	0.0256	0.0195			12.98	-7.10			5.88	8.72	0.22	0.36
0	0.2	0.0131	0.0109			6.65	-3.96			2.69	4.27	0.11	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0037	0.0032			1.90	-1.18			0.72	1.19	0.03	0.36
0.4	0	0.0072	0.0060			3.65	-2.18			1.48	2.35	0.06	0.36
0.6	0	0.0093	0.0075			4.71	-2.75			1.96	3.06	0.08	0.36
0.8	0	0.0103	0.0083			5.23	-3.03			2.20	3.41	0.08	0.36
1	0	0.0107	0.0086			5.41	-3.12			2.29	3.54	0.09	0.36
1	0.2	-0.0016	-0.0016			-0.80	0.57			-0.23	-0.46	-0.01	-0.36
1	0.4	-0.0079	-0.0060			-4.02	2.19			-1.83	-2.70	-0.07	-0.36
1	0.6	-0.0086	-0.0059			-4.35	2.15			-2.20	-3.06	-0.08	-0.36
1	0.8	-0.0053	-0.0034			-2.68	1.23			-1.44	-1.94	-0.05	-0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.8	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.8	0.8	-0.0053	-0.0034			-2.69	1.23			-1.46	-1.95	-0.05	-0.36
0.8	0.6	-0.0086	-0.0059			-4.38	2.14			-2.24	-3.10	-0.08	-0.36
0.8	0.4	-0.0080	-0.0061			-4.08	2.22			-1.86	-2.75	-0.07	-0.36
0.8	0.2	-0.0018	-0.0017			-0.91	0.61			-0.30	-0.54	-0.01	-0.36

max negative moment, M_{ux}(-) = -3.10 ft-k/ft

max negative steel req'd, A_s(-) = -0.08 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 8.95 ft-k/ft

max positive steel req'd, A_s(+) = 0.23 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrostatic - Soil Static

M _y - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186	-0.853							Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		506.717	-364.443										
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0030	0.0019			1.50	-0.70			0.80	1.08	0.03	0.36
0	0.6	0.0051	0.0035			2.56	-1.28			1.28	1.79	0.04	0.36
0	0.4	0.0051	0.0039			2.59	-1.41			1.18	1.74	0.04	0.36
0	0.2	0.0026	0.0022			1.33	-0.80			0.52	0.84	0.02	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0187	0.0161			9.50	-5.88			3.62	5.97	0.14	0.36
0.4	0	0.0359	0.0298			18.21	-10.87			7.34	11.69	0.28	0.37
0.6	0	0.0465	0.0378			23.54	-13.78			9.76	15.28	0.37	0.38
0.8	0	0.0517	0.0416			26.19	-15.17			11.02	17.09	0.41	0.38
1	0	0.0533	0.0428			26.99	-15.59			11.40	17.63	0.43	0.38
1	0.2	-0.0009	-0.0026			-0.45	0.95			0.50	0.12	0.00	0.36
1	0.4	-0.0211	-0.0166			-10.68	6.06			-4.61	-7.04	-0.17	-0.36
1	0.6	-0.0211	-0.0139			-10.67	5.06			-5.61	-7.63	-0.18	-0.36
1	0.8	-0.0120	-0.0068			-6.09	2.47			-3.62	-4.61	-0.11	-0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
1	0.4	-0.0211	-0.0166			-10.68	6.06			-4.61	-7.04	-0.17	-0.36
0.8	0.4	-0.0204	-0.0161			-10.33	5.88			-4.46	-6.81	-0.16	-0.36
0.6	0.4	-0.0181	-0.0144			-9.15	5.24			-3.91	-6.01	-0.14	-0.36
0.4	0.4	-0.0134	-0.0108			-6.78	3.92			-2.86	-4.43	-0.10	-0.36
0.2	0.4	-0.0055	-0.0046			-2.78	1.68			-1.11	-1.78	-0.04	-0.36

max negative moment, M_{uy}(-) = -7.63 ft-k/ft

max negative steel req'd, A_s(-) = -0.18 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 17.63 ft-k/ft

max positive steel req'd, A_s(+) = 0.43 in²/ft

minimum steel req'd = 0.38 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrostatic - Soil Static

Shear Summary												
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	-0.0632	-0.0414			-1.55	0.73			-0.82	-1.11	10.81
0	0.8	0.1004	0.0516			2.46	-0.91			1.55	1.92	10.81
0	0.6	0.1909	0.1217			4.68	-2.15			2.53	3.39	10.81
0	0.4	0.2393	0.1906			5.87	-3.36			2.51	3.85	10.81
0	0.2	0.1431	0.1364			3.51	-2.40			1.10	2.06	10.81
0	0.00	-0.0111	-0.0017			-0.27	0.03			-0.24	-0.25	10.81
0.2	0	0.1892	0.1809			4.64	-3.19			1.45	2.72	10.81
0.4	0	0.3061	0.2753			7.50	-4.85			2.65	4.59	10.81
0.6	0	0.3543	0.3116			8.69	-5.49			3.19	5.39	10.81
0.8	0	0.3724	0.3246			9.13	-5.72			3.40	5.69	10.81
1	0	0.3768	0.3277			9.24	-5.78			3.46	5.77	10.81
0.2	1	-0.0071	-0.0119			-0.17	0.21			0.04	-0.05	10.81
0.4	1	0.0520	0.0266			1.27	-0.47			0.81	0.99	10.81
0.6	1	0.0771	0.0437			1.89	-0.77			1.12	1.43	10.81
0.8	1	0.0863	0.0501			2.11	-0.88			1.23	1.58	10.81
1	1	0.0885	0.0516			2.17	-0.91			1.26	1.62	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 5.77 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrodynamical - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 19.67 = 39.34$ ft
 plate dimension, a = **19.67** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.9516



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	19.000	1.186	1	1
B	400	15.500	-0.853	0.6	0.6
C	400	19.000	0.066	1.4	1.4
D	400	19.000	0.153	1.4	1.4

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrodynamical - Soil Static

M _x - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186	-0.853	0.066	0.153					Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		506.717	-364.443	28.198	65.369								
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0	0.8	0.0149	0.0095	0.0149	0.0149	7.54	-3.47	0.42	0.97	5.46	7.41	0.19	0.36
0	0.6	0.0252	0.0174	0.0252	0.0252	12.75	-6.34	0.71	1.64	8.77	12.25	0.31	0.36
0	0.4	0.0256	0.0195	0.0256	0.0256	12.98	-7.10	0.72	1.67	8.27	12.07	0.31	0.36
0	0.2	0.0131	0.0109	0.0131	0.0131	6.65	-3.96	0.37	0.86	3.92	5.99	0.15	0.36
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0.2	0	0.0037	0.0032	0.0037	0.0037	1.90	-1.18	0.11	0.24	1.07	1.68	0.04	0.36
0.4	0	0.0072	0.0060	0.0072	0.0072	3.65	-2.18	0.20	0.47	2.15	3.29	0.08	0.36
0.6	0	0.0093	0.0075	0.0093	0.0093	4.71	-2.75	0.26	0.61	2.83	4.28	0.11	0.36
0.8	0	0.0103	0.0083	0.0103	0.0103	5.23	-3.03	0.29	0.67	3.17	4.77	0.12	0.36
1	0	0.0107	0.0086	0.0107	0.0107	5.41	-3.12	0.30	0.70	3.29	4.94	0.12	0.36
1	0.2	-0.0016	-0.0016	-0.0016	-0.0016	-0.80	0.57	-0.04	-0.10	-0.38	-0.67	-0.02	-0.36
1	0.4	-0.0079	-0.0060	-0.0079	-0.0079	-4.02	2.19	-0.22	-0.52	-2.57	-3.74	-0.09	-0.36
1	0.6	-0.0086	-0.0059	-0.0086	-0.0086	-4.35	2.15	-0.24	-0.56	-3.01	-4.19	-0.10	-0.36
1	0.8	-0.0053	-0.0034	-0.0053	-0.0053	-2.68	1.23	-0.15	-0.35	-1.94	-2.63	-0.07	-0.36
1	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0.8	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0.8	0.8	-0.0053	-0.0034	-0.0053	-0.0053	-2.69	1.23	-0.15	-0.35	-1.95	-2.64	-0.07	-0.36
0.8	0.6	-0.0086	-0.0059	-0.0086	-0.0086	-4.38	2.14	-0.24	-0.57	-3.05	-4.23	-0.11	-0.36
0.8	0.4	-0.0080	-0.0061	-0.0080	-0.0080	-4.08	2.22	-0.23	-0.53	-2.61	-3.80	-0.09	-0.36
0.8	0.2	-0.0018	-0.0017	-0.0018	-0.0018	-0.91	0.61	-0.05	-0.12	-0.46	-0.78	-0.02	-0.36

max negative moment, M_{ux}(-) = -4.23 ft-k/ft

max negative steel req'd, A_s(-) = -0.11 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 12.25 ft-k/ft

max positive steel req'd, A_s(+) = 0.31 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrodynami - Soil Static

M _y - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.186	-0.853	0.066	0.153					Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
0	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0	0.8	0.0030	0.0019	0.0030	0.0030	1.50	-0.70	0.08	0.19	1.08	1.47	0.03	0.36
0	0.6	0.0051	0.0035	0.0051	0.0051	2.56	-1.28	0.14	0.33	1.76	2.46	0.06	0.36
0	0.4	0.0051	0.0039	0.0051	0.0051	2.59	-1.41	0.14	0.33	1.65	2.41	0.06	0.36
0	0.2	0.0026	0.0022	0.0026	0.0026	1.33	-0.80	0.07	0.17	0.77	1.19	0.03	0.36
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0.2	0	0.0187	0.0161	0.0187	0.0187	9.50	-5.88	0.53	1.23	5.37	8.42	0.20	0.36
0.4	0	0.0359	0.0298	0.0359	0.0359	18.21	-10.87	1.01	2.35	10.70	16.40	0.40	0.38
0.6	0	0.0465	0.0378	0.0465	0.0465	23.54	-13.78	1.31	3.04	14.11	21.36	0.52	0.38
0.8	0	0.0517	0.0416	0.0517	0.0517	26.19	-15.17	1.46	3.38	15.85	23.86	0.58	0.38
1	0	0.0533	0.0428	0.0533	0.0533	26.99	-15.59	1.50	3.48	16.38	24.61	0.60	0.38
1	0.2	-0.0009	-0.0026	-0.0009	-0.0009	-0.45	0.95	-0.03	-0.06	0.42	0.00	0.00	0.36
1	0.4	-0.0211	-0.0166	-0.0211	-0.0211	-10.68	6.06	-0.59	-1.38	-6.58	-9.80	-0.23	-0.36
1	0.6	-0.0211	-0.0139	-0.0211	-0.0211	-10.67	5.06	-0.59	-1.38	-7.58	-10.39	-0.25	-0.36
1	0.8	-0.0120	-0.0068	-0.0120	-0.0120	-6.09	2.47	-0.34	-0.79	-4.75	-6.19	-0.15	-0.36
1	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
1	0.4	-0.0211	-0.0166	-0.0211	-0.0211	-10.68	6.06	-0.59	-1.38	-6.58	-9.80	-0.23	-0.36
0.8	0.4	-0.0204	-0.0161	-0.0204	-0.0204	-10.33	5.88	-0.58	-1.33	-6.37	-9.48	-0.23	-0.36
0.6	0.4	-0.0181	-0.0144	-0.0181	-0.0181	-9.15	5.24	-0.51	-1.18	-5.60	-8.38	-0.20	-0.36
0.4	0.4	-0.0134	-0.0108	-0.0134	-0.0134	-6.78	3.92	-0.38	-0.87	-4.11	-6.18	-0.15	-0.36
0.2	0.4	-0.0055	-0.0046	-0.0055	-0.0055	-2.78	1.68	-0.15	-0.36	-1.62	-2.50	-0.06	-0.36

max negative moment, M_{uy}(-) = -10.39 ft-k/ft

max negative steel req'd, A_s(-) = -0.25 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 24.61 ft-k/ft

max positive steel req'd, A_s(+) = 0.60 in²/ft

minimum steel req'd = 0.38 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 4: Hydrodynami - Soil Static

Shear Summary												
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY		
		1.186	-0.853	0.066	0.153					Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		24.515	-17.632	1.364	3.163							
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	-0.0632	-0.0414	-0.0632	-0.0632	-1.55	0.73	-0.09	-0.20	-1.11	-1.51	10.81
0	0.8	0.1004	0.0516	0.1004	0.1004	2.46	-0.91	0.14	0.32	2.01	2.55	10.81
0	0.6	0.1909	0.1217	0.1909	0.1909	4.68	-2.15	0.26	0.60	3.40	4.60	10.81
0	0.4	0.2393	0.1906	0.2393	0.2393	5.87	-3.36	0.33	0.76	3.59	5.37	10.81
0	0.2	0.1431	0.1364	0.1431	0.1431	3.51	-2.40	0.20	0.45	1.75	2.97	10.81
0	0.00	-0.0111	-0.0017	-0.0111	-0.0111	-0.27	0.03	-0.02	-0.04	-0.29	-0.33	10.81
0.2	0	0.1892	0.1809	0.1892	0.1892	4.64	-3.19	0.26	0.60	2.30	3.92	10.81
0.4	0	0.3061	0.2753	0.3061	0.3061	7.50	-4.85	0.42	0.97	4.03	6.53	10.81
0.6	0	0.3543	0.3116	0.3543	0.3543	8.69	-5.49	0.48	1.12	4.80	7.63	10.81
0.8	0	0.3724	0.3246	0.3724	0.3724	9.13	-5.72	0.51	1.18	5.09	8.05	10.81
1	0	0.3768	0.3277	0.3768	0.3768	9.24	-5.78	0.51	1.19	5.16	8.16	10.81
0.2	1	-0.0071	-0.0119	-0.0071	-0.0071	-0.17	0.21	-0.01	-0.02	0.00	-0.09	10.81
0.4	1	0.0520	0.0266	0.0520	0.0520	1.27	-0.47	0.07	0.16	1.04	1.32	10.81
0.6	1	0.0771	0.0437	0.0771	0.0771	1.89	-0.77	0.11	0.24	1.47	1.92	10.81
0.8	1	0.0863	0.0501	0.0863	0.0863	2.11	-0.88	0.12	0.27	1.62	2.13	10.81
1	1	0.0885	0.0516	0.0885	0.0885	2.17	-0.91	0.12	0.28	1.66	2.18	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 8.16 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 19.67 = 39.34$ ft
 plate dimension, a = **19.67** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.9516



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	15.500	0.853	2.25	1.6
B	100	15.500	0.100	2.25	1.6
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil Static

M _x - Moment Summary																	
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY							
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 9")					
		x / a		y / b		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft				
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36				
0	0.8	0.0095	0.0309			3.47	1.32			4.79	10.78	0.27	0.36				
0	0.6	0.0174	0.0524			6.34	2.24			8.58	19.30	0.50	0.36				
0	0.4	0.0195	0.0495			7.10	2.11			9.22	20.74	0.54	0.36				
0	0.2	0.0109	0.0221			3.96	0.95			4.91	11.04	0.28	0.36				
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36				
0.2	0	0.0032	0.0058			1.18	0.25			1.42	3.20	0.08	0.36				
0.4	0	0.0060	0.0120			2.18	0.51			2.69	6.05	0.15	0.36				
0.6	0	0.0075	0.0160			2.75	0.68			3.43	7.73	0.19	0.36				
0.8	0	0.0083	0.0181			3.03	0.77			3.80	8.55	0.22	0.36				
1	0	0.0086	0.0187			3.12	0.80			3.92	8.82	0.22	0.36				
1	0.2	-0.0016	-0.0018			-0.57	-0.08			-0.64	-1.45	-0.04	-0.36				
1	0.4	-0.0060	-0.0154			-2.19	-0.66			-2.85	-6.41	-0.16	-0.36				
1	0.6	-0.0059	-0.0182			-2.15	-0.78			-2.92	-6.58	-0.16	-0.36				
1	0.8	-0.0034	-0.0109			-1.23	-0.46			-1.70	-3.82	-0.10	-0.36				
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36				
0.8	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36				
0.8	0.8	-0.0034	-0.0108			-1.23	-0.46			-1.69	-3.80	-0.09	-0.36				
0.8	0.6	-0.0059	-0.0183			-2.14	-0.78			-2.92	-6.58	-0.16	-0.36				
0.8	0.4	-0.0061	-0.0157			-2.22	-0.67			-2.89	-6.50	-0.16	-0.36				
0.8	0.2	-0.0017	-0.0022			-0.61	-0.10			-0.71	-1.59	-0.04	-0.36				

max negative moment, M_{ux}(-) = -6.58 ft-k/ft

max negative steel req'd, A_s(-) = -0.16 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 20.74 ft-k/ft

max positive steel req'd, A_s(+) = 0.54 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil Static

M _y - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.853	0.100							Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		364.443	42.725										
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0019	0.0062			0.70	0.26			0.97	2.18	0.05	0.36
0	0.6	0.0035	0.0105			1.28	0.45			1.73	3.88	0.09	0.36
0	0.4	0.0039	0.0099			1.41	0.42			1.84	4.13	0.10	0.36
0	0.2	0.0022	0.0044			0.80	0.19			0.99	2.23	0.05	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0161	0.0295			5.88	1.26			7.14	16.07	0.39	0.38
0.4	0	0.0298	0.0601			10.87	2.57			13.44	30.23	0.75	0.38
0.6	0	0.0378	0.0801			13.78	3.42			17.20	38.71	0.98	0.38
0.8	0	0.0416	0.0904			15.17	3.86			19.03	42.82	1.09	0.38
1	0	0.0428	0.0935			15.59	3.99			19.59	44.07	1.13	0.38
1	0.2	-0.0026	0.0044			-0.95	0.19			-0.76	-1.72	-0.04	-0.36
1	0.4	-0.0166	-0.0401			-6.06	-1.71			-7.78	-17.50	-0.42	-0.38
1	0.6	-0.0139	-0.0466			-5.06	-1.99			-7.05	-15.87	-0.38	-0.38
1	0.8	-0.0068	-0.0249			-2.47	-1.06			-3.53	-7.95	-0.19	-0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
1	0.4	-0.0166	-0.0401			-6.06	-1.71			-7.78	-17.50	-0.42	-0.38
0.8	0.4	-0.0161	-0.0387			-5.88	-1.65			-7.53	-16.94	-0.41	-0.38
0.6	0.4	-0.0144	-0.0342			-5.24	-1.46			-6.70	-15.07	-0.36	-0.38
0.4	0.4	-0.0108	-0.0251			-3.92	-1.07			-4.99	-11.23	-0.27	-0.36
0.2	0.4	-0.0046	-0.0101			-1.68	-0.43			-2.11	-4.74	-0.11	-0.36

max negative moment, M_{uy}(-) = -17.50 ft-k/ft

max negative steel req'd, A_s(-) = -0.42 in²/ft

minimum steel req'd = -0.38 in²/ft

Use

max positive moment, M_{uy}(+) = 44.07 ft-k/ft

max positive steel req'd, A_s(+) = 1.13 in²/ft

minimum steel req'd = 0.38 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil Static

Shear Summary												
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q , or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	-0.0414	-0.1279			-0.73	-0.26			-0.99	-1.59	10.81
0	0.8	0.0516	0.2002			0.91	0.41			1.32	2.12	10.81
0	0.6	0.1217	0.4431			2.15	0.92			3.06	4.90	10.81
0	0.4	0.1906	0.4539			3.36	0.94			4.30	6.88	10.81
0	0.2	0.1364	0.1762			2.40	0.36			2.77	4.43	10.81
0	0.00	-0.0017	-0.0486			-0.03	-0.10			-0.13	-0.21	10.81
0.2	0	0.1809	0.2280			3.19	0.47			3.66	5.86	10.81
0.4	0	0.2753	0.4329			4.85	0.89			5.75	9.20	10.81
0.6	0	0.3116	0.5256			5.49	1.09			6.58	10.53	10.81
0.8	0	0.3246	0.5619			5.72	1.16			6.89	11.02	10.81
1	0	0.3277	0.5711			5.78	1.18			6.96	11.13	10.81
0.2	1	-0.0119	-0.0080			-0.21	-0.02			-0.23	-0.36	10.81
0.4	1	0.0266	0.1144			0.47	0.24			0.70	1.13	10.81
0.6	1	0.0437	0.1659			0.77	0.34			1.11	1.78	10.81
0.8	1	0.0501	0.1848			0.88	0.38			1.27	2.02	10.81
1	1	0.0516	0.1893			0.91	0.39			1.30	2.08	10.81

NG
NG

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 11.13 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

SHEAR NOT SATISFIED ! , CHANGE PLATE THICKNESS, or CHECK SHEAR AT DISTANCE "d".

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil EQ

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 19.67 = 39.34$ ft
 plate dimension, a = **19.67** ft
 plate dimension, b = **20.67** ft
 plate sides ratio, a/b = 0.9516



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	15.500	0.853	1.6	1.6
B	400	15.500	0.412	1.4	1.4
C	400	15.500	-0.376	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$ ", and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil EQ

M _x - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.853	0.412	-0.376						Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients				A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0	0.8	0.0095	0.0095	0.0095		3.47	1.68	-1.53		3.62	5.76	0.14	0.36
0	0.6	0.0174	0.0174	0.0174		6.34	3.06	-2.79		6.60	10.51	0.27	0.36
0	0.4	0.0195	0.0195	0.0195		7.10	3.43	-3.13		7.40	11.79	0.30	0.36
0	0.2	0.0109	0.0109	0.0109		3.96	1.91	-1.75		4.13	6.57	0.16	0.36
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.2	0	0.0032	0.0032	0.0032		1.18	0.57	-0.52		1.22	1.95	0.05	0.36
0.4	0	0.0060	0.0060	0.0060		2.18	1.05	-0.96		2.27	3.61	0.09	0.36
0.6	0	0.0075	0.0075	0.0075		2.75	1.33	-1.21		2.87	4.56	0.11	0.36
0.8	0	0.0083	0.0083	0.0083		3.03	1.46	-1.34		3.16	5.03	0.13	0.36
1	0	0.0086	0.0086	0.0086		3.12	1.51	-1.38		3.25	5.18	0.13	0.36
1	0.2	-0.0016	-0.0016	-0.0016		-0.57	-0.27	0.25		-0.59	-0.94	-0.02	-0.36
1	0.4	-0.0060	-0.0060	-0.0060		-2.19	-1.06	0.97		-2.28	-3.63	-0.09	-0.36
1	0.6	-0.0059	-0.0059	-0.0059		-2.15	-1.04	0.95		-2.24	-3.56	-0.09	-0.36
1	0.8	-0.0034	-0.0034	-0.0034		-1.23	-0.60	0.54		-1.28	-2.04	-0.05	-0.36
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.8	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.8	0.8	-0.0034	-0.0034	-0.0034		-1.23	-0.59	0.54		-1.28	-2.04	-0.05	-0.36
0.8	0.6	-0.0059	-0.0059	-0.0059		-2.14	-1.03	0.94		-2.23	-3.55	-0.09	-0.36
0.8	0.4	-0.0061	-0.0061	-0.0061		-2.22	-1.07	0.98		-2.31	-3.68	-0.09	-0.36
0.8	0.2	-0.0017	-0.0017	-0.0017		-0.61	-0.30	0.27		-0.64	-1.02	-0.03	-0.36

max negative moment, M_{ux}(-) = -3.68 ft-k/ft

max negative steel req'd, A_s(-) = -0.09 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 11.79 ft-k/ft

max positive steel req'd, A_s(+) = 0.30 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil EQ

M _y - Moment Summary													
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.853	0.412	-0.376						Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0	0.8	0.0019	0.0019	0.0019		0.70	0.34	-0.31		0.73	1.17	0.03	0.36
0	0.6	0.0035	0.0035	0.0035		1.28	0.62	-0.56		1.33	2.12	0.05	0.36
0	0.4	0.0039	0.0039	0.0039		1.41	0.68	-0.62		1.47	2.34	0.06	0.36
0	0.2	0.0022	0.0022	0.0022		0.80	0.39	-0.35		0.84	1.33	0.03	0.36
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.2	0	0.0161	0.0161	0.0161		5.88	2.84	-2.59		6.13	9.76	0.23	0.36
0.4	0	0.0298	0.0298	0.0298		10.87	5.25	-4.79		11.33	18.03	0.44	0.38
0.6	0	0.0378	0.0378	0.0378		13.78	6.66	-6.07		14.36	22.86	0.56	0.38
0.8	0	0.0416	0.0416	0.0416		15.17	7.33	-6.69		15.81	25.17	0.62	0.38
1	0	0.0428	0.0428	0.0428		15.59	7.53	-6.87		16.25	25.87	0.64	0.38
1	0.2	-0.0026	-0.0026	-0.0026		-0.95	-0.46	0.42		-0.99	-1.58	-0.04	-0.36
1	0.4	-0.0166	-0.0166	-0.0166		-6.06	-2.93	2.67		-6.32	-10.06	-0.24	-0.36
1	0.6	-0.0139	-0.0139	-0.0139		-5.06	-2.44	2.23		-5.27	-8.40	-0.20	-0.36
1	0.8	-0.0068	-0.0068	-0.0068		-2.47	-1.19	1.09		-2.57	-4.10	-0.10	-0.36
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
1	0.4	-0.0166	-0.0166	-0.0166		-6.06	-2.93	2.67		-6.32	-10.06	-0.24	-0.36
0.8	0.4	-0.0161	-0.0161	-0.0161		-5.88	-2.84	2.59		-6.12	-9.75	-0.23	-0.36
0.6	0.4	-0.0144	-0.0144	-0.0144		-5.24	-2.53	2.31		-5.46	-8.69	-0.21	-0.36
0.4	0.4	-0.0108	-0.0108	-0.0108		-3.92	-1.89	1.73		-4.09	-6.50	-0.15	-0.36
0.2	0.4	-0.0046	-0.0046	-0.0046		-1.68	-0.81	0.74		-1.75	-2.78	-0.07	-0.36

max negative moment, M_{uy}(-) = -10.06 ft-k/ft

max negative steel req'd, A_s(-) = -0.24 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 25.87 ft-k/ft

max positive steel req'd, A_s(+) = 0.64 in²/ft

minimum steel req'd = 0.38 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Soil EQ

Shear Summary												
a = 19.67 b = 20.67 a / b = 0.9516		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	-0.0414	-0.0414	-0.0414		-0.73	-0.35	0.32		-0.76	-1.21	10.81
0	0.8	0.0516	0.0516	0.0516		0.91	0.44	-0.40		0.95	1.51	10.81
0	0.6	0.1217	0.1217	0.1217		2.15	1.04	-0.95		2.24	3.56	10.81
0	0.4	0.1906	0.1906	0.1906		3.36	1.62	-1.48		3.50	5.57	10.81
0	0.2	0.1364	0.1364	0.1364		2.40	1.16	-1.06		2.51	3.99	10.81
0	0.00	-0.0017	-0.0017	-0.0017		-0.03	-0.01	0.01		-0.03	-0.05	10.81
0.2	0	0.1809	0.1809	0.1809		3.19	1.54	-1.41		3.32	5.29	10.81
0.4	0	0.2753	0.2753	0.2753		4.85	2.34	-2.14		5.06	8.05	10.81
0.6	0	0.3116	0.3116	0.3116		5.49	2.65	-2.42		5.73	9.12	10.81
0.8	0	0.3246	0.3246	0.3246		5.72	2.76	-2.52		5.97	9.50	10.81
1	0	0.3277	0.3277	0.3277		5.78	2.79	-2.55		6.02	9.59	10.81
0.2	1	-0.0119	-0.0119	-0.0119		-0.21	-0.10	0.09		-0.22	-0.35	10.81
0.4	1	0.0266	0.0266	0.0266		0.47	0.23	-0.21		0.49	0.78	10.81
0.6	1	0.0437	0.0437	0.0437		0.77	0.37	-0.34		0.80	1.28	10.81
0.8	1	0.0501	0.0501	0.0501		0.88	0.43	-0.39		0.92	1.47	10.81
1	1	0.0516	0.0516	0.0516		0.91	0.44	-0.40		0.95	1.51	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 9.59 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

**Area 4 - Actiflo™
Wall 5 - Moment & Shear**

		Horizontal Span						
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	SQX_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	5.55	8.94	13.00	0.69	34	126	0.27
1.2F+1.4E	1.00	6.92	6.92	13.00	0.53	42	126	0.33
1.4E (Water 2-Sides)	1.00	4.48	4.48	13.00	0.34	25	126	0.20

		Vertical Span (Mid-Height)						
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	2.00	3.22	14.50	0.22	0	126	0.00
1.2F+1.4E	1.00	2.34	2.34	14.50	0.16	0	126	0.00
1.4E (Water 2-Sides)	1.00	1.25	1.25	14.50	0.09	0	126	0.00

		Vertical Span (Bottom)						
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	4.60	7.41	14.50	0.51	35	126	0.28
1.2F+1.4E	1.00	5.55	5.55	14.50	0.38	42	126	0.33
1.4E (Water 2-Sides)	1.00	3.18	3.18	14.50	0.22	23	126	0.18

<- OK
 <- OK
 <- OK
 <- OK
 <- OK
 <- OK



Software licensed to Carollo Engineers


Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willametter River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	5				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 5.std	Date/Time	09-Aug-2017 15:39		

- MX (local)
- lb-in/in
- <= -5555
- 4980
- 4405
- 3830
- 3255
- 2681
- 2106
- 1531
- 956
- 381
- 194
- 769
- 1343
- 1918
- 2493
- 3068
- >= 3643



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	5				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 5.std	Date/Time	09-Sep-2017 21:45		

- MX (local)
- lb-in/in
- <= -6924
- 6206
- 5488
- 4769
- 4051
- 3333
- 2615
- 1897
- 1178
- 460
- 258
- 976
- 1694
- 2412
- 3131
- 3849
- >= 4567





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	5	Ref			
By		Date	04-Aug-17	Chd	
File	Wall 5.std	Date/Time	09-Sep-2017 21:45		

- MX (local)
- lb-in/in
- <= -4481
- 4015
- 3549
- 3084
- 2618
- 2153
- 1687
- 1221
- 756
- 290
- 176
- 641
- 1107
- 1573
- 2038
- 2504
- >= 2969





Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev
--------	-----------	----------	---	-----


PartWall 5

Ref

By Date04-Aug-17 Chd

File Wall 5.std Date/Time 09-Aug-2017 15:39

- MY (local)
- lb-in/in
- <= -4621
- 4208
- 3794
- 3381
- 2967
- 2553
- 2140
- 1726
- 1313
- 899
- 485
- 71.8
- 342
- 755
- 1169
- 1583
- >= 1996





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	5				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 5.std	Date/Time	09-Sep-2017 21:45		

- MY (local)
- lb-in/in
- <= -5550
- 5057
- 4564
- 4071
- 3578
- 3085
- 2592
- 2099
- 1606
- 1113
- 620
- 127
- 366
- 859
- 1352
- 1845
- >= 2338





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall	5
-----------	---

Ref	
-----	--

By		Date	04-Aug-17	Chd	
----	--	------	-----------	-----	--

File	Wall 5.std	Date/Time	09-Sep-2017 21:45
------	------------	-----------	-------------------

- MY (local)
- lb-in/in
- <= -3178
- 2901
- 2624
- 2347
- 2070
- 1793
- 1516
- 1239
- 962
- 685
- 408
- 131
- 146
- 423
- 700
- 977
- >= 1254





Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willametter River WTP

Job No
10721A.10

Sheet No

1

Page 158

PartWall 5

Ref

By

Date04-Aug-17

Chd


File Wall 5.std

Date/Time 09-Aug-2017 15:39

SQX (local)

psi

- <= -34.1
- 29.8
- 25.6
- 21.3
- 17
- 12.8
- 8.52
- 4.26
- 0
- 4.26
- 8.52
- 12.8
- 17
- 21.3
- 25.6
- 29.8
- >= 34.1





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall	5
-----------	---


Ref	
-----	--

By		Date	04-Aug-17	Chd	
----	--	------	-----------	-----	--

File	Wall 5.std	Date/Time	09-Sep-2017 21:45
------	------------	-----------	-------------------

SQX (local)
psi

- <= -41.6
- 36.4
- 31.2
- 26
- 20.8
- 15.6
- 10.4
- 5.19
- 0
- 5.19
- 10.4
- 15.6
- 20.8
- 26
- 31.2
- 36.4
- >= 41.6





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall	5
-----------	---


Ref	
-----	--

By		Date	04-Aug-17	Chd	
----	--	------	-----------	-----	--

File	Wall 5.std	Date/Time	09-Sep-2017 21:45
------	------------	-----------	-------------------

SQX (local)
psi

- <= -25.3
- 22.1
- 18.9
- 15.8
- 12.6
- 9.47
- 6.32
- 3.16
- 0
- 3.16
- 6.32
- 9.47
- 12.6
- 15.8
- 18.9
- 22.1
- >= 25.3





Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 5

Ref

By

Date 04-Aug-17

Chd


File Wall 5.std

Date/Time 09-Aug-2017 15:39

SQY (local)

psi

- <= -9.3
- 6.51
- 3.72
- 0.936
- 1.85
- 4.64
- 7.42
- 10.2
- 13
- 15.8
- 18.6
- 21.4
- 24.1
- 26.9
- 29.7
- 32.5
- >= 35.3





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall	5
-----------	---

Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 5.std	Date/Time	09-Sep-2017 21:45
------	------------	-----------	-------------------

- SQY (local)
psi
- <= -11.3
 - 8.01
 - 4.69
 - 1.37
 - 1.95
 - 5.27
 - 8.59
 - 11.9
 - 15.2
 - 18.5
 - 21.9
 - 25.2
 - 28.5
 - 31.8
 - 35.1
 - 38.5
 - >= 41.8





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.4E (Water 2-Sides)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev
--------	-----------	----------	---	-----


Part/Wall 5

Ref

By Date 04-Aug-17 Chd

File Wall 5.std Date/Time 09-Sep-2017 21:45

- SQY (local)
psi
- <= -6.72
 - 4.86
 - 3
 - 1.14
 - 0.724
 - 2.59
 - 4.45
 - 6.31
 - 8.17
 - 10
 - 11.9
 - 13.8
 - 15.6
 - 17.5
 - 19.3
 - 21.2
 - >= 23.1



**Area 4 - Actiflo™
Wall 6A - Moment & Shear**

		Horizontal Span							
	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	V_u (Kip)	V_n (Kip)	DCR	
1.4E (Water 2-Sides)	1.4F	1.61	14.32	23.06	30.50	0.76	6.76	17.55	0.39
	1.2F+1.4E	1.00	19.84	19.84	30.50	0.65	8.45	17.55	0.48
	1.00	15.35	15.35	30.50	0.50	5.33	17.55	0.30	

		Vertical Span (Mid-Height)							
	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (Kip)	V_n (Kip)	DCR	
1.4E (Water 2-Sides)	1.4F	1.61	5.21	8.38	17.50	0.48	0.00	14.51	0.00
	1.2F+1.4E	1.00	6.30	6.30	17.50	0.36	0.00	14.51	0.00
	1.00	2.75	2.75	17.50	0.16	0.00	14.51	0.00	


		Vertical Span (Bottom)							
	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (Kip)	V_n (Kip)	DCR	
1.4E (Water 2-Sides)	1.4F	1.61	17.88	28.78	43.00	0.67	9.56	17.55	0.54
	1.2F+1.4E	1.00	22.55	22.55	43.00	0.52	11.65	17.55	0.66
	1.00	11.81	11.81	43.00	0.27	5.52	17.55	0.31	

<- OK
 <- OK
 <- OK
 <- OK
 <- OK
 <- OK


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6A - Hydrostatic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = 2*a = 2 * 9.5 = **19** ft
 plate dimension, a = **9.5** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.5938



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		1.186	2.25	1.4
B					
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **14** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	11"	3"
My bending	11.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6A - Hydrostatic

M _x - Moment Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 11")	
		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		x/a	y/b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0233				7.08				7.08	15.94	0.33	0.44
0	0.8	0.0294				8.94				8.94	20.11	0.42	0.44
0	0.6	0.0337				10.23				10.23	23.01	0.48	0.44
0	0.4	0.0314				9.54				9.54	21.47	0.45	0.44
0	0.2	0.0165				5.02				5.02	11.30	0.23	0.42
0	0	0.0000				0.00				0.00	0.00	0.00	0.42
0.2	0	0.0019				0.57				0.57	1.29	0.03	0.42
0.4	0	0.0044				1.33				1.33	3.00	0.06	0.42
0.6	0	0.0066				1.99				1.99	4.49	0.09	0.42
0.8	0	0.0079				2.40				2.40	5.41	0.11	0.42
1	0	0.0084				2.56				2.56	5.75	0.12	0.42
1	0.2	-0.0052				-1.57				-1.57	-3.52	-0.07	-0.42
1	0.4	-0.0136				-4.13				-4.13	-9.29	-0.19	-0.42
1	0.6	-0.0158				-4.80				-4.80	-10.81	-0.22	-0.42
1	0.8	-0.0148				-4.49				-4.49	-10.11	-0.21	-0.42
1	1	-0.0139				-4.22				-4.22	-9.48	-0.19	-0.42
0.8	1	-0.0121				-3.68				-3.68	-8.28	-0.17	-0.42
0.8	0.8	-0.0132				-4.00				-4.00	-8.99	-0.18	-0.42
0.8	0.6	-0.0144				-4.36				-4.36	-9.81	-0.20	-0.42
0.8	0.4	-0.0126				-3.83				-3.83	-8.61	-0.18	-0.42
0.8	0.2	-0.0050				-1.50				-1.50	-3.39	-0.07	-0.42

max negative moment, M_{ux}(-) = -10.81 ft-k/ft

max negative steel req'd, A_s(-) = -0.22 in²/ft

minimum steel req'd = -0.42 in²/ft

Use

max positive moment, M_{ux}(+) = 23.01 ft-k/ft

max positive steel req'd, A_s(+) = 0.48 in²/ft

minimum steel req'd = 0.44 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6A - Hydrostatic

M _y - Moment Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 11.5")	
		Moment Coefficients				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0000				0.00				0.00	0.00	0.00	0.42
0	0.8	0.0059				1.79				1.79	4.02	0.08	0.42
0	0.6	0.0068				2.06				2.06	4.63	0.09	0.42
0	0.4	0.0062				1.89				1.89	4.26	0.08	0.42
0	0.2	0.0033				1.01				1.01	2.27	0.04	0.42
0	0	0.0000				0.00				0.00	0.00	0.00	0.42
0.2	0	0.0093				2.81				2.81	6.33	0.12	0.42
0.4	0	0.0222				6.73				6.73	15.15	0.30	0.42
0.6	0	0.0330				10.01				10.01	22.53	0.45	0.46
0.8	0	0.0398				12.09				12.09	27.20	0.54	0.46
1	0	0.0421				12.77				12.77	28.74	0.58	0.46
1	0.2	-0.0027				-0.81				-0.81	-1.83	-0.04	-0.42
1	0.4	-0.0126				-3.82				-3.82	-8.61	-0.17	-0.42
1	0.6	-0.0097				-2.94				-2.94	-6.62	-0.13	-0.42
1	0.8	-0.0037				-1.11				-1.11	-2.50	-0.05	-0.42
1	1	0.0000				0.00				0.00	0.00	0.00	0.42
1	0.4	-0.0126				-3.82				-3.82	-8.61	-0.17	-0.42
0.8	0.4	-0.0119				-3.60				-3.60	-8.10	-0.16	-0.42
0.6	0.4	-0.0095				-2.89				-2.89	-6.50	-0.13	-0.42
0.4	0.4	-0.0056				-1.71				-1.71	-3.85	-0.07	-0.42
0.2	0.4	-0.0001				-0.03				-0.03	-0.06	0.00	-0.42

max negative moment, M_{uy}(-) = -8.61 ft-k/ft

max negative steel req'd, A_s(-) = -0.17 in²/ft

minimum steel req'd = -0.42 in²/ft

Use

max positive moment, M_{uy}(+) = 28.74 ft-k/ft

max positive steel req'd, A_s(+) = 0.58 in²/ft

minimum steel req'd = 0.46 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10721A.10
 DESIGN TASK: Wall 6A - Hydrostatic

Shear Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Shear Coefficient Multipliers								Final Shears			
		x / a	y / b	A	B	C	D	A	B	C	D	V k/ft	V _u k/ft
		1.186											
		18.976											
		Shear Coefficients				Shears, k/ft							
0	1	0.0530				1.00				1.00	1.41	13.09	
0	0.8	0.1616				3.07				3.07	4.29	13.09	
0	0.6	0.2202				4.18				4.18	5.85	13.09	
0	0.4	0.2546				4.83				4.83	6.76	13.09	
0	0.2	0.1522				2.89				2.89	4.04	13.09	
0	0.00	-0.0124				-0.24				-0.24	-0.33	13.09	
0.2	0	0.0940				1.78				1.78	2.50	13.09	
0.4	0	0.2242				4.25				4.25	5.96	13.09	
0.6	0	0.3044				5.78				5.78	8.09	13.09	
0.8	0	0.3468				6.58				6.58	9.21	13.09	
1	0	0.3600				6.83				6.83	9.56	13.09	

Concrete strength reduction factor for shear, φ = 0.75

d = 11.5 in

maximum shear, V_u = 9.56 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 11.5) / 1000 = 13.09 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = 2*a = 2 * 9.5 = **19** ft
 plate dimension, a = **9.5** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.5938



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		1.186	1.2	1.2
B	1		0.168	1.4	1.4
C	4		0.176	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **14** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	11"	3"
My bending	11.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic

M _x - Moment Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		1.186	0.168	0.176						Final Moments		Reinforcing: (d = 11")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
x / a	y / b	Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
		A	B	C	D	A	B	C	D				
0	1	0.0233	0.1174	0.0233		7.08	5.05	1.05		13.19	17.04	0.35	0.44
0	0.8	0.0294	0.1077	0.0294		8.94	4.63	1.33		14.90	19.07	0.40	0.44
0	0.6	0.0337	0.0905	0.0337		10.23	3.89	1.52		15.63	19.84	0.41	0.44
0	0.4	0.0314	0.0650	0.0314		9.54	2.79	1.42		13.75	17.35	0.36	0.44
0	0.2	0.0165	0.0271	0.0165		5.02	1.17	0.74		6.93	8.70	0.18	0.42
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.42
0.2	0	0.0019	0.0027	0.0019		0.57	0.12	0.09		0.78	0.97	0.02	0.42
0.4	0	0.0044	0.0071	0.0044		1.33	0.31	0.20		1.84	2.30	0.05	0.42
0.6	0	0.0066	0.0114	0.0066		1.99	0.49	0.30		2.78	3.49	0.07	0.42
0.8	0	0.0079	0.0142	0.0079		2.40	0.61	0.36		3.37	4.24	0.09	0.42
1	0	0.0084	0.0152	0.0084		2.56	0.65	0.38		3.59	4.51	0.09	0.42
1	0.2	-0.0052	-0.0088	-0.0052		-1.57	-0.38	-0.23		-2.18	-2.73	-0.06	-0.42
1	0.4	-0.0136	-0.0297	-0.0136		-4.13	-1.28	-0.61		-6.02	-7.60	-0.16	-0.42
1	0.6	-0.0158	-0.0433	-0.0158		-4.80	-1.86	-0.71		-7.38	-9.37	-0.19	-0.42
1	0.8	-0.0148	-0.0513	-0.0148		-4.49	-2.21	-0.67		-7.37	-9.42	-0.19	-0.42
1	1	-0.0139	-0.0572	-0.0139		-4.22	-2.46	-0.63		-7.30	-9.38	-0.19	-0.42
0.8	1	-0.0121	-0.0510	-0.0121		-3.68	-2.19	-0.55		-6.42	-8.25	-0.17	-0.42
0.8	0.8	-0.0132	-0.0459	-0.0132		-4.00	-1.97	-0.59		-6.56	-8.39	-0.17	-0.42
0.8	0.6	-0.0144	-0.0389	-0.0144		-4.36	-1.67	-0.65		-6.68	-8.48	-0.17	-0.42
0.8	0.4	-0.0126	-0.0270	-0.0126		-3.83	-1.16	-0.57		-5.56	-7.01	-0.14	-0.42
0.8	0.2	-0.0050	-0.0082	-0.0050		-1.50	-0.35	-0.22		-2.08	-2.61	-0.05	-0.42

max negative moment, M_{ux}(-) = -9.42 ft-k/ft

max negative steel req'd, A_s(-) = -0.19 in²/ft

minimum steel req'd = -0.42 in²/ft

Use

max positive moment, M_{ux}(+) = 19.84 ft-k/ft

max positive steel req'd, A_s(+) = 0.41 in²/ft

minimum steel req'd = 0.44 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic

M _y - Moment Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		1.186	0.168	0.176						Final Moments		Reinforcing: (d = 11.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		303.616	43.008	45.056									
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.42
0	0.8	0.0059	0.0215	0.0059		1.79	0.92	0.27		2.98	3.81	0.07	0.42
0	0.6	0.0068	0.0181	0.0068		2.06	0.78	0.31		3.14	3.99	0.08	0.42
0	0.4	0.0062	0.0130	0.0062		1.89	0.56	0.28		2.73	3.45	0.07	0.42
0	0.2	0.0033	0.0054	0.0033		1.01	0.23	0.15		1.39	1.74	0.03	0.42
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.42
0.2	0	0.0093	0.0134	0.0093		2.81	0.57	0.42		3.80	4.76	0.09	0.42
0.4	0	0.0222	0.0359	0.0222		6.73	1.55	1.00		9.28	11.64	0.23	0.42
0.6	0	0.0330	0.0569	0.0330		10.01	2.45	1.49		13.95	17.52	0.35	0.46
0.8	0	0.0398	0.0710	0.0398		12.09	3.05	1.79		16.94	21.30	0.42	0.46
1	0	0.0421	0.0759	0.0421		12.77	3.27	1.90		17.93	22.55	0.45	0.46
1	0.2	-0.0027	0.0064	-0.0027		-0.81	0.28	-0.12		-0.65	-0.75	-0.01	-0.42
1	0.4	-0.0126	-0.0152	-0.0126		-3.82	-0.65	-0.57		-5.04	-6.30	-0.12	-0.42
1	0.6	-0.0097	-0.0178	-0.0097		-2.94	-0.76	-0.44		-4.15	-5.21	-0.10	-0.42
1	0.8	-0.0037	-0.0122	-0.0037		-1.11	-0.53	-0.16		-1.80	-2.30	-0.04	-0.42
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.42
1	0.4	-0.0126	-0.0152	-0.0126		-3.82	-0.65	-0.57		-5.04	-6.30	-0.12	-0.42
0.8	0.4	-0.0119	-0.0141	-0.0119		-3.60	-0.61	-0.53		-4.74	-5.92	-0.12	-0.42
0.6	0.4	-0.0095	-0.0108	-0.0095		-2.89	-0.46	-0.43		-3.78	-4.72	-0.09	-0.42
0.4	0.4	-0.0056	-0.0051	-0.0056		-1.71	-0.22	-0.25		-2.19	-2.72	-0.05	-0.42
0.2	0.4	-0.0001	0.0029	-0.0001		-0.03	0.12	0.00		0.09	0.14	0.00	0.42

max negative moment, M_{uy}(-) = -6.30 ft-k/ft

max negative steel req'd, A_s(-) = -0.12 in²/ft

minimum steel req'd = -0.42 in²/ft

Use

max positive moment, M_{uy}(+) = 22.55 ft-k/ft

max positive steel req'd, A_s(+) = 0.45 in²/ft

minimum steel req'd = 0.46 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic

Shear Summary												
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		1.186	0.168	0.176						Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		18.976	2.688	2.816								
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	0.0530	0.6299	0.0530		1.00	1.69	0.15		2.85	3.79	13.09
0	0.8	0.1616	0.6334	0.1616		3.07	1.70	0.46		5.22	6.70	13.09
0	0.6	0.2202	0.5392	0.2202		4.18	1.45	0.62		6.25	7.91	13.09
0	0.4	0.2546	0.4388	0.2546		4.83	1.18	0.72		6.73	8.45	13.09
0	0.2	0.1522	0.1701	0.1522		2.89	0.46	0.43		3.77	4.71	13.09
0	0.00	-0.0124	-0.0469	-0.0124		-0.24	-0.13	-0.03		-0.40	-0.51	13.09
0.2	0	0.0940	0.0609	0.0940		1.78	0.16	0.26		2.21	2.74	13.09
0.4	0	0.2242	0.2695	0.2242		4.25	0.72	0.63		5.61	7.00	13.09
0.6	0	0.3044	0.4219	0.3044		5.78	1.13	0.86		7.77	9.72	13.09
0.8	0	0.3468	0.5114	0.3468		6.58	1.37	0.98		8.93	11.19	13.09
1	0	0.3600	0.5406	0.3600		6.83	1.45	1.01		9.30	11.65	13.09

Concrete strength reduction factor for shear, φ = 0.75

d = 11.5 in

maximum shear, V_u = 11.65 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 11.5) / 1000 = 13.09 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic (Water 2-Sides)

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 9.5 = 19$ ft
 plate dimension, a = **9.5** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.5938



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	1		0.326	1.4	1.4
B	4		0.195	1.4	1.4
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **14** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	11"	3"
My bending	11.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic (Water 2-Sides)

M _x - Moment Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 11")	
		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.1174	0.0233			9.80	1.16			10.96	15.35	0.32	0.42
0	0.8	0.1077	0.0294			8.98	1.47			10.45	14.64	0.30	0.42
0	0.6	0.0905	0.0337			7.55	1.68			9.23	12.92	0.27	0.42
0	0.4	0.0650	0.0314			5.42	1.57			6.99	9.79	0.20	0.42
0	0.2	0.0271	0.0165			2.26	0.83			3.09	4.32	0.09	0.42
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.42
0.2	0	0.0027	0.0019			0.22	0.09			0.32	0.45	0.01	0.42
0.4	0	0.0071	0.0044			0.60	0.22			0.81	1.14	0.02	0.42
0.6	0	0.0114	0.0066			0.95	0.33			1.28	1.79	0.04	0.42
0.8	0	0.0142	0.0079			1.19	0.39			1.58	2.21	0.04	0.42
1	0	0.0152	0.0084			1.27	0.42			1.69	2.36	0.05	0.42
1	0.2	-0.0088	-0.0052			-0.73	-0.26			-0.99	-1.38	-0.03	-0.42
1	0.4	-0.0297	-0.0136			-2.48	-0.68			-3.16	-4.42	-0.09	-0.42
1	0.6	-0.0433	-0.0158			-3.62	-0.79			-4.41	-6.17	-0.13	-0.42
1	0.8	-0.0513	-0.0148			-4.29	-0.74			-5.02	-7.03	-0.14	-0.42
1	1	-0.0572	-0.0139			-4.77	-0.69			-5.47	-7.65	-0.16	-0.42
0.8	1	-0.0510	-0.0121			-4.25	-0.61			-4.86	-6.80	-0.14	-0.42
0.8	0.8	-0.0459	-0.0132			-3.83	-0.66			-4.49	-6.28	-0.13	-0.42
0.8	0.6	-0.0389	-0.0144			-3.25	-0.72			-3.97	-5.55	-0.11	-0.42
0.8	0.4	-0.0270	-0.0126			-2.25	-0.63			-2.88	-4.03	-0.08	-0.42
0.8	0.2	-0.0082	-0.0050			-0.68	-0.25			-0.93	-1.30	-0.03	-0.42

max negative moment, M_{ux}(-) = -7.65 ft-k/ft

max negative steel req'd, A_s(-) = -0.16 in²/ft

minimum steel req'd = -0.42 in²/ft

Use

max positive moment, M_{ux}(+) = 15.35 ft-k/ft

max positive steel req'd, A_s(+) = 0.32 in²/ft

minimum steel req'd = 0.42 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic (Water 2-Sides)

M _y - Moment Summary													
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 11.5")	
		Moment Coefficients				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.42
0	0.8	0.0215	0.0059			1.79	0.29			2.09	2.92	0.06	0.42
0	0.6	0.0181	0.0068			1.51	0.34			1.85	2.58	0.05	0.42
0	0.4	0.0130	0.0062			1.08	0.31			1.39	1.95	0.04	0.42
0	0.2	0.0054	0.0033			0.45	0.17			0.62	0.87	0.02	0.42
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.42
0.2	0	0.0134	0.0093			1.11	0.46			1.58	2.21	0.04	0.42
0.4	0	0.0359	0.0222			3.00	1.11			4.11	5.75	0.11	0.42
0.6	0	0.0569	0.0330			4.74	1.65			6.39	8.95	0.17	0.42
0.8	0	0.0710	0.0398			5.93	1.99			7.91	11.08	0.22	0.42
1	0	0.0759	0.0421			6.34	2.10			8.44	11.81	0.23	0.42
1	0.2	0.0064	-0.0027			0.54	-0.13			0.40	0.57	0.01	0.42
1	0.4	-0.0152	-0.0126			-1.26	-0.63			-1.89	-2.65	-0.05	-0.42
1	0.6	-0.0178	-0.0097			-1.48	-0.48			-1.97	-2.75	-0.05	-0.42
1	0.8	-0.0122	-0.0037			-1.02	-0.18			-1.20	-1.68	-0.03	-0.42
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.42
1	0.4	-0.0152	-0.0126			-1.26	-0.63			-1.89	-2.65	-0.05	-0.42
0.8	0.4	-0.0141	-0.0119			-1.18	-0.59			-1.77	-2.48	-0.05	-0.42
0.6	0.4	-0.0108	-0.0095			-0.90	-0.48			-1.37	-1.92	-0.04	-0.42
0.4	0.4	-0.0051	-0.0056			-0.43	-0.28			-0.71	-0.99	-0.02	-0.42
0.2	0.4	0.0029	-0.0001			0.24	0.00			0.24	0.33	0.01	0.42

max negative moment, M_{uy}(-) = -2.75 ft-k/ft

max negative steel req'd, A_s(-) = -0.05 in²/ft

minimum steel req'd = -0.42 in²/ft

Use

max positive moment, M_{uy}(+) = 11.81 ft-k/ft

max positive steel req'd, A_s(+) = 0.23 in²/ft

minimum steel req'd = 0.42 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 4 - Actiflo™ JOB NO: 10723A.10
 DESIGN TASK: Wall 6A - Hydrodynamic (Water 2-Sides)

Shear Summary												
a = 9.5 b = 16 a / b = 0.5938		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	0.6299	0.0530			3.29	0.17			3.45	4.83	13.09
0	0.8	0.6334	0.1616			3.30	0.50			3.81	5.33	13.09
0	0.6	0.5392	0.2202			2.81	0.69			3.50	4.90	13.09
0	0.4	0.4388	0.2546			2.29	0.79			3.08	4.32	13.09
0	0.2	0.1701	0.1522			0.89	0.47			1.36	1.91	13.09
0	0.00	-0.0469	-0.0124			-0.24	-0.04			-0.28	-0.40	13.09
0.2	0	0.0609	0.0940			0.32	0.29			0.61	0.86	13.09
0.4	0	0.2695	0.2242			1.41	0.70			2.11	2.95	13.09
0.6	0	0.4219	0.3044			2.20	0.95			3.15	4.41	13.09
0.8	0	0.5114	0.3468			2.67	1.08			3.75	5.25	13.09
1	0	0.5406	0.3600			2.82	1.12			3.94	5.52	13.09

Concrete strength reduction factor for shear, φ = 0.75

d = 11.5 in

maximum shear, V_u = 5.52 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 11.5) / 1000 = 13.09 \text{ k/ft}$$


Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

BY: C. Che DATE Sep-17 CLIENT Willamette Springs WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 4 - Actiflo™ JOB NO. 10721A.10
 DESIGN TASK Wall 6B - Hydrodynamic (Water 2-Sides) - Cantilever

WALL DESIGN LOADS, PROPERTIES & GEOMETRY

Service Level Load Diagram, Shear & Moment

M = Service moment	=	9.34	ft-k
Mu = Factored moment	=	13.08	ft-k
Vu = Factored Shear	=	2.70	kips
h = Member thick	=	12.00	in
b = Member width	=	12.00	in
Cover = Reinforcing cover	=	2.00	in
Is this mat of rebar closest to surface (Y / N)?	=	Y	
d = Depth to flexural reinforcing	=	9.69	in
f _c = Specified compressive strength of concrete	=	4,000	psi
f _y = Specified yield strength of reinforcement	=	60,000	psi

FLEXURAL REINFORCING

ϕ , bending	=	1.00	
$m = f_y / (0.85 * f_c)$	=	17.65	
$R_n = M_u / (\phi * b * d^2)$	=	139	psi
$A_{s, req} = (b * d / m) * (1 - (1 - ((2 * m * R_n) / f_y))^{1/2})$	=	0.28	in ²
Use # 5	=	@ 12"	
d _b = Bar diameter	=	0.625	in
$A_s = (\pi / 4) * d_b^2 * (12" / \text{Spacing})$	=	0.31	in ² <-- Rebar OK

SHEAR CAPACITY

ϕ , shear	=	1.00	
Vu = Factored Shear	=	2.70	kips
$\phi V_c = \phi * 2 * (f_c)^{1/2} * b * d$	=	14.70	kips <-- Shear OK



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref

By CC


Date 04-Aug-17

Chd

File Wall 7.std

Date/Time 09-Aug-2017 15:54

- MX (local)
- lb-in/in
- <= -9500
- 8639
- 7779
- 6918
- 6057
- 5197
- 4336
- 3475
- 2615
- 1754
- 893
- 32.6
- 828
- 1689
- 2549
- 3410
- >= 4271



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 7

Ref

By CC

Date 04-Aug-17

Chd

File Wall 7.std

Date/Time 09-Sep-2017 23:10

MX (local)

lb-in/in

<= -11.6 E3

-10.6 E3

-9504

-8451

-7398

-6346

-5293

-4241

-3188

-2135

-1083

-30.2


1022

2075

3128

4180

>= 5233



Load 2



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 7	
-------------	--

Ref	
-----	--

By CC	Date 04-Aug-17	Chd
-------	----------------	-----

File Wall 7.std	Date/Time 09-Aug-2017 15:54
-----------------	-----------------------------

- MY (local)
- lb-in/in
- <= -13.2 E3
- 11.9 E3
- 10.7 E3
- 9.402
- 8.138
- 6.875
- 5.611
- 4.347
- 3.084
- 1.820
- 557
- 707
- 1970
- 3234
- 4497
- 5761
- >= 7024



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev
Part/Wall	7	Ref		
By	CC	Date	04-Aug-17	Chd
File	Wall 7.std	Date/Time	09-Sep-2017 23:10	

- MY (local)
- lb-in/in
- <= -15.9 E3
- 14.4 E3
- 12.9 E3
- 11.3 E3
- 9.792
- 8.261
- 6.730
- 5.199
- 3.668
- 2.137
- 606
- 925
- 2456
- 3987
- 5518
- 7050
- >= 8581



Load 2



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 183

Part/Wall 7

Ref

By CC

Date 04-Aug-17

Chd


File Wall 7.std

Date/Time 09-Aug-2017 15:54

SQX (local)

psi

- <= -36.9
- 32.3
- 27.7
- 23.1
- 18.5
- 13.9
- 9.24
- 4.62
- 0
- 4.62
- 9.24
- 13.9
- 18.5
- 23.1
- 27.7
- 32.3
- >= 36.9



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No

10721A.10

Sheet No

1

Rev

Part/Wall 7

Ref

By CC

Date 04-Aug-17

Chd


File Wall 7.std

Date/Time 09-Sep-2017 23:10

SQX (local)

psi

- <= -45.1
- 39.5
- 33.8
- 28.2
- 22.6
- 16.9
- 11.3
- 5.64
- 0
- 5.64
- 11.3
- 16.9
- 22.6
- 28.2
- 33.8
- 39.5
- >= 45.1



Load 2



Software licensed to Carollo Engineers

Job Title Area 4 - ActiFlo

Load Case: 1.4F

Client Willamette River WTP

Job No

10721A.10

Sheet No

1

Rev

Part/Wall 7

Ref

By CC

Date 04-Aug-17

Chd


File Wall 7.std

Date/Time 09-Aug-2017 15:54

SQY (local)

psi

- <= -25.6
- 20.9
- 16.2
- 11.5
- 6.81
- 2.1
- 2.6
- 7.31
- 12
- 16.7
- 21.4
- 26.1
- 30.8
- 35.5
- 40.2
- 45
- >= 49.7



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 4 - ActiFlo

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No

10721A.10

Sheet No

1

Rev

Part/Wall 7

Ref

By CC

Date 04-Aug-17

Chd


File Wall 7.std

Date/Time 09-Sep-2017 23:10

SQY (local)


psi

- <= -33.6
- 27.8
- 22
- 16.2
- 10.4
- 4.63
- 1.16
- 6.96
- 12.8
- 18.5
- 24.3
- 30.1
- 35.9
- 41.7
- 47.5
- 53.3
- >= 59.1



Load 2

Area 5 - Ozonation Concrete Structure
ACI 350 Evaluation



- NOTES:
1. USE STAINLESS STEEL OR TRER WSPR FOR ALL WSPR JOINTS
 2. SEE NOTE 1/4S-1

RECORD DRAWING

This record drawing has been prepared entirely or in part on the basis of unverified information compiled and furnished to the engineer by others. The engineer is not responsible for any inaccuracies, errors or omissions which may have been incorporated into the document as a result of such information.

CONTRACTOR HAS TO VERIFY ALL DIMENSIONS OF A 10" DIA. PVC PIPE IN USE ON THE ROUND OPINGS SHALL HAVE CENTERLINE AS THE SQUARE OPENS (TYP)

NOTE: SHALL EXTENSION STARTS AT EL. 156.00. SEE SEC C/ FOR REINFORCEMENT INFO

FOUNDATION PLAN



Portland Oregon

City of WILSONVILLE in OREGON



WILSONVILLE RECREATION PLANT STRUCTURAL FOUNDATION PLAN

SHEET 5S-01

REVISION	DATE	DESCRIPTION	SCALE	WARNING	DESIGNED	SUBMITTED BY	LICENSE NO.	DATE
1	10/25/08	RECORD DRAWING	AS SHOWN	IF THIS DRAWING IS NOT TO SCALE	CHECKED			

REVISION	DATE	BY	DESCRIPTION


SCALE	3/8"=1'-0"
WARNING	IF THIS DRAWING IS USED FOR CONSTRUCTION, THE USER ASSUMES ALL RESPONSIBILITY FOR THE ACCURACY OF THE INFORMATION SHOWN HEREON. THE ENGINEER'S OFFICE DOES NOT ASSUME ANY LIABILITY FOR SUCH USE.
DESIGNED BY	B. CROOK
CHECKED BY	B. CROOK

ISSUED BY	
LICENSE NO.	
DATE	


MWH
 MONTGOMERY WATSON HARZA
 Portland Oregon

City of WILSONVILLE
 in OREGON

WILAMETTE RIVER PLANT
 OZONATION STRUCTURAL SECTION
 SHEET 55-03



NOTES:
 1. ALL REINFORCING SHOWN SHALL BE #506 UNLESS NOTED OTHERWISE

REV	DATE	BY	DESCRIPTION

SCALE
3/8"=1'-0"

WARNING
IF THIS DRAWING DOES NOT SCALE THEN THE DRAWING IS NOT TO SCALE

DESIGNED BY: B. CROOK
CHECKED BY: B. CROOK

SUBMITTED BY: _____
LICENSE NO.: _____ DATE: _____




Portland Oregon



WILSONVILLE WASTEWATER TREATMENT PLANT
STRUCTURAL SECTION

SHEET 55-07

RECORD DRAWING
This record drawing has been prepared entirely or in part on the basis of surveyed information compiled and verified by the engineer or architect and is not responsible for any inaccuracies, errors or omissions which may have been incorporated into the document.




SECTION E
55-01
55-02

NOTES:
1. ALL REINFORCING SHOWN SHALL BE #5@6" UNLESS NOTED OTHERWISE

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 10 ft
 tank wall thickness, t_w = 12 inch
 wall height to underside of roof, H_w = 24 ft
 liquid height, H_L = 20.67 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) * \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION

(wall fixity = pinned at roof & fixed at floor)

Soil Data


The site has no groundwater.

soil height above top of foundation base = 12 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0.11 k/ft³
 live load lateral surcharge = 0.100 ksf
 0
 concrete strength, $f'_c = 4$ ksi
 concrete density, $\gamma_c = 0.150$ k/ft³
 concrete modulus of elasticity, $E_c = 3605.0$ ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, $R_{wi} = 2.5$
 Response modification factor, $R_{wc} = 1$



WALL PLAN

Load Cases:

- case 1 = water
- case 2 = water + water seismic + wall seismic
- case 3 = soil + lateral surcharge
- case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures

Weights:

unit 1-ft width wall mass, $W_w = (12/12) * (24) * 0.15 = 3.60$ kip
 wall c.g. relative to base, $h_w = 24 / 2 = 12.000$ ft

unit width liquid mass, $W_L = (10) * (1) * (20.67) * 32.17 = 12.90$ kip

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

wall mass, $m_w = H_w * (t_w / 12) * \rho_c = 0.11191$ k-sec²/ft²

liquid mass, $m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.18943$ k-sec²/ft²

centroidal distance of masses, $h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 10.364$ ft



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

wall flexure stiffness, $k = Ec * (tw * Hw / h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 404.84$ k/ft/ft

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (404.84 / (0.1119 + 0.1894))^{1/2} = 36.6536 \text{ rad/sec}$$

period of tank plus impulsive mass, $T_i = 2\pi / \omega_i = 2\pi / 36.6536 = 0.1714$ sec

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

design factored spectral response acceleration for impulsive mass (5% damping), $S_{ai} = S_{DS} = 0.611$ g

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (2.067)))^{1/2} = 10.0825$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 10.0825 / (10)^{1/2} = 3.1884 \text{ rad/sec,}$$


period of the convective mass, $T_c = 2\pi / \omega_c = 2\pi / 3.1884 = 1.9707$ sec

Long transition period (from map figure 22-15 ASCE 7), $T_L = 16$ sec

design spectral response acceleration for convective mass (0.5% damping), $S_{ac} = 1.5 * Sd1 / Tc = 0.499$ g

effective mass coeff., $\epsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021$, but $\leq 1.0 = 0.9322$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures



L = 10 ft
 B = 1 ft
 HL = 20.67 ft
 WL = 12.9 kip

L / HL = 0.48379
 HL / L = 2.06700

3). lateral fluid impulsive force: Dynamic Model

Wi = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 12.9 * (\tanh(0.866 * (0.4838)) / 0.866 * (0.4838)) = 12.19 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 20.67 * (0.5 - 0.09375 * (0.4838)) = 9.398 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * 0.45 = 9.302 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.5) * 12.19 = 3.7 \text{ kip}$$

4). lateral fluid convective force:

Wc = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 12.9 * (0.264 * (0.4838) * \tanh(3.16 * (2.067))) = 1.65 \text{ kip}$$

$$h_c \text{ (EBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 17.515 \text{ ft}$$

$$h_c \text{ (IBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 17.524 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.4993 * 1.25 / 1) * 1.65 = 1.0 \text{ kip}$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.60$ kip
 wall c.g. relative to base, $h_w = 12.000$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.9322 / 2.5) * 3.6 = 1.03 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (10 / 2) * (0.4993 / 1.4 * 1.25) = 2.23 \text{ ft}$$


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 3.70$ kip
 $h_i = 9.398$ ft
 at $y = H_L$, $p_{iy} = 0.065$ ksf
 at base $y = 0$, $p_{iy} = 0.114$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 1.00$ kip
 $h_c = 17.515$ ft
 at $y = H_L$, $p_{cy} = 0.075$ ksf
 at base $y = 0$, $p_{cy} = -0.026$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$$\ddot{u} = 0.2444$$

$$\text{at } y = H_L, p_{vy} = 0.000 \text{ ksf}$$

$$\text{at base } y = 0, p_{vy} = 0.315 \text{ ksf}$$

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$$p_{wy} = 0.2848 * \gamma_c * (t_w/12)$$

$$\text{at } y = H_w, p_{wy} = 0.043 \text{ ksf}$$

$$\text{at base } y = 0, p_{wy} = 0.043 \text{ ksf}$$

hydrostatic:

$$q_{hy} = \gamma_L (H_L - y) =$$

$$\text{at } y = H_L, q_{hy} = 0.000 \text{ ksf}$$


$$\text{at base } y = 0, q_{hy} = 1.290 \text{ ksf}$$

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_w^2} =$$

$$\text{at } y = H_w, p_y = 0.131 \text{ ksf}$$




$$\text{at base } y = 0, p_y = 0.353 \text{ ksf}$$



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 24$ ft
 liquid height, $H_L = 20.67$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 24 ft
 soil height above top of base = 12 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.6600 ksf
 unfactored soil, q3 = 0.0000 ksf



equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.6600 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **3.825** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **8** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.6375 ksf
 wall seismic (see wall page 5), q10 = 0.0427 ksf
 equivalent soil seismic, q11 = q9 = 0.6375 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.6375 ksf

unfactored equivalent soil seismic, q8 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q9 = 0.6375 / 1.4 = 0.4554 ksf
 unfactored wall seismic, q10 = 0.0427 / 1.4 = 0.0305 ksf
 unfactored equivalent soil seismic, q11 = 0.6375 / 1.4 = 0.4554 ksf
 unfactored equivalent soil seismic, q12 = -0.6375 / 1.4 = -0.4554 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 1 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 24 ft
 water depth = 20.67 ft

b). load case 2: hydrostatic + dynamic:




wall height = 24 ft
 water depth = 20.67 ft

c). load case 3: static soil + LL surcharge:

wall height = 24 ft
 soil height on wall = 12 ft

equivalent static soil & surcharge loadings...


LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.660 ksf
 unfactored soil, q3 = 0.000 ksf



equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.660 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 24 ft
 soil height on wall = 12 ft




unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.455 ksf
 unfactored equivalent soil seismic, q10 = 0.031 ksf
 unfactored equivalent soil seismic, q11 = 0.455 ksf
 unfactored equivalent soil seismic, q12 = -0.455 ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 6 ft
 tank wall thickness, t_w = 12 inch
 wall height to underside of roof, H_w = 20.67 ft
 liquid height, H_L = 20.67 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w$ = 0.0624 k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g$ = 0.00194 k-sec²/ft⁴



WALL SECTION
 (wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = 0 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0 k/ft³
 live load lateral surcharge = 0.100 ksf
 0
 concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g$ = 0.004663 k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = 0.611 *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = 0.656 *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, R_{wi} = 2.5
 Response modification factor, R_{wc} = 1



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (12/12) * (20.67) * 0.15 = 3.10 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 20.67 / 2 = 10.335 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (6) * (1) * (20.67) * 32.17 = 7.74 \text{ kip}$$

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.09638 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.11779 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 10.026 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = Ec * (tw * Hw / h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 552.63 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (552.63 / (0.0964 + 0.1178))^{1/2} = 50.7968 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 50.7968 = 0.1237 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (3.445)))^{1/2} = 10.0825$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 10.0825 / (6)^{1/2} = 4.1162 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 4.1162 = 1.5265 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * Sd1 / Tc = 0.645 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.9669$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures



L = 6 ft
 B = 1 ft
 H_L = 20.67 ft
 W_L = 7.74 kip

L / H_L = 0.29028
 H_L / L = 3.44500

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 7.74 * (\tanh(0.866 * (0.2903)) / 0.866 * (0.2903)) = 7.58 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 20.67 * (0.5 - 0.09375 * (0.2903)) = 9.773 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * 0.45 = 9.302 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.5) * 7.58 = 2.3 \text{ kip}$$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 7.74 * (0.264 * (0.2903) * \tanh(3.16 * (3.445))) = 0.59 \text{ kip}$$

$$h_c \text{ (EBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 18.771 \text{ ft}$$

$$h_c \text{ (IBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 18.771 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.6446 * 1.25 / 1) * 0.59 = 0.5 \text{ kip}$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.10$ kip
 wall c.g. relative to base, $h_w = 10.335$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.9669 / 2.5) * 3.1 = 0.92 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (6 / 2) * (0.6446 / 1.4 * 1.25) = 1.73 \text{ ft}$$

Wave height is greater than the freeboard of 0-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 2.30$ kip
 $h_i = 9.773$ ft
 at $y = H_L$, $p_{iy} = 0.047$ ksf
 at base $y = 0$, $p_{iy} = 0.065$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 0.50$ kip
 $h_c = 18.771$ ft
 at $y = H_L$, $p_{cy} = 0.042$ ksf
 at base $y = 0$, $p_{cy} = -0.018$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.315$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2954 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.044$ ksf
 at base $y = 0$, $p_{wy} = 0.044$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.290$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_w^2} =$$




at $y = H_w$, $p_y = 0.100$ ksf
 at base $y = 0$, $p_y = 0.334$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.67$ ft
 liquid height, $H_L = 20.67$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 20.67 ft
 soil height above top of base = 0 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.0000 ksf
 unfactored soil, q3 = 0.0000 ksf
 0.000




equivalent soil loadings:
 unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.0000 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **0** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **0** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.0000 ksf
 wall seismic (see wall page 5), q10 = 0.0443 ksf
 equivalent soil seismic, q11 = q8 - q9 = 0.0000 ksf
 equivalent soil seismic, q12 = q9 = 0.0000 ksf

unfactored equivalent soil seismic, q8 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q9 = 0 / 1.4 = 0.0000 ksf
 unfactored wall seismic, q10 = 0.0443 / 1.4 = 0.0316 ksf
 unfactored equivalent soil seismic, q11 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q12 = 0 / 1.4 = 0.0000 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.67 ft
 water depth = 20.67 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.67 ft
 water depth = 20.67 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.67 ft
 soil height on wall = 0 ft

equivalent static soil & surcharge loadings...




LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.000 ksf
 unfactored soil, q3 = 0.000 ksf
 0.000

equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.000 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.67 ft
 soil height on wall = 0 ft



unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.000 ksf
 unfactored equivalent soil seismic, q10 = 0.032 ksf
 unfactored equivalent soil seismic, q11 = 0.000 ksf
 unfactored equivalent soil seismic, q12 = 0.000 ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 3 Pressure (water 2-Sides)

Hydrodynamic analysis of an interior wall with equal water each side per ASCE 7-10 and the 2012 IBC code:

wall connection fixity = **pinned at roof & fixed at floor**


tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 6 ft
 inside serpentine wall thickness, t_w = 12 inch
 wall height to underside of roof, H_w = 24 ft
 roof thickness, t_r = 1 inch

liquid height, H_L = 20.67 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624 \text{ k/ft}^3$
 acceleration due to gravity, $g = 32.17 \text{ ft/sec}^2$
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194 \text{ k-sec}^2/\text{ft}^4$

foundation footing thickness, t_f = 1.5 ft
 foundation projection toe side, l_t = 6 ft
 foundation projection heel side, l_h = 6 ft

allowable soil bearing pressure static = 2 ksf
 allowable soil bearing pressure seismic = 2.67 ksf

yield strength of reinforcement, f_y = 60 ksi
 concrete strength, f'_c = 4 ksi
 concrete density, $\gamma_c = 0.150 \text{ k/ft}^3$
 concrete modulus of elasticity, $E_c = 3605.0 \text{ ksi}$
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663 \text{ k-sec}^2/\text{ft}^4$




Interior Wall Section
 (wall fixity = pinned at roof & fixed at floor)

Seismic data from the IBC code:

Structure Risk Category = 3
 Seismic importance factor, I = 1.25
 Response modification factor, R_i = 2.5
 Response modification factor, R_c = 1.5

Note:
 Hydrodynamic seismic forces on the interior wall will be the sum of half the impulsive and convective forces from water on each side of the wall.



interior wall being analyzed (equal water both sides)
 seismic direction

Interior Wall Plan

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 3 Pressure (water 2-Sides)

Weights:

unit 1-ft width wall mass, $W_w = (12/12) * (24) * 0.15 = 3.60$ kip
 wall c.g. relative to base, $h_w = 24 / 2 = 12.000$ ft
 unit width liquid mass, $W_L = 6 * 1 * 20.67 * 0.0624 = 7.74$ kip


Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Note: Hydrodynamic seismic forces on the interior wall will be the sum of half the impulsive and convective forces from water on each side of the wall.

1). wall stiffness and dynamic property:

Note: W_i and h_i are impulsive component variables calculated on page 3.



wall mass, $m_w = H_w * (t_w / 12) * \rho_c = 0.11191$ k-sec²/ft²
 liquid mass, $m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.11779$ k-sec²/ft²
 centroidal distance of masses, $h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 10.858$ ft
 wall fixity condition is pinned at roof & fixed at floor:
 wall stiffness is determined using a unit mass load located at the centroidal distance h .
 wall flexure stiffness, $k = Ec * (t_w * H_w / h)^3 / (12 * (4 * H_w - h) * (H_w - h)^2) = 381.23$ k/ft-ft

$$\omega_1 = \sqrt{\frac{k}{m_w + m_i}} = (381.23 / (0.1119 + 0.1178))^{1/2} = 40.73918 \text{ rad/sec}$$

period of vibration of the wall plus impulsive mass, $T_i = 2\pi / \omega_1 = 2 * \pi / 40.73918 = 0.1542$ sec

design factored spectral response acceleration for impulsive mass (5% damping), $S_{ai} = S_{DS} = 0.611$ *g

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = 10.0825 \quad \omega_c = \frac{\lambda}{\sqrt{L}} = 10.0825 / (6)^{1/2} = 4.1162 \text{ rad/sec,}$$


period of the convective mass, $T_c = 2\pi / \omega_c = 2 * \pi / 4.1162 = 1.5265$ sec

Long transition period (from map figure 22-12 ASCE 7), $T_L = 16$ sec

design spectral response acceleration for convective mass (0.5% damping), $S_{ac} = 1.5 * S_{d1} / T_c = 0.6446$ *g

effective mass coeff., $\epsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021$, but $\leq 1.0 = 0.9669$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 3 Pressure (water 2-Sides)



L = 6 ft
 B = 1 ft
 HL = 20.67 ft
 WL = 7.74 kip
 L / HL = 0.29028
 HL / L = 3.44500

3). lateral fluid impulsive force:

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 7.58 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 20.67 * (0.5 - 0.09375 * (0.2903)) = 9.773 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * 0.45 = 9.302 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_i} \right) W_i = (0.611 * 1.25 / 2.5) * 7.58 = 2.32 \text{ kip}$$

impulsive force moment excluding bottom pressure, $M_{i(EBP)} = P_i * h_{i(EBP)} = 2.32 * 9.773 = 22.67 \text{ ft-k}$
 impulsive force moment including bottom pressure, $M_{i(IBP)} = P_i * h_{i(IBP)} = 2.32 * 9.302 = 21.58 \text{ ft-k}$

4). lateral fluid convective force:

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 0.59 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 1}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 18.771 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 2.01}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 18.771 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_c} \right) W_c = (0.6446 * 1.25 / 1.5) * 0.59 = 0.32 \text{ kip}$$

convective force moment excluding bottom pressure, $M_{c(EBP)} = P_c * h_{c(EBP)} = 0.32 * 18.771 = 6.01 \text{ ft-k}$
 convective force moment including bottom pressure, $M_{c(IBP)} = P_c * h_{c(IBP)} = 0.32 * 18.771 = 6.01 \text{ ft-k}$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 3 Pressure (water 2-Sides)

5). lateral inertia force of the accelerating wall:

$$\text{mass of a unit 1-ft width wall, } W_w = 3.60 \text{ kip}$$

$$\text{wall c.g. relative to base, } h_w = 12.000 \text{ ft}$$

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_i} \right) W_w = (0.611 * 1.25 * 0.9669 / 2.5) * 3.6 = 1.06 \text{ kip}$$

$$\text{wall inertia force moment, } M_w = P_w * h_w = 1.06 * 12 = 12.72 \text{ ft-k}$$

6). total base shear:

$$V = \sqrt{(P_i + P_w)^2 + P_c^2}$$

$$V = ((2.32 + 1.06)^2 + (0.32)^2)^{1/2} = 3.40 \text{ kip}$$

7). total moment at the base excluding bottom pressure (EBP):

$$M_b = \sqrt{(M_i + M_w)^2 + M_c^2}$$

$$M_b = ((22.67 + 12.72)^2 + (6.01)^2)^{1/2} = 35.90 \text{ ft-k}$$

8). total moment at the base including bottom pressure (IBP):

$$M_o = \sqrt{(M_i + M_w)^2 + M_c^2}$$

$$M_o = ((21.58 + 12.72)^2 + (6.01)^2)^{1/2} = 34.82 \text{ ft-k}$$

9). maximum wave slosh height displacement: (see ASCE-10, 15.7.6.1 notes c and d)

(Risk Category = 3) I = 1.25 ,use TL = 4 ,Sd1 = 0.656 ,Tc = 1.5265


$$S_{ac} = 1.5 * Sd1 / Tc = 0.6446 * g$$

$$d_{(max)} = 0.42 (L) (S_{ac} I) = 0.42 * (6) * (0.6446 * 1.25) = 2.03 \text{ ft}$$

(minimum freeboard see table 15.7-3 of ASCE 7) , d(min) = 0.7 * d(max) = 1.42 ft

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 3 Pressure (water 2-Sides)

10). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

Note: this accounts for the impulsive pressure on each side of the wall.

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{B H_L^2} =$$

$$P_i = 2.32 \text{ kip}$$

$$h_i = 9.773 \text{ ft}$$

$$\text{at } y = H_L, p_{iy} = 0.094 \text{ ksf}$$

$$\text{at base } y = 0, p_{iy} = 0.131 \text{ ksf}$$

convective:

Note: this accounts for the convective pressure on each side of the wall.

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{B H_L^2} =$$

$$P_c = 0.32 \text{ kip}$$

$$h_c = 18.771 \text{ ft}$$

$$\text{at } y = H_L, p_{cy} = 0.053 \text{ ksf}$$

$$\text{at base } y = 0, p_{cy} = -0.022 \text{ ksf}$$

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_i} =$$

$$p_{wy} = 0.2954 * \gamma_c * t_w$$

$$\text{at } y = H_w, p_{wy} = 0.044 \text{ ksf}$$


$$\text{at base } y = 0, p_{wy} = 0.044 \text{ ksf}$$

combine the effects of the hydrodynamic pressures on the wall:

$$p_y = \sqrt{(p_{iy} + p_{wy})^2 + p_{cy}^2} =$$

$$\text{at } y = H_w, p_y = 0.148 \text{ ksf}$$

$$\text{at base } y = 0, p_y = 0.176 \text{ ksf}$$




resultant dynamic pressures

BY: C. Che **DATE:** Sep-17 **CLIENT:** Willamette River WTP **SHEET:** _____
CHKD: _____ **DESCRIPTION:** Area 5 - Ozonation **JOB NO:** 10721A.10
DESIGN TASK: Wall 3 Pressure (water 2-Sides)


11). wall design pressures for hydrodynamic seismic:

wall height, $H_w = 24$ ft

liquid height, $H_L = 20.67$ ft



unfactored load = 0.106 ksf



unfactored load = 0.126 ksf

unfactored resultant dynamic pressures

**Area 5 - Ozonation
Wall 1 - Moment & Shear**

		Horizontal Span				Vertical Span			
	S _d	M _{ux} (k-ft)	S _d *M _{ux} (k-ft)	M _n (k-ft)	DCR	SQX _u (psi)	SQ _n (psi)	DCR	
1.4F	1.23	3.96	4.88	25.50	0.19	33	126	0.26	<- OK
1.2F+1.4E	1.00	4.32	4.32	25.50	0.17	35	126	0.28	<- OK
1.6(H+L)	1.08	2.05	2.21	25.50	0.09	20	126	0.15	<- OK
1.6H+1.4E	1.00	2.74	2.74	25.50	0.11	22	126	0.18	<- OK
Vertical Span									
	S _d	M _{uy} (k-ft)	S _d *M _{uy} (k-ft)	M _n (k-ft)	DCR	SQY _u (psi)	SQ _n (psi)	DCR	
1.4F	1.23	3.47	4.27	28.50	0.15	33	126	0.26	<- OK
1.2F+1.4E	1.00	3.71	3.71	28.50	0.13	35	126	0.28	<- OK
1.6(H+L)	1.08	1.96	2.11	28.50	0.07	19	126	0.15	<- OK
1.6H+1.4E	1.00	2.28	2.28	28.50	0.08	21	126	0.17	<- OK



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

MX (local)

lb-in/in

- <= -3897
- 3406
- 2915
- 2424
- 1933
- 1442
- 951
- 460
- 31.6
- 523
- 1014
- 1505
- 1996
- 2487
- 2978
- 3469
- >= 3961



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 5 - Ozonation

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 213

Rev

PartWall 1

Ref

By

Date04-Aug-17

Chd


File Wall 1.std

Date/Time 09-Sep-2017 23:44

MX (local)

lb-in/in

- <= -4239
- 3705
- 3170
- 2635
- 2101
- 1566
- 1031
- 497
- 37.8
- 572
- 1107
- 1642
- 2176
- 2711
- 3246
- 3780
- >= 4315



Load 2



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref


By Date 04-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 09:04

- MX (local)
- lb-in/in
- <= -2050
- 1796
- 1542
- 1288
- 1034
- 780
- 526
- 272
- 17.9
- 236
- 490
- 744
- 998
- 1252
- 1506
- 1760
- >= 2014



Load 3



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref


By Date 04-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 09:04

- MX (local)
- lb-in/in
- <= -2713
- 2372
- 2032
- 1691
- 1350
- 1010
- 669
- 329
- 11.9
- 353
- 693
- 1034
- 1374
- 1715
- 2055
- 2396
- >= 2737



Load 4



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By

Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

MY (local)

lb-in/in

- <= -3466
- 3152
- 2838
- 2524
- 2210
- 1896
- 1582
- 1268
- 954
- 640
- 326
- 12.4
- 302
- 616
- 930
- 1244
- >= 1558



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 5 - Ozonation

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev
--------	-----------	----------	---	-----


Part/Wall	1
-----------	---

Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 1.std	Date/Time	09-Sep-2017 23:44
------	------------	-----------	-------------------

- MY (local)
lb-in/in
- <= -3711
 - 3375
 - 3040
 - 2705
 - 2369
 - 2034
 - 1698
 - 1363
 - 1027
 - 692
 - 356
 - 20.9
 - 315
 - 650
 - 985
 - 1321
 - >= 1656





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

MY (local)

lb-in/in

- <= -1964
- 1781
- 1598
- 1414
- 1231
- 1047
- 864
- 681
- 497
- 314
- 130
- 53
- 236
- 420
- 603
- 787
- >= 970



Load 3



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

MY (local)

lb-in/in

- <= -2284
- 2076
- 1869
- 1661
- 1454
- 1246
- 1039
- 831
- 624
- 416
- 209
- 1.29
- 206
- 414
- 621
- 829
- >= 1036



Load 4



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

SQX (local)

psi

- <= -33.1
- 29
- 24.8
- 20.7
- 16.6
- 12.4
- 8.28
- 4.14
- 0
- 4.14
- 8.28
- 12.4
- 16.6
- 20.7
- 24.8
- 29
- >= 33.1



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 5 - Ozonation

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

PartWall 1

Ref

By

Date04-Aug-17

Chd


File Wall 1.std

Date/Time 09-Sep-2017 23:44

SQX (local)

psi

- <= -35.3
- 30.9
- 26.5
- 22.1
- 17.7
- 13.2
- 8.83
- 4.41
- 0
- 4.41
- 8.83
- 13.2
- 17.7
- 22.1
- 26.5
- 30.9
- >= 35.3



Load 2



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 222
Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

SQX (local)

psi

- <= -19.5
- 17.1
- 14.6
- 12.2
- 9.76
- 7.32
- 4.88
- 2.44
- 0
- 2.44
- 4.88
- 7.32
- 9.76
- 12.2
- 14.6
- 17.1
- >= 19.5



Load 3



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

PartWall 1

Ref

By

Date04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

SQX (local)

psi

- <= -22.4
- 19.6
- 16.9
- 14.1
- 11.4
- 8.64
- 5.89
- 3.14
- 0.387
- 2.36
- 5.11
- 7.86
- 10.6
- 13.4
- 16.1
- 18.9
- >= 21.6



Load 4



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 224

Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

SQY (local)

psi

- <= -21.1
- 17.8
- 14.4
- 11
- 7.59
- 4.2
- 0.816
- 2.57
- 5.96
- 9.35
- 12.7
- 16.1
- 19.5
- 22.9
- 26.3
- 29.7
- >= 33.1



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 5 - Ozonation

Load Case: 1.2F+1.4E


Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev
--------	-----------	----------	---	-----

PartWall 1
Ref

By	Date	04-Aug-17	Chd
File	Wall 1.std	Date/Time	09-Sep-2017 23:44

- SQY (local)
psi
- <= -22.5
 - 18.9
 - 15.3
 - 11.7
 - 8.08
 - 4.47
 - 0.866
 - 2.74
 - 6.34
 - 9.95
 - 13.6
 - 17.2
 - 20.8
 - 24.4
 - 28
 - 31.6
 - >= 35.2





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 1

Ref

By Date 04-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 09:04

SQY (local)

psi

- <= -12.3
- 10.3
- 8.38
- 6.42
- 4.46
- 2.51
- 0.554
- 1.4
- 3.36
- 5.31
- 7.27
- 9.22
- 11.2
- 13.1
- 15.1
- 17
- >= 19



Load 3



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 227

Rev

Part/Wall 1

Ref

By

Date 04-Aug-17



Chd

File Wall 1.std

Date/Time 10-Aug-2017 09:04

SQY (local)

psi




Load 4


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 5 = 10$ ft
 plate dimension, a = **5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.2439



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		1.290	1.73	1.4
B					
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

M _x - Moment Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 9")	
		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0021				1.11				1.11	1.92	0.05	0.36
0	0.8	0.0043				2.36				2.36	4.08	0.10	0.36
0	0.6	0.0079				4.30				4.30	7.43	0.19	0.36
0	0.4	0.0110				5.95				5.95	10.29	0.26	0.36
0	0.2	0.0099				5.39				5.39	9.32	0.23	0.36
0	0	0.0000				0.00				0.00	0.00	0.00	0.36
0.2	0	0.0004				0.21				0.21	0.36	0.01	0.36
0.4	0	0.0010				0.52				0.52	0.90	0.02	0.36
0.6	0	0.0015				0.83				0.83	1.44	0.04	0.36
0.8	0	0.0019				1.04				1.04	1.80	0.04	0.36
1	0	0.0020				1.09				1.09	1.89	0.05	0.36
1	0.2	-0.0046				-2.49				-2.49	-4.31	-0.11	-0.36
1	0.4	-0.0055				-2.98				-2.98	-5.16	-0.13	-0.36
1	0.6	-0.0040				-2.18				-2.18	-3.76	-0.09	-0.36
1	0.8	-0.0023				-1.23				-1.23	-2.12	-0.05	-0.36
1	1	-0.0013				-0.70				-0.70	-1.22	-0.03	-0.36
0.8	1	-0.0011				-0.60				-0.60	-1.04	-0.03	-0.36
0.8	0.8	-0.0020				-1.07				-1.07	-1.86	-0.05	-0.36
0.8	0.6	-0.0036				-1.97				-1.97	-3.41	-0.08	-0.36
0.8	0.4	-0.0049				-2.66				-2.66	-4.61	-0.11	-0.36
0.8	0.2	-0.0042				-2.28				-2.28	-3.94	-0.10	-0.36

max negative moment, M_{ux}(-) = -5.16 ft-k/ft

max negative steel req'd, A_s(-) = -0.13 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 10.29 ft-k/ft

max positive steel req'd, A_s(+) = 0.26 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

M _y - Moment Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficients				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		x / a	y / b	A	B	C	D	A	B				
0	1	0.0000				0.00				0.00	0.00	0.00	0.36
0	0.8	0.0008				0.46				0.46	0.80	0.02	0.36
0	0.6	0.0016				0.88				0.88	1.52	0.04	0.36
0	0.4	0.0022				1.20				1.20	2.07	0.05	0.36
0	0.2	0.0019				1.06				1.06	1.83	0.04	0.36
0	0	0.0000				0.00				0.00	0.00	0.00	0.36
0.2	0	0.0019				1.04				1.04	1.80	0.04	0.36
0.4	0	0.0050				2.71				2.71	4.68	0.11	0.36
0.6	0	0.0078				4.22				4.22	7.30	0.17	0.36
0.8	0	0.0096				5.21				5.21	9.01	0.21	0.36
1	0	0.0103				5.58				5.58	9.65	0.23	0.36
1	0.2	-0.0030				-1.62				-1.62	-2.80	-0.07	-0.36
1	0.4	-0.0020				-1.06				-1.06	-1.84	-0.04	-0.36
1	0.6	-0.0009				-0.50				-0.50	-0.87	-0.02	-0.36
1	0.8	-0.0002				-0.10				-0.10	-0.17	0.00	-0.36
1	1	0.0000				0.00				0.00	0.00	0.00	0.36
1	0.4	-0.0020				-1.06				-1.06	-1.84	-0.04	-0.36
0.8	0.4	-0.0018				-0.96				-0.96	-1.66	-0.04	-0.36
0.6	0.4	-0.0012				-0.65				-0.65	-1.13	-0.03	-0.36
0.4	0.4	-0.0004				-0.19				-0.19	-0.33	-0.01	-0.36
0.2	0.4	0.0008				0.43				0.43	0.74	0.02	0.36

max negative moment, M_{uy}(-) = -2.80 ft-k/ft

max negative steel req'd, A_s(-) = -0.07 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 9.65 ft-k/ft

max positive steel req'd, A_s(+) = 0.23 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrostatic

Shear Summary												
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	0.0144				0.38				0.38	0.53	10.81
0	0.8	0.0508				1.34				1.34	1.88	10.81
0	0.6	0.0990				2.62				2.62	3.66	10.81
0	0.4	0.1481				3.92				3.92	5.48	10.81
0	0.2	0.1475				3.90				3.90	5.46	10.81
0	0.00	0.0313				0.83				0.83	1.16	10.81
0.2	0	0.0301				0.80				0.80	1.11	10.81
0.4	0	0.1029				2.72				2.72	3.81	10.81
0.6	0	0.1531				4.05				4.05	5.67	10.81
0.8	0	0.1819				4.81				4.81	6.73	10.81
1	0	0.1911				5.05				5.05	7.08	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 7.08 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 5 = 10$ ft
 plate dimension, a = **5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.2439



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		1.290	1.2	1.2
B	1		0.071	1.4	1.4
C	4		0.168	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

M _x - Moment Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		1.290	0.071	0.168						Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0021	0.0199	0.0021		1.11	0.59	0.14		1.85	2.37	0.06	0.36
0	0.8	0.0043	0.0196	0.0043		2.36	0.58	0.31		3.25	4.08	0.10	0.36
0	0.6	0.0079	0.0196	0.0079		4.30	0.58	0.56		5.44	6.76	0.17	0.36
0	0.4	0.0110	0.0188	0.0110		5.95	0.56	0.77		7.28	9.01	0.23	0.36
0	0.2	0.0099	0.0133	0.0099		5.39	0.40	0.70		6.49	8.00	0.20	0.36
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.2	0	0.0004	0.0005	0.0004		0.21	0.01	0.03		0.25	0.31	0.01	0.36
0.4	0	0.0010	0.0012	0.0010		0.52	0.04	0.07		0.62	0.77	0.02	0.36
0.6	0	0.0015	0.0019	0.0015		0.83	0.06	0.11		1.00	1.23	0.03	0.36
0.8	0	0.0019	0.0024	0.0019		1.04	0.07	0.14		1.25	1.54	0.04	0.36
1	0	0.0020	0.0026	0.0020		1.09	0.08	0.14		1.31	1.62	0.04	0.36
1	0.2	-0.0046	-0.0063	-0.0046		-2.49	-0.19	-0.32		-3.00	-3.71	-0.09	-0.36
1	0.4	-0.0055	-0.0095	-0.0055		-2.98	-0.28	-0.39		-3.65	-4.52	-0.11	-0.36
1	0.6	-0.0040	-0.0100	-0.0040		-2.18	-0.30	-0.28		-2.76	-3.43	-0.09	-0.36
1	0.8	-0.0023	-0.0100	-0.0023		-1.23	-0.30	-0.16		-1.69	-2.11	-0.05	-0.36
1	1	-0.0013	-0.0104	-0.0013		-0.70	-0.31	-0.09		-1.10	-1.41	-0.03	-0.36
0.8	1	-0.0011	-0.0091	-0.0011		-0.60	-0.27	-0.08		-0.95	-1.21	-0.03	-0.36
0.8	0.8	-0.0020	-0.0089	-0.0020		-1.07	-0.26	-0.14		-1.48	-1.86	-0.05	-0.36
0.8	0.6	-0.0036	-0.0089	-0.0036		-1.97	-0.26	-0.26		-2.49	-3.09	-0.08	-0.36
0.8	0.4	-0.0049	-0.0085	-0.0049		-2.66	-0.25	-0.35		-3.26	-4.04	-0.10	-0.36
0.8	0.2	-0.0042	-0.0057	-0.0042		-2.28	-0.17	-0.30		-2.75	-3.39	-0.08	-0.36

max negative moment, M_{ux}(-) = -4.52 ft-k/ft

max negative steel req'd, A_s(-) = -0.11 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 9.01 ft-k/ft

max positive steel req'd, A_s(+) = 0.23 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

M _y - Moment Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		1.290	0.071	0.168						Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0	0.8	0.0008	0.0039	0.0008		0.46	0.12	0.06		0.64	0.80	0.02	0.36
0	0.6	0.0016	0.0039	0.0016		0.88	0.12	0.11		1.11	1.38	0.03	0.36
0	0.4	0.0022	0.0037	0.0022		1.20	0.11	0.16		1.47	1.81	0.04	0.36
0	0.2	0.0019	0.0026	0.0019		1.06	0.08	0.14		1.27	1.57	0.04	0.36
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
0.2	0	0.0019	0.0022	0.0019		1.04	0.07	0.14		1.24	1.53	0.04	0.36
0.4	0	0.0050	0.0060	0.0050		2.71	0.18	0.35		3.24	3.99	0.09	0.36
0.6	0	0.0078	0.0096	0.0078		4.22	0.29	0.55		5.06	6.24	0.15	0.36
0.8	0	0.0096	0.0120	0.0096		5.21	0.36	0.68		6.25	7.71	0.18	0.36
1	0	0.0103	0.0129	0.0103		5.58	0.38	0.73		6.69	8.25	0.20	0.36
1	0.2	-0.0030	-0.0033	-0.0030		-1.62	-0.10	-0.21		-1.93	-2.38	-0.06	-0.36
1	0.4	-0.0020	-0.0028	-0.0020		-1.06	-0.08	-0.14		-1.29	-1.59	-0.04	-0.36
1	0.6	-0.0009	-0.0022	-0.0009		-0.50	-0.06	-0.07		-0.63	-0.79	-0.02	-0.36
1	0.8	-0.0002	-0.0018	-0.0002		-0.10	-0.05	-0.01		-0.17	-0.21	-0.01	-0.36
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.36
1	0.4	-0.0020	-0.0028	-0.0020		-1.06	-0.08	-0.14		-1.29	-1.59	-0.04	-0.36
0.8	0.4	-0.0018	-0.0025	-0.0018		-0.96	-0.08	-0.13		-1.16	-1.43	-0.03	-0.36
0.6	0.4	-0.0012	-0.0017	-0.0012		-0.65	-0.05	-0.09		-0.79	-0.97	-0.02	-0.36
0.4	0.4	-0.0004	-0.0004	-0.0004		-0.19	-0.01	-0.03		-0.23	-0.28	-0.01	-0.36
0.2	0.4	0.0008	0.0016	0.0008		0.43	0.05	0.06		0.53	0.65	0.02	0.36

max negative moment, M_{uy}(-) = -2.38 ft-k/ft

max negative steel req'd, A_s(-) = -0.06 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 8.25 ft-k/ft

max positive steel req'd, A_s(+) = 0.20 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

Shear Summary												
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		1.290	0.071	0.168						Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
Shear Coefficients												
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	0.0144	0.2423	0.0144		0.38	0.35	0.05		0.78	1.02	10.81
0	0.8	0.0508	0.2459	0.0508		1.34	0.36	0.17		1.88	2.36	10.81
0	0.6	0.0990	0.2452	0.0990		2.62	0.36	0.34		3.31	4.12	10.81
0	0.4	0.1481	0.2456	0.1481		3.92	0.36	0.51		4.78	5.91	10.81
0	0.2	0.1475	0.1881	0.1475		3.90	0.27	0.51		4.68	5.78	10.81
0	0.00	0.0313	0.0308	0.0313		0.83	0.04	0.11		0.98	1.21	10.81
0.2	0	0.0301	0.0231	0.0301		0.80	0.03	0.10		0.93	1.15	10.81
0.4	0	0.1029	0.1104	0.1029		2.72	0.16	0.35		3.24	3.99	10.81
0.6	0	0.1531	0.1743	0.1531		4.05	0.25	0.53		4.83	5.95	10.81
0.8	0	0.1819	0.2122	0.1819		4.81	0.31	0.63		5.74	7.08	10.81
1	0	0.1911	0.2246	0.1911		5.05	0.33	0.66		6.04	7.44	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 7.44 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 5 = 10$ ft
 plate dimension, a = **5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.2439



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	1		0.106	1.4	1.4
B	4		0.020	1.4	1.4
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

M _x - Moment Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.106	0.020							Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0199	0.0021			0.89	0.02			0.90	1.26	0.03	0.36
0	0.8	0.0196	0.0043			0.87	0.04			0.91	1.27	0.03	0.36
0	0.6	0.0196	0.0079			0.87	0.07			0.94	1.31	0.03	0.36
0	0.4	0.0188	0.0110			0.84	0.09			0.93	1.30	0.03	0.36
0	0.2	0.0133	0.0099			0.59	0.08			0.68	0.95	0.02	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0005	0.0004			0.02	0.00			0.02	0.03	0.00	0.36
0.4	0	0.0012	0.0010			0.06	0.01			0.06	0.09	0.00	0.36
0.6	0	0.0019	0.0015			0.09	0.01			0.10	0.14	0.00	0.36
0.8	0	0.0024	0.0019			0.11	0.02			0.12	0.17	0.00	0.36
1	0	0.0026	0.0020			0.11	0.02			0.13	0.18	0.00	0.36
1	0.2	-0.0063	-0.0046			-0.28	-0.04			-0.32	-0.45	-0.01	-0.36
1	0.4	-0.0095	-0.0055			-0.42	-0.05			-0.47	-0.66	-0.02	-0.36
1	0.6	-0.0100	-0.0040			-0.45	-0.03			-0.48	-0.67	-0.02	-0.36
1	0.8	-0.0100	-0.0023			-0.45	-0.02			-0.46	-0.65	-0.02	-0.36
1	1	-0.0104	-0.0013			-0.46	-0.01			-0.47	-0.66	-0.02	-0.36
0.8	1	-0.0091	-0.0011			-0.41	-0.01			-0.42	-0.58	-0.01	-0.36
0.8	0.8	-0.0089	-0.0020			-0.39	-0.02			-0.41	-0.58	-0.01	-0.36
0.8	0.6	-0.0089	-0.0036			-0.40	-0.03			-0.43	-0.60	-0.01	-0.36
0.8	0.4	-0.0085	-0.0049			-0.38	-0.04			-0.42	-0.58	-0.01	-0.36
0.8	0.2	-0.0057	-0.0042			-0.26	-0.04			-0.29	-0.41	-0.01	-0.36

max negative moment, M_{ux}(-) = -0.67 ft-k/ft

max negative steel req'd, A_s(-) = -0.02 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 1.31 ft-k/ft

max positive steel req'd, A_s(+) = 0.03 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

M _y - Moment Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.106	0.020							Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0039	0.0008			0.17	0.01			0.18	0.25	0.01	0.36
0	0.6	0.0039	0.0016			0.17	0.01			0.19	0.26	0.01	0.36
0	0.4	0.0037	0.0022			0.17	0.02			0.19	0.26	0.01	0.36
0	0.2	0.0026	0.0019			0.12	0.02			0.13	0.19	0.00	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0022	0.0019			0.10	0.02			0.11	0.16	0.00	0.36
0.4	0	0.0060	0.0050			0.27	0.04			0.31	0.43	0.01	0.36
0.6	0	0.0096	0.0078			0.43	0.07			0.49	0.69	0.02	0.36
0.8	0	0.0120	0.0096			0.54	0.08			0.62	0.86	0.02	0.36
1	0	0.0129	0.0103			0.57	0.09			0.66	0.92	0.02	0.36
1	0.2	-0.0033	-0.0030			-0.15	-0.03			-0.17	-0.24	-0.01	-0.36
1	0.4	-0.0028	-0.0020			-0.13	-0.02			-0.14	-0.20	0.00	-0.36
1	0.6	-0.0022	-0.0009			-0.10	-0.01			-0.10	-0.15	0.00	-0.36
1	0.8	-0.0018	-0.0002			-0.08	0.00			-0.08	-0.11	0.00	-0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
1	0.4	-0.0028	-0.0020			-0.13	-0.02			-0.14	-0.20	0.00	-0.36
0.8	0.4	-0.0025	-0.0018			-0.11	-0.01			-0.13	-0.18	0.00	-0.36
0.6	0.4	-0.0017	-0.0012			-0.07	-0.01			-0.08	-0.12	0.00	-0.36
0.4	0.4	-0.0004	-0.0004			-0.02	0.00			-0.02	-0.03	0.00	-0.36
0.2	0.4	0.0016	0.0008			0.07	0.01			0.08	0.11	0.00	0.36

max negative moment, M_{uy}(-) = -0.24 ft-k/ft

max negative steel req'd, A_s(-) = -0.01 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 0.92 ft-k/ft

max positive steel req'd, A_s(+) = 0.02 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 5 - Ozonation JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic (Water 2-Sides)

Shear Summary													
a = 5 b = 20.5 a / b = 0.2439		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Shear Coefficient Multipliers								Final Shears			
		x / a		y / b		Shear Coefficients				Shears, k/ft			
		A	B	C	D	A	B	C	D	V k/ft	V _u k/ft	φV _c k/ft	
0	1	0.2423	0.0144			0.53	0.01			0.53	0.75	10.81	
0	0.8	0.2459	0.0508			0.53	0.02			0.56	0.78	10.81	
0	0.6	0.2452	0.0990			0.53	0.04			0.57	0.80	10.81	
0	0.4	0.2456	0.1481			0.53	0.06			0.59	0.83	10.81	
0	0.2	0.1881	0.1475			0.41	0.06			0.47	0.66	10.81	
0	0.00	0.0308	0.0313			0.07	0.01			0.08	0.11	10.81	
0.2	0	0.0231	0.0301			0.05	0.01			0.06	0.09	10.81	
0.4	0	0.1104	0.1029			0.24	0.04			0.28	0.39	10.81	
0.6	0	0.1743	0.1531			0.38	0.06			0.44	0.62	10.81	
0.8	0	0.2122	0.1819			0.46	0.07			0.54	0.75	10.81	
1	0	0.2246	0.1911			0.49	0.08			0.57	0.79	10.81	

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 0.83 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

BY: C. Che DATE Sep-17 CLIENT Willamette Springs WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 5 - Ozonation JOB NO. 10721A.10
 DESIGN TASK Wall 3 - Hydrodynamic (Water 2-Sides) - Horizontal Span At Bottom

WALL DESIGN LOADS, PROPERTIES & GEOMETRY

M_u = Factored moment	=	2.21	ft-k
V_u = Factored Shear	=	0.88	kips
h = Member thick	=	12.00	in
b = Member width	=	12.00	in
Cover = Reinforcing cover	=	3.00	in
Is this mat of rebar closest to surface (Y / N)?	=	N	
d = Depth to flexural reinforcing	=	8.69	in
f'_c = Specified compressive strength of concrete	=	4,000	psi
f_y = Specified yield strength of reinforcement	=	60,000	psi

FLEXURAL REINFORCING

ϕ , bending	=	1.00	
$m = f_y / (0.85 * f'_c)$	=	17.65	
$R_n = M_u / (\phi * b * d^2)$	=	29	psi
$A_s = (b * d / m) * (1 - (1 - ((2 * m * R_n) / f_y))^{1/2})$	=	0.05	in ²
$A_{s-min} = 200 * (12 \text{ in}) * d / f_y \text{ or } (4 / 3) * A_s$	=	0.07	in ²
minimum bar shrinkage/temperatur ratio	=	0.00500	
A_{s-temp}	=	0.36	in ²
A_{s-req}	=	0.36	
		Use # 5 @ 6"	
d_b = Bar diameter	=	0.625	in
$A_s = (\pi / 4) * d_b^2 * (12" / \text{Spacing})$	=	0.61	in ²

<-- For Double Layer Reinforcement
 <-- Rebar OK

SHEAR CAPACITY

ϕ , shear	=	1.00	
V_u = Factored Shear	=	0.88	kips
$\phi V_c = \phi * 2 * (f'_c)^{1/2} * b * d$	=	13.19	kips

<-- Shear OK

**Area 5 - Ozonation
Wall 4 - Moment & Shear**

	Horizontal Span - Outside Face				
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR
1.6(H+L)	1.41	9.83	13.86	13.00	0.28
1.6H+1.4E	1.00	17.70	17.70	13.00	0.51
				SQX_u (psi)	SQ_n (psi)
				35	126
				65	126
					DCR
					0.28
					<- NG

	Vertical Span (Bottom) - Outside Face				
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR
1.6(H+L)	1.41	16.00	22.56	35.00	0.38
1.6H+1.4E	1.00	23.50	23.50	35.00	0.48
				SQY_u (psi)	SQ_n (psi)
				48	126
				61	126
					DCR
					0.38
					<- OK

	Horizontal Span - Inside Face				
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR
1.6(H+L)	1.41	3.04	4.29	13.00	0.00
1.6H+1.4E	1.00	5.88	5.88	13.00	0.00
				SQX_u (psi)	SQ_n (psi)
				0	126
				0	126
					DCR
					0.00
					<- OK

	Vertical Span (Mid-Height) - Inside Face				
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR
1.6(H+L)	1.41	6.83	9.63	20.50	0.00
1.6H+1.4E	1.00	11.40	11.40	20.50	0.00
				SQY_u (psi)	SQ_n (psi)
				0	126
				0	126
					DCR
					0.00
					<- OK



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 13:10

MX (local)

lb-in/in

- <= -98333
- 9029
- 8224
- 7419
- 6614
- 5810
- 5005
- 4200
- 3395
- 2591
- 1786
- 981
- 176
- 628
- 1433
- 2238
- >= 3043





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC


Date 05-Aug-17

Chd

File Wall 4.std

Date/Time 11-Aug-2017 13:10

- MX (local)
- lb-in/in
- <= -17.7 E3
- 16.2 E3
- 14.7 E3
- 13.2 E3
- 11.8 E3
- 10.3 E3
- 8.833
- 7.361
- 5.890
- 4.418
- 2.947
- 1.475
- 3.67
- 1468
- 2939
- 4411
- >= 5882





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Page 245

Part/Wall 4

Ref

By CC


Date 05-Aug-17

Chd

File Wall 4.std

Date/Time 11-Aug-2017 13:10

- MY (local)
- lb-in/in
- <= -16 E3
- 14.6 E3
- 13.1 E3
- 11.7 E3
- 10.3 E3
- 8858
- 7432
- 6006
- 4581
- 3155
- 1729
- 303
- 1122
- 2548
- 3974
- 5399
- >= 6825





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No

10721A.10

Sheet No

1

Page 246

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 13:10

MY (local)

lb-in/in

- <= -23.5 E3
- 21.3 E3
- 19.1 E3
- 17 E3
- 14.8 E3
- 12.6 E3
- 10.4 E3
- 8.229
- 6.047
- 3.865
- 1.683
- 499
- 2681
- 4863
- 7045
- 9228
- >= 11.4 E3





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Williametter River WTP

Job No
10721A.10

Sheet No

1

Page 247

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 13:10

SQX (local)

psi

- <= -28.9
- 24.8
- 20.8
- 16.8
- 12.8
- 8.82
- 4.81
- 0.806
- 3.2
- 7.21
- 11.2
- 15.2
- 19.2
- 23.2
- 27.2
- 31.3
- >= 35.3





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Williametter River WTP

Job No

10721A.10

Sheet No

1

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 13:10

SQX (local)

psi

- <= -53.3
- 45.9
- 38.5
- 31.1
- 23.7
- 16.3
- 8.94
- 1.55
- 5.85
- 13.2
- 20.6
- 28
- 35.4
- 42.8
- 50.2
- 57.6
- >= 65





Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6(H+L)

Client Willametter River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 13:10

SQY (local)

psi

- <= -28.3
- 23.5
- 18.8
- 14
- 9.28
- 4.53
- 0.229
- 4.98
- 9.74
- 14.5
- 19.3
- 24
- 28.8
- 33.5
- 38.3
- 43
- >= 47.8



Legend 1



Software licensed to Carollo Engineers

Job Title Area 5 - Ozonation

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC


Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 13:10

- SQY (local)
psi
- <= -49.6
 - 42.7
 - 35.8
 - 28.9
 - 22
 - 15
 - 8.14
 - 1.23
 - 5.68
 - 12.6
 - 19.5
 - 26.4
 - 33.3
 - 40.2
 - 47.1
 - 54.1
 - >= 61



Area 6 - Filters Concrete Structure
ACI 350 Evaluation



<p>REVISIONS</p> <table border="1"> <thead> <tr> <th>NO.</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>1</td> <td></td> <td></td> </tr> </tbody> </table>	NO.	DATE	DESCRIPTION	1			<p>SCALE</p> <p>1/4"=1'-0"</p> <p>WARNING</p> <p>IF THIS DRAWING DOES NOT TO SCALE</p>	<p>DESIGNED BY: B. CROOK</p> <p>CHECKED BY: B. CROOK</p>	<p>DATE</p> <p>LICENSE NO.</p>	<p>City of WILSONVILLE in OREGON</p>	<p>WILMETTE INLET FILTER REMEDIATION PROJECT</p> <p>FOUNDATION PLAN</p>	<p>SHEET</p> <p>65-01</p>
NO.	DATE	DESCRIPTION										
1												

RECORD DRAWING


This record drawing has been prepared, entirely or in part, for the use of the City of Wilsonville. It is not to be furnished to others by the preparer who is not and who may not be held responsible for the consequences which may result from its use as a result.

- NOTES:**
1. PROVIDE EXPOSED W/SP. PROTECTION FOR EXPOSED W/SP AND REBAR.
 2. PROVIDE EXPOSED W/SP AND REBAR PROTECTION FOR EAST END OF SETTLED WATER CHANNEL BETWEEN ELEVATIONS 141.50 AND 149.00

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 23 ft
 tank wall thickness, t_w = 14 inch
 wall height to underside of roof, H_w = 18.17 ft
 liquid height, H_L = 15.42 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w$ = 0.0624 k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g$ = 0.00194 k-sec²/ft⁴



WALL SECTION
 (wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = 8 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0.11 k/ft³
 live load lateral surcharge = 0.100 ksf
 0
 concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g$ = 0.004663 k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = 0.611 *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = 0.656 *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, R_{wi} = 2.37
 Response modification factor, R_{wc} = 1.11



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (14/12) * (18.17) * 0.15 = 3.18 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 18.17 / 2 = 9.085 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (23) * (1) * (15.42) * 32.17 = 22.13 \text{ kip}$$

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.09884 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.22895 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 6.779 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = E_c * (t_w * H_w / h)^3 / (12 * (4 * H_w - h) * (H_w - h)^2) = 1856.35 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (1856.35 / (0.0988 + 0.2289))^{1/2} = 75.2544 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 75.2544 = 0.0835 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.6704)))^{1/2} = 9.9379$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 9.9379 / (23)^{1/2} = 2.0722 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 2.0722 = 3.0321 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * S_{d1} / T_c = 0.325 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.7700$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures



L = 23 ft
 B = 1 ft
 H_L = 15.42 ft
 W_L = 22.13 kip

L / H_L = 1.49157
 H_L / L = 0.67043

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 22.13 * (\tanh(0.866 * (1.4916)) / 0.866 * (1.4916)) = 14.73 \text{ kip}$$

h_i (EBP) = H_L * 0.375 = 15.42 * 0.375 = 5.783 ft

h_i (IBP) = H_L * {{{(0.866*L/H_L)/(2*tanh(0.866*L/H_L))} - 1/8} = 9.659 ft

impulsive force, P_i = $\left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.37) * 14.73 = 4.7 \text{ kip}$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 22.13 * (0.264 * (1.4916) * \tanh(3.16 * (0.6704))) = 8.47 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 9.704 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 11.497 \text{ ft}$$

convective force, P_c = $\left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.3245 * 1.25 / 1.11) * 8.47 = 3.1 \text{ kip}$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.18$ kip
 wall c.g. relative to base, $h_w = 9.085$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.77 / 2.37) * 3.18 = 0.79 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (23 / 2) * (0.3245 / 1.4 * 1.25) = 3.33 \text{ ft}$$

Wave height is greater than the freeboard of 2.75-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 4.70$ kip
 $h_i = 5.783$ ft
 at $y = H_L$, $p_{iy} = 0.038$ ksf
 at base $y = 0$, $p_{iy} = 0.267$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 3.10$ kip
 $h_c = 9.704$ ft
 at $y = H_L$, $p_{cy} = 0.179$ ksf
 at base $y = 0$, $p_{cy} = 0.023$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.235$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2481 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.043$ ksf
 at base $y = 0$, $p_{wy} = 0.043$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 0.962$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_w^2} =$$




at $y = H_w$, $p_y = 0.196$ ksf
 at base $y = 0$, $p_y = 0.390$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 18.17$ ft
 liquid height, $H_L = 15.42$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 18.17 ft
 soil height above top of base = 8 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.4400 ksf
 unfactored soil, q3 = 0.0000 ksf



equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.4400 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **1.088** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **5.33** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0003 ksf
 equivalent soil seismic, q9 = 0.2717 ksf
 wall seismic (see wall page 5), q10 = 0.0434 ksf
 equivalent soil seismic, q11 = q9 = 0.2717 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.2713 ksf

unfactored equivalent soil seismic, q8 = 0.0003 / 1.4 = 0.0002 ksf
 unfactored equivalent soil seismic, q9 = 0.2717 / 1.4 = 0.1940 ksf
 unfactored wall seismic, q10 = 0.0434 / 1.4 = 0.0310 ksf
 unfactored equivalent soil seismic, q11 = 0.2717 / 1.4 = 0.1940 ksf
 unfactored equivalent soil seismic, q12 = -0.2713 / 1.4 = -0.1938 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 1 thru 6 - Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 18.17 ft
 water depth = 15.42 ft

b). load case 2: hydrostatic + dynamic:




wall height = 18.17 ft
 water depth = 15.42 ft

c). load case 3: static soil + LL surcharge:

wall height = 18.17 ft
 soil height on wall = 8 ft

equivalent static soil & surcharge loadings...

LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.440 ksf
 unfactored soil, q3 = 0.000 ksf




equivalent soil loadings:

unfactored q5 = 0.100 ksf
 unfactored q6 = 0.440 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 18.17 ft
 soil height on wall = 8 ft



unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.194 ksf
 unfactored equivalent soil seismic, q10 = 0.031 ksf
 unfactored equivalent soil seismic, q11 = 0.194 ksf
 unfactored equivalent soil seismic, q12 = -0.194 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**

tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 14 ft
 tank wall thickness, t_w = 14 inch
 wall height to underside of roof, H_w = 21 ft

liquid height, H_L = 0.1 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION

(wall fixity = pinned at roof & fixed at floor)

Soil Data

The site has no groundwater.


soil height above top of foundation base = 11 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0.11 k/ft³
 live load lateral surcharge = 0.100 ksf

concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, $R_{wi} = 2.5$
 Response modification factor, $R_{wc} = 1$



WALL PLAN

Load Cases:

- case 1 = water
- case 2 = water + water seismic + wall seismic
- case 3 = soil + lateral surcharge
- case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures

Weights:

unit 1-ft width wall mass, $W_w = (14/12) * (21) * 0.15 = 3.68$ kip
 wall c.g. relative to base, $h_w = 21 / 2 = 10.500$ ft

unit width liquid mass, $W_L = (14) * (1) * (0.1) * 32.17 = 0.09$ kip

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

wall mass, $m_w = H_w * (t_w / 12) * \rho_c = 0.11424$ k-sec²/ft²

liquid mass, $m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.00000$ k-sec²/ft²

centroidal distance of masses, $h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 10.5$ ft



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

wall flexure stiffness, $k = Ec * (tw * Hw / h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 813.83$ k/ft/ft

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (813.83 / (0.1142 + 0))^{1/2} = 84.4039 \text{ rad/sec}$$

period of tank plus impulsive mass, $T_i = 2\pi / \omega_i = 2\pi / 84.4039 = 0.0744$ sec

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

design factored spectral response acceleration for impulsive mass (5% damping), $S_{ai} = S_{DS} = 0.611$ g

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.0071)))^{1/2} = 1.5146$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 1.5146 / (14)^{1/2} = 0.4048 \text{ rad/sec,}$$


period of the convective mass, $T_c = 2\pi / \omega_c = 2\pi / 0.4048 = 15.5214$ sec

Long transition period (from map figure 22-15 ASCE 7), $T_L = 16$ sec

design spectral response acceleration for convective mass (0.5% damping), $S_{ac} = 1.5 * Sd1 / Tc = 0.063$ g

effective mass coeff., $\epsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021$, but $\leq 1.0 = 1.0000$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures



$L = 14$ ft
 $B = 1$ ft
 $H_L = 0.1$ ft
 $W_L = 0.09$ kip

$L / H_L = #####$
 $H_L / L = 0.00714$

3). lateral fluid impulsive force: Dynamic Model

$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) =$ $W_i =$ equivalent mass of the impulsive component of liquid.
 $0.09 * (\tanh(0.866 * (14)) / 0.866 * (14)) = 0$ kip

h_i (EBP) = $H_L * 0.375 = 0.1 * 0.375 = 0.038$ ft
 h_i (IBP) = $H_L * \left\{ \frac{0.866 * L / H_L}{2 * \tanh(0.866 * L / H_L)} - 1/8 \right\} = 6.05$ ft

impulsive force, $P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.5) * 0 = 0.0$ kip

4). lateral fluid convective force:

$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) =$ $W_c =$ equivalent mass of the convective component of liquid.
 $0.09 * (0.264 * (14)) * \tanh(3.16 * (0.0071)) = 0.08$ kip

h_c (EBP) = $H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 0.05$ ft

h_c (IBP) = $H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 198.279$ ft

convective force, $P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.0634 * 1.25 / 1) * 0.08 = 0.0$ kip

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 3.68$ kip
 wall c.g. relative to base, $h_w = 10.500$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 1 / 2.5) * 3.68 = 1.12 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (14 / 2) * (0.0634 / 1.4 * 1.25) = 0.40 \text{ ft}$$


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 0.00$ kip
 $h_i = 0.038$ ft
 at $y = H_L$, $p_{iy} = 0.000$ ksf
 at base $y = 0$, $p_{iy} = 0.000$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 0.00$ kip
 $h_c = 0.05$ ft
 at $y = H_L$, $p_{cy} = 0.000$ ksf
 at base $y = 0$, $p_{cy} = 0.000$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$$\ddot{u} = 0.2444$$

at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.002$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$$p_{wy} = 0.3055 * \gamma_c * (t_w/12)$$

at $y = H_w$, $p_{wy} = 0.053$ ksf
 at base $y = 0$, $p_{wy} = 0.053$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 0.006$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_{wy}^2} =$$




at $y = H_w$, $p_y = 0.053$ ksf
 at base $y = 0$, $p_y = 0.053$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 21$ ft
 liquid height, $H_L = 0.1$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures

10). wall design pressures for external soil loading:

static soil:




The site has no groundwater.

wall height = 21 ft
 soil height above top of base = 11 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:

LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.6050 ksf
 unfactored soil, q3 = 0.0000 ksf



equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.6050 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **2.057** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **7.33** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0003 ksf
 equivalent soil seismic, q9 = 0.3737 ksf
 wall seismic (see wall page 5), q10 = 0.0535 ksf
 equivalent soil seismic, q11 = q9 = 0.3737 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.3733 ksf

unfactored equivalent soil seismic, q8 = 0.0003 / 1.4 = 0.0002 ksf
 unfactored equivalent soil seismic, q9 = 0.3737 / 1.4 = 0.2669 ksf
 unfactored wall seismic, q10 = 0.0535 / 1.4 = 0.0382 ksf
 unfactored equivalent soil seismic, q11 = 0.3737 / 1.4 = 0.2669 ksf
 unfactored equivalent soil seismic, q12 = -0.3733 / 1.4 = -0.2667 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 10721A.10
 DESIGN TASK: Wall 7 - Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 21 ft
 water depth = 0.1 ft

b). load case 2: hydrostatic + dynamic:




wall height = 21 ft
 water depth = 0.1 ft

c). load case 3: static soil + LL surcharge:

wall height = 21 ft
 soil height on wall = 11 ft

equivalent static soil & surcharge loadings...


LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.605 ksf
 unfactored soil, q3 = 0.000 ksf



equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.605 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 21 ft
 soil height on wall = 11 ft



unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.267 ksf
 unfactored equivalent soil seismic, q10 = 0.038 ksf
 unfactored equivalent soil seismic, q11 = 0.267 ksf
 unfactored equivalent soil seismic, q12 = -0.267 ksf

Area 6 - Filters
Wall 1 - Moment & Shear

	S_d	M_{ux} (K-ft)	$S_d * M_{ux}$ (K-ft)	Horizontal Span		SQX_u (psi)	SQ_n (psi)	DCR	
				M_n (K-ft)	DCR				
1.4F	1.61	9.93	15.99	30.50	0.52	35	126	0.27	<- OK
1.2F+1.4E	1.00	13.60	13.60	30.50	0.45	45	126	0.36	<- OK
1.6(H+L)	1.41	4.45	6.27	30.50	0.21	18	126	0.15	<- OK
1.6H+1.4E	1.00	5.71	5.71	30.50	0.19	22	126	0.17	<- OK

	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	Vertical Span		SQY_u (psi)	SQ_n (psi)	DCR	
				M_n (K-ft)	DCR				
1.4F	1.61	14.60	23.51	43.50	0.54	45	126	0.35	<- OK
1.2F+1.4E	1.00	19.20	19.20	43.50	0.44	57	126	0.45	<- OK
1.6(H+L)	1.41	5.73	8.08	43.50	0.19	26	126	0.21	<- OK
1.6H+1.4E	1.00	6.52	6.52	43.50	0.15	28	126	0.22	<- OK



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC


Date 05-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 13:44

- MX (local)
- lb-in/in
- <= -9929
- 9011
- 8093
- 7175
- 6257
- 5338
- 4420
- 3502
- 2584
- 1666
- 748
- 170
- 1088
- 2006
- 2924
- 3843
- >= 4761



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 269
Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 13:44

MX (local)

lb-in/in

<= -13.6 E3

-12.3 E3

-11 E3

-9785

-8523

-7262

-6000

-4738

-3477

-2215

-953

308


1570

2831

4093

5355

>= 6616



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC


Date 05-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 13:44

- MX (local)
- lb-in/in
- <= -4452
- 4023
- 3593
- 3164
- 2734
- 2305
- 1875
- 1446
- 1016
- 587
- 157
- 272
- 701
- 1131
- 1560
- 1990
- >= 2419



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 271

Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 13:44

MX (local)

lb-in/in

- <= -5706
- 5152
- 4597
- 4042
- 3487
- 2932
- 2377
- 1822
- 1267
- 712
- 157
- 398
- 953
- 1508
- 2063
- 2618
- >= 3173



Load 4



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 272

Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 13:44

MY (local)

lb-in/in

<= -14.6 E3

-13.3 E3

-12 E3

-10.7 E3

-9371

-8067

-6762

-5458

-4154

-2850

-1546

-241


1063

2367

3671

4975

>= 6280



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC


Date 05-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 13:44

- MY (local)
- lb-in/in
- <= -19.2 E3
- 17.5 E3
- 15.7 E3
- 14 E3
- 12.3 E3
- 10.6 E3
- 8849
- 7125
- 5401
- 3677
- 1954
- 230
- 1494
- 3218
- 4942
- 6666
- >= 8390



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 13:44

MY (local)

lb-in/in

- <= -5726
- 5210
- 4695
- 4179
- 3663
- 3147
- 2631
- 2115
- 1600
- 1084
- 568
- 52.1
- 464
- 980
- 1495
- 2011
- >= 2527



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 13:44

MY (local)

lb-in/in

- <= -6520
- 5933
- 5346
- 4758
- 4171
- 3584
- 2996
- 2409
- 1822
- 1234
- 647
- 59.7
- 528
- 1115
- 1702
- 2290
- >= 2877



Load 4



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC


Date 05-Aug-17

Chd

File Wall 1.std

Date/Time 10-Aug-2017 13:44

- SQX (local)
psi
- <= -34.6
 - 30.3
 - 26.1
 - 21.8
 - 17.5
 - 13.2
 - 8.96
 - 4.68
 - 0.409
 - 3.87
 - 8.14
 - 12.4
 - 16.7
 - 21
 - 25.2
 - 29.5
 - >= 33.8



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters


Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1				
Ref					
By	CC	Date	05-Aug-17	Chd	
File	Wall 1.std	Date/Time	10-Aug-2017 13:44		

SQX (local)
psi

- <= -45.4
- 39.8
- 34.2
- 28.6
- 23
- 17.4
- 11.8
- 6.18
- 0.574
- 5.03
- 10.6
- 16.2
- 21.9
- 27.5
- 33.1
- 38.7
- >= 44.3



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 278

Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 13:44

SQX (local)

psi

- <= -18.4
- 16.2
- 14.1
- 11.9
- 9.81
- 7.67
- 5.53
- 3.39
- 1.26
- 0.882
- 3.02
- 5.16
- 7.3
- 9.44
- 11.6
- 13.7
- >= 15.9



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 13:44

SQX (local)

psi

- <= -21.8
- 19.3
- 16.7
- 14.1
- 11.6
- 8.98
- 6.42
- 3.85
- 1.28
- 1.29
- 3.86
- 6.43
- 9
- 11.6
- 14.1
- 16.7
- >= 19.3



Load 4



Software licensed to Carollo Engineers

Job Title Area 6 - Filters


Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	1				
Ref					
By	CC	Date	05-Aug-17	Chd	
File	Wall 1.std	Date/Time	10-Aug-2017 13:44		

SQY (local)
psi

<= -14.4
-10.7
-7.01
-3.3
0.405
4.11
7.82
11.5
15.2
18.9
22.6
26.4
30.1
33.8
37.5
41.2
>= 44.9



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 1	
-------------	--

Ref	
-----	--

By CC	Date 05-Aug-17	Chd	
-------	----------------	-----	--

File Wall 1.std	Date/Time 10-Aug-2017 13:44
-----------------	-----------------------------

- SQY (local)
psi
- <= -19.6
 - 14.8
 - 9.99
 - 5.19
 - 0.390
 - 4.41
 - 9.21
 - 14
 - 18.8
 - 23.6
 - 28.4
 - 33.2
 - 38
 - 42.8
 - 47.6
 - 52.4
 - >= 57.2



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall	1
-----------	---

Ref	
-----	--

By	CC	Date	05-Aug-17	Chd	
----	----	------	-----------	-----	--

File	Wall 1.std	Date/Time	10-Aug-2017 13:44
------	------------	-----------	-------------------

- SQY (local)
psi
- <= -7.7
 - 5.59
 - 3.47
 - 1.35
 - 0.767
 - 2.89
 - 5
 - 7.12
 - 9.24
 - 11.4
 - 13.5
 - 15.6
 - 17.7
 - 19.8
 - 21.9
 - 24.1
 - >= 26.2



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Part/Wall 1

Ref

By CC

Date 05-Aug-17

Chd


File Wall 1.std

Date/Time 10-Aug-2017 13:44

SQY (local)

psi

- <= -9.66
- 7.34
- 5.01
- 2.68
- 0.358
- 1.97
- 4.29
- 6.62
- 8.95
- 11.3
- 13.6
- 15.9
- 18.3
- 20.6
- 22.9
- 25.2
- >= 27.6



Load 4

Area 6 - Filters
Wall 2 - Moment & Shear

		Horizontal Span						
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.4F	1.61	4.78	7.70	18.50	0.42	28	126	0.22
1.2F+1.4E	1.00	5.99	5.99	18.50	0.32	35	126	0.28

		Vertical Span (Mid-Height) - Dry Side						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	4.94	7.95	14.50	0.55	0	126	0.00
1.2F+1.4E	1.00	6.20	6.20	14.50	0.43	0	126	0.00

		Vertical Span (Bottom) - Wet Side						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	8.10	13.04	27.50	0.47	40	126	0.31
1.2F+1.4E	1.00	10.00	10.00	27.50	0.36	49	126	0.39

<- OK
<- OK
<- OK
<- OK



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 2	
-------------	--

Ref	
-----	--

By CC	Date 05-Aug-17	Chd	
-------	----------------	-----	--

File Wall 2.std	Date/Time 10-Aug-2017 14:31
-----------------	-----------------------------

- MX (local)
lb-in/in
- <= -4780
 - 4371
 - 3963
 - 3554
 - 3145
 - 2736
 - 2327
 - 1918
 - 1510
 - 1101
 - 692
 - 283
 - 126
 - 535
 - 943
 - 1352
 - >= 1761



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 2

Ref

By CC

Date 05-Aug-17

Chd


File Wall 2.std

Date/Time 10-Aug-2017 14:31

MX (local)

lb-in/in

- <= -5986
- 5474
- 4962
- 4450
- 3938
- 3426
- 2914
- 2402
- 1890
- 1378
- 866
- 354
- 158
- 670
- 1182
- 1694
- >= 2206



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 2

Ref

By CC

Date 05-Aug-17

Chd


File Wall 2.std

Date/Time 10-Aug-2017 14:31

MY (local)

lb-in/in

- <= -8096
- 7281
- 6467
- 5653
- 4839
- 4024
- 3210
- 2396
- 1581
- 767
- 47.1
- 861
- 1676
- 2490
- 3304
- 4119
- >= 4933



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 2	
-------------	--

Ref	
-----	--

By CC	Date 05-Aug-17	Chd
-------	----------------	-----

File Wall 2.std	Date/Time 10-Aug-2017 14:31
-----------------	-----------------------------

- MY (local)
- lb-in/in
- <= -10.1 E3
- 9044
- 8028
- 7013
- 5997
- 4982
- 3966
- 2951
- 1936
- 920
- 95.4
- 1111
- 2126
- 3142
- 4157
- 5173
- >= 6188



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 289
Rev

Part/Wall 2

Ref

By CC

Date 05-Aug-17

Chd


File Wall 2.std

Date/Time 10-Aug-2017 14:31

SQX (local)

psi

- <= -28
- 24.5
- 21
- 17.5
- 14
- 10.5
- 7.01
- 3.51
- 0.011
- 3.49
- 6.99
- 10.5
- 14
- 17.5
- 21
- 24.5
- >= 28



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 2	
-------------	--

Ref	
-----	--

By CC	Date 05-Aug-17	Chd	
-------	----------------	-----	--

File Wall 2.std	Date/Time 10-Aug-2017 14:31
-----------------	-----------------------------

- SQX (local)
psi
- <= -35.1
 - 30.7
 - 26.3
 - 21.9
 - 17.6
 - 13.2
 - 8.78
 - 4.4
 - 0.013
 - 4.37
 - 8.76
 - 13.1
 - 17.5
 - 21.9
 - 26.3
 - 30.7
 - >= 35.1



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 2	
-------------	--

Ref	
-----	--

By CC	Date 05-Aug-17	Chd	
-------	----------------	-----	--

File Wall 2.std	Date/Time 10-Aug-2017 14:31
-----------------	-----------------------------

- SQY (local)
psi
- <= -22.3
 - 18.4
 - 14.5
 - 10.7
 - 6.78
 - 2.89
 - 0.988
 - 4.87
 - 8.75
 - 12.6
 - 16.5
 - 20.4
 - 24.3
 - 28.2
 - 32
 - 35.9
 - >= 39.8



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 2

Ref

By CC

Date 05-Aug-17

Chd


File Wall 2.std

Date/Time 10-Aug-2017 14:31

SQY (local)

psi

- <= -29.5
- 24.6
- 19.7
- 14.8
- 9.86
- 4.95
- 0.040
- 4.87
- 9.79
- 14.7
- 19.6
- 24.5
- 29.4
- 34.3
- 39.3
- 44.2
- >= 49.1



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

MX (local)

lb-in/in

- <= -9135
- 8276
- 7418
- 6559
- 5701
- 4842
- 3984
- 3125
- 2266
- 1408
- 549
- 309
- 1168
- 2026
- 2885
- 3744
- >= 4602



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC


Date 05-Aug-17

Chd

File Wall 3.std

Date/Time 10-Aug-2017 15:38

- MX (local)
- lb-in/in
- <= -12.5 E3
- 11.3 E3
- 10.1 E3
- 8956
- 7776
- 6595
- 5415
- 4235
- 3055
- 1874
- 694
- 486
- 1666
- 2847
- 4027
- 5207
- >= 6388



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev


Part/Wall 3

Ref

By CC Date 05-Aug-17 Chd

File Wall 3.std Date/Time 10-Aug-2017 15:38

- MX (local)
- lb-in/in
- <= -2400
- 2182
- 1965
- 1747
- 1529
- 1312
- 1094
- 876
- 659
- 441
- 223
- 5.81
- 212
- 429
- 647
- 865
- >= 1082



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

MX (local)

lb-in/in

- <= -3320
- 3012
- 2705
- 2397
- 2090
- 1782
- 1475
- 1168
- 860
- 553
- 245
- 62.1
- 370
- 677
- 984
- 1292
- >= 1599



Load 4



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 298

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd

File Wall 3.std

Date/Time 10-Aug-2017 15:38

MY (local)

lb-in/in

<= -14.4 E3

-13.1 E3

-11.8 E3

-10.6 E3

-9.254

-7.958

-6.661

-5.365

-4.069

-2.772

-1.476

-1.80


1.116

2.413

3.709

5.005

>= 6302



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC


Date 05-Aug-17

Chd

File Wall 3.std

Date/Time 10-Aug-2017 15:38

- MY (local)
- lb-in/in
- <= -19 E3
- 17.3 E3
- 15.5 E3
- 13.8 E3
- 12.1 E3
- 10.4 E3
- 8.705
- 6.995
- 5.284
- 3.574
- 1.863
- 1.53
- 1.558
- 3.269
- 4.979
- 6.690
- >= 84.00



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

MY (local)

lb-in/in

- <= -4997
- 4553
- 4110
- 3667
- 3224
- 2781
- 2338
- 1895
- 1452
- 1008
- 565
- 122
- 321
- 764
- 1207
- 1650
- >= 2093



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

MY (local)

lb-in/in

- <= -6181
- 5633
- 5086
- 4538
- 3991
- 3444
- 2896
- 2349
- 1801
- 1254
- 706
- 159
- 389
- 936
- 1484
- 2031
- >= 2579



Load 4



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No

10721A.10

Sheet No

1

Rev

Part/Wall 3

Ref

By CC

Date05-Aug-17



Chd

File Wall 3.std

Date/Time 10-Aug-2017 15:38

SQX (local)

psi



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

SQX (local)

psi

- <= -38
- 33.3
- 28.5
- 23.8
- 19
- 14.3
- 9.5
- 4.75
- 0
- 4.75
- 9.5
- 14.3
- 19
- 23.8
- 28.5
- 33.3
- >= 38



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall	3
-----------	---


Ref	
-----	--

By	CC	Date	05-Aug-17	Chd	
----	----	------	-----------	-----	--

File	Wall 3.std	Date/Time	10-Aug-2017 15:38
------	------------	-----------	-------------------

SQX (local)
psi

- <= -10.2
- 8.94
- 7.66
- 6.38
- 5.11
- 3.83
- 2.55
- 1.28
- 0
- 1.28
- 2.55
- 3.83
- 5.11
- 6.38
- 7.66
- 8.94
- >= 10.2



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

SQX (local)

psi

- <= -12.3
- 10.8
- 9.25
- 7.71
- 6.16
- 4.62
- 3.08
- 1.54
- 0
- 1.54
- 3.08
- 4.62
- 6.16
- 7.71
- 9.25
- 10.8
- >= 12.3



Load 4



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

SQY (local)

psi

- <= -8,6
- 5,28
- 1,95
- 1,37
- 4,69
- 8,01
- 11,3
- 14,7
- 18
- 21,3
- 24,6
- 28
- 31,3
- 34,6
- 37,9
- 41,2
- >= 44,6



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 3

Ref

By CC

Date 05-Aug-17

Chd


File Wall 3.std

Date/Time 10-Aug-2017 15:38

SQY (local)

psi

- ≤ -13.4
- -8.99
- -4.61
- -0.225
- 4.16
- 8.54
- 12.9
- 17.3
- 21.7
- 26.1
- 30.5
- 34.8
- 39.2
- 43.6
- 48
- 52.4
- ≥ 56.8



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 3	
-------------	--

Ref	
-----	--

By CC	Date 05-Aug-17	Chd
-------	----------------	-----

File Wall 3.std	Date/Time 10-Aug-2017 15:38
-----------------	-----------------------------

- SQY (local)
psi
- <= -2.37
 - 0.999
 - 0.375
 - 1.75
 - 3.12
 - 4.5
 - 5.87
 - 7.24
 - 8.62
 - 9.99
 - 11.4
 - 12.7
 - 14.1
 - 15.5
 - 16.9
 - 18.2
 - >= 19.6



Load 3



Software licensed to Carollo Engineers

Job Title Area 6 - Filters


Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No	10721A.10	Sheet No	1	Rev	
Part/Wall	3				
Ref					
By	CC	Date	05-Aug-17	Chd	
File	Wall 3.std		Date/Time	10-Aug-2017 15:38	

SQY (local)
psi

- <= -3.07
- 1.54
- 0.014
- 1.52
- 3.05
- 4.58
- 6.11
- 7.64
- 9.17
- 10.7
- 12.2
- 13.8
- 15.3
- 16.8
- 18.3
- 19.9
- >= 21.4



Load 4

Area 6 - Filters
Wall 4 - Moment & Shear

		Horizontal Span						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	9.30	14.97	16.00	0.94	29	126	0.23
1.2F+1.4E	1.00	12.80	12.80	16.00	0.80	38	126	0.30

		Vertical Span (Mid-Height)						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	6.40	10.30	17.50	0.59	0	126	0.00
1.2F+1.4E	1.00	8.56	8.56	17.50	0.49	0	126	0.00

		Vertical Span (Bottom)						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.4F	1.61	14.60	23.51	43.00	0.55	45	126	0.35
1.2F+1.4E	1.00	19.20	19.20	43.00	0.45	57	126	0.45

<- OK
<- OK
<- OK



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC

Date05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 10:43

MX (local)

lb-in/in

- <= -9314
- 8436
- 7557
- 6678
- 5799
- 4921
- 4042
- 3163
- 2284
- 1406
- 527
- 352
- 1231
- 2110
- 2988
- 3867
- >= 4746



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC


Date 05-Aug-17

Chd

File Wall 4.std

Date/Time 11-Aug-2017 10:43

- MX (local)
- lb-in/in
- <= -12.8 E3
- 11.5 E3
- 10.3 E3
- 9126
- 7917
- 6708
- 5499
- 4290
- 3081
- 1873
- 664
- 545
- 1754
- 2963
- 4172
- 5381
- >= 6590



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willametter River WTP

Job No
10721A.10

Sheet No
1

Rev


Part/Wall 4

Ref

By CC Date05-Aug-17 Chd

File Wall 4.std Date/Time 11-Aug-2017 10:43

- MY (local)
- lb-in/in
- <= -14.6 E3
- 13.3 E3
- 12 E3
- 10.7 E3
- 9373
- 8062
- 6751
- 5440
- 4129
- 2818
- 1507
- 196
- 1115
- 2426
- 3737
- 5048
- >= 6359



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC


Date 05-Aug-17

Chd

File Wall 4.std

Date/Time 11-Aug-2017 10:43

- MY (local)
- lb-in/in
- <= -19.2 E3
- 17.5 E3
- 15.8 E3
- 14 E3
- 12.3 E3
- 10.5 E3
- 8806
- 7070
- 5334
- 3598
- 1862
- 126
- 1610
- 3347
- 5083
- 6819
- >= 8555



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willametter River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 10:43

SQX (local)

psi

- <= -28.9
- 25.3
- 21.7
- 18.1
- 14.5
- 10.8
- 7.23
- 3.61
- 0
- 3.61
- 7.23
- 10.8
- 14.5
- 18.1
- 21.7
- 25.3
- >= 28.9



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 10:43

SQX (local)

psi

- <= -38.4
- 33.6
- 28.8
- 24
- 19.2
- 14.4
- 9.61
- 4.8
- 0
- 4.8
- 9.61
- 14.4
- 19.2
- 24
- 28.8
- 33.6
- >= 38.4



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 4

Ref

By CC

Date05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 10:43

SQY (local)

psi

- <= -7.4
- 4.13
- 0.863
- 2.4
- 5.67
- 8.93
- 12.2
- 15.5
- 18.7
- 22
- 25.3
- 28.5
- 31.8
- 35.1
- 38.3
- 41.6
- >= 44.9



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 4

Ref

By CC

Date 05-Aug-17

Chd


File Wall 4.std

Date/Time 11-Aug-2017 10:43

SQY (local)

psi

- <= -11.7
- 7.41
- 3.1
- 1.2
- 5.51
- 9.82
- 14.1
- 18.4
- 22.7
- 27
- 31.3
- 35.7
- 40
- 44.3
- 48.6
- 52.9
- >= 57.2



Load 2

**Area 6 - Filters
Wall 5 - Moment & Shear**

		Horizontal Span				Vertical Span			
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR	SQX_u (psi)	SQ_n (psi)	DCR	
1.4F	1.61	4.68	7.53	24.50	0.31	17	126	0.13	<- OK
		Vertical Span				Horizontal Span			
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR	
1.4F	1.61	5.30	8.53	35.00	0.24	26	126	0.21	<- OK



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 5

Ref

By CC


Date 05-Aug-17

Chd

File Wall 5.std

Date/Time 11-Aug-2017 10:52

- MX (local)
- lb-in/in
- <= -4678
- 4220
- 3761
- 3303
- 2845
- 2386
- 1928
- 1469
- 1011
- 553
- 94.1
- 364
- 823
- 1281
- 1740
- 2198
- >= 2656



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 5

Ref

By CC


Date05-Aug-17

Chd

File Wall 5.std

Date/Time 11-Aug-2017 10:52

- MY (local)
- lb-in/in
- <= -5267
- 4772
- 4278
- 3783
- 3288
- 2794
- 2299
- 1804
- 1309
- 815
- 320
- 175
- 669
- 1164
- 1659
- 2154
- >= 2648



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 5

Ref

By CC

Date 05-Aug-17

Chd


File Wall 5.std

Date/Time 11-Aug-2017 10:52

SQX (local)

psi

- <= -16.8
- 14.7
- 12.6
- 10.5
- 8.42
- 6.32
- 4.21
- 2.11
- 0
- 2.11
- 4.21
- 6.32
- 8.42
- 10.5
- 12.6
- 14.7
- >= 16.8



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 5

Ref

By CC

Date 05-Aug-17

Chd


File Wall 5.std

Date/Time 11-Aug-2017 10:52

SQY (local)

psi

- <= -25.4
- 22.2
- 18.9
- 15.7
- 12.5
- 9.28
- 6.06
- 2.84
- 0.378
- 3.6
- 6.82
- 10
- 13.3
- 16.5
- 19.7
- 22.9
- >= 26.1



Load 1

**Area 6 - Filters
Wall 7 - Moment & Shear**

		Horizontal Span						
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR	SQX_u (psi)	SQ_n (psi)	DCR
1.6(H+L)	1.41	4.74	6.68	16.00	0.42	19	126	0.15
1.6H+1.4E	1.00	5.91	5.91	16.00	0.37	23	126	0.18

		Vertical Span (Mid-Height)						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.6(H+L)	1.41	4.13	5.82	17.50	0.33	0	126	0.00
1.6H+1.4E	1.00	5.12	5.12	17.50	0.29	0	126	0.00

		Vertical Span (Bottom)						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY_u (psi)	SQ_n (psi)	DCR
1.6(H+L)	1.41	7.96	11.22	33.50	0.34	30	126	0.23
1.6H+1.4E	1.00	9.32	9.32	33.50	0.28	32	126	0.26

<- OK
<- OK
<- OK
<- OK



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref

By CC


Date 05-Aug-17

Chd

File Wall 7.std

Date/Time 11-Aug-2017 13:31

- MX (local)
- lb-in/in
- <= -4736
- 4332
- 3928
- 3525
- 3121
- 2717
- 2314
- 1910
- 1506
- 1103
- 699
- 295
- 108
- 512
- 916
- 1319
- >= 1723



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6-1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref

By CC


Date 05-Aug-17

Chd

File Wall 7.std

Date/Time 11-Aug-2017 13:31

- MX (local)
- lb-in/in
- <= -5907
- 5402
- 4898
- 4394
- 3889
- 3385
- 2880
- 2376
- 1871
- 1367
- 862
- 358
- 147
- 651
- 1155
- 1660
- >= 2164



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref

By CC

Date 05-Aug-17

Chd


File Wall 7.std

Date/Time 11-Aug-2017 13:31

MY (local)

lb-in/in

- <= -7959
- 7203
- 6448
- 5692
- 4936
- 4180
- 3425
- 2669
- 1913
- 1158
- 402
- 354
- 1109
- 1865
- 2621
- 3377
- >= 4132



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6+1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Page 328

Part/Wall 7

Ref

By CC

Date 05-Aug-17

Chd


File Wall 7.std

Date/Time 11-Aug-2017 13:31

MY (local)

lb-in/in

- <= -9320
- 8417
- 7515
- 6612
- 5710
- 4807
- 3905
- 3002
- 2099
- 1197
- 294
- 608
- 1511
- 2413
- 3316
- 4219
- >= 5121



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref

By CC

Date 05-Aug-17

Chd


File Wall 7.std

Date/Time 11-Aug-2017 13:31

SQX (local)

psi

- <= -19
- 16.6
- 14.2
- 11.9
- 9.48
- 7.11
- 4.74
- 2.37
- 0
- 2.37
- 4.74
- 7.11
- 9.48
- 11.9
- 14.2
- 16.6
- >= 19



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6-1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref



By CC

Date 05-Aug-17

Chd

File Wall 7.std

Date/Time 11-Aug-2017 13:31



Load 2



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.10

Sheet No

1

Rev

Part/Wall 7

Ref

By CC

Date 05-Aug-17

Chd


File Wall 7.std

Date/Time 11-Aug-2017 13:31

SQY (local)

psi

- <= -8.79
- 6.39
- 3.98
- 1.58
- 0.824
- 3.23
- 5.63
- 8.04
- 10.4
- 12.8
- 15.2
- 17.7
- 20.1
- 22.5
- 24.9
- 27.3
- >= 29.7



Load 1



Software licensed to Carollo Engineers

Job Title Area 6 - Filters

Load Case: 1.6-1.4E

Client Willamette River WTP

Job No
10721A.10

Sheet No
1

Rev

Part/Wall 7

Ref

By CC


Date 05-Aug-17

Chd

File Wall 7.std

Date/Time 11-Aug-2017 13:31

- SQY (local)
- psi
- <= -13.5
- 10.6
- 7.74
- 4.88
- 2.02
- 0.836
- 3.69
- 6.55
- 9.41
- 12.3
- 15.1
- 18
- 20.8
- 23.7
- 26.6
- 29.4
- >= 32.3




Load 2


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 4 = 8$ ft
 plate dimension, a = **4** ft
 plate dimension, b = **11** ft
 plate sides ratio, a/b = 0.3636



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	8.000	0.440	2.25	1.6
B	100	8.000	0.100	2.25	1.6
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil Static

M _x - Moment Summary													
a = 4 b = 11 a / b = 0.3636		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 9")	
		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0010	0.0080			0.05	0.10			0.15	0.34	0.01	0.36
0	0.8	0.0035	0.0160			0.19	0.19			0.38	0.86	0.02	0.36
0	0.6	0.0085	0.0303			0.45	0.37			0.82	1.84	0.05	0.36
0	0.4	0.0142	0.0340			0.76	0.41			1.17	2.63	0.07	0.36
0	0.2	0.0120	0.0202			0.64	0.24			0.88	1.99	0.05	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0007	0.0010			0.04	0.01			0.05	0.11	0.00	0.36
0.4	0	0.0016	0.0025			0.09	0.03			0.12	0.26	0.01	0.36
0.6	0	0.0024	0.0040			0.13	0.05			0.18	0.40	0.01	0.36
0.8	0	0.0031	0.0050			0.16	0.06			0.22	0.50	0.01	0.36
1	0	0.0033	0.0054			0.17	0.06			0.24	0.54	0.01	0.36
1	0.2	-0.0049	-0.0089			-0.26	-0.11			-0.37	-0.83	-0.02	-0.36
1	0.4	-0.0067	-0.0162			-0.36	-0.20			-0.55	-1.24	-0.03	-0.36
1	0.6	-0.0044	-0.0149			-0.23	-0.18			-0.41	-0.93	-0.02	-0.36
1	0.8	-0.0020	-0.0087			-0.11	-0.11			-0.21	-0.48	-0.01	-0.36
1	1	-0.0011	-0.0058			-0.06	-0.07			-0.13	-0.29	-0.01	-0.36
0.8	1	-0.0009	-0.0049			-0.05	-0.06			-0.11	-0.24	-0.01	-0.36
0.8	0.8	-0.0018	-0.0075			-0.09	-0.09			-0.18	-0.42	-0.01	-0.36
0.8	0.6	-0.0039	-0.0134			-0.21	-0.16			-0.37	-0.83	-0.02	-0.36
0.8	0.4	-0.0061	-0.0147			-0.33	-0.18			-0.50	-1.13	-0.03	-0.36
0.8	0.2	-0.0046	-0.0082			-0.25	-0.10			-0.34	-0.77	-0.02	-0.36

max negative moment, M_{ux}(-) = -1.24 ft-k/ft

max negative steel req'd, A_s(-) = -0.03 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 2.63 ft-k/ft

max positive steel req'd, A_s(+) = 0.07 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil Static

M _y - Moment Summary													
a = 4 b = 11 a / b = 0.3636		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficients				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		x / a	y / b	A	B	C	D	A	B				
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0	0.8	0.0007	0.0032			0.03	0.04			0.07	0.16	0.00	0.36
0	0.6	0.0017	0.0060			0.09	0.07			0.16	0.37	0.01	0.36
0	0.4	0.0028	0.0068			0.15	0.08			0.23	0.52	0.01	0.36
0	0.2	0.0024	0.0040			0.13	0.05			0.18	0.40	0.01	0.36
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
0.2	0	0.0033	0.0048			0.17	0.06			0.23	0.52	0.01	0.36
0.4	0	0.0082	0.0126			0.43	0.15			0.59	1.32	0.03	0.36
0.6	0	0.0124	0.0199			0.66	0.24			0.90	2.03	0.05	0.36
0.8	0	0.0152	0.0249			0.81	0.30			1.11	2.50	0.06	0.36
1	0	0.0161	0.0267			0.86	0.32			1.18	2.66	0.06	0.36
1	0.2	-0.0050	-0.0059			-0.27	-0.07			-0.34	-0.76	-0.02	-0.36
1	0.4	-0.0046	-0.0101			-0.24	-0.12			-0.37	-0.82	-0.02	-0.36
1	0.6	-0.0010	-0.0070			-0.05	-0.08			-0.14	-0.31	-0.01	-0.36
1	0.8	0.0005	0.0004			0.03	0.00			0.03	0.07	0.00	0.36
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.36
1	0.4	-0.0046	-0.0101			-0.24	-0.12			-0.37	-0.82	-0.02	-0.36
0.8	0.4	-0.0042	-0.0093			-0.23	-0.11			-0.34	-0.76	-0.02	-0.36
0.6	0.4	-0.0032	-0.0070			-0.17	-0.08			-0.25	-0.57	-0.01	-0.36
0.4	0.4	-0.0015	-0.0033			-0.08	-0.04			-0.12	-0.27	-0.01	-0.36
0.2	0.4	0.0005	0.0015			0.03	0.02			0.04	0.10	0.00	0.36

max negative moment, M_{uy}(-) = -0.82 ft-k/ft

max negative steel req'd, A_s(-) = -0.02 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 2.66 ft-k/ft

max positive steel req'd, A_s(+) = 0.06 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil Static

Shear Summary												
a = 4 b = 11 a / b = 0.3636		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x / a	y / b	A	B	C	D	A	B			
0	1	-0.0074	0.0151			-0.04	0.02			-0.02	-0.03	10.81
0	0.8	0.0184	0.1032			0.09	0.11			0.20	0.32	10.81
0	0.6	0.0678	0.2949			0.33	0.32			0.65	1.04	10.81
0	0.4	0.1523	0.3564			0.74	0.39			1.13	1.81	10.81
0	0.2	0.1525	0.2186			0.74	0.24			0.98	1.57	10.81
0	0.00	0.0156	0.0025			0.08	0.00			0.08	0.13	10.81
0.2	0	0.0514	0.0324			0.25	0.04			0.28	0.46	10.81
0.4	0	0.1387	0.1650			0.67	0.18			0.85	1.36	10.81
0.6	0	0.1936	0.2586			0.94	0.28			1.22	1.95	10.81
0.8	0	0.2233	0.3131			1.08	0.34			1.43	2.28	10.81
1	0	0.2326	0.3309			1.13	0.36			1.49	2.38	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 2.38 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil EQ

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 4 =$ **8** ft
 plate dimension, a = **4** ft
 plate dimension, b = **11** ft
 plate sides ratio, a/b = 0.3636



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	8.000	0.440	1.6	1.6
B	100	8.000	0.194	1.4	1.4
C	400	8.000	-0.194	1.4	1.4
D	1		0.037	1.4	1.4

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil EQ

M _x - Moment Summary													
a = 4 b = 11 a / b = 0.3636		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.440	0.194	-0.194	0.037					Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0010	0.0080	0.0010	0.0447	0.05	0.19	-0.02	0.20	0.42	0.60	0.01	0.36
0	0.8	0.0035	0.0160	0.0035	0.0439	0.19	0.38	-0.08	0.20	0.68	0.98	0.02	0.36
0	0.6	0.0085	0.0303	0.0085	0.0419	0.45	0.71	-0.20	0.19	1.15	1.70	0.04	0.36
0	0.4	0.0142	0.0340	0.0142	0.0363	0.76	0.80	-0.33	0.16	1.38	2.09	0.05	0.36
0	0.2	0.0120	0.0202	0.0120	0.0205	0.64	0.47	-0.28	0.09	0.92	1.42	0.04	0.36
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0.2	0	0.0007	0.0010	0.0007	0.0009	0.04	0.02	-0.02	0.00	0.05	0.07	0.00	0.36
0.4	0	0.0016	0.0025	0.0016	0.0025	0.09	0.06	-0.04	0.01	0.12	0.18	0.00	0.36
0.6	0	0.0024	0.0040	0.0024	0.0040	0.13	0.09	-0.06	0.02	0.18	0.28	0.01	0.36
0.8	0	0.0031	0.0050	0.0031	0.0051	0.16	0.12	-0.07	0.02	0.23	0.35	0.01	0.36
1	0	0.0033	0.0054	0.0033	0.0054	0.17	0.13	-0.08	0.02	0.25	0.38	0.01	0.36
1	0.2	-0.0049	-0.0089	-0.0049	-0.0091	-0.26	-0.21	0.12	-0.04	-0.40	-0.61	-0.02	-0.36
1	0.4	-0.0067	-0.0162	-0.0067	-0.0179	-0.36	-0.38	0.16	-0.08	-0.66	-0.99	-0.02	-0.36
1	0.6	-0.0044	-0.0149	-0.0044	-0.0212	-0.23	-0.35	0.10	-0.09	-0.57	-0.85	-0.02	-0.36
1	0.8	-0.0020	-0.0087	-0.0020	-0.0222	-0.11	-0.20	0.05	-0.10	-0.36	-0.53	-0.01	-0.36
1	1	-0.0011	-0.0058	-0.0011	-0.0233	-0.06	-0.14	0.03	-0.10	-0.27	-0.40	-0.01	-0.36
0.8	1	-0.0009	-0.0049	-0.0009	-0.0205	-0.05	-0.12	0.02	-0.09	-0.23	-0.34	-0.01	-0.36
0.8	0.8	-0.0018	-0.0075	-0.0018	-0.0196	-0.09	-0.18	0.04	-0.09	-0.32	-0.46	-0.01	-0.36
0.8	0.6	-0.0039	-0.0134	-0.0039	-0.0188	-0.21	-0.31	0.09	-0.08	-0.51	-0.76	-0.02	-0.36
0.8	0.4	-0.0061	-0.0147	-0.0061	-0.0160	-0.33	-0.35	0.14	-0.07	-0.60	-0.90	-0.02	-0.36
0.8	0.2	-0.0046	-0.0082	-0.0046	-0.0084	-0.25	-0.19	0.11	-0.04	-0.37	-0.56	-0.01	-0.36

max negative moment, M_{ux}(-) = -0.99 ft-k/ft

max negative steel req'd, A_s(-) = -0.02 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{ux}(+) = 2.09 ft-k/ft

max positive steel req'd, A_s(+) = 0.05 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil EQ

M _y - Moment Summary													
a = 4 b = 11 a / b = 0.3636		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.440	0.194	-0.194	0.037					Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		53.240	23.474	-23.474	4.477								
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0	0.8	0.0007	0.0032	0.0007	0.0088	0.03	0.07	-0.02	0.04	0.13	0.19	0.00	0.36
0	0.6	0.0017	0.0060	0.0017	0.0083	0.09	0.14	-0.04	0.04	0.23	0.34	0.01	0.36
0	0.4	0.0028	0.0068	0.0028	0.0073	0.15	0.16	-0.07	0.03	0.28	0.42	0.01	0.36
0	0.2	0.0024	0.0040	0.0024	0.0041	0.13	0.09	-0.06	0.02	0.18	0.28	0.01	0.36
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
0.2	0	0.0033	0.0048	0.0033	0.0047	0.17	0.11	-0.08	0.02	0.23	0.36	0.01	0.36
0.4	0	0.0082	0.0126	0.0082	0.0127	0.43	0.30	-0.19	0.06	0.60	0.92	0.02	0.36
0.6	0	0.0124	0.0199	0.0124	0.0202	0.66	0.47	-0.29	0.09	0.93	1.43	0.03	0.36
0.8	0	0.0152	0.0249	0.0152	0.0252	0.81	0.58	-0.36	0.11	1.15	1.77	0.04	0.36
1	0	0.0161	0.0267	0.0161	0.0270	0.86	0.63	-0.38	0.12	1.23	1.89	0.04	0.36
1	0.2	-0.0050	-0.0059	-0.0050	-0.0048	-0.27	-0.14	0.12	-0.02	-0.31	-0.49	-0.01	-0.36
1	0.4	-0.0046	-0.0101	-0.0046	-0.0077	-0.24	-0.24	0.11	-0.03	-0.41	-0.62	-0.01	-0.36
1	0.6	-0.0010	-0.0070	-0.0010	-0.0060	-0.05	-0.16	0.02	-0.03	-0.22	-0.32	-0.01	-0.36
1	0.8	0.0005	0.0004	0.0005	-0.0040	0.03	0.01	-0.01	-0.02	0.01	0.01	0.00	0.36
1	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
1	0.4	-0.0046	-0.0101	-0.0046	-0.0077	-0.24	-0.24	0.11	-0.03	-0.41	-0.62	-0.01	-0.36
0.8	0.4	-0.0042	-0.0093	-0.0042	-0.0071	-0.23	-0.22	0.10	-0.03	-0.38	-0.57	-0.01	-0.36
0.6	0.4	-0.0032	-0.0070	-0.0032	-0.0051	-0.17	-0.16	0.08	-0.02	-0.28	-0.43	-0.01	-0.36
0.4	0.4	-0.0015	-0.0033	-0.0015	-0.0019	-0.08	-0.08	0.04	-0.01	-0.13	-0.20	0.00	-0.36
0.2	0.4	0.0005	0.0015	0.0005	0.0024	0.03	0.04	-0.01	0.01	0.06	0.09	0.00	0.36

max negative moment, M_{uy}(-) = -0.62 ft-k/ft

max negative steel req'd, A_s(-) = -0.01 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 1.89 ft-k/ft

max positive steel req'd, A_s(+) = 0.04 in²/ft

minimum steel req'd = 0.36 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 6 - Filters JOB NO: 9789A.10
 DESIGN TASK: Wall 8 - Soil EQ

Shear Summary												
a = 4 b = 11 a / b = 0.3636		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		0.440	0.194	-0.194	0.037					Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		4.840	2.134	-2.134	0.407							
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	-0.0074	0.0151	-0.0074	0.3593	-0.04	0.03	0.02	0.15	0.16	0.21	10.81
0	0.8	0.0184	0.1032	0.0184	0.3769	0.09	0.22	-0.04	0.15	0.42	0.61	10.81
0	0.6	0.0678	0.2949	0.0678	0.3652	0.33	0.63	-0.14	0.15	0.96	1.41	10.81
0	0.4	0.1523	0.3564	0.1523	0.3465	0.74	0.76	-0.33	0.14	1.31	1.99	10.81
0	0.2	0.1525	0.2186	0.1525	0.2130	0.74	0.47	-0.33	0.09	0.97	1.50	10.81
0	0.00	0.0156	0.0025	0.0156	0.0012	0.08	0.01	-0.03	0.00	0.05	0.08	10.81
0.2	0	0.0514	0.0324	0.0514	0.0292	0.25	0.07	-0.11	0.01	0.22	0.36	10.81
0.4	0	0.1387	0.1650	0.1387	0.1615	0.67	0.35	-0.30	0.07	0.79	1.24	10.81
0.6	0	0.1936	0.2586	0.1936	0.2564	0.94	0.55	-0.41	0.10	1.18	1.84	10.81
0.8	0	0.2233	0.3131	0.2233	0.3123	1.08	0.67	-0.48	0.13	1.40	2.18	10.81
1	0	0.2326	0.3309	0.2326	0.3307	1.13	0.71	-0.50	0.13	1.47	2.28	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 2.28 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

Area 8 - Washwater Basin Pump Station
ASCE 41 Evaluation

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Seismic

SEISMIC HAZARD LEVEL & BASIC PERFORMANCE OBJECTIVE

Note: **4.1.2 Seismic Hazard Level** The Seismic Hazard Level for the Tier 1 screening shall be BSE-1E per Table 2-1 for the Basic Performance Objective for Existing Buildings (BPOE).

Table 2-1. Basic Performance Objective for Existing Buildings (BPOE)

Risk Category	Tier 1*	Tier 2*	Tier 3	
	BSE-1E	BSE-1E	BSE-1E	BSE-2E
I & II	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Collapse Prevention Structural Performance Nonstructural Performance Not Considered (5-D)
III	See footnote b for Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Limited Safety Structural Performance Nonstructural Performance Not Considered (4-D)
IV	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Life Safety Structural Performance Nonstructural Performance Not Considered (3-D)

*For Tier 1 and 2 assessments, seismic performance for the BSE-2E is not explicitly evaluated.
 *For Risk Category III, the Tier 1 screening checklists shall be based on the Life Safety Performance Level (S-3), except that checklist statements using the Quick Check procedures of Section 4.5.3 shall be based on MS-factors and other limits that are an average of the values for Life Safety and Immediate Occupancy.

BUILDING PERIOD (SECTION 4.5.2.4)

building height, $h_n = 11.33$ ft
 building period adjustment factor, $C_t = 0.020$
 effective viscous damping ratio, $\beta = 0.75$
 fundamental building period, $T = 0.124$ sec

SEISMIC PARAMETERS

Building Type = **RM1** Table 3-1
 modification factor, $C = 1.00$ Table 4-8

Table 4-8. Modification Factor, C

Building Type*	Number of Stories			
	1	2	3	≥4
Wood (W1, W1a, W2) Moment frame (S1, S3, C1, PC2a)	1.3	1.1	1.0	1.0
Shear wall (S4, S5, C2, C3, PC1a, PC2, RM2, URMa)	1.4	1.2	1.1	1.0
Braced frame (S2)				
Unreinforced masonry (URM)	1.0	1.0	1.0	1.0
Flexible diaphragms (S1a, S2a, S5a, C2a, C3a, PC1, RM1)				

*Defined in Table 3-1.

spectral acceleration at 1-sec for BSE-1E, $S_{x1} = 0.372$ g USGS Seismic Map
 spectral acceleration at short period for BSE-1E, $S_{xs} = 0.611$ g USGS Seismic Map
 spectral acceleration, $S_a = 0.611$ g $S_a = \frac{S_{x1}}{T}$ but S_a shall not exceed S_{xs} .
 base shear coefficient, $V = 0.611$ W Eq 4-1



BY: C. Che **DATE:** Sep-17 **CLIENT:** Wilamette River WTP **SHEET**
CHKD BY: **DESCRIPTION:** Area 8 - Washwater Basin PS **JOB NO.:** 10721A.00
DESIGN TASK: ASCE 41 (Tier 1 Screening) - Building Weight & Base Shear

DEAD LOAD (Seismic Weight)

Roof Weight

Roofing	=	5.00	psf
Metal Roof Deck	=	3.00	psf
Steel Joist	=	7.00	psf
Miscellaneous (MEP)	=	5.00	psf
Total =			20.00 psf

Roof Length	=	36.67	ft
Roof Width	=	16.67	ft
Total Roof Weight =			12.23 kips

	UW (in)	Trib Ht (ft)	Length (ft)		
Parapet Wall	84.00	2.00	109.34	=	18.37 kips
Wall Below	84.00	5.67	109.34	=	52.03 kips
Roof Seismic Weight =					82.63 kips

Seismic Weight & Base Shear

Base Shear Coefficient	=	0.611	g
Total Seismic Weight	=	83	kips
Design Base Shear	=	50	kips

LIVE LOAD

Roof Live Load	=	20.0	psf
----------------	---	------	-----



BY: C. Che **DATE:** Sep-17 **CLIENT:** Wilamette River WTP **SHEET**
CHKD BY: **DESCRIPTION:** Area 8 - Washwater Basin PS **JOB NO.:** 10721A.00
DESIGN TASK: ASCE 41 (Tier 1 Screening) - CMU Wall Story Rigidity

SHEAR WALL RIGIDITY

P = 1000 kip -- applied unit force

f_m = 1500 psi -- concrete compressive strength

E_{mc} = 194400 ksf -- modulus of elasticity

E_{mv} = 77760 ksf -- shear modulus

Cantilever at Top of Each Floor:

$$\delta_c = \frac{4P}{Et} \left[\left(\frac{H}{L} \right)^3 + 0.75 \frac{H}{L} \right]$$

Fixed at Openings:

$$\delta_f = \frac{P}{Et} \left[\left(\frac{H}{L} \right)^3 + 3 \frac{H}{L} \right]$$

	Thick (in)	Height (ft)	Length (ft)	I (ft ³)	Δ (in)	R 1/Δ
CMU Walls NS-Direction						
East	7.63	13.33	38.00	2907	0.1189	8.41
West	7.63	13.33	38.00	2907	0.1189	8.41
					ΣR =	16.82



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Concrete Wall Story Rigidity

SOFT STORY CHECK (Relative Rigidity for Story Drift)

P = 1000 kip – applied unit force

f_c = 4000 psi – concrete compressive strength

E_{mc} = 519119.5 ksf – modulus of elasticity

E_v = 207647.8 ksf – shear modulus

Cantilever at Top of Each Floor:

$$\delta_c = \frac{4P}{Et} \left[\left(\frac{H}{L} \right)^3 + 0.75 \frac{H}{L} \right]$$

Fixed at Openings:

$$\delta_f = \frac{P}{Et} \left[\left(\frac{H}{L} \right)^3 + 3 \frac{H}{L} \right]$$

	Thick (in)	Height (ft)	Length (ft)	I (ft ³)	Δ (in)	R 1/Δ
Concrete Walls Below CMU Walls in NS-Direction						
East	18.00	17	10.00	125	0.3814	2.62
West	18.00	17	38.00	6859	0.0262	38.16
					ΣR =	40.79

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Shear Stress

SEISMIC LOAD VERTICAL DISTRIBUTION

Wall Shear Stress Check

4.5.3.3 Shear Stress in Shear Walls The average shear stress in shear walls, v_j^{avg} , shall be calculated in accordance with Eq. (4-9).

$$v_j^{avg} = \frac{1}{M_s} \left(\frac{V_j}{A_w} \right) \quad (4-9)$$

where V_j = Story shear at level j computed in accordance with Section 4.5.2.2.

A_w = Summation of the horizontal cross-sectional area of all shear walls in the direction of loading. Openings shall be taken into consideration when computing A_w . For masonry walls, the net area shall be used. For wood-framed walls, the length shall be used rather than the area.

M_s = System modification factor; M_s shall be taken from Table 4-9.

$V_{s,allow} = 70$ psi
 $M_s = 3.0$ <-- "Damage Control (between "LS" & "IO")

	t_{wall} (in)	$L_{net, wall}$ (ft)	A_{wall} (in ²)	V (kips)	V_{shear} (psi)	
Walls in NS-Dir	7.63	70.67	6466	50.00	2.58	<= OK
Walls in EW-Dir	7.63	31.34	2868	50.00	5.81	<= OK


Table 4-9. M_s Factors for Shear Walls

Wall Type	Level of Performance	
	LS	IO
Reinforced concrete, precast concrete, wood, and reinforced masonry	4.0	2.0
Unreinforced masonry	1.5	1.0

Table 4-10. M_s Factors for Diagonal Braces

Brace Type	d/t^*	Level of Performance	
		LS	IO
Tube ^b	$< 90/(F_y)^{1/2}$	6.0	2.5
	$> 190/(F_y)^{1/2}$	3.0	1.5
Pipe ^b	$< 1500/F_{ye}$	6.0	2.5
	$> 6000/F_{ye}$	3.0	1.5
Tension-only		3.0	1.5
All others		6.0	2.5

*Depth-to-thickness ratio.
^bInterpolation to be used for tubes and pipes.
 $F_{ye} = 1.25F_y$; expected yield stress.





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Transverse Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K =$	1.00	per Table 6-1
seismic modification factors, $C_1C_2 =$	1.40	per Table 7-3
effective mass factor, $C_m =$	1.00	per Table 7-4
diaphragm shear, m_1 -factor =	1.625	per Table 9-4 (between "IO" & "LS")
diaphragm chord, m_2 -factor =	3.625	per Table 9-4 (between "IO" & "LS")
force-delivery reduction factor, $J =$	2.00	per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} =$	36.67 ft	
diaphragm depth, $L_{diaph} =$	16.67 ft	
spectral acceleration, $S_a =$	0.611 g	
building seismic weight, $W =$	83 kips	
pseudo seismic force, $V = F_d = C_1C_2C_mS_aW =$	71 kips	
diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) =$	2130 plf	
allowable diaphragm shear =	1069 plf	per IAPMO-ER #0217
conversion factor for strength design, $C_{buckling} =$	1.60	per IAPMO-ER #0217
diaph shear capacity, $Q_{CE} =$	1710 plf	
$m_1 * K * Q_{CE} =$	2779 plf	


Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) =$	19522 lbs
strength reduction factor, $\phi =$	1.00
Number of Bars =	2 bars
Bar Size =	#5
Yield Stress $f_y =$	60,000 psi
$A_{s, total} =$	0.62 in ²
Tensile Capacity at Opng, $\phi T_n =$	37200 lbs
$m_2 * K * Q_{CE} =$	134850 lbs

Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, $d_b =$	0.750 in
anchorage spacing, $s =$	24.00 in
anchor bolt effective embed, $l_b =$	3.50 in
anchor bolt yield stress, $f_y =$	36.00 ksi
masonry compressive strength, $f_m =$	1500 psi





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Transverse Direction

$$\text{anchor bolt shear, } Q_E = V_{\text{bolt}} = (V / 2L_{\text{diaph}}) * (s/12) = 4259 \text{ lbs /bolt}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 1521 \text{ lbs /bolt}$$

$$\text{projected area of anchor bolt shear, } A_{pv} = 38.48 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{projected area of anchor bolt tension, } A_{pt} = 76.97 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{cross section area of anchor bolt, } A_b = 0.44 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{strength reduction factor, } \phi = 1.00$$

$$KQ_{CL} = K\phi B_{vnb} = K * \phi * 4 * A_{pv} * (f'_m)^{0.5} = 5962 \text{ lbs /bolt} \quad \text{masonry breakout}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 1050 * (f'_m * A_b)^{1/4} = 5327 \text{ lbs /bolt} \quad \text{masonry crushing}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 8 * A_{pt} * (f'_m)^{0.5} = 23848 \text{ lbs /bolt} \quad \text{anchor bolt pryout}$$

$$KQ_{CL} = K\phi B_{vns} = K * \phi * 0.6 * A_b * f_y = 15904 \text{ lbs /bolt} \quad \text{steel yielding}$$

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (*newtons*) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

$$\text{effective puddle weld diameter} = 0.500 \text{ in}$$

$$\text{puddle weld spacing} = 12.00 \text{ in}$$

$$\text{puddle weld shear, } Q_E = V_{\text{bolt}} = (V / 2L_{\text{diaph}}) * (s/12) = 2130 \text{ lbs /weld}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 761 \text{ lbs /weld}$$

$$\text{allowable strength of weld} = 1257 \text{ lbs /weld}$$

$$\text{conversion factor for strength design, } C_{WELD} = 1.65 \quad \text{per IAPMO-ER \#0217}$$

$$KQ_{CL} = 2074 \text{ lbs /weld}$$

Numerical Acceptance Criteria

$$\text{acceptance criteria (max allowable DCR)} = 1.00$$

<u>demand capacity ratio, DCR</u>	0.77	<--	OK	diaphragm shear
<u>demand capacity ratio, DCR</u>	0.14	<--	OK	diaphragm chord
<u>demand capacity ratio, DCR</u>	0.26	<--	OK	masonry breakout
<u>demand capacity ratio, DCR</u>	0.29	<--	OK	masonry crushing
<u>demand capacity ratio, DCR</u>	0.06	<--	OK	anchor bolt pryout
<u>demand capacity ratio, DCR</u>	0.10	<--	OK	steel yielding
<u>demand capacity ratio, DCR</u>	0.37	<--	OK	puddle weld strength



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Longitudinal Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K =$	1.00	per Table 6-1
seismic modification factors, $C_1C_2 =$	1.40	per Table 7-3
effective mass factor, $C_m =$	1.00	per Table 7-4
diaphragm shear, m_1 -factor =	1.625	per Table 9-4 (between "IO" & "LS")
diaphragm chord, m_2 -factor =	3.625	per Table 9-4 (between "IO" & "LS")
force-delivery reduction factor, $J =$	2.00	per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} =$	16.67 ft	
diaphragm depth, $L_{diaph} =$	36.67 ft	
spectral acceleration, $S_a =$	0.611 g	
building seismic weight, $W =$	83 kips	
pseudo seismic force, $V = F_d = C_1C_2C_mS_aW =$	71 kips	
diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) =$	968 plf	
allowable diaphragm shear =	1069 plf	per IAPMO-ER #0217
conversion factor for strength design, $C_{buckling} =$	1.60	per IAPMO-ER #0217
diaph shear capacity, $Q_{CE} =$	1710 plf	allowable multiplied by 1.4 for strength level
$m_1 * K * Q_{CE} =$	2779 plf	


Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) =$	4034 lbs
strength reduction factor, $\phi =$	1.00
Number of Bars =	2 bars
Bar Size =	#5
Yield Stress $f_y =$	60,000 psi
$A_{s, total} =$	0.62 in ²
Tensile Capacity at Opng, $\phi T_n =$	37200 lbs
$m_2 * K * Q_{CE} =$	134850 lbs

Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, $d_b =$	0.750 in
anchorage spacing, $s =$	24.00 in
anchor bolt effective embed, $l_b =$	3.50 in
anchor bolt yield stress, $f_y =$	36.00 ksi
masonry compressive strength, $f_m =$	1500 psi





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in Longitudinal Direction

$$\text{anchor bolt shear, } Q_E = V_{\text{bolt}} = (V / 2L_{\text{diaph}}) * (s/12) = 1936 \text{ lbs /bolt}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 691 \text{ lbs /bolt}$$

$$\text{projected area of anchor bolt shear, } A_{pv} = 38.48 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{projected area of anchor bolt tension, } A_{pt} = 76.97 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{cross section area of anchor bolt, } A_b = 0.44 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{strength reduction factor, } \phi = 1.00$$

$$KQ_{CL} = K\phi B_{vnb} = K * \phi * 4 * A_{pv} * (f'_m)^{0.5} = 5962 \text{ lbs /bolt} \quad \text{masonry breakout}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 1050 * (f'_m * A_b)^{1/4} = 5327 \text{ lbs /bolt} \quad \text{masonry crushing}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 8 * A_{pt} * (f'_m)^{0.5} = 23848 \text{ lbs /bolt} \quad \text{anchor bolt pryout}$$

$$KQ_{CL} = K\phi B_{vns} = K * \phi * 0.6 * A_b * f_y = 15904 \text{ lbs /bolt} \quad \text{steel yielding}$$

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (*newtons*) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

$$\text{effective puddle weld diameter} = 0.500 \text{ in}$$

$$\text{puddle weld spacing} = 12.00 \text{ in}$$

$$\text{puddle weld shear, } Q_E = V_{\text{bolt}} = (V / 2L_{\text{diaph}}) * (s/12) = 968 \text{ lbs /weld}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 346 \text{ lbs /weld}$$

$$\text{allowable strength of weld} = 1257 \text{ lbs /weld}$$

$$\text{conversion factor for strength design, } C_{WELD} = 1.65 \quad \text{per IAPMO- allowable multiplied by 1.4 for}$$

$$KQ_{CL} = 2074 \text{ lbs /weld}$$

Numerical Acceptance Criteria

$$\text{acceptance criteria (max allowable DCR)} = 1.00$$

<u>demand capacity ratio, DCR</u>	0.35	<--	OK	diaphragm shear
<u>demand capacity ratio, DCR</u>	0.03	<--	OK	diaphragm chord
<u>demand capacity ratio, DCR</u>	0.12	<--	OK	masonry breakout
<u>demand capacity ratio, DCR</u>	0.13	<--	OK	masonry crushing
<u>demand capacity ratio, DCR</u>	0.03	<--	OK	anchor bolt pryout
<u>demand capacity ratio, DCR</u>	0.04	<--	OK	steel yielding
<u>demand capacity ratio, DCR</u>	0.17	<--	OK	puddle weld strength

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Joist Supports

WALL ANCHORAGE FORCE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \tag{4-13}$$


Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall height to diaphragm, h_w = 11.33 ft
- parapet height, h_p = 2.00 ft
- unit weight of wall, w_p = 84.00 psf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- beam spacing = 6.11 ft
- wall out-of-plane load = 590 lbs/ ft
- wall anchorage force, T_c = 3605 lbs

<-- "Damage Control (between "LS" & "IO")"

Masonry & Steel Strength

- number of anchor bolts = 2
- anchor bolt size = 0.625 in
- anchor bolt embed = 6.00 in
- anchor bolt edge distance = 3.81 in
- anchorage spacing = 6.00 in
- anchor bolt yield stress, f_y = 36.00 ksi
- masonry compressive strength, f_m = 1500 psi
- projected area of anchor bolt shear, A_{pv} = 46 in²
- projected area of anchor bolt tension, A_{pt} = 137 in²
- cross section area of anchor bolt, A_b = 0.31 in²



- $\phi B_{vnb} = 1.0 \cdot 4 \cdot A_{pv} \cdot (f_m)^{0.5} = 7,074$ lbs
- $\phi B_{vnpry} = 1.0 \cdot 1050 \cdot (f_m \cdot A_b)^{1/4} = 9,726$ lbs
- $\phi B_{vnpry} = 1.0 \cdot 8 \cdot A_{pt} \cdot (f_m)^{0.5} = 42,525$ lbs
- $\phi B_{vns} = 1.0 \cdot 0.6 \cdot A_b \cdot f_y = 13,254$ lbs

- masonry breakout
- masonry crushing
- anchor bolt pryout
- steel yielding

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

- demand capacity ratio, DCR = 0.51 <-- **OK** masonry breakout
- demand capacity ratio, DCR = 0.37 <-- **OK** masonry crushing
- demand capacity ratio, DCR = 0.08 <-- **OK** anchor bolt pryout
- demand capacity ratio, DCR = 0.27 <-- **OK** steel yielding

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

WALL ANCHORAGE FORCE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$


Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall height to diaphragm, h_w = 11.33 ft
- parapet height, h_p = 2.00 ft
- unit weight of wall, w_p = 84.00 psf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- anchor bolts spacing = 24.00 in
- wall out-of-plane load = 590 lbs/ ft
- wall anchorage force, T_c = 1180 lbs /bolt

<-- "Damage Control (between "LS" & "IO")"

Masonry & Steel Strength

- anchor bolt size = 0.750 in
- anchor bolt embed = 3.50 in
- anchor bolt edge distance = 3.81 in
- anchorage spacing = 6.00 in
- anchor bolt yield stress, f_y = 36.00 ksi
- masonry compressive strength, f_m = 1500 psi
- projected area of anchor bolt tension, A_{pt} = 38 in²
- cross section area of anchor bolt, A_b = 0.44 in²
- $\phi B_{anb} = 1.0 * 4 * A_{pt} * (f_m)^{0.5} = 5,962$ lbs
- $\phi B_{ans} = 1.0 * A_b * f_y = 15,904$ lbs



masonry breakout
 steel yielding

Ledger Angle

- yield strength, f_y = 36,000 psi
- ledger angle thick, t = 0.31 in
- moment arm, l_{arm} = 1.19 in
- effective width, b = 3.00 in
- section modulus, S = 0.0488 in³
- shear stress = 1,259 psi
- moment = 1,404 lb-in
- flexural stress = 28,763 psi

distance from top of ledger to center of AB



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.20	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.07	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.03	<--	<u>OK</u>	ledger shear
<u>demand capacity ratio, DCR =</u>	0.80	<--	<u>OK</u>	ledger flexural

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck


STEEL DECK PROPERTIES (ASTM A653, Grade 33)

Modulus of Elasticity, E = 29500 ksi

Yield Strength, F_y = 38 ksi

Ultimate Strength, F_u = 52 ksi

PLB™-36
HSB®-36



Steel Deck = HSB-36

Gage = 20

Deck Span, L = 5.67 ft

Gage	Weight		Section Properties per ft (m) of width		
	Galv psf N/m ²	Painted psf N/m ²	I in. ⁴ mm ⁴	+ S in. ³ mm ³	- S in. ³ mm ³
22	1.9 91.0	1.8 86.2	0.175 238,978	0.187 10,054	0.198 10,645
20	2.3 110.1	2.2 105.3	0.216 294,967	0.235 12,634	0.248 13,333
18	2.9 138.9	2.8 134.1	0.302 412,408	0.322 17,312	0.335 18,011
16	3.5 167.6	3.4 162.8	0.377 514,827	0.411 22,097	0.417 22,419

DESIGN LOAD (Service Level)

Roof Load, w = 30 psf --- steel deck gravity

Wall Out-of-Plane Load, F = 590 lb/ft --- deck axial load

Design Flexural Moment :

Neutral Axis, y_b = 0.919 in

M_{roof} = 1.447 kip-in /ft --- moment due to gravity load = w * L² / 8

M_{ecc} = 0.387 kip-in /ft --- moment due to wall out-of-plane = (F/1.4) * y_b

M_{total} = 1.834 kip-in /ft

ARC-SPOT WELD (WALL OUT-OF-PLANE)

Effective Weld Size Dia, d_e = 1/2 in

Weld Pattern = 5 per 36/sheet

Allowable Weld Capacity = 2.10 kip/ft <= OK

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

Allowable shear strength for 1/2" effective diameter puddle welds.



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE COMPRESSION

Effective Length Factor, $K = 1.00$
 Deck Thickness, $t = 0.0359$ in
 Width of Top Flange, $w = 3.50$ in
 Gross Section Area, $A_g = 0.599$ in²/ft
 radius of gyration, $r = 0.601$ in
 $KL/r = 113$
 $\lambda_c = 1.29$
 $F_n = 18.85$ ksi

Effective Width of Top & Bottom Flange Under Compression
(Assume Bottom Flange Fully Effective)

$\Omega_c = 1.8$ --- factor of safety
 $k = 4$ k = Plate buckling coefficient
 = 4 for stiffened elements supported by a web on each longitudinal edge.
 Values for different types of elements are given in the applicable sections.
 Poisson's Ratio = 0.300
 $F_{cr} = 11.22$
 $\lambda = 1.296$
 $\rho = 0.641$
 Effective Flange Width, $b = 2.242$ in --- effective flange width = ρw
 Effective Section Area, $A_e = 0.554$ in²/ft --- effective section area
 $P_n / \Omega_c = 5.80$ kip /ft **<= OK** --- $A_e * F_n / \Omega_c$

STEEL DECK ALLOWABLE TENSION

Gross Section Area, $A_g = 0.599$ in²/ft
 $\Omega_{T1} = 1.67$
 $T_{n1} / \Omega_{T1} = 13.63$ kip /ft **<= OK** --- $A_g * F_y / \Omega_{T1}$
 $\Omega_{T2} = 2.00$
 $T_{n2} / \Omega_{T2} = 15.57$ kip /ft **<= OK** --- $A_g * F_u / \Omega_{T2}$

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET
 CHKD BY DESCRIPTION Area 8 - Washwater Basin PS JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE BENDING

$$\Omega_b = 1.67$$

$$S_+ = 0.235 \text{ in}^3/\text{ft} \quad \text{--- positive section modulus}$$

$$\frac{M_n}{\Omega_b} = 5.35 \text{ kip-in/ft} \quad \leq \text{OK} \quad \text{--- } S_+ * F_y / \Omega_b$$

COMBINED LOAD INTERACTION

Bending-Tension Interaction:

$$\text{DCR} = 0.386 \quad \leq \text{OK}$$

Bending-Compression Interaction:

$$\text{DCR} = 0.445 \quad \leq \text{OK}$$

Area 8 - Washwater Basin Concrete Structure
ACI 350 Evaluation

REV	DATE	BY	DESCRIPTION

SCALE	3/8"=1'-0"
WARNING	IF THIS DRAWING DOES NOT TO SCALE
DESIGNED BY	B. CROOK
CHECKED BY	
SUBMITTED BY	
LICENSE NO.	
DATE	




Portland
Oregon

City of
WILSONVILLE
in OREGON




WASTE WATER TREATMENT PLANT
STATION-STRUCTURAL
FOUNDATION PLAN

SHEET
8S-01



RECORD DRAWING

This record drawing has been prepared, entirely or in part, furnished by others to the preparer who is not responsible for any inaccuracies, errors or omissions which may have resulted therefrom as a result of the preparation.



REV	DATE BY	DESCRIPTION
R	12-02 AP	RECORD DRAWING

SCALE	3/8"=1'-0"	WARNING	IF THIS DRAWING DOES NOT SCALE THEN DRAWING IS NOT TO SCALE	DESIGNED BY	B. CROOK	CHECKED BY	B. CROOK	SUBMITTED BY	DATE	LICENSE NO.	DATE	LICENSE NO.
-------	------------	---------	---	-------------	----------	------------	----------	--------------	------	-------------	------	-------------



City of
WILSONVILLE
in OREGON




WILSONVILLE WASTE WATER TREATMENT PLANT
STATION - STRUCTURAL
SECTION

SECTION	A
VAR	

RECORD DRAWING
This record drawing has been prepared, entirely or in part, for the project of... responsible for any inaccuracies, errors or omissions which may have been made as a result of...


REV	DATE	BY	DESCRIPTION	SCALE	WARNING	DESIGNED BY	CHECKED	SUBMITTED BY	LICENSE NO.	DATE	LICENSE NO.	DATE	 MWH MONTGOMERY WATSON HARZA Portland Oregon	City of WILSONVILLE in OREGON	 WILSONVILLE CITY OF WILSONVILLE WASTE WATER TREATMENT PLANT STATION - STRUCTURAL	WILSONVILLE WASTE WATER TREATMENT PLANT STATION - STRUCTURAL SECTION	SHEET 85-05
RECORD DRAWING	3/8"=1'-0"	0	IF THIS DATE DOES NOT TO SCALE	B. CROOK													



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**
 tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 58 ft
 tank wall thickness, t_w = 18 inch
 wall height to underside of roof, H_w = 20.5 ft
 liquid height, H_L = 18.5 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION
(wall fixity = pinned at roof & fixed at floor)


Soil Data

The site has no groundwater.
 soil height above top of foundation base = 20.5 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0 k/ft³
 live load lateral surcharge = 0.100 ksf
 0
 concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, $R_{wi} = 2.15$
 Response modification factor, $R_{wc} = 1.3$



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (18/12) * (20.5) * 0.15 = 4.61 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 20.5 / 2 = 10.250 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (58) * (1) * (18.5) * 32.17 = 66.96 \text{ kip}$$

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.14338 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.37999 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 7.845 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = Ec * (tw * Hw / h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 2632.44 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (2632.44 / (0.1434 + 0.38))^{1/2} = 70.9214 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 70.9214 = 0.0886 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.319)))^{1/2} = 8.8181$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 8.8181 / (58)^{1/2} = 1.1579 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 1.1579 = 5.4265 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * Sd1 / Tc = 0.181 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.5712$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures



L = 58 ft
 B = 1 ft
 H_L = 18.5 ft
 W_L = 66.96 kip

L / H_L = 3.13514
 H_L / L = 0.31897

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 66.96 * (\tanh(0.866 * (3.13514)) / 0.866 * (3.13514)) = 24.45 \text{ kip}$$

h_i (EBP) = H_L * 0.375 = 18.5 * 0.375 = 6.938 ft

h_i (IBP) = H_L * {{{(0.866*L/H_L)/(2*tanh(0.866*L/H_L))} - 1/8} = 23.023 ft

impulsive force, P_i = $\left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.15) * 24.45 = 8.7 \text{ kip}$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 66.96 * (0.264 * (3.13514) * \tanh(3.16 * (0.319))) = 42.39 \text{ kip}$$

$$h_c \text{ (EBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 9.961 \text{ ft}$$

$$h_c \text{ (IBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 25.572 \text{ ft}$$

convective force, P_c = $\left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.1813 * 1.25 / 1.3) * 42.39 = 7.4 \text{ kip}$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 4.61$ kip
 wall c.g. relative to base, $h_w = 10.250$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.5712 / 2.15) * 4.61 = 0.94 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (58 / 2) * (0.1813 / 1.4 * 1.25) = 4.69 \text{ ft}$$

Wave height is greater than the freeboard of 2-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 8.70$ kip
 $h_i = 6.938$ ft
 at $y = H_L$, $p_{iy} = 0.059$ ksf
 at base $y = 0$, $p_{iy} = 0.411$ ksf

convective:

$$P_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 7.40$ kip
 $h_c = 9.961$ ft
 at $y = H_L$, $p_{cy} = 0.246$ ksf
 at base $y = 0$, $p_{cy} = 0.154$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$$\ddot{u} = 0.2444$$

at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.282$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$$p_{wy} = 0.2029 * \gamma_c * (t_w/12)$$

at $y = H_w$, $p_{wy} = 0.046$ ksf
 at base $y = 0$, $p_{wy} = 0.046$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.154$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_{wy}^2} =$$




at $y = H_w$, $p_y = 0.267$ ksf
 at base $y = 0$, $p_y = 0.559$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.5$ ft
 liquid height, $H_L = 18.5$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures

10). wall design pressures for external soil loading:


static soil:



The site has no groundwater.

wall height = 20.5 ft
 soil height above top of base = 20.5 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:



LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 1.1275 ksf
 unfactored soil, q3 = 0.0000 ksf

equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 1.1275 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **7.14** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **13.66** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0007 ksf
 equivalent soil seismic, q9 = 0.6959 ksf
 wall seismic (see wall page 5), q10 = 0.0457 ksf
 equivalent soil seismic, q11 = q9 + q10 = 0.7416 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.6952 ksf

unfactored equivalent soil seismic, q8 = 0.0007 / 1.4 = 0.0005 ksf
 unfactored equivalent soil seismic, q9 = 0.6959 / 1.4 = 0.4971 ksf
 unfactored wall seismic, q10 = 0.0457 / 1.4 = 0.0326 ksf
 unfactored equivalent soil seismic, q11 = 0.7416 / 1.4 = 0.5297 ksf
 unfactored equivalent soil seismic, q12 = -0.6952 / 1.4 = -0.4966 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.5 ft
 water depth = 18.5 ft

b). load case 2: hydrostatic + dynamic:




wall height = 20.5 ft
 water depth = 18.5 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.5 ft
 soil height on wall = 20.5 ft

equivalent static soil & surcharge loadings...




LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 1.128 ksf
 unfactored soil, q3 = 0.000 ksf

equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 1.128 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.5 ft
 soil height on wall = 20.5 ft



unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.497 ksf
 unfactored equivalent soil seismic, q10 = 0.033 ksf
 unfactored equivalent soil seismic, q11 = 0.530 ksf
 unfactored equivalent soil seismic, q12 = -0.497 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **no roof & fixed at floor**

tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 58 ft
 tank wall thickness, t_w = 18 inch
 wall height, H_w = 18 ft

liquid height, H_L = 16 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION

Soil Data


The site has no groundwater.

soil height above top of foundation base = 18 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0 k/ft³
 live load lateral surcharge = 0.100 ksf
 0
 concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Design, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Design, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, $R_{wi} = 3$
 Response modification factor, $R_{wc} = 1$



WALL PLAN

Load Cases:

- case 1 = water
- case 2 = water + water seismic + wall seismic
- case 3 = soil + lateral surcharge
- case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures

Weights:

unit 1-ft width wall mass, $W_w = (18/12) * (18) * 0.15 = 4.05$ kip
 wall c.g. relative to base, $h_w = 18 / 2 = 9.000$ ft

unit width liquid mass, $W_L = (58) * (1) * (16) * 32.17 = 57.91$ kip

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

wall mass, $m_w = H_w * (t_w / 12) * \rho_c = 0.12589$ k-sec²/ft²

liquid mass, $m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.28566$ k-sec²/ft²

centroidal distance of masses, $h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 6.918$ ft



wall fixity condition is no roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

wall flexure stiffness, $k = Ec * (tw/h)^3 / 48 = 1322.94$ k/ft/ft

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (1322.94 / (0.1259 + 0.2857))^{1/2} = 56.6968 \text{ rad/sec}$$

period of tank plus impulsive mass, $T_i = 2\pi / \omega_i = 2\pi / 56.6968 = 0.1108$ sec

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

design factored spectral response acceleration for impulsive mass (5% damping), $S_{ai} = S_{DS} = 0.611$ g

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.2759)))^{1/2} = 8.4492$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 8.4492 / (58)^{1/2} = 1.1094 \text{ rad/sec,}$$


period of the convective mass, $T_c = 2\pi / \omega_c = 2\pi / 1.1094 = 5.6634$ sec

Long transition period (from map figure 22-15 ASCE 7), $T_L = 16$ sec

design spectral response acceleration for convective mass (0.5% damping), $S_{ac} = 1.5 * Sd1 / Tc = 0.174$ g

effective mass coeff., $\epsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021$, but $\leq 1.0 = 0.5278$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures



L = 58 ft
 B = 1 ft
 H_L = 16 ft
 W_L = 57.91 kip

L / H_L = 3.62500
 H_L / L = 0.27586

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 57.91 * (\tanh(0.866 * (3.625)) / 0.866 * (3.625)) = 18.38 \text{ kip}$$

h_i (EBP) = H_L * 0.375 = 16 * 0.375 = 6 ft

h_i (IBP) = H_L * {{{(0.866*L/H_L)/(2*tanh(0.866*L/H_L))} - 1/8} = 23.208 ft

impulsive force, P_i = $\left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 3) * 18.38 = 4.7 \text{ kip}$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 57.91 * (0.264 * (3.625) * \tanh(3.16 * (0.2759))) = 38.92 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 8.471 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 27.264 \text{ ft}$$

convective force, P_c = $\left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.1737 * 1.25 / 1) * 38.92 = 8.5 \text{ kip}$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 4.05$ kip
 wall c.g. relative to base, $h_w = 9.000$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.5278 / 3) * 4.05 = 0.54 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (58 / 2) * (0.1737 / 1.4 * 1.25) = 4.50 \text{ ft}$$

Wave height is greater than the freeboard of 2-ft. Check effects of wave spillage.


7). vertical acceleration:

design horizontal acceration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = \frac{0.2444 * 1 * 1}{1} = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 4.70$ kip
 $h_i = 6$ ft
 at $y = H_L$, $p_{iy} = 0.037$ ksf
 at base $y = 0$, $p_{iy} = 0.257$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 8.50$ kip
 $h_c = 8.471$ ft
 at $y = H_L$, $p_{cy} = 0.313$ ksf
 at base $y = 0$, $p_{cy} = 0.219$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.244$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.1344 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.030$ ksf
 at base $y = 0$, $p_{wy} = 0.030$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 0.998$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_w^2} =$$




at $y = H_w$, $p_y = 0.320$ ksf
 at base $y = 0$, $p_y = 0.436$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 18$ ft
 liquid height, $H_L = 16$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures

10). wall design pressures for external soil loading:


static soil:



The site has no groundwater.

wall height = 18 ft
 soil height above top of base = 18 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:



LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.9900 ksf
 unfactored soil, q3 = 0.0000 ksf

equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.9900 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **5.51** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **12** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.6122 ksf
 wall seismic (see wall page 5), q10 = 0.0302 ksf
 equivalent soil seismic, q11 = q9 + q10 = 0.6425 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.6122 ksf

unfactored equivalent soil seismic, q8 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q9 = 0.6122 / 1.4 = 0.4373 ksf
 unfactored wall seismic, q10 = 0.0302 / 1.4 = 0.0216 ksf
 unfactored equivalent soil seismic, q11 = 0.6425 / 1.4 = 0.4589 ksf
 unfactored equivalent soil seismic, q12 = -0.6122 / 1.4 = -0.4373 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 18 ft
 water depth = 16 ft

b). load case 2: hydrostatic + dynamic:




wall height = 18 ft
 water depth = 16 ft

c). load case 3: static soil + LL surcharge:

wall height = 18 ft
 soil height on wall = 18 ft


equivalent static soil & surcharge loadings...



LL lateral surcharge, $q_1 = 0.100$ ksf
 unfactored soil, $q_2 = 0.990$ ksf
 unfactored soil, $q_3 = 0.000$ ksf

equivalent soil loadings:
 unfactored $q_5 = 0.100$ ksf
 unfactored $q_6 = 0.990$ ksf

d). load case 4: soil seismic: (*note: add static soil pressure q_6 & q_7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...




wall height = 18 ft
 soil height on wall = 18 ft

unfactored equivalent soil seismic, $q_8 = 0.000$ ksf
 unfactored equivalent soil seismic, $q_9 = 0.437$ ksf
 unfactored equivalent soil seismic, $q_{10} = 0.022$ ksf
 unfactored equivalent soil seismic, $q_{11} = 0.459$ ksf
 unfactored equivalent soil seismic, $q_{12} = -0.437$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **no roof & fixed at floor**
 tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 35 ft
 tank wall thickness, t_w = 18 inch
 wall height, H_w = 20.5 ft
 liquid height, H_L = 18.5 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION


Soil Data

The site has no groundwater.
 soil height above top of foundation base = 20.5 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0 k/ft³
 live load lateral surcharge = 0.100 ksf
 0
 concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, $R_{wi} = 3$
 Response modification factor, $R_{wc} = 1$



WALL PLAN

Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (18/12) * (20.5) * 0.15 = 4.61 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 20.5 / 2 = 10.250 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (35) * (1) * (18.5) * 32.17 = 40.40 \text{ kip}$$

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.14338 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.35534 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 7.89 \text{ ft}$$



wall fixity condition is no roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = Ec * (tw/h)^3 / 48 = 891.76 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (891.76 / (0.1434 + 0.3553))^{1/2} = 42.2863 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 42.2863 = 0.1486 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.5286)))^{1/2} = 9.7315$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 9.7315 / (35)^{1/2} = 1.6449 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 1.6449 = 3.8197 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5% damping), } S_{ac} = 1.5 * Sd1 / Tc = 0.258 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.7141$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures



L = 35 ft
 B = 1 ft
 H_L = 18.5 ft
 W_L = 40.4 kip

L / H_L = 1.89189
 H_L / L = 0.52857

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 40.4 * (\tanh(0.866 * (1.8919)) / 0.866 * (1.8919)) = 22.86 \text{ kip}$$

h_i (EBP) = H_L * 0.375 = 18.5 * 0.375 = 6.938 ft

h_i (IBP) = H_L * {((0.866*L/H_L)/(2*tanh(0.866*L/H_L))) - 1/8} = 14.032 ft

impulsive force, P_i = $\left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 3) * 22.86 = 5.8 \text{ kip}$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 40.4 * (0.264 * (1.8919) * \tanh(3.16 * (0.5286))) = 18.8 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 10.933 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 15.298 \text{ ft}$$

convective force, P_c = $\left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.2576 * 1.25 / 1) * 18.8 = 6.1 \text{ kip}$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 4.61$ kip
 wall c.g. relative to base, $h_w = 10.250$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.7141/3) * 4.61 = 0.84 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (35 / 2) * (0.2576 / 1.4 * 1.25) = 4.03 \text{ ft}$$

Wave height is greater than the freeboard of 2-ft. Check effects of wave spillage.


7). vertical acceleration:

design horizontal acceration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 5.80$ kip
 $h_i = 6.938$ ft
 at $y = H_L$, $p_{iy} = 0.039$ ksf
 at base $y = 0$, $p_{iy} = 0.274$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 6.10$ kip
 $h_c = 10.933$ ft
 at $y = H_L$, $p_{cy} = 0.255$ ksf
 at base $y = 0$, $p_{cy} = 0.075$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.282$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.1818 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.041$ ksf
 at base $y = 0$, $p_{wy} = 0.041$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 1.154$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_w^2} =$$




at $y = H_w$, $p_y = 0.267$ ksf
 at base $y = 0$, $p_y = 0.430$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 20.5$ ft
 liquid height, $H_L = 18.5$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures

10). wall design pressures for external soil loading:


static soil:



The site has no groundwater.

wall height = 20.5 ft
 soil height above top of base = 20.5 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:



LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 1.1275 ksf
 unfactored soil, q3 = 0.0000 ksf

equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 1.1275 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **7.14** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **13.66** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0007 ksf
 equivalent soil seismic, q9 = 0.6959 ksf
 wall seismic (see wall page 5), q10 = 0.0409 ksf
 equivalent soil seismic, q11 = q9 + q10 = 0.7368 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.6952 ksf

unfactored equivalent soil seismic, q8 = 0.0007 / 1.4 = 0.0005 ksf
 unfactored equivalent soil seismic, q9 = 0.6959 / 1.4 = 0.4971 ksf
 unfactored wall seismic, q10 = 0.0409 / 1.4 = 0.0292 ksf
 unfactored equivalent soil seismic, q11 = 0.7368 / 1.4 = 0.5263 ksf
 unfactored equivalent soil seismic, q12 = -0.6952 / 1.4 = -0.4966 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 4 - Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 20.5 ft
 water depth = 18.5 ft


b). load case 2: hydrostatic + dynamic:



wall height = 20.5 ft
 water depth = 18.5 ft

c). load case 3: static soil + LL surcharge:

wall height = 20.5 ft
 soil height on wall = 20.5 ft




LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 1.128 ksf
 unfactored soil, q3 = 0.000 ksf

equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 1.128 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 20.5 ft
 soil height on wall = 20.5 ft



unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.497 ksf
 unfactored equivalent soil seismic, q10 = 0.029 ksf
 unfactored equivalent soil seismic, q11 = 0.526 ksf
 unfactored equivalent soil seismic, q12 = -0.497 ksf

**Area 8 - Washwater Basin
Wall 1 - Moment & Shear**

		Horizontal Span						
	S_d	M_{uy} (K-ft)	$S_d * M_{ux}$ (K-ft)	M_n (K-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.4F	1.61	17.89	28.81	55.00	0.52	7.89	23.53	0.34
1.2F+1.4E	1.00	25.17	25.17	55.00	0.46	10.85	23.53	0.46
1.6(H+L)	1.41	27.79	39.19	55.00	0.71	11.27	23.53	0.48
1.6H+1.4E	1.00	35.79	35.79	55.00	0.65	13.63	23.53	0.58

		Vertical Span (Mid-Height) - Outside Face						
	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.4F	1.12	13.43	15.04	88.50	0.17	0.00	23.53	0.00
1.2F+1.4E	1.00	18.73	18.73	88.50	0.21	0.00	23.53	0.00

		Vertical Span (Bottom) - Outside Face						
	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.6(H+L)	1.00	48.70	48.70	88.50	0.55	16.61	23.53	0.71
1.6H+1.4E	1.00	56.68	56.68	88.50	0.64	18.16	23.53	0.77

		Vertical Span (Mid-Height) - Inside Face						
	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.6(H+L)	1.00	20.91	20.91	66.00	0.32	0.00	23.53	0.00
1.6H+1.4E	1.00	27.42	27.42	66.00	0.42	0.00	23.53	0.00


		Vertical Span (Bottom) - Inside Face						
	S_d	M_{uy} (K-ft)	$S_d * M_{uy}$ (K-ft)	M_n (K-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.4F	1.12	34.01	38.09	88.50	0.43	12.29	23.53	0.52
1.2F+1.4E	1.00	46.25	46.25	88.50	0.52	16.06	23.53	0.68

<- OK
<- OK
<- OK


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Hydrostatic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.8537



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	18.500	1.154	2.25	1.4
B					
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Hydrostatic

M _x - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 15")	
		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0000				0.00				0.00	0.00	0.00	0.54
0	0.8	0.0148				7.18				7.18	16.15	0.24	0.54
0	0.6	0.0253				12.29				12.29	27.65	0.42	0.56
0	0.4	0.0264				12.78				12.78	28.76	0.44	0.58
0	0.2	0.0138				6.68				6.68	15.03	0.23	0.54
0	0	0.0000				0.00				0.00	0.00	0.00	0.54
0.2	0	0.0032				1.54				1.54	3.47	0.05	0.54
0.4	0	0.0064				3.11				3.11	7.00	0.10	0.54
0.6	0	0.0085				4.13				4.13	9.29	0.14	0.54
0.8	0	0.0097				4.70				4.70	10.58	0.16	0.54
1	0	0.0100				4.86				4.86	10.94	0.16	0.54
1	0.2	-0.0022				-1.09				-1.09	-2.45	-0.04	-0.54
1	0.4	-0.0088				-4.27				-4.27	-9.60	-0.14	-0.54
1	0.6	-0.0094				-4.55				-4.55	-10.23	-0.15	-0.54
1	0.8	-0.0057				-2.76				-2.76	-6.21	-0.09	-0.54
1	1	0.0000				0.00				0.00	0.00	0.00	0.54
0.8	1	0.0000				0.00				0.00	0.00	0.00	0.54
0.8	0.8	-0.0056				-2.71				-2.71	-6.10	-0.09	-0.54
0.8	0.6	-0.0092				-4.48				-4.48	-10.08	-0.15	-0.54
0.8	0.4	-0.0088				-4.26				-4.26	-9.60	-0.14	-0.54
0.8	0.2	-0.0024				-1.18				-1.18	-2.66	-0.04	-0.54

max negative moment, M_{ux}(-) = -10.23 ft-k/ft

max negative steel req'd, A_s(-) = -0.15 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{ux}(+) = 28.76 ft-k/ft

max positive steel req'd, A_s(+) = 0.44 in²/ft

minimum steel req'd = 0.58 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Hydrostatic

M _y - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficients								M _y Moments, ft-k/ft		M _y	M _{uy}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0000				0.00				0.00	0.00	0.00	0.54
0	0.8	0.0029				1.42				1.42	3.20	0.05	0.54
0	0.6	0.0051				2.45				2.45	5.51	0.08	0.54
0	0.4	0.0052				2.54				2.54	5.71	0.08	0.54
0	0.2	0.0028				1.34				1.34	3.01	0.04	0.54
0	0	0.0000				0.00				0.00	0.00	0.00	0.54
0.2	0	0.0158				7.68				7.68	17.28	0.25	0.54
0.4	0	0.0319				15.49				15.49	34.85	0.51	0.62
0.6	0	0.0426				20.68				20.68	46.53	0.69	0.62
0.8	0	0.0483				23.44				23.44	52.74	0.79	0.62
1	0	0.0501				24.29				24.29	54.64	0.81	0.62
1	0.2	-0.0021				-1.01				-1.01	-2.28	-0.03	-0.54
1	0.4	-0.0198				-9.59				-9.59	-21.58	-0.31	-0.54
1	0.6	-0.0185				-8.95				-8.95	-20.15	-0.29	-0.54
1	0.8	-0.0101				-4.90				-4.90	-11.02	-0.16	-0.54
1	1	0.0000				0.00				0.00	0.00	0.00	0.54
1	0.4	-0.0198				-9.59				-9.59	-21.58	-0.31	-0.54
0.8	0.4	-0.0189				-9.19				-9.19	-20.67	-0.30	-0.54
0.6	0.4	-0.0164				-7.95				-7.95	-17.88	-0.26	-0.54
0.4	0.4	-0.0116				-5.63				-5.63	-12.67	-0.18	-0.54
0.2	0.4	-0.0041				-2.01				-2.01	-4.52	-0.07	-0.54

max negative moment, M_{uy}(-) = -21.58 ft-k/ft

max negative steel req'd, A_s(-) = -0.31 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{uy}(+) = 54.64 ft-k/ft

max positive steel req'd, A_s(+) = 0.81 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Hydrostatic

Shear Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		Shear Coefficient Multipliers								Final Shears			
		x / a	y / b	A	B	C	D	A	B	C	D	V k/ft	V _u k/ft
		1.154											
		23.657											
		Shear Coefficients				Shears, k/ft							
0	1	-0.0590				-1.40				-1.40	-1.96	17.65	
0	0.8	0.0958				2.27				2.27	3.17	17.65	
0	0.6	0.1858				4.40				4.40	6.15	17.65	
0	0.4	0.2383				5.64				5.64	7.89	17.65	
0	0.2	0.1444				3.42				3.42	4.78	17.65	
0	0.00	-0.0119				-0.28				-0.28	-0.39	17.65	
0.2	0	0.1665				3.94				3.94	5.52	17.65	
0.4	0	0.2871				6.79				6.79	9.51	17.65	
0.6	0	0.3424				8.10				8.10	11.34	17.65	
0.8	0	0.3652				8.64				8.64	12.09	17.65	
1	0	0.3712				8.78				8.78	12.29	17.65	
0.2	1	-0.0190				-0.45				-0.45	-0.63	17.65	
0.4	1	0.0404				0.96				0.96	1.34	17.65	
0.6	1	0.0694				1.64				1.64	2.30	17.65	
0.8	1	0.0819				1.94				1.94	2.71	17.65	
1	1	0.0853				2.02				2.02	2.82	17.65	

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 12.29 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:


Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.




BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Hydrodynamic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.8537



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	18.500	1.154	1.2	1.2
B	100	18.500	0.191	1.4	1.4
C	400	18.500	0.208	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00300**
 minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Hydrodynamic

M _x - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.154	0.191	0.208						Final Moments		Reinforcing: (d = 15")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0	0.8	0.0148	0.0424	0.0148		7.18	3.40	1.29		11.88	15.19	0.23	0.32
0	0.6	0.0253	0.0652	0.0253		12.29	5.23	2.21		19.73	25.17	0.38	0.51
0	0.4	0.0264	0.0580	0.0264		12.78	4.65	2.30		19.74	25.07	0.38	0.50
0	0.2	0.0138	0.0250	0.0138		6.68	2.01	1.20		9.89	12.51	0.19	0.32
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0.2	0	0.0032	0.0051	0.0032		1.54	0.41	0.28		2.23	2.81	0.04	0.32
0.4	0	0.0064	0.0114	0.0064		3.11	0.92	0.56		4.59	5.80	0.09	0.32
0.6	0	0.0085	0.0161	0.0085		4.13	1.29	0.74		6.17	7.81	0.12	0.32
0.8	0	0.0097	0.0187	0.0097		4.70	1.50	0.85		7.05	8.93	0.13	0.32
1	0	0.0100	0.0196	0.0100		4.86	1.57	0.88		7.31	9.26	0.14	0.32
1	0.2	-0.0022	-0.0033	-0.0022		-1.09	-0.27	-0.20		-1.55	-1.95	-0.03	-0.32
1	0.4	-0.0088	-0.0198	-0.0088		-4.27	-1.59	-0.77		-6.63	-8.43	-0.13	-0.32
1	0.6	-0.0094	-0.0243	-0.0094		-4.55	-1.95	-0.82		-7.31	-9.33	-0.14	-0.32
1	0.8	-0.0057	-0.0162	-0.0057		-2.76	-1.30	-0.50		-4.56	-5.83	-0.09	-0.32
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0.8	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0.8	0.8	-0.0056	-0.0159	-0.0056		-2.71	-1.27	-0.49		-4.47	-5.72	-0.09	-0.32
0.8	0.6	-0.0092	-0.0239	-0.0092		-4.48	-1.92	-0.81		-7.20	-9.19	-0.14	-0.32
0.8	0.4	-0.0088	-0.0197	-0.0088		-4.26	-1.58	-0.77		-6.61	-8.40	-0.13	-0.32
0.8	0.2	-0.0024	-0.0037	-0.0024		-1.18	-0.30	-0.21		-1.69	-2.13	-0.03	-0.32

max negative moment, M_{ux}(-) = -9.33 ft-k/ft

max negative steel req'd, A_s(-) = -0.14 in²/ft

minimum steel req'd = -0.32 in²/ft

Use

max positive moment, M_{ux}(+) = 25.17 ft-k/ft

max positive steel req'd, A_s(+) = 0.38 in²/ft

minimum steel req'd = 0.51 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Hydrodynamic

M _y - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.154	0.191	0.208						Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		484.969	80.268	87.412									
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0	0.8	0.0029	0.0085	0.0029		1.42	0.68	0.26		2.36	3.02	0.04	0.32
0	0.6	0.0051	0.0130	0.0051		2.45	1.04	0.44		3.94	5.02	0.07	0.32
0	0.4	0.0052	0.0116	0.0052		2.54	0.93	0.46		3.92	4.99	0.07	0.32
0	0.2	0.0028	0.0050	0.0028		1.34	0.40	0.24		1.98	2.50	0.04	0.32
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0.2	0	0.0158	0.0267	0.0158		7.68	2.14	1.38		11.21	14.16	0.20	0.32
0.4	0	0.0319	0.0574	0.0319		15.49	4.61	2.79		22.89	28.95	0.42	0.56
0.6	0	0.0426	0.0805	0.0426		20.68	6.47	3.73		30.87	39.09	0.58	0.62
0.8	0	0.0483	0.0936	0.0483		23.44	7.51	4.22		35.18	44.56	0.66	0.62
1	0	0.0501	0.0977	0.0501		24.29	7.84	4.38		36.51	46.25	0.69	0.62
1	0.2	-0.0021	0.0052	-0.0021		-1.01	0.42	-0.18		-0.78	-0.88	-0.01	-0.32
1	0.4	-0.0198	-0.0404	-0.0198		-9.59	-3.25	-1.73		-14.56	-18.47	-0.27	-0.36
1	0.6	-0.0185	-0.0509	-0.0185		-8.95	-4.09	-1.61		-14.66	-18.73	-0.27	-0.36
1	0.8	-0.0101	-0.0339	-0.0101		-4.90	-2.72	-0.88		-8.50	-10.92	-0.16	-0.32
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
1	0.4	-0.0198	-0.0404	-0.0198		-9.59	-3.25	-1.73		-14.56	-18.47	-0.27	-0.36
0.8	0.4	-0.0189	-0.0386	-0.0189		-9.19	-3.10	-1.66		-13.94	-17.68	-0.26	-0.34
0.6	0.4	-0.0164	-0.0330	-0.0164		-7.95	-2.65	-1.43		-12.03	-15.25	-0.22	-0.32
0.4	0.4	-0.0116	-0.0227	-0.0116		-5.63	-1.82	-1.01		-8.47	-10.73	-0.15	-0.32
0.2	0.4	-0.0041	-0.0073	-0.0041		-2.01	-0.58	-0.36		-2.96	-3.74	-0.05	-0.32

max negative moment, M_{uy}(-) = -18.73 ft-k/ft

max negative steel req'd, A_s(-) = -0.27 in²/ft

minimum steel req'd = -0.36 in²/ft

Use

max positive moment, M_{uy}(+) = 46.25 ft-k/ft

max positive steel req'd, A_s(+) = 0.69 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 1 - Hydrodynamic

Shear Summary												
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY		
		1.154	0.191	0.208						Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		23.657	3.916	4.264								
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	-0.0590	-0.1470	-0.0590		-1.40	-0.58	-0.25		-2.22	-2.83	17.65
0	0.8	0.0958	0.3409	0.0958		2.27	1.33	0.41		4.01	5.16	17.65
0	0.6	0.1858	0.5259	0.1858		4.40	2.06	0.79		7.25	9.27	17.65
0	0.4	0.2383	0.4856	0.2383		5.64	1.90	1.02		8.55	10.85	17.65
0	0.2	0.1444	0.1742	0.1444		3.42	0.68	0.62		4.71	5.91	17.65
0	0.00	-0.0119	-0.0566	-0.0119		-0.28	-0.22	-0.05		-0.55	-0.72	17.65
0.2	0	0.1665	0.1843	0.1665		3.94	0.72	0.71		5.37	6.73	17.65
0.4	0	0.2871	0.4128	0.2871		6.79	1.62	1.22		9.63	12.13	17.65
0.6	0	0.3424	0.5340	0.3424		8.10	2.09	1.46		11.65	14.69	17.65
0.8	0	0.3652	0.5885	0.3652		8.64	2.30	1.56		12.50	15.77	17.65
1	0	0.3712	0.6037	0.3712		8.78	2.36	1.58		12.73	16.06	17.65
0.2	1	-0.0190	0.0244	-0.0190		-0.45	0.10	-0.08		-0.44	-0.52	17.65
0.4	1	0.0404	0.1915	0.0404		0.96	0.75	0.17		1.88	2.44	17.65
0.6	1	0.0694	0.2681	0.0694		1.64	1.05	0.30		2.99	3.86	17.65
0.8	1	0.0819	0.2998	0.0819		1.94	1.17	0.35		3.46	4.46	17.65
1	1	0.0853	0.3082	0.0853		2.02	1.21	0.36		3.59	4.62	17.65

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 16.06 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.8537



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		1.128	2.25	1.6
B	1		0.100	2.25	1.6
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil Static

M _x - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.128	0.100							Final Moments		Reinforcing: (d = 15")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}				
x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0	0.8	0.0185	0.0492			8.77	2.07			10.83	24.38	0.37	0.54
0	0.6	0.0304	0.0701			14.42	2.95			17.37	39.08	0.60	0.60
0	0.4	0.0300	0.0595			14.20	2.50			16.70	37.58	0.57	0.60
0	0.2	0.0149	0.0252			7.07	1.06			8.14	18.30	0.27	0.54
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0.2	0	0.0034	0.0051			1.60	0.22			1.82	4.09	0.06	0.54
0.4	0	0.0069	0.0116			3.29	0.49			3.78	8.50	0.13	0.54
0.6	0	0.0093	0.0165			4.42	0.69			5.11	11.49	0.17	0.54
0.8	0	0.0107	0.0192			5.06	0.81			5.87	13.20	0.20	0.54
1	0	0.0111	0.0201			5.25	0.84			6.10	13.71	0.21	0.54
1	0.2	-0.0023	-0.0033			-1.10	-0.14			-1.23	-2.77	-0.04	-0.54
1	0.4	-0.0100	-0.0204			-4.76	-0.86			-5.62	-12.65	-0.19	-0.54
1	0.6	-0.0113	-0.0261			-5.35	-1.10			-6.45	-14.50	-0.22	-0.54
1	0.8	-0.0071	-0.0188			-3.37	-0.79			-4.16	-9.35	-0.14	-0.54
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0.8	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0.8	0.8	-0.0070	-0.0184			-3.30	-0.77			-4.08	-9.18	-0.14	-0.54
0.8	0.6	-0.0111	-0.0257			-5.28	-1.08			-6.36	-14.30	-0.21	-0.54
0.8	0.4	-0.0100	-0.0202			-4.76	-0.85			-5.61	-12.63	-0.19	-0.54
0.8	0.2	-0.0025	-0.0037			-1.19	-0.15			-1.35	-3.03	-0.05	-0.54

max negative moment, M_{ux}(-) = -14.50 ft-k/ft

max negative steel req'd, A_s(-) = -0.22 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{ux}(+) = 39.08 ft-k/ft

max positive steel req'd, A_s(+) = 0.60 in²/ft

minimum steel req'd = 0.60 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil Static

M _y - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.128	0.100							Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0	0.8	0.0037	0.0098			1.74	0.41			2.15	4.84	0.07	0.54
0	0.6	0.0061	0.0140			2.88	0.59			3.47	7.81	0.11	0.54
0	0.4	0.0060	0.0119			2.82	0.50			3.32	7.48	0.11	0.54
0	0.2	0.0030	0.0050			1.41	0.21			1.62	3.64	0.05	0.54
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0.2	0	0.0168	0.0258			7.96	1.08			9.04	20.35	0.30	0.54
0.4	0	0.0346	0.0582			16.38	2.44			18.82	42.35	0.63	0.62
0.6	0	0.0467	0.0822			22.15	3.46			25.60	57.60	0.86	0.62
0.8	0	0.0533	0.0959			25.27	4.03			29.30	65.92	0.99	0.62
1	0	0.0553	0.1002			26.23	4.21			30.44	68.49	1.03	0.62
1	0.2	-0.0009	0.0068			-0.43	0.29			-0.14	-0.32	0.00	-0.54
1	0.4	-0.0219	-0.0396			-10.37	-1.67			-12.04	-27.09	-0.40	-0.54
1	0.6	-0.0227	-0.0545			-10.78	-2.29			-13.07	-29.42	-0.43	-0.57
1	0.8	-0.0135	-0.0426			-6.38	-1.79			-8.17	-18.38	-0.27	-0.54
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
1	0.4	-0.0219	-0.0396			-10.37	-1.67			-12.04	-27.09	-0.40	-0.54
0.8	0.4	-0.0209	-0.0378			-9.93	-1.59			-11.52	-25.91	-0.38	-0.54
0.6	0.4	-0.0180	-0.0320			-8.54	-1.35			-9.88	-22.23	-0.32	-0.54
0.4	0.4	-0.0127	-0.0216			-6.00	-0.91			-6.90	-15.53	-0.23	-0.54
0.2	0.4	-0.0044	-0.0063			-2.07	-0.27			-2.34	-5.26	-0.08	-0.54

max negative moment, M_{uy}(-) = -29.42 ft-k/ft

max negative steel req'd, A_s(-) = -0.43 in²/ft

minimum steel req'd = -0.57 in²/ft

Use

max positive moment, M_{uy}(+) = 68.49 ft-k/ft

max positive steel req'd, A_s(+) = 1.03 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil Static

Shear Summary												
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x/a	y/b	A	B	C	D	A	B			
0	1	-0.0732	-0.1571			-1.69	-0.32			-2.01	-3.22	17.65
0	0.8	0.1311	0.4490			3.03	0.92			3.95	6.32	17.65
0	0.6	0.2317	0.5559			5.36	1.14			6.50	10.40	17.65
0	0.4	0.2626	0.4734			6.07	0.97			7.04	11.27	17.65
0	0.2	0.1442	0.1684			3.34	0.35			3.68	5.89	17.65
0	0.00	-0.0167	-0.0577			-0.39	-0.12			-0.50	-0.81	17.65
0.2	0	0.1660	0.1790			3.84	0.37			4.21	6.73	17.65
0.4	0	0.2981	0.4110			6.89	0.84			7.74	12.38	17.65
0.6	0	0.3610	0.5369			8.35	1.10			9.45	15.12	17.65
0.8	0	0.3876	0.5946			8.96	1.22			10.18	16.29	17.65
1	0	0.3948	0.6108			9.13	1.25			10.38	16.61	17.65
0.2	1	-0.0171	0.0788			-0.40	0.16			-0.23	-0.37	17.65
0.4	1	0.0567	0.2702			1.31	0.55			1.87	2.99	17.65
0.6	1	0.0919	0.3549			2.13	0.73			2.85	4.56	17.65
0.8	1	0.1068	0.3894			2.47	0.80			3.27	5.23	17.65
1	1	0.1109	0.3985			2.56	0.82			3.38	5.41	17.65

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 16.61 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil EQ

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **20.5** ft
 plate sides ratio, a/b = 0.8537



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		1.128	1.6	1.6
B	1		0.524	1.4	1.4
C	4		-0.497	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil EQ

M _x - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.128	0.524	-0.497						Final Moments		Reinforcing: (d = 15")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		Moment Coefficients								ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0	0.8	0.0185	0.0492	0.0185		8.77	10.84	-3.86		15.74	23.79	0.36	0.54
0	0.6	0.0304	0.0701	0.0304		14.42	15.43	-6.36		23.50	35.79	0.54	0.60
0	0.4	0.0300	0.0595	0.0300		14.20	13.10	-6.26		21.05	32.31	0.49	0.60
0	0.2	0.0149	0.0252	0.0149		7.07	5.56	-3.12		9.52	14.74	0.22	0.54
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0.2	0	0.0034	0.0051	0.0034		1.60	1.13	-0.71		2.03	3.16	0.05	0.54
0.4	0	0.0069	0.0116	0.0069		3.29	2.55	-1.45		4.39	6.81	0.10	0.54
0.6	0	0.0093	0.0165	0.0093		4.42	3.63	-1.95		6.10	9.42	0.14	0.54
0.8	0	0.0107	0.0192	0.0107		5.06	4.22	-2.23		7.06	10.89	0.16	0.54
1	0	0.0111	0.0201	0.0111		5.25	4.42	-2.31		7.36	11.36	0.17	0.54
1	0.2	-0.0023	-0.0033	-0.0023		-1.10	-0.72	0.48		-1.33	-2.08	-0.03	-0.54
1	0.4	-0.0100	-0.0204	-0.0100		-4.76	-4.50	2.10		-7.16	-10.98	-0.16	-0.54
1	0.6	-0.0113	-0.0261	-0.0113		-5.35	-5.74	2.36		-8.73	-13.30	-0.20	-0.54
1	0.8	-0.0071	-0.0188	-0.0071		-3.37	-4.14	1.48		-6.02	-9.10	-0.14	-0.54
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0.8	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0.8	0.8	-0.0070	-0.0184	-0.0070		-3.30	-4.06	1.46		-5.91	-8.93	-0.13	-0.54
0.8	0.6	-0.0111	-0.0257	-0.0111		-5.28	-5.65	2.33		-8.60	-13.10	-0.20	-0.54
0.8	0.4	-0.0100	-0.0202	-0.0100		-4.76	-4.45	2.10		-7.11	-10.91	-0.16	-0.54
0.8	0.2	-0.0025	-0.0037	-0.0025		-1.19	-0.81	0.53		-1.48	-2.31	-0.03	-0.54

max negative moment, M_{ux}(-) = -13.30 ft-k/ft

max negative steel req'd, A_s(-) = -0.20 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{ux}(+) = 35.79 ft-k/ft

max positive steel req'd, A_s(+) = 0.54 in²/ft

minimum steel req'd = 0.60 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil EQ

M _y - Moment Summary													
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY			
		1.128	0.524	-0.497						Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft	in ² /ft	in ² /ft
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0	0.8	0.0037	0.0098	0.0037		1.74	2.17	-0.77		3.14	4.75	0.07	0.54
0	0.6	0.0061	0.0140	0.0061		2.88	3.09	-1.27		4.70	7.16	0.10	0.54
0	0.4	0.0060	0.0119	0.0060		2.82	2.62	-1.24		4.20	6.44	0.09	0.54
0	0.2	0.0030	0.0050	0.0030		1.41	1.10	-0.62		1.89	2.93	0.04	0.54
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0.2	0	0.0168	0.0258	0.0168		7.96	5.68	-3.51		10.13	15.78	0.23	0.54
0.4	0	0.0346	0.0582	0.0346		16.38	12.81	-7.22		21.97	34.04	0.50	0.62
0.6	0	0.0467	0.0822	0.0467		22.15	18.11	-9.76		30.49	47.12	0.70	0.62
0.8	0	0.0533	0.0959	0.0533		25.27	21.11	-11.13		35.25	54.40	0.81	0.62
1	0	0.0553	0.1002	0.0553		26.23	22.07	-11.56		36.74	56.68	0.85	0.62
1	0.2	-0.0009	0.0068	-0.0009		-0.43	1.50	0.19		1.26	1.68	0.02	0.54
1	0.4	-0.0219	-0.0396	-0.0219		-10.37	-8.73	4.57		-14.53	-22.42	-0.33	-0.54
1	0.6	-0.0227	-0.0545	-0.0227		-10.78	-12.01	4.75		-18.04	-27.42	-0.40	-0.54
1	0.8	-0.0135	-0.0426	-0.0135		-6.38	-9.38	2.81		-12.95	-19.41	-0.28	-0.54
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
1	0.4	-0.0219	-0.0396	-0.0219		-10.37	-8.73	4.57		-14.53	-22.42	-0.33	-0.54
0.8	0.4	-0.0209	-0.0378	-0.0209		-9.93	-8.32	4.37		-13.87	-21.41	-0.31	-0.54
0.6	0.4	-0.0180	-0.0320	-0.0180		-8.54	-7.06	3.76		-11.83	-18.27	-0.27	-0.54
0.4	0.4	-0.0127	-0.0216	-0.0127		-6.00	-4.75	2.64		-8.10	-12.54	-0.18	-0.54
0.2	0.4	-0.0044	-0.0063	-0.0044		-2.07	-1.39	0.91		-2.55	-3.99	-0.06	-0.54

max negative moment, M_{uy}(-) = -27.42 ft-k/ft

max negative steel req'd, A_s(-) = -0.40 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{uy}(+) = 56.68 ft-k/ft

max positive steel req'd, A_s(+) = 0.85 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 1 - Soil EQ

Shear Summary												
a = 17.5 b = 20.5 a / b = 0.8537		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x/a	y/b	A	B	C	D	A	B			
0	1	-0.0732	-0.1571	-0.0732		-1.69	-1.69	0.75		-2.63	-4.03	17.65
0	0.8	0.1311	0.4490	0.1311		3.03	4.82	-1.34		6.52	9.73	17.65
0	0.6	0.2317	0.5559	0.2317		5.36	5.97	-2.36		8.97	13.63	17.65
0	0.4	0.2626	0.4734	0.2626		6.07	5.09	-2.68		8.48	13.09	17.65
0	0.2	0.1442	0.1684	0.1442		3.34	1.81	-1.47		3.67	5.81	17.65
0	0.00	-0.0167	-0.0577	-0.0167		-0.39	-0.62	0.17		-0.84	-1.25	17.65
0.2	0	0.1660	0.1790	0.1660		3.84	1.92	-1.69		4.07	6.47	17.65
0.4	0	0.2981	0.4110	0.2981		6.89	4.42	-3.04		8.27	12.96	17.65
0.6	0	0.3610	0.5369	0.3610		8.35	5.77	-3.68		10.44	16.28	17.65
0.8	0	0.3876	0.5946	0.3876		8.96	6.39	-3.95		11.40	17.75	17.65
1	0	0.3948	0.6108	0.3948		9.13	6.56	-4.02		11.67	18.16	17.65
0.2	1	-0.0171	0.0788	-0.0171		-0.40	0.85	0.17		0.62	0.80	17.65
0.4	1	0.0567	0.2702	0.0567		1.31	2.90	-0.58		3.64	5.35	17.65
0.6	1	0.0919	0.3549	0.0919		2.13	3.81	-0.94		5.00	7.43	17.65
0.8	1	0.1068	0.3894	0.1068		2.47	4.18	-1.09		5.56	8.28	17.65
1	1	0.1109	0.3985	0.1109		2.56	4.28	-1.13		5.71	8.51	17.65

NG
NG
Ok for phi=1.0

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 18.16 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

SHEAR NOT SATISFIED ! , CHANGE PLATE THICKNESS, or CHECK SHEAR AT DISTANCE "d".

Reference:
 "Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

V_n=23.5-kips for phi=1.0, Shear OK

Notes:

- Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
- The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
- The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

Area 8 - Washwater Basin
Wall 2 - Moment & Shear

		Horizontal Span						
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.4F	1.61	20.15	32.44	55.00	0.59	5.53	23.53	0.23
1.2F+1.4E	1.00	37.57	37.57	55.00	0.68	7.80	23.53	0.33
1.6(H+L)	1.41	45.07	63.55	55.00	1.16	9.89	23.53	0.42
1.6H+1.4E	1.00	78.20	78.20	55.00	1.42	18.57	23.53	0.79

		Vertical Span						
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	V_u (kip)	V_n (kip)	DCR
1.4F	1.12	31.22	34.97	66.00	0.53	10.33	23.53	0.44
1.2F+1.4E	1.00	46.72	46.72	66.00	0.71	14.10	23.53	0.60
1.6(H+L)	1.00	52.10	52.10	66.00	0.79	15.32	23.53	0.65
1.6H+1.4E	1.00	69.97	69.97	66.00	1.06	18.19	23.53	0.77


		Vertical to Slab Transition - Slab Top Bar			
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR
1.4F	1.61	31.22	50.26	39.50	1.27
1.2F+1.4E	1.00	46.72	46.72	39.50	1.18

		Vertical to Slab Transition - Slab Bottom Bar			
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR
1.6(H+L)	1.00	52.10	52.10	53.00	0.98
1.6H+1.4E	1.00	69.97	69.97	53.00	1.32


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Hydrostatic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **18** ft
 plate sides ratio, a/b = 0.9722



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	16.000	0.999	2.25	1.4
B					
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00500**
 minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Hydrostatic

M _x - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 15")	
		Moment Coefficients				M _x Moments, ft-k/ft				M _x	M _{ux}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0445				14.39				14.39	32.37	0.49	0.60
0	0.8	0.0431				13.96				13.96	31.42	0.48	0.60
0	0.6	0.0392				12.70				12.70	28.57	0.43	0.58
0	0.4	0.0307				9.93				9.93	22.33	0.34	0.54
0	0.2	0.0137				4.45				4.45	10.01	0.15	0.54
0	0	0.0000				0.00				0.00	0.00	0.00	0.54
0.2	0	0.0039				1.26				1.26	2.84	0.04	0.54
0.4	0	0.0081				2.63				2.63	5.93	0.09	0.54
0.6	0	0.0113				3.67				3.67	8.26	0.12	0.54
0.8	0	0.0132				4.26				4.26	9.60	0.14	0.54
1	0	0.0138				4.46				4.46	10.03	0.15	0.54
1	0.2	-0.0005				-0.17				-0.17	-0.37	-0.01	-0.54
1	0.4	-0.0102				-3.32				-3.32	-7.46	-0.11	-0.54
1	0.6	-0.0154				-5.00				-5.00	-11.25	-0.17	-0.54
1	0.8	-0.0181				-5.85				-5.85	-13.16	-0.20	-0.54
1	1	-0.0200				-6.48				-6.48	-14.58	-0.22	-0.54
0.8	1	-0.0182				-5.89				-5.89	-13.24	-0.20	-0.54
0.8	0.8	-0.0166				-5.37				-5.37	-12.09	-0.18	-0.54
0.8	0.6	-0.0145				-4.70				-4.70	-10.57	-0.16	-0.54
0.8	0.4	-0.0099				-3.21				-3.21	-7.23	-0.11	-0.54
0.8	0.2	-0.0008				-0.25				-0.25	-0.56	-0.01	-0.54

max negative moment, M_{ux}(-) = -14.58 ft-k/ft

max negative steel req'd, A_s(-) = -0.22 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{ux}(+) = 32.37 ft-k/ft

max positive steel req'd, A_s(+) = 0.49 in²/ft

minimum steel req'd = 0.60 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Hydrostatic

M _y - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Moment Coefficient Multipliers								Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficients				M _y Moments, ft-k/ft				M _y	M _{uy}	A _{s(req'd)}	A _{s(min)}
		x / a	y / b	A	B	C	D	A	B	C	D	ft-k/ft	ft-k/ft
0	1	0.0000				0.00				0.00	0.00	0.00	0.54
0	0.8	0.0086				2.78				2.78	6.26	0.09	0.54
0	0.6	0.0079				2.55				2.55	5.73	0.08	0.54
0	0.4	0.0061				1.98				1.98	4.46	0.06	0.54
0	0.2	0.0028				0.90				0.90	2.03	0.03	0.54
0	0	0.0000				0.00				0.00	0.00	0.00	0.54
0.2	0	0.0194				6.28				6.28	14.14	0.20	0.54
0.4	0	0.0408				13.20				13.20	29.70	0.43	0.58
0.6	0	0.0565				18.29				18.29	41.15	0.61	0.62
0.8	0	0.0658				21.30				21.30	47.93	0.71	0.62
1	0	0.0689				22.30				22.30	50.16	0.75	0.62
1	0.2	0.0102				3.31				3.31	7.44	0.11	0.54
1	0.4	-0.0119				-3.84				-3.84	-8.64	-0.12	-0.54
1	0.6	-0.0131				-4.25				-4.25	-9.56	-0.14	-0.54
1	0.8	-0.0068				-2.20				-2.20	-4.94	-0.07	-0.54
1	1	0.0000				0.00				0.00	0.00	0.00	0.54
1	0.4	-0.0119				-3.84				-3.84	-8.64	-0.12	-0.54
0.8	0.4	-0.0116				-3.77				-3.77	-8.48	-0.12	-0.54
0.6	0.4	-0.0107				-3.46				-3.46	-7.78	-0.11	-0.54
0.4	0.4	-0.0082				-2.65				-2.65	-5.95	-0.09	-0.54
0.2	0.4	-0.0027				-0.88				-0.88	-1.99	-0.03	-0.54

max negative moment, M_{uy}(-) = -9.56 ft-k/ft

max negative steel req'd, A_s(-) = -0.14 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{uy}(+) = 50.16 ft-k/ft

max positive steel req'd, A_s(+) = 0.75 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Hydrostatic

Shear Summary												
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V	V _u	φV _c
x / a	y / b	A	B	C	D	A	B	C	D	k/ft	k/ft	k/ft
0	1	0.1194				2.15				2.15	3.00	17.65
0	0.8	0.1780				3.20				3.20	4.48	17.65
0	0.6	0.1915				3.44				3.44	4.82	17.65
0	0.4	0.2195				3.95				3.95	5.53	17.65
0	0.2	0.1212				2.18				2.18	3.05	17.65
0	0.00	-0.0156				-0.28				-0.28	-0.39	17.65
0.2	0	0.1706				3.07				3.07	4.29	17.65
0.4	0	0.3002				5.40				5.40	7.56	17.65
0.6	0	0.3679				6.62				6.62	9.26	17.65
0.8	0	0.4007				7.21				7.21	10.09	17.65
1	0	0.4105				7.38				7.38	10.33	17.65

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 10.33 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **18** ft
 plate sides ratio, a/b = 0.9722



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	16.000	0.999	1.2	1.2
B	100	16.000	0.228	1.4	1.4
C	400	16.000	0.083	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00300**

minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

M _x - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.999	0.228	0.083						Final Moments		Reinforcing: (d = 15")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		323.676	73.872	26.892									
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0445	0.1801	0.0445		14.39	13.31	1.20		28.89	37.57	0.57	0.60
0	0.8	0.0431	0.1560	0.0431		13.96	11.52	1.16		26.64	34.51	0.52	0.60
0	0.6	0.0392	0.1225	0.0392		12.70	9.05	1.05		22.80	29.38	0.44	0.59
0	0.4	0.0307	0.0791	0.0307		9.93	5.85	0.82		16.60	21.25	0.32	0.43
0	0.2	0.0137	0.0281	0.0137		4.45	2.08	0.37		6.90	8.77	0.13	0.32
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0.2	0	0.0039	0.0068	0.0039		1.26	0.50	0.10		1.87	2.36	0.04	0.32
0.4	0	0.0081	0.0172	0.0081		2.63	1.27	0.22		4.12	5.24	0.08	0.32
0.6	0	0.0113	0.0260	0.0113		3.67	1.92	0.31		5.90	7.53	0.11	0.32
0.8	0	0.0132	0.0317	0.0132		4.26	2.34	0.35		6.96	8.89	0.13	0.32
1	0	0.0138	0.0336	0.0138		4.46	2.48	0.37		7.31	9.34	0.14	0.32
1	0.2	-0.0005	0.0021	-0.0005		-0.17	0.15	-0.01		-0.03	-0.01	0.00	-0.32
1	0.4	-0.0102	-0.0273	-0.0102		-3.32	-2.01	-0.28		-5.60	-7.18	-0.11	-0.32
1	0.6	-0.0154	-0.0490	-0.0154		-5.00	-3.62	-0.42		-9.03	-11.65	-0.17	-0.32
1	0.8	-0.0181	-0.0630	-0.0181		-5.85	-4.65	-0.49		-10.99	-14.21	-0.21	-0.32
1	1	-0.0200	-0.0736	-0.0200		-6.48	-5.44	-0.54		-12.45	-16.14	-0.24	-0.32
0.8	1	-0.0182	-0.0674	-0.0182		-5.89	-4.98	-0.49		-11.35	-14.72	-0.22	-0.32
0.8	0.8	-0.0166	-0.0579	-0.0166		-5.37	-4.28	-0.45		-10.10	-13.06	-0.20	-0.32
0.8	0.6	-0.0145	-0.0456	-0.0145		-4.70	-3.37	-0.39		-8.46	-10.90	-0.16	-0.32
0.8	0.4	-0.0099	-0.0258	-0.0099		-3.21	-1.90	-0.27		-5.39	-6.90	-0.10	-0.32
0.8	0.2	-0.0008	0.0016	-0.0008		-0.25	0.12	-0.02		-0.15	-0.16	0.00	-0.32

max negative moment, M_{ux}(-) = -16.14 ft-k/ft

max negative steel req'd, A_s(-) = -0.24 in²/ft

minimum steel req'd = -0.32 in²/ft

Use

max positive moment, M_{ux}(+) = 37.57 ft-k/ft

max positive steel req'd, A_s(+) = 0.57 in²/ft

minimum steel req'd = 0.60 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

M _y - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.999	0.228	0.083						Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		323.676	73.872	26.892									
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0	0.8	0.0086	0.0312	0.0086		2.78	2.30	0.23		5.32	6.89	0.10	0.32
0	0.6	0.0079	0.0245	0.0079		2.55	1.81	0.21		4.56	5.88	0.08	0.32
0	0.4	0.0061	0.0158	0.0061		1.98	1.17	0.16		3.32	4.25	0.06	0.32
0	0.2	0.0028	0.0056	0.0028		0.90	0.42	0.07		1.39	1.77	0.03	0.32
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
0.2	0	0.0194	0.0339	0.0194		6.28	2.51	0.52		9.31	11.78	0.17	0.32
0.4	0	0.0408	0.0859	0.0408		13.20	6.35	1.10		20.64	26.26	0.38	0.51
0.6	0	0.0565	0.1303	0.0565		18.29	9.63	1.52		29.43	37.55	0.55	0.62
0.8	0	0.0658	0.1584	0.0658		21.30	11.70	1.77		34.78	44.42	0.66	0.62
1	0	0.0689	0.1680	0.0689		22.30	12.41	1.85		36.56	46.72	0.69	0.62
1	0.2	0.0102	0.0507	0.0102		3.31	3.74	0.27		7.32	9.59	0.14	0.32
1	0.4	-0.0119	-0.0101	-0.0119		-3.84	-0.75	-0.32		-4.91	-6.10	-0.09	-0.32
1	0.6	-0.0131	-0.0294	-0.0131		-4.25	-2.17	-0.35		-6.77	-8.63	-0.12	-0.32
1	0.8	-0.0068	-0.0199	-0.0068		-2.20	-1.47	-0.18		-3.85	-4.95	-0.07	-0.32
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.32
1	0.4	-0.0119	-0.0101	-0.0119		-3.84	-0.75	-0.32		-4.91	-6.10	-0.09	-0.32
0.8	0.4	-0.0116	-0.0102	-0.0116		-3.77	-0.75	-0.31		-4.84	-6.02	-0.09	-0.32
0.6	0.4	-0.0107	-0.0098	-0.0107		-3.46	-0.72	-0.29		-4.47	-5.57	-0.08	-0.32
0.4	0.4	-0.0082	-0.0069	-0.0082		-2.65	-0.51	-0.22		-3.38	-4.20	-0.06	-0.32
0.2	0.4	-0.0027	0.0009	-0.0027		-0.88	0.07	-0.07		-0.89	-1.07	-0.02	-0.32

max negative moment, M_{uy}(-) = -8.63 ft-k/ft

max negative steel req'd, A_s(-) = -0.12 in²/ft

minimum steel req'd = -0.32 in²/ft

Use

max positive moment, M_{uy}(+) = 46.72 ft-k/ft

max positive steel req'd, A_s(+) = 0.69 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 2 - Hydrodynamic

Shear Summary												
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		0.999	0.228	0.083						Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V	V _u	φV _c
x / a	y / b	A	B	C	D	A	B	C	D	k/ft	k/ft	k/ft
0	1	0.1194	0.7365	0.1194		2.15	3.02	0.18		5.35	7.06	17.65
0	0.8	0.1780	0.6762	0.1780		3.20	2.78	0.27		6.24	8.10	17.65
0	0.6	0.1915	0.5684	0.1915		3.44	2.33	0.29		6.06	7.80	17.65
0	0.4	0.2195	0.4327	0.2195		3.95	1.78	0.33		6.05	7.68	17.65
0	0.2	0.1212	0.0884	0.1212		2.18	0.36	0.18		2.72	3.38	17.65
0	0.00	-0.0156	-0.0805	-0.0156		-0.28	-0.33	-0.02		-0.63	-0.83	17.65
0.2	0	0.1706	0.1490	0.1706		3.07	0.61	0.25		3.93	4.89	17.65
0.4	0	0.3002	0.4390	0.3002		5.40	1.80	0.45		7.65	9.63	17.65
0.6	0	0.3679	0.6285	0.3679		6.62	2.58	0.55		9.75	12.32	17.65
0.8	0	0.4007	0.7304	0.4007		7.21	3.00	0.60		10.80	13.68	17.65
1	0	0.4105	0.7622	0.4105		7.38	3.13	0.61		11.12	14.10	17.65

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 14.10 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **18** ft
 plate sides ratio, a/b = 0.9722



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		0.990	2.25	1.6
B	1		0.100	2.25	1.6
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil Static

M _x - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.990	0.100							Final Moments		Reinforcing: (d = 15")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0622	0.2537			19.95	8.22			28.17	63.38	0.99	0.60
0	0.8	0.0586	0.2092			18.79	6.78			25.57	57.52	0.89	0.60
0	0.6	0.0507	0.1517			16.27	4.91			21.19	47.67	0.73	0.60
0	0.4	0.0370	0.0905			11.88	2.93			14.81	33.33	0.51	0.60
0	0.2	0.0155	0.0302			4.97	0.98			5.95	13.39	0.20	0.54
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0.2	0	0.0042	0.0070			1.35	0.23			1.58	3.55	0.05	0.54
0.4	0	0.0092	0.0189			2.97	0.61			3.58	8.05	0.12	0.54
0.6	0	0.0132	0.0297			4.24	0.96			5.21	11.71	0.18	0.54
0.8	0	0.0156	0.0367			5.00	1.19			6.18	13.92	0.21	0.54
1	0	0.0164	0.0391			5.25	1.27			6.51	14.66	0.22	0.54
1	0.2	-0.0001	0.0036			-0.03	0.12			0.08	0.19	0.00	0.54
1	0.4	-0.0124	-0.0315			-3.99	-1.02			-5.01	-11.28	-0.17	-0.54
1	0.6	-0.0201	-0.0609			-6.45	-1.97			-8.42	-18.95	-0.28	-0.54
1	0.8	-0.0243	-0.0831			-7.78	-2.69			-10.48	-23.57	-0.36	-0.54
1	1	-0.0272	-0.0995			-8.72	-3.22			-11.94	-26.87	-0.41	-0.54
0.8	1	-0.0247	-0.0915			-7.94	-2.96			-10.90	-24.53	-0.37	-0.54
0.8	0.8	-0.0223	-0.0764			-7.16	-2.48			-9.64	-21.68	-0.33	-0.54
0.8	0.6	-0.0189	-0.0563			-6.05	-1.82			-7.87	-17.72	-0.27	-0.54
0.8	0.4	-0.0120	-0.0294			-3.85	-0.95			-4.80	-10.80	-0.16	-0.54
0.8	0.2	-0.0004	0.0031			-0.12	0.10			-0.02	-0.04	0.00	-0.54

max negative moment, M_{ux}(-) = -26.87 ft-k/ft

max negative steel req'd, A_s(-) = -0.41 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{ux}(+) = 63.38 ft-k/ft

max positive steel req'd, A_s(+) = 0.99 in²/ft

minimum steel req'd = 0.60 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil Static

M _y - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.990	0.100							Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0	0.8	0.0117	0.0418			3.75	1.35			5.11	11.49	0.17	0.54
0	0.6	0.0101	0.0303			3.25	0.98			4.24	9.53	0.14	0.54
0	0.4	0.0074	0.0181			2.36	0.59			2.95	6.64	0.10	0.54
0	0.2	0.0031	0.0061			1.00	0.20			1.20	2.70	0.04	0.54
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
0.2	0	0.0211	0.0350			6.76	1.13			7.89	17.76	0.26	0.54
0.4	0	0.0464	0.0948			14.89	3.07			17.96	40.41	0.60	0.62
0.6	0	0.0660	0.1485			21.16	4.81			25.97	58.44	0.87	0.62
0.8	0	0.0778	0.1834			24.95	5.94			30.89	69.50	1.05	0.62
1	0	0.0818	0.1954			26.23	6.33			32.56	73.26	1.11	0.62
1	0.2	0.0159	0.0687			5.10	2.23			7.33	16.49	0.24	0.54
1	0.4	-0.0113	0.0028			-3.61	0.09			-3.52	-7.92	-0.11	-0.54
1	0.6	-0.0159	-0.0243			-5.08	-0.79			-5.87	-13.21	-0.19	-0.54
1	0.8	-0.0093	-0.0240			-2.98	-0.78			-3.76	-8.46	-0.12	-0.54
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.54
1	0.4	-0.0113	0.0028			-3.61	0.09			-3.52	-7.92	-0.11	-0.54
0.8	0.4	-0.0111	0.0022			-3.56	0.07			-3.49	-7.85	-0.11	-0.54
0.6	0.4	-0.0102	0.0012			-3.27	0.04			-3.23	-7.28	-0.10	-0.54
0.4	0.4	-0.0077	0.0018			-2.46	0.06			-2.40	-5.41	-0.08	-0.54
0.2	0.4	-0.0020	0.0065			-0.65	0.21			-0.44	-0.99	-0.01	-0.54

max negative moment, M_{uy}(-) = -13.21 ft-k/ft

max negative steel req'd, A_s(-) = -0.19 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{uy}(+) = 73.26 ft-k/ft

max positive steel req'd, A_s(+) = 1.11 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil Static

Shear Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		Shear Coefficient Multipliers								Final Shears			
		x / a		y / b		Shear Coefficients				Shears, k/ft			
		A	B	C	D	A	B	C	D	V k/ft	V _u k/ft	φV _c k/ft	
0	1	0.1894	1.1771			3.38	2.12			5.49	8.79	17.65	
0	0.8	0.2520	0.9404			4.49	1.69			6.18	9.89	17.65	
0	0.6	0.2481	0.6236			4.42	1.12			5.54	8.87	17.65	
0	0.4	0.2426	0.4028			4.32	0.73			5.05	8.08	17.65	
0	0.2	0.1129	0.0509			2.01	0.09			2.10	3.37	17.65	
0	0.00	-0.0238	-0.0916			-0.42	-0.16			-0.59	-0.94	17.65	
0.2	0	0.1644	0.1118			2.93	0.20			3.13	5.01	17.65	
0.4	0	0.3145	0.4335			5.60	0.78			6.38	10.21	17.65	
0.6	0	0.3985	0.6610			7.10	1.19			8.29	13.27	17.65	
0.8	0	0.4407	0.7883			7.85	1.42			9.27	14.84	17.65	
1	0	0.4535	0.8288			8.08	1.49			9.57	15.32	17.65	

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 15.32 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:


Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.




BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil EQ

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 17.5 = 35$ ft
 plate dimension, a = **17.5** ft
 plate dimension, b = **18** ft
 plate sides ratio, a/b = 0.9722



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	4		0.990	1.6	1.6
B	1		0.524	1.4	1.4
C	4		-0.497	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **18** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00500**

minimum ratio of vertical shrinkage-temperature steel = **0.00500**

bar locations	d (in)	d' (in)
Mx bending	15"	3"
My bending	15.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil EQ

M _x - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.990	0.524	-0.497						Final Moments		Reinforcing: (d = 15")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		320.760	169.776	-161.028									
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0622	0.2537	0.0622		19.95	43.07	-10.01		53.01	78.20	1.23	0.60
0	0.8	0.0586	0.2092	0.0586		18.79	35.52	-9.43		44.87	66.58	1.04	0.60
0	0.6	0.0507	0.1517	0.0507		16.27	25.75	-8.17		33.85	50.65	0.78	0.60
0	0.4	0.0370	0.0905	0.0370		11.88	15.36	-5.96		21.28	32.16	0.49	0.60
0	0.2	0.0155	0.0302	0.0155		4.97	5.13	-2.50		7.60	11.64	0.17	0.54
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0.2	0	0.0042	0.0070	0.0042		1.35	1.19	-0.68		1.86	2.88	0.04	0.54
0.4	0	0.0092	0.0189	0.0092		2.97	3.21	-1.49		4.69	7.16	0.11	0.54
0.6	0	0.0132	0.0297	0.0132		4.24	5.04	-2.13		7.15	10.86	0.16	0.54
0.8	0	0.0156	0.0367	0.0156		5.00	6.23	-2.51		8.72	13.21	0.20	0.54
1	0	0.0164	0.0391	0.0164		5.25	6.64	-2.63		9.25	14.00	0.21	0.54
1	0.2	-0.0001	0.0036	-0.0001		-0.03	0.61	0.02		0.60	0.83	0.01	0.54
1	0.4	-0.0124	-0.0315	-0.0124		-3.99	-5.36	2.00		-7.34	-11.08	-0.17	-0.54
1	0.6	-0.0201	-0.0609	-0.0201		-6.45	-10.34	3.24		-13.56	-20.27	-0.30	-0.54
1	0.8	-0.0243	-0.0831	-0.0243		-7.78	-14.12	3.91		-17.99	-26.75	-0.40	-0.54
1	1	-0.0272	-0.0995	-0.0272		-8.72	-16.89	4.38		-21.23	-31.46	-0.48	-0.60
0.8	1	-0.0247	-0.0915	-0.0247		-7.94	-15.53	3.99		-19.48	-28.86	-0.44	-0.58
0.8	0.8	-0.0223	-0.0764	-0.0223		-7.16	-12.98	3.59		-16.54	-24.59	-0.37	-0.54
0.8	0.6	-0.0189	-0.0563	-0.0189		-6.05	-9.56	3.04		-12.57	-18.81	-0.28	-0.54
0.8	0.4	-0.0120	-0.0294	-0.0120		-3.85	-5.00	1.93		-6.91	-10.45	-0.16	-0.54
0.8	0.2	-0.0004	0.0031	-0.0004		-0.12	0.53	0.06		0.47	0.63	0.01	0.54

max negative moment, M_{ux}(-) = -31.46 ft-k/ft

max negative steel req'd, A_s(-) = -0.48 in²/ft

minimum steel req'd = -0.60 in²/ft

Use

max positive moment, M_{ux}(+) = 78.20 ft-k/ft

max positive steel req'd, A_s(+) = 1.23 in²/ft

minimum steel req'd = 0.60 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil EQ

M _y - Moment Summary													
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.990	0.524	-0.497						Final Moments		Reinforcing: (d = 15.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		320.760	169.776	-161.028									
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0	0.8	0.0117	0.0418	0.0117		3.75	7.10	-1.88		8.97	13.31	0.19	0.54
0	0.6	0.0101	0.0303	0.0101		3.25	5.14	-1.63		6.76	10.12	0.15	0.54
0	0.4	0.0074	0.0181	0.0074		2.36	3.07	-1.19		4.25	6.42	0.09	0.54
0	0.2	0.0031	0.0061	0.0031		1.00	1.03	-0.50		1.53	2.34	0.03	0.54
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
0.2	0	0.0211	0.0350	0.0211		6.76	5.94	-3.39		9.30	14.38	0.21	0.54
0.4	0	0.0464	0.0948	0.0464		14.89	16.09	-7.48		23.50	35.88	0.53	0.62
0.6	0	0.0660	0.1485	0.0660		21.16	25.21	-10.62		35.74	54.27	0.81	0.62
0.8	0	0.0778	0.1834	0.0778		24.95	31.14	-12.52		43.56	65.98	0.99	0.62
1	0	0.0818	0.1954	0.0818		26.23	33.17	-13.17		46.23	69.97	1.06	0.62
1	0.2	0.0159	0.0687	0.0159		5.10	11.66	-2.56		14.20	20.91	0.30	0.54
1	0.4	-0.0113	0.0028	-0.0113		-3.61	0.47	1.81		-1.32	-2.58	-0.04	-0.54
1	0.6	-0.0159	-0.0243	-0.0159		-5.08	-4.13	2.55		-6.66	-10.34	-0.15	-0.54
1	0.8	-0.0093	-0.0240	-0.0093		-2.98	-4.08	1.50		-5.56	-8.38	-0.12	-0.54
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.54
1	0.4	-0.0113	0.0028	-0.0113		-3.61	0.47	1.81		-1.32	-2.58	-0.04	-0.54
0.8	0.4	-0.0111	0.0022	-0.0111		-3.56	0.37	1.79		-1.40	-2.67	-0.04	-0.54
0.6	0.4	-0.0102	0.0012	-0.0102		-3.27	0.21	1.64		-1.42	-2.65	-0.04	-0.54
0.4	0.4	-0.0077	0.0018	-0.0077		-2.46	0.31	1.24		-0.92	-1.78	-0.03	-0.54
0.2	0.4	-0.0020	0.0065	-0.0020		-0.65	1.10	0.33		0.77	0.95	0.01	0.54

max negative moment, M_{uy}(-) = -10.34 ft-k/ft

max negative steel req'd, A_s(-) = -0.15 in²/ft

minimum steel req'd = -0.54 in²/ft

Use

max positive moment, M_{uy}(+) = 69.97 ft-k/ft

max positive steel req'd, A_s(+) = 1.06 in²/ft

minimum steel req'd = 0.62 in²/ft

Use



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.00
 DESIGN TASK: Wall 2 - Soil EQ

Shear Summary												
a = 17.5 b = 18 a / b = 0.9722		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		0.990	0.524	-0.497						Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V	V _u	φV _c
x / a	y / b	A	B	C	D	A	B	C	D	k/ft	k/ft	k/ft
0	1	0.1894	1.1771	0.1894		3.38	11.10	-1.69		12.78	18.57	17.65
0	0.8	0.2520	0.9404	0.2520		4.49	8.87	-2.25		11.11	16.45	17.65
0	0.6	0.2481	0.6236	0.2481		4.42	5.88	-2.22		8.08	12.20	17.65
0	0.4	0.2426	0.4028	0.2426		4.32	3.80	-2.17		5.95	9.20	17.65
0	0.2	0.1129	0.0509	0.1129		2.01	0.48	-1.01		1.48	2.48	17.65
0	0.00	-0.0238	-0.0916	-0.0238		-0.42	-0.86	0.21		-1.08	-1.59	17.65
0.2	0	0.1644	0.1118	0.1644		2.93	1.05	-1.47		2.51	4.11	17.65
0.4	0	0.3145	0.4335	0.3145		5.60	4.09	-2.81		6.88	10.75	17.65
0.6	0	0.3985	0.6610	0.3985		7.10	6.23	-3.57		9.77	15.10	17.65
0.8	0	0.4407	0.7883	0.4407		7.85	7.43	-3.94		11.35	17.45	17.65
1	0	0.4535	0.8288	0.4535		8.08	7.82	-4.06		11.84	18.19	17.65

NG
Ok for phi=1.0

NG
Ok for phi=1.0

Concrete strength reduction factor for shear, φ = 0.75

d = 15.5 in

maximum shear, V_u = 18.57 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 15.5) / 1000 = 17.65 \text{ k/ft}$$

SHEAR NOT SATISFIED ! , CHANGE PLATE THICKNESS, or CHECK SHEAR AT DISTANCE "d".

Reference:
 "Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Vn=23.5-kips for phi=1.0, Shear OK

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.

BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)

Hydrodynamic analysis of an interior wall with equal water each side per ASCE 7-10 and the 2012 IBC code:

wall connection fixity = **pinned at roof & fixed at floor**


tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = **28.25** ft
 inside serpentine wall thickness, t_w = **18** inch
 wall height to underside of roof, H_w = **18** ft
 roof thickness, t_r = **1** inch

liquid height, H_L = **16** ft
 liquid specific gravity = **1**
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, $g = 32.17$ ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴

foundation footing thickness, t_f = 1.5 ft
 foundation projection toe side, l_t = 6 ft
 foundation projection heel side, l_h = 6 ft

allowable soil bearing pressure static = **2** ksf
 allowable soil bearing pressure seismic = **2.67** ksf

yield strength of reinforcement, f_y = **60** ksi
 concrete strength, f'_c = **4** ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴




Interior Wall Section
 (wall fixity = pinned at roof & fixed at floor)

Seismic data from the IBC code:

Structure Risk Category = **3**
 Seismic importance factor, I = **1.25**
 Response modification factor, R_i = **3**
 Response modification factor, R_c = **1.5**

Note:
 Hydrodynamic seismic forces on the interior wall will be the sum of half the impulsive and convective forces from water on each side of the wall.



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)

Weights:

unit 1-ft width wall mass, $W_w = (18/12) * (18) * 0.15 = 4.05$ kip
 wall c.g. relative to base, $h_w = 18 / 2 = 9.000$ ft
 unit width liquid mass, $W_L = 28.25 * 1 * 16 * 0.0624 = 28.20$ kip


Seismic:

Design, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Design, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Note: Hydrodynamic seismic forces on the interior wall will be the sum of half the impulsive and convective forces from water on each side of the wall.

1). wall stiffness and dynamic property:

Note: W_i and h_i are impulsive component variables calculated on page 3.



wall mass, $m_w = H_w * (t_w / 12) * \rho_c = 0.12589$ k-sec²/ft²
 liquid mass, $m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.26100$ k-sec²/ft²
 centroidal distance of masses, $h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 6.976$ ft
 wall fixity condition is pinned at roof & fixed at floor:
 wall stiffness is determined using a unit mass load located at the centroidal distance h .
 wall flexure stiffness, $k = Ec * (t_w * H_w / h)^3 / (12 * (4 * H_w - h) * (H_w - h)^2) = 3808.79$ k/ft-ft

$$\omega_1 = \sqrt{\frac{k}{m_w + m_i}} = (3808.79 / (0.1259 + 0.261))^{1/2} = 99.21943 \text{ rad/sec}$$

period of vibration of the wall plus impulsive mass, $T_1 = 2\pi / \omega_1 = 2 * \pi / 99.21943 = 0.0633$ sec

design factored spectral response acceleration for impulsive mass (5% damping), $S_{ai} = S_{DS} = 0.611$ *g

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = 9.8051 \quad \omega_c = \frac{\lambda}{\sqrt{L}} = 9.8051 / (28.25)^{1/2} = 1.8448 \text{ rad/sec,}$$


period of the convective mass, $T_c = 2\pi / \omega_c = 2 * \pi / 1.8448 = 3.4059$ sec

Long transition period (from map figure 22-12 ASCE 7), $T_L = 16$ sec

design spectral response acceleration for convective mass (0.5% damping), $S_{ac} = 1.5 * S_{d1} / T_c = 0.2889$ *g

effective mass coeff., $\varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021$, but $\leq 1.0 = 0.7312$

BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)



L = 28.25 ft
 B = 1 ft
 H_L = 16 ft
 W_L = 28.2 kip
 L / H_L = 1.76563
 H_L / L = 0.56637

3). lateral fluid impulsive force:

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 16.79 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * 0.375 = 16 * 0.375 = 6 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * \left\{ \left\{ \frac{0.866 * L / H_L}{2 * \tanh(0.866 * L / H_L)} \right\} - 1/8 \right\} = 11.438 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_i} \right) W_i = (0.611 * 1.25 / 3) * 16.79 = 4.27 \text{ kip}$$

$$\text{impulsive force moment excluding bottom pressure, } M_{i(\text{EBP})} = P_i * h_{i(\text{EBP})} = 4.27 * 6 = 25.62 \text{ ft-k}$$

$$\text{impulsive force moment including bottom pressure, } M_{i(\text{IBP})} = P_i * h_{i(\text{IBP})} = 4.27 * 11.438 = 48.84 \text{ ft-k}$$

4). lateral fluid convective force:

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 12.43 \text{ kip}$$

$$h_{c \text{ (EBP)}} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 1}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 9.619 \text{ ft}$$

$$h_{c \text{ (IBP)}} = H_L \left(1 - \frac{\cosh \left(3.16 \left(\frac{H_L}{L} \right) \right) - 2.01}{3.16 \left(\frac{H_L}{L} \right) \sinh \left(3.16 \left(\frac{H_L}{L} \right) \right)} \right) = 12.721 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_c} \right) W_c = (0.2889 * 1.25 / 1.5) * 12.43 = 2.99 \text{ kip}$$

$$\text{convective force moment excluding bottom pressure, } M_{c(\text{EBP})} = P_c * h_{c(\text{EBP})} = 2.99 * 9.619 = 28.76 \text{ ft-k}$$

$$\text{convective force moment including bottom pressure, } M_{c(\text{IBP})} = P_c * h_{c(\text{IBP})} = 2.99 * 12.721 = 38.04 \text{ ft-k}$$

BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)

5). lateral inertia force of the accelerating wall:

$$\text{mass of a unit 1-ft width wall, } W_w = 4.05 \text{ kip}$$

$$\text{wall c.g. relative to base, } h_w = 9.000 \text{ ft}$$

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \epsilon}{R_i} \right) W_w = (0.611 * 1.25 * 0.7312 / 3) * 4.05 = 0.75 \text{ kip}$$

$$\text{wall inertia force moment, } M_w = P_w * h_w = 0.75 * 9 = 6.75 \text{ ft-k}$$

6). total base shear:

$$V = \sqrt{(P_i + P_w)^2 + P_c^2}$$

$$V = ((4.27 + 0.75)^2 + (2.99)^2)^{1/2} = 5.84 \text{ kip}$$

7). total moment at the base excluding bottom pressure (EBP):

$$M_b = \sqrt{(M_i + M_w)^2 + M_c^2}$$

$$M_b = ((25.62 + 6.75)^2 + (28.76)^2)^{1/2} = 43.30 \text{ ft-k}$$

8). total moment at the base including bottom pressure (IBP):

$$M_o = \sqrt{(M_i + M_w)^2 + M_c^2}$$

$$M_o = ((48.84 + 6.75)^2 + (38.04)^2)^{1/2} = 67.36 \text{ ft-k}$$

9). maximum wave slosh height displacement: (see ASCE-10, 15.7.6.1 notes c and d)

(Risk Category = 3) I = 1.25 ,use TL = 4 ,Sd1 = 0.656 ,Tc = 3.4059


$$S_{ac} = 1.5 * Sd1 / Tc = 0.2889 \text{ *g}$$

$$d_{(max)} = 0.42 (L) (S_{ac} I) = 0.42 * (28.25) * (0.2889 * 1.25) = 4.28 \text{ ft}$$

(minimum freeboard see table 15.7-3 of ASCE 7) , d(min) = 0.7 * d(max) = 3 ft

BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)

10). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

Note: this accounts for the impulsive pressure on each side of the wall.

$$p_{iy} = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{B H_L^2} =$$

$P_i = 4.27$ kip
 $h_i = 6$ ft
 at $y = H_L$, $p_{iy} = 0.067$ ksf
 at base $y = 0$, $p_{iy} = 0.467$ ksf

convective:

Note: this accounts for the convective pressure on each side of the wall.

$$p_{cy} = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{B H_L^2} =$$

$P_c = 2.99$ kip
 $h_c = 9.619$ ft
 at $y = H_L$, $p_{cy} = 0.300$ ksf
 at base $y = 0$, $p_{cy} = 0.073$ ksf

wall inertia:


$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_i} =$$

$p_{wy} = 0.1861 * \gamma_c * t_w$
 at $y = H_w$, $p_{wy} = 0.042$ ksf
 at base $y = 0$, $p_{wy} = 0.042$ ksf

combine the effects of the hydrodynamic pressures on the wall:

$$p_y = \sqrt{(p_{iy} + p_{wy})^2 + p_{cy}^2} =$$

at $y = H_w$, $p_y = 0.319$ ksf
 at base $y = 0$, $p_y = 0.514$ ksf





resultant dynamic pressures

BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)

11). wall design pressures for hydrodynamic seismic:

wall height, $H_w = 18$ ft
 liquid height, $H_L = 16$ ft



unfactored resultant dynamic pressures

load factor applied to dynamic shear = 1.4
 load factor applied to dynamic moment = 1.4

factored shear, $V_u = 1.4 * (\text{dynamic shear})$
 factored moment, $M_u = 1.4 * (\text{dynamic moment})$

WALL REACTIONS for HYDROSTATIC + SEISMIC		
Reactions, Shears, and Moments (kips/ft and ft-kips/ft)		
Location	unfactored loads	factored loads
	Hydrodynamic	Static + Dynamic
shear reaction at (A)	1.302	1.822
moment at (A)	0.000	0.000
shear reaction at (B)	3.458	4.842
moment at (B)	-11.687	-16.362
distance from base, y	y = 11.000	
shear at distance y	-0.053	-0.074
moment at distance y	6.080	8.512

"y" is any arbitrary distance above the base in which to investigate moment and shears.
 (max positive moment occurs at a "y" where shear = zero)



BY: C. Che DATE: Sep-17 CLIENT: Willametter River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 8 - Washwater Basin PS JOB NO: 10721A.10
 DESIGN TASK: Wall 3 - Hydrodynamic (Water 2-Sides)

tank wall thickness, $t_w = 18$ inch
 depth to wall tension steel, $d = 15.69$ inch
 wall bar clear cover = **2** inch
 curtains of rebar in the wall (1 or 2 ?) = **2**
 wall min vert temp. / shrinkage steel ratio = **0.00250**
 wall min horz temp. / shrinkage steel ratio = **0.00250**
 ϕ for shear is dependent upon the load factors used. See code. (typically 0.85 or 0.75), ϕ , Shear = **1**

concrete strength, $f'_c = 4$ ksi
 strength of reinforcement, $f_y = 60$ ksi
 wall design width, $b = 12$ inch
 tank wall thickness, $t_w = 18$ inch
 ϕ , Bending = 0.9

*** WALL VERTICAL REINFORCEMENT REQUIRED ***								
Wall Locations		Load Case	Wall Shear		Wall Moment		A_s required in ² /ft	A_s min in ² /ft
			factored V_u k/ft	factored ϕV_c k/ft	service M ft-k/ft	factored M_u ft-k/ft		
top of wall	heel side	seismic	1.822	23.816	0.000	0.000	0.00	0.27
bottom of wall	heel side	seismic	4.842	23.816	-11.687	-16.362	0.23	0.31
distance y = 11-ft from the base	toe side	seismic	-0.074	23.816	6.080	8.512	0.12	0.27

WALL SHEAR OKAY!!

*** WALL VERTICAL & HORIZONTAL STEEL PROVIDED ***								
Wall Locations		load case	M (ft-k/ft)	M_u (ft-k/ft)	A_s or $A_{(min)}$ (required) (in ² /ft)	bar number size	bar spacing (in.)	A_s (provided) (in ² /ft)
top of wall	heel side	seismic	0.000	0.000	0.27	5	12	0.31
bottom of wall	heel side	seismic	-11.687	-16.362	0.31	5	12	0.31
distance y = 11-ft from the base	toe side	seismic	6.080	8.512	0.27	5	12	0.31
Horizontal reinforcement required each face $A_s = \rho * b * t_w / (\text{number of curtains})$					0.27	5	12	0.31

** Note: Crack control is not a requirement for the seismic load case.

WALL MOMENT OKAY!!

**Area 8 - Washwater Basin
Wall 4 - Moment & Shear**

		Horizontal Span							
	S_d	M_{ux} (k-ft)	$S_d * M_{ux}$ (k-ft)	M_n (k-ft)	DCR	SQX _u (psi)	SQ _n (psi)	DCR	
1.4F	1.61	21.10	33.97	55.00	0.62	59	126	0.46	<- OK
1.2F+1.4E	1.00	36.40	36.40	55.00	0.66	95	126	0.75	<- OK
1.6(H+L)	1.41	46.20	65.14	55.00	1.18	118	126	0.93	<- NG
1.6H+1.4E	1.00	84.20	84.20	55.00	1.53	210	126	1.66	<- NG

		Vertical Span							
	S_d	M_{uy} (k-ft)	$S_d * M_{uy}$ (k-ft)	M_n (k-ft)	DCR	SQY _u (psi)	SQ _n (psi)	DCR	
1.4F	1.12	30.40	34.05	88.50	0.38	59	126	0.46	<- OK
1.2F+1.4E	1.00	46.10	46.10	88.50	0.52	76	126	0.60	<- OK
1.6(H+L)	1.00	52.40	52.40	88.50	0.59	76	126	0.60	<- OK
1.6H+1.4E	1.00	83.80	83.80	88.50	0.95	127	126	1.00	<- NG



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.4F

Client Willamette River WTP

Job No
10721A.00

Sheet No
1

Page 424

Part/Wall 4

Ref

By Date 04-Aug-17


Chd

File Wall 4.std

Date/Time 10-Aug-2017 12:10

MX (local)
lb-in/in

- <= -21.1 E3
- 19.3 E3
- 17.4 E3
- 15.6 E3
- 13.8 E3
- 12 E3
- 10.1 E3
- 8.302
- 6.476
- 4.650
- 2.823
- 997
- 829
- 2655
- 4482
- 6308
- >= 8134



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 8 - Washwater Basin

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
Part/Wall 4					
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 4.std	Date/Time	15-Sep-2017 11:53		

- MX (local)
lb-in/in
- <= -36.4 E3
 - 33.3 E3
 - 30.2 E3
 - 27 E3
 - 23.9 E3
 - 20.8 E3
 - 17.6 E3
 - 14.5 E3
 - 11.3 E3
 - 8.216
 - 5.082
 - 1.949
 - 1.185
 - 4.319
 - 7.453
 - 10.6 E3
 - >= 13.7 E3



Load 2



Software licensed to Carollo Engineers


Job Title Area 8 - Washwater Basin

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
Part/Wall	4				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 4.std	Date/Time	10-Aug-2017 12:10		

- MX (local)
lb-in/in
- <= -46.2 E3
 - 42.2 E3
 - 38.3 E3
 - 34.3 E3
 - 30.4 E3
 - 26.4 E3
 - 22.5 E3
 - 18.6 E3
 - 14.6 E3
 - 10.7 E3
 - 6.715
 - 2.769
 - 1.177
 - 5.123
 - 9.069
 - 13 E3
 - >= 17 E3





Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.00

Sheet No

1

Page 427

Rev

Part/Wall 4

Ref

By Date 04-Aug-17

Chd


File Wall 4.std

Date/Time 10-Aug-2017 12:10

MX (local)

lb-in/in

- <= -84.2 E3
- 77 E3
- 69.9 E3
- 62.7 E3
- 55.6 E3
- 48.5 E3
- 41.3 E3
- 34.2 E3
- 27 E3
- 19.9 E3
- 12.8 E3
- 5627
- 1512
- 8651
- 15.8 E3
- 22.9 E3
- >= 30.1 E3



Load 4



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 4	
-------------	--

Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 4.std	Date/Time	10-Aug-2017 12:10
------	------------	-----------	-------------------

- MY (local)
lb-in/in
- <= -30.4 E3
 - 27.9 E3
 - 25.3 E3
 - 22.7 E3
 - 20.1 E3
 - 17.6 E3
 - 15 E3
 - 12.4 E3
 - 9.833
 - 7.257
 - 4.681
 - 2.105
 - 471
 - 3047
 - 5623
 - 8199
 - >= 10.8 E3





Software licensed to Carollo Engineers
CONNECTED User: Caleb Che


Job Title Area 8 - Wastewater Basin

Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
Part/Wall	4	Ref			
By		Date	04-Aug-17	Chd	
File	Wall 4.std	Date/Time	15-Sep-2017 11:53		

- MY (local)
lb-in/in
- <= -46.1 E3
 - 42.3 E3
 - 38.4 E3
 - 34.5 E3
 - 30.6 E3
 - 26.8 E3
 - 22.9 E3
 - 19 E3
 - 15.1 E3
 - 11.3 E3
 - 7.378
 - 3.502
 - 373
 - 4248
 - 8123
 - 12 E3
 - >= 15.9 E3



Load 2



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.00

Sheet No

1

Rev

Part/Wall 4

Ref

By Date 04-Aug-17

Chd


File Wall 4.std

Date/Time 10-Aug-2017 12:10

MY (local)

lb-in/in

- <= -52.4 E3
- 48.1 E3
- 43.7 E3
- 39.4 E3
- 35 E3
- 30.7 E3
- 26.3 E3
- 22 E3
- 17.6 E3
- 13.2 E3
- 8896
- 4544
- 192
- 4160
- 8512
- 12.9 E3
- >= 17.2 E3



Load 3



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.00

Sheet No
1

Rev

Part/Wall 4

Ref

By Date 04-Aug-17

Chd


File Wall 4.std

Date/Time 10-Aug-2017 12:10

MY (local)

lb-in/in

- <= -83.8 E3
- 76.9 E3
- 70.1 E3
- 63.2 E3
- 56.3 E3
- 49.5 E3
- 42.6 E3
- 35.7 E3
- 28.8 E3
- 22 E3
- 15.1 E3
- 8238
- 1368
- 5502
- 12.4 E3
- 19.2 E3
- >= 26.1 E3



Load 4




Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
Part/Wall	4				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 4.std	Date/Time	10-Aug-2017 12:10		



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 8 - Washwater Basin


Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
Part/Wall	4	Ref			
By		Date	04-Aug-17	Chd	
File	Wall 4.std	Date/Time	15-Sep-2017 11:53		

SQX (local)
psi

- <= -91.1
- 79.5
- 67.8
- 56.2
- 44.6
- 33
- 21.4
- 9.79
- 1.82
- 13.4
- 25
- 36.7
- 48.3
- 59.9
- 71.5
- 83.1
- >= 94.7



Load 2



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--

Part/Wall 4


Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 4.std	Date/Time	10-Aug-2017 12:10
------	------------	-----------	-------------------

SQX (local)
psi

<= -113
-98.3
-83.9
-69.5
-55.1
-40.7
-26.3
-11.9
2.48
16.9
31.3
45.7
60.1
74.5
88.9
103
>= 118



Load 3



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.00

Sheet No
1

Rev

Part/Wall 4

Ref

By Date 04-Aug-17

Chd


File Wall 4.std

Date/Time 10-Aug-2017 12:10

SQX (local)

psi

- <= -200
- 174
- 149
- 123
- 97.6
- 72
- 46.4
- 20.8
- 4.83
- 30.4
- 56.1
- 81.7
- 107
- 133
- 159
- 184
- >= 210



Load 4



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.4F

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
--------	-----------	----------	---	-----	--


Part/Wall 4	
-------------	--

Ref	
-----	--

By	Date	04-Aug-17	Chd
----	------	-----------	-----

File	Wall 4.std	Date/Time	10-Aug-2017 12:10
------	------------	-----------	-------------------

- SQY (local)
psi
- <= -34.9
 - 29.1
 - 23.2
 - 17.4
 - 11.6
 - 5.73
 - 0.102
 - 5.94
 - 11.8
 - 17.6
 - 23.4
 - 29.3
 - 35.1
 - 41
 - 46.8
 - 52.6
 - >= 58.5



Load 1



Software licensed to Carollo Engineers
CONNECTED User: Caleb Che

Job Title Area 8 - Washwater Basin


Load Case: 1.2F+1.4E

Client Willamette River WTP

Job No	10721A.00	Sheet No	1	Rev	
Part/Wall	4				
Ref					
By		Date	04-Aug-17	Chd	
File	Wall 4.std	Date/Time	15-Sep-2017 11:53		

SQY (local)
psi

- <= -59
- 50.6
- 42.2
- 33.8
- 25.4
- 17
- 8.55
- 0.148
- 8.25
- 16.7
- 25.1
- 33.5
- 41.9
- 50.3
- 58.7
- 67.1
- >= 75.5



Load 2



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6(H+L)

Client Willamette River WTP

Job No
10721A.00

Sheet No

1

Rev

Part/Wall 4

Ref

By

Date 04-Aug-17

Chd


File Wall 4.std

Date/Time 10-Aug-2017 12:10

SQY (local)

psi

- <= -72.2
- 63
- 53.7
- 44.5
- 35.3
- 26
- 16.8
- 7.54
- 1.7
- 10.9
- 20.2
- 29.4
- 38.6
- 47.9
- 57.1
- 66.4
- >= 75.6



Load 3



Software licensed to Carollo Engineers

Job Title Area 8 - Washwater Basin

Load Case: 1.6H+1.4E

Client Willamette River WTP

Job No
10721A.00

Sheet No

1

Page 439

Part/Wall 4

Ref

By

Date 04-Aug-17

Chd


File Wall 4.std

Date/Time 10-Aug-2017 12:10

SQY (local)

psi

- <= -127
- 113
- 98.7
- 84.7
- 70.7
- 56.7
- 42.7
- 28.6
- 14.6
- 0.612
- 13.4
- 27.4
- 41.4
- 55.5
- 69.5
- 83.5
- >= 97.5



Load 4

Area 9 - High Service Pump Station
ASCE 41 Evaluation

BY JAD DATE 5/18/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
CHKD. BY DATE FINISHED WATER P.S. JOB NO. 9865A.00

TIER 1 CHECKLISTS

16.1.2 IO

VERTICAL IRREGULARITY:

- NC - ○ WEST WALL HAS NO SHEAR WALL BELOW. CHECK RESERVOIR SLAB FOR ADEQUATE SHEAR CAPACITY.
- INTERIOR WALL IS DISCONTINUOUS. CHECK RESERVOIR SLAB FOR ADEQUATE SHEAR CAPACITY. ALSO, CHECK COLUMN FOR ADDITIONAL OVERTURNING FORCE.

PERFORM ANALYSIS PER SEC. 5.2.4.

OVERTURNING:

$$l_{min,sw} = 29.2 \text{ FT}$$

$$h_{BLOG} = 22.33 \text{ FT}$$

$$29.2 / 22.33 = 1.31 > 0.267 \text{ OK}$$

16.10 IO

SHEAR STRESS CHECK: (E-W CHECK ONLY)

$$V_j = (0.611) W_j$$

$$W_j = 691 \text{ k}$$

$$A_w = (8 \text{ in.}) (352 \text{ in.} + 388 \text{ in.} + 274 \text{ in.} + 250 \text{ in.}) = 10,112 \text{ in.}^2$$

$$V_j^{AVG \text{ E-W}} = \frac{(0.611)(691 \text{ k})}{(2.0)(10,112 \text{ in.}^2)} = 0.021 \text{ ksi OK}$$

REINFORCING STL:

$$\text{VERT } 8" \text{ WALL } A_{st,v} = \frac{(0.88 \text{ in.}^2)}{(12 \text{ in.})(8 \text{ in.})} = 0.0092 > 0.0012$$

BY JAD DATE 5/19/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
CHKD. BY DATE FINISHED WATER P.S. JOB NO. 9865A.00

HORZ 8" WALL $A_{STH} = \frac{(0.31 \text{ in}^2)}{(8 \text{ in})(12 \text{ in})} = 0.0032 > 0.0020 \text{ OK}$

WALL ANCHORAGE: (PER SEC. 4.3.5.7)

$$T_c = \psi S_x W_p A_p$$

$$T_c = 1.8 (0.611) W_p A_p$$

$$A_p \text{ WEST WALL} = [3.33 \text{ FT} + 2.33 \text{ FT} + 22 \text{ FT}/2](7.33 \text{ FT}) = 122 \text{ FT}^2$$

$$A_p \text{ NORTH WALL} = [2.33 \text{ FT} + 22 \text{ FT}/2](2.0 \text{ FT}) = 26.7 \text{ FT}^2$$

$$T_c \text{ WEST WALL} = 1.8 (0.611)(122 \text{ FT}^2)(8/12 \text{ FT})(150 \text{ PSF}) = 13,418 \text{ LB}$$

$$T_c \text{ NORTH WALL} = 1.8 (0.611)(26.7 \text{ FT}^2)(8/12 \text{ FT})(150 \text{ PSF}) = 2,936 \text{ LB}$$

$$T_c \text{ TOP WEST WALL} = 1.8 (0.611)(95.8 \text{ FT}^2)(100 \text{ PSF}) = 10,542 \text{ LB}$$


⇒ DETAILS ABOUT JOIST SEATS AND LEDGER ANCHORAGE ARE MISSING FROM THE DRAWINGS.

ASSUMING $3/4" \phi \times 6"$ EMBED W/ EPOXY @ 24" O.C. @ LEDGER ANGLES

NO ADHESIVE ANCHOR MEETS APPENDIX D BUT STRENGTH IS OK.

ASSUMING (2) $3/4" \phi \times 8"$ EMBED ANCHOR BOLTS @ JOIST BEARING SEATS. CHECK CONDITION W/ 5.75-FT JOIST SPACING.

$$DCR = 1.55 > 1.0 \quad \text{NG}$$



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

1
 Willamette River WTP
 Area 09 / Ledger Anchr
 5/19/2015

Specifier's comments:

1 Input data

Anchor type and diameter: HIT-RE 500-SD + HAS B7 3/4

Effective embedment depth: $h_{ef,ect} = 6.000$ in. ($h_{ef,limit} = -$ in.)

Material: ASTM A 193 Grade B7

Evaluation Service Report: ESR-2322

Issued | Valid: 2/1/2014 | 4/1/2016

Proof: Design method ACI 318-11 / Chem

Stand-off Installation: - (Recommended plate thickness: not calculated)


Profile: no profile

Base material: cracked concrete, 4000, $f'_c = 4000$ psi; $h = 8.000$ in., Temp. short/long: 32/32 °F


Installation: hammer drilled hole, Installation condition: Dry

Reinforcement: tension: condition A, shear: condition A; no supplemental splitting reinforcement present
 edge reinforcement: > No. 4 bar

Seismic loads (cat. C, D, E, or F) Tension load: yes (D.3.3.4.3 (a))
 Shear load: yes (D.3.3.5.3 (a))



Geometry [in.] & Loading [lb, in.lb]




Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 2
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Area 09 / Ledger Anchr
 Date: 5/19/2015

2 Load case/Resulting anchor forces

Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	2936	0	0	0

max. concrete compressive strain: - [%_o]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000): 0 [lb]
 resulting compression force in (x/y)=(0.000/0.000): 0 [lb]

3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{ua}/\phi N_n$	Status
Steel Strength*	2936	50172	6	OK
Bond Strength**	2936	9189	32	not recommended ^A
Sustained Tension Load Bond Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Strength**	2936	15802	19	not recommended ^A

* anchor having the highest loading **anchor group (anchors in tension)

^A When D.3.3.4.3 (a) is selected for seismic design, the design steel strength must be the governing design strength having the highest utilization.

3.1 Steel Strength

N_{sa} = ESR value refer to ICC-ES ESR-2322
 $\phi N_{steel} \geq N_{ua}$ ACI 318-11 Table D.4.1.1

Variables


n	$A_{sa,N}$ [in. ²]	f_{ua} [psi]
1	0.33	125000

Calculations

N_{sa} [lb]
41810

Results

N_{sa} [lb]	ϕ_{steel}	ϕN_{sa} [lb]	N_{ua} [lb]
41810	1.200	50172	2936



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

3
 Willamette River WTP
 Area 09 / Ledger Anchr
 5/19/2015

3.2 Bond Strength

$$N_a = \left(\frac{A_{Na}}{A_{Na0}} \right) \psi_{ed,Na} \psi_{cp,Na} N_{ba} \quad \text{ACI 318-11 Eq. (D-18)}$$

$$\phi N_a \geq N_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Na} = \text{see ACI 318-11, Part D.5.5.1, Fig. RD.5.5.1(b)}$$

$$A_{Na0} = (2 C_{Na})^2 \quad \text{ACI 318-11 Eq. (D-20)}$$

$$C_{Na} = 10 d_a \sqrt{\frac{\tau_{uncr}}{1100}} \quad \text{ACI 318-11 Eq. (D-21)}$$

$$\psi_{ec,Na} = \left(\frac{1}{1 + \frac{e_N}{C_{Na}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-23)}$$

$$\psi_{ed,Na} = 0.7 + 0.3 \left(\frac{C_{a,min}}{C_{Na}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-25)}$$

$$\psi_{cp,Na} = \text{MAX} \left(\frac{C_{a,min}}{C_{ac}}, \frac{C_{Na}}{C_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-27)}$$

$$N_{ba} = \lambda_a \cdot \tau_{k,c} \cdot \alpha_{N,seis} \cdot \kappa_{bond} \cdot \pi \cdot d_a \cdot h_{ef} \quad \text{ACI 318-11 Eq. (D-22)}$$

Variables

$\tau_{k,c,uncr}$ [psi]	d_a [in.]	h_{ef} [in.]	$C_{a,min}$ [in.]	$\tau_{k,c}$ [psi]	
2065	0.750	6.000	∞	1000	
$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	C_{ac} [in.]	κ_{bond}	λ_a	$\alpha_{N,seis}$
0.000	0.000	14.703	1.00	1.000	0.650

Calculations

C_{Na} [in.]	A_{Na} [in. ²]	A_{Na0} [in. ²]	$\psi_{ed,Na}$
10.230	418.58	418.58	1.000
$\psi_{ec1,Na}$	$\psi_{ec2,Na}$	$\psi_{cp,Na}$	N_{ba} [lb]
1.000	1.000	1.000	9189

Results

N_a [lb]	ϕ_{bond}	$\phi_{seismic}$	ϕN_a [lb]	N_{ua} [lb]
9189	1.000	1.000	9189	2936


Profis Anchor 2.5.0
www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

4
 Willamette River WTP
 Area 09 / Ledger Anchr
 5/19/2015

3.3 Concrete Breakout Strength

$$N_{cb} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \quad \text{ACI 318-11 Eq. (D-3)}$$

$$\phi N_{cb} \geq N_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

$$A_{Nc} \text{ see ACI 318-11, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-11 Eq. (D-5)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-8)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-10)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-12)}$$

$$N_b = k_c \lambda_a \sqrt{f_c} h_{ef}^{1.5} \quad \text{ACI 318-11 Eq. (D-6)}$$

Variables


h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$
6.000	0.000	0.000	∞	1.000
c_{ac} [in.]	k_c	λ_a	f_c [psi]	
14.703	17	1.000	4000	

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
324.00	324.00	1.000	1.000	1.000	1.000	15802

Results

N_{cb} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	ϕN_{cb} [lb]	N_{ua} [lb]
15802	1.000	1.000	15802	2936


Profis Anchor 2.5.0
www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 5
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Area 09 / Ledger Anchr
 Date: 5/19/2015

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_v = V_{ua} / \phi V_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength (Bond Strength controls)*	N/A	N/A	N/A	N/A
Concrete edge failure in direction **	N/A	N/A	N/A	N/A

* anchor having the highest loading **anchor group (relevant anchors)

5 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Design Strengths of adhesive anchor systems are influenced by the cleaning method. Refer to the INSTRUCTIONS FOR USE given in the Evaluation Service Report for cleaning and installation instructions
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-11 Appendix D, Part D.3.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Part D.3.3.4.3 (b), Part D.3.3.4.3 (c), or Part D.3.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Part D.3.3.5.3 (a), Part D.3.3.5.3 (b), or Part D.3.3.5.3 (c).
- Part D.3.3.4.3 (b) / part D.3.3.5.3 (a) requires that the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Part D.3.3.4.3 (c) / part D.3.3.5.3 (b) waives the ductility requirements and requires that the anchors shall be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Part D.3.3.4.3 (d) / part D.3.3.5.3 (c) waives the ductility requirements and requires the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by Ω_0 .
- Installation of Hilti adhesive anchor systems shall be performed by personnel trained to install Hilti adhesive anchors. Reference ACI 318-11, Part D.9.1

Fastening does not meet the design criteria!


Profis Anchor 2.5.0
www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 6
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Area 09 / Ledger Anchr
 Date: 5/19/2015

6 Installation data

Anchor plate, steel: -
 Profile: -
 Hole diameter in the fixture: -
 Plate thickness (input): -
 Recommended plate thickness: -
 Cleaning: Premium cleaning of the drilled hole is required

Anchor type and diameter: HIT-RE 500-SD + HAS B7 3/4
 Installation torque: 1200.000 in.lb
 Hole diameter in the base material: 0.875 in.
 Hole depth in the base material: 6.000 in.
 Minimum thickness of the base material: 7.750 in.

Coordinates Anchor in.

Anchor	x	y	C-x	C+x	C-y	C+y
1	0.000	0.000	-	-	-	-

7 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

1
 Willamette River WTP
 Area 09
 5/21/2015

Specifier's comments: Ledger Anchors / Diaphragm Boundary

1 Input data

Anchor type and diameter: HIT-RE 500-SD + HAS B7 3/4

Effective embedment depth: $h_{ef,act} = 6.000$ in. ($h_{ef,limit} = -$ in.)

Material: ASTM A 193 Grade B7

Evaluation Service Report: ESR-2322

Issued | Valid: 2/1/2014 | 4/1/2016

Proof: Design method ACI 318-11 / Chem

Stand-off installation: $e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.

Anchor plate: $l_x \times l_y \times t = 4.000$ in. x 24.000 in. x 0.500 in.; (Recommended plate thickness: not calculated)

Profile: no profile

Base material: cracked concrete, 4000, $f'_c = 4000$ psi; $h = 8.000$ in., Temp. short/long: 32/32 °F


Installation: hammer drilled hole, Installation condition: Dry

Reinforcement: tension: condition B, shear: condition B; no supplemental splitting reinforcement present
 edge reinforcement: none or < No. 4 bar

Seismic loads (cat. C, D, E, or F) Tension load: yes (D.3.3.4.3 (a))
 Shear load: yes (D.3.3.5.3 (c))



Geometry [in.] & Loading [lb, in.lb]





Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

2
 Willamette River WTP
 Area 09
 5/21/2015

2 Load case/Resulting anchor forces


Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	0	8728	0	8728

max. concrete compressive strain: - [%_o]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000): 0 [lb]
 resulting compression force in (x/y)=(0.000/0.000): 0 [lb]



3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_{kt} = N_{ua} / \phi N_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Bond Strength**	N/A	N/A	N/A	N/A
Sustained Tension Load Bond Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Strength**	N/A	N/A	N/A	N/A

* anchor having the highest loading **anchor group (anchors in tension)



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 3
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Area 09
 Date: 5/21/2015

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_v = V_{ua}/\phi V_n$	Status
Steel Strength*	8728	11414	77	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength (Bond Strength controls)**	8728	12865	68	OK
Concrete edge failure in direction x-**	8728	51530	17	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

$V_{sa} = \alpha_{V,seis} (n \cdot 0.6 A_{se,V} f_{uta})$ refer to ICC-ES ESR-2322
 $\phi V_{steel} \geq V_{ua}$ ACI 318-11 Table D.4.1.1

Variables

n	$A_{se,V}$ [in. ²]	f_{uta} [psi]	$\alpha_{V,seis}$	$(n \cdot 0.6 A_{se,V} f_{uta})$ [lb]
1	0.33	125000	0.700	25085

Calculations

$V_{sa,eq}$ [lb]
17560

Results

$V_{sa,eq}$ [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
17560	0.650	11414	8728

4.2 Pryout Strength (Bond Strength controls)

$V_{cp} = k_{cp} \left[\left(\frac{A_{Na}}{A_{Na0}} \right) \psi_{ed,Na} \psi_{p,Na} N_{a0} \right]$ ACI 318-11 Eq. (D-40)
 $\phi V_{cp} \geq V_{ua}$ ACI 318-11 Table (D.4.1.1)
 A_{Na} see ACI 318-11, Part D.5.5.1, Fig. RD.5.5.1(b)
 $A_{Na0} = (2 C_{Na})^2$ ACI 318-11 Eq. (D-20)
 $C_{Na} = 10 d_a \sqrt{\frac{\tau_{uncr}}{1100}}$ ACI 318-11 Eq. (D-21)
 $\psi_{ec,Na} = \left(\frac{1}{1 + \frac{e_N}{C_{Na}}} \right) \leq 1.0$ ACI 318-11 Eq. (D-23)
 $\psi_{ed,Na} = 0.7 + 0.3 \left(\frac{C_{a,min}}{C_{ac}} \right) \leq 1.0$ ACI 318-11 Eq. (D-25)
 $\psi_{cp,Na} = \text{MAX} \left(\frac{C_{a,min}}{C_{ac}}, \frac{C_{Na}}{C_{ac}} \right) \leq 1.0$ ACI 318-11 Eq. (D-27)
 $N_{ba} = \lambda_a \cdot \tau_{k,c} \cdot \alpha_{N,seis} \cdot k_{bond} \cdot \pi \cdot d_a \cdot h_{ef}$ ACI 318-11 Eq. (D-22)

Variables

k_{cp}	$\tau_{k,c,uncr}$ [psi]	d_a [in.]	h_{ef} [in.]	$C_{a,min}$ [in.]	$\tau_{k,c}$ [psi]
2	2065	0.750	6.000	28.000	1000
$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	C_{ac} [in.]	k_{bond}	λ_a	$\alpha_{N,seis}$
0.000	0.000	14.703	1.00	1.000	0.650

Calculations

C_{Na} [in.]	A_{Na} [in. ²]	A_{Na0} [in. ²]	$\psi_{ed,Na}$
10.230	418.58	418.58	1.000
$\psi_{ec1,Na}$	$\psi_{ec2,Na}$	$\psi_{cp,Na}$	N_{ba} [lb]
1.000	1.000	1.000	9189

Results

V_{cp} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	ϕV_{cp} [lb]	V_{ua} [lb]
18378	0.700	1.000	1.000	12865	8728

Input data and results must be checked for agreement with the existing conditions and for plausibility!
 PROFIS Anchor (c) 2003-2009 Hilti AG, FL-9494 Schaan Hilti is a registered Trademark of Hilti AG, Schaan


Profis Anchor 2.5.0
www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

4
 Willamette River WTP
 Area 09
 5/21/2015

4.3 Concrete edge failure in direction x-

$$V_{cb} = \left(\frac{A_{Vc}}{A_{Vcd}} \right) \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{parallel,V} V_b \quad \text{ACI 318-11 Eq. (D-30)}$$

$$\phi V_{cb} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

A_{Vc} see ACI 318-11, Part D.6.2.1, Fig. RD.6.2.1(b)

$$A_{Vcd} = 4.5 C_{a1}^2 \quad \text{ACI 318-11 Eq. (D-32)}$$

$$\psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3C_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-36)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{C_{a2}}{1.5C_{a1}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-38)}$$

$$\psi_{h,V} = \sqrt{\frac{1.5C_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-11 Eq. (D-39)}$$

$$V_b = 9 \lambda_a \sqrt{f'_c} C_{a1}^{1.5} \quad \text{ACI 318-11 Eq. (D-34)}$$

Variables

C_{a1} [in.]	C_{a2} [in.]	e_{cV} [in.]	$\psi_{c,V}$	h_a [in.]
28.000	-	0.000	1.000	8.000
l_a [in.]	λ_a	d_a [in.]	f'_c [psi]	$\psi_{parallel,V}$
6.000	1.000	0.750	4000	2.000

Calculations

A_{Vc} [in. ²]	A_{Vcd} [in. ²]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	V_b [lb]
672.00	3528.00	1.000	1.000	2.291	84335

Results

V_{cb} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	ϕV_{cb} [lb]	V_{ua} [lb]
73614	0.700	1.000	1.000	51530	8728

5 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Design Strengths of adhesive anchor systems are influenced by the cleaning method. Refer to the INSTRUCTIONS FOR USE given in the Evaluation Service Report for cleaning and installation instructions
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-11 Appendix D, Part D.3.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Part D.3.3.4.3 (b), Part D.3.3.4.3 (c), or Part D.3.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Part D.3.3.5.3 (a), Part D.3.3.5.3 (b), or Part D.3.3.5.3 (c).
- Part D.3.3.4.3 (b) / part D.3.3.5.3 (a) requires that the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Part D.3.3.4.3 (c) / part D.3.3.5.3 (b) waives the ductility requirements and requires that the anchors shall be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Part D.3.3.4.3 (d) / part D.3.3.5.3 (c) waives the ductility requirements and requires the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by Ω_0 .
- Installation of Hilti adhesive anchor systems shall be performed by personnel trained to install Hilti adhesive anchors. Reference ACI 318-11, Part D.9.1

Fastening meets the design criteria!



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:


Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

5
 Willamette River WTP
 Area 09
 5/21/2015

6 Installation data

Anchor plate, steel: -
 Profile: no profile; 0.000 x 0.000 x 0.000 in.
 Hole diameter in the fixture: $d_f = 0.813$ in.
 Plate thickness (input): 0.500 in.
 Recommended plate thickness: not calculated
 Cleaning: Premium cleaning of the drilled hole is required

Anchor type and diameter: HIT-RE 500-SD + HAS B7 3/4
 Installation torque: 600.000 in.lb
 Hole diameter in the base material: 0.875 in.
 Hole depth in the base material: 6.000 in.
 Minimum thickness of the base material: 7.750 in.



Coordinates Anchor in.

Anchor	x	y	c _x	c _{1x}	c _y	c _{1y}
1	0.000	0.000	28.000	-	-	-


Profis Anchor 2.5.0
www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 6
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Area 09
 Date: 5/21/2015

7 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.



BY: JAD	DATE: May-15	CLIENT: Tualatin Valley Water District	SHEET: 9865A.00
CHKD BY:		DESCRIPTION: Finished Water Pump Station	JOB NO.:
DESIGN TASK: Weight Estimate			

Building Weight Summary - Finished Water Pump Station (Reference Drawings 13S, 18S, and 19S)

North-South Seismic

Material Properties		pcf	psf	psf	Quantity	Length (ft)	Width/Trib. Height (ft)	Area (ft ²)	Seismic Weight (psf)	Weight, w _i (kip)	Weight, w _i (kip/ft)
Concrete Density	8" Masonry DL	150.0	84.00								
Element	Roof					138.00	27.17	3749.05	15.00	56.24	2.07
	Exterior Conc Walls				2	27.17	13.67	371.29	100.00	74.26	2.73
	Interior Conc Walls				2	27.17	11.00	298.84	100.00	59.77	2.20
										190.26	

East-West Seismic

Material Properties		pcf	psf	psf	Quantity	Length (ft)	Width/Trib. Height (ft)	Area (ft ²)	Seismic Weight (psf)	Weight, w _i (kip)	Weight, w _i (kip/ft)
Concrete Density	8" Masonry DL	150.0	84.00								
Element	Roof					27.17	138.00	3749.05	15.00	56.24	0.41
	West Wall				1	138.00	17.00	2346.00	150.00	351.90	2.55
	East Wall				1	138.00	13.67	1886.05	150.00	282.91	2.05
										691.04	

BY JAD DATE 5/21/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
 CHKD. BY DATE FINISHED WATER P.S. JOB NO. 9865A.00

BUILDING ANALYSIS PER SEC. 5.2.4 (EAST-WEST DIRECTION ONLY)

- EVALUATION OF DIAPHRAGM
- " OF OVERTURNING / SHEAR TRANSFER @ DISCONTINUOUS WALLS
- " OF WALL ANCHORAGE

$$V = C_1 C_2 C_m S_a W$$

$$M_{max} < 2 \quad T < 0.3 \text{ s}$$

$$C_1 C_2 = 1.1 \text{ PER TABLE 7-3}$$

$$C_m = 1.0 \text{ PER TABLE 7-4}$$

$$T_s = S_{x1} / S_{xs} = 0.372 / 0.611 = 0.61$$

$$T_o = 0.120 (0.61) = 0.12$$

$$T_L = 16 \text{ s}$$


$$\beta = 0.02 \quad (\text{NO CLADDING @ THE EXTERIOR}) \quad \beta = 0.05 \quad \left(\begin{array}{l} \text{ASSUMING CONC} \\ \text{WALLS ARE} \\ \text{CLADDING} \end{array} \right)$$

$$S_a = S_{xs} / B_1 \quad (\text{EQ 2-6})$$

$$B_1 = \frac{4}{(5.6 - \ln(100 \times \beta_1))} = \frac{4}{(5.6 - \ln 2)} = 0.815 \quad (1.00)$$

$$\Rightarrow S_a = 0.611 / 0.815 = 0.75 \quad \begin{array}{l} 2\% \text{ DAMPED} \\ 5\% \text{ DAMPED} \end{array}$$

$$V = 1.1 (1.0) (0.75) W = 0.825 W \quad (0.672 W)$$



BY JAD DATE 5/21/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
 CHKD. BY DATE FINISHED WATER P.S. JOB NO. 9865A.00

$$V_{SEIS} = 0.825 (\underset{\substack{\uparrow \\ \text{ROOF}}}{410 \text{ PLF}} + \underset{\substack{\uparrow \\ \text{WEST WALL} \\ (8" \times 12") \\ 17' \text{ TRIB}}}{2,550 \text{ PLF}} + \underset{\substack{\uparrow \\ \text{EAST WALL} \\ (8" \times 12") \\ 13.5' \text{ TRIB}}}{1,688 \text{ PLF}})$$

$$= 4,648 \text{ PLF}$$

$$F_{P1} = \frac{\sum F_i}{\sum W_i} W_x = \frac{V}{W} W_1 = \frac{0.825 W}{W} W_1 = 0.825 W_1$$

$$F_{P1} = 0.825 (4,648 \text{ PLF}) = 3,835 \text{ PLF}$$

$$F_D = (3,835 \text{ PLF})(68 \text{ FT}) = 260,780 \text{ LB}$$

$$F_d = 260,780 \text{ LB} / 2 = 130,390 \text{ LB}$$

$$V_{DIAP} = \frac{(130,390 \text{ LB})}{27.17 \text{ FT}} = 4,800 \text{ PLF}$$

$$Q_{UD} = 4,800 \text{ PLF} \text{ (DEFORMATION CONTROLLED)}$$

$$Q_{UF} = \frac{Q_E}{C_1 C_2 J} = \frac{4,800 \text{ PLF}}{(1.1)(1.0)} = 4,364 \text{ PLF}$$

$$\text{MIX } Q_{CE} > Q_{UD}$$

$$M = 1.25 \quad \chi = 1.0 \text{ (ASSUMING } \frac{1}{2} \text{"} \phi \text{ WELDS @ } 3G/5 \text{ PATTERN AND @ TSW @ } 12 \text{"} \text{ o.c.)}$$

$$1 \frac{1}{2} \text{"} \times 20 \text{ GA VERO DECK (MSB-36) / SPANS @ } 6 \text{'} \text{-} 0 \text{'}$$

$$Q_{CE} = 1.60 (1,069 \text{ PLF}) = 1,710 \text{ PLF}$$

$$(1.25)(1.0)(1,710 \text{ PLF}) = 2,138 \text{ PLF}$$

$$DCR = 4,800 / 2,138 = 2.25 > 1.0 \quad \text{NG}$$

PER UES ER-0217, USE MODIFICATION FACTOR "C" TO OBTAIN STRENGTH LEVEL CAPACITIES FOR LISTED ASD VALUES.

$$\text{PANEL BUCKLING: } C_{\text{BUCKLING}} = 2.00 \times 0.80 = 1.60$$

$$\text{WELD CONNECTIONS: } C_{\text{WELDS}} = 3.00 \times 0.55 = 1.55$$



FSC
www.fsc.org

MIX

Paper from
responsible sources
FSC® C051133

BY JAD DATE 5/21/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
 CHKD. BY DATE FINISHED WATER P.S. JOB NO. 98654.00

$$KQ_{CL} > Q_{UF}$$

$$f_{CL} = (1,091 \text{ LB/WELD})(1.55) = 1,691 \text{ LB/WELD}$$

$$n_{\text{WELDS}} = 5 / 3 \text{ FT} = 1.67 \text{ WELDS/FT}$$

ADJACENT SPAN SHEAR, ↳ @ EACH SIDE OF WALL
 NO DETAIL, BUT PHOTOS SHOW LEDGERS ON EACH SIDE.

$$V_{\text{DIAPHR}} = \frac{(2,857 \text{ PLF})(52 \text{ FT} / 2)}{27.17 \text{ FT}} = 2,734 \text{ PLF}$$

$$Q_{UF \text{ TOT}} = (3,598 \text{ PLF} + 2,734 \text{ PLF})$$

$$Q_{CL} = (1,691 \text{ LB/WELD})(1.67 \text{ WELD/FT})(27.17 \text{ FT}) = 76,718 \text{ LB}$$

$$Q_{UF} = (4,364 \text{ PLF})(27.17 \text{ FT}) = 118,557 \text{ LB}$$

$$DCR = 119.8 / 76.7 = 1.55 > 1.0 \quad \text{NG}$$

⇒ ROOF DIAPHRAGM HAS INSUFFICIENT SHEAR CAPACITY @ BOUNDARIES OF 68' AND 52' SPAN DIAPHRAGMS. ROUGHLY 50% OF THE DIAPHRAGM IS OVERSTRESSED.

CHECK CHORD FORCE,

$$Q_{UD} = \frac{(4,800 \text{ PLF})(68 \text{ FT})^2}{8(27.17 \text{ FT})} = 102,124 \text{ LB}$$

$$Q_{CE} = \phi T_n = (1.0)(4)(0.31 \text{ in}^2)(60 \text{ ksi})(1.25) = 93 \text{ k}$$

$$DCR = 102 / 93 = 1.10 > 1.0 \quad \text{NG}$$

CONNECTIONS @ TALL WINDOWS ARE FORCE-CONTROLLED,

$$\text{HSS } 5 \times 5 \times 3/8$$

$$A_{gt} = 6.18 \text{ in}^2$$

$$F_y = 46 \text{ ksi}$$

⇒ RETROFIT SHOULD ENHANCE OR REPLACE TUBE STL TIES FROM WALL TO WALL FOR CHORD CONTINUITY.



FSC
www.fsc.org

MIX

Paper from
responsible sources
FSC® C051133

BY JAD DATE 5/21/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
CHKD. BY DATE FINISHED WATER PS JOB NO. 9865A.00

CHECK SHEAR TRANSFER TO WALLS FROM DIAPHRAGM,
3/4" ϕ ADHESIVE ANCHORS W/ 6" EMBED @ 2'-0" O.C.
USING $\phi = 1.0$

$$Q_{UF} = (4,364 \text{ PCF})(2 \text{ FT}) = 8,728 \text{ LB}$$

$$Q_{CL} = (2,249 \text{ LB})(1.0) = 2,249 \text{ LB} \quad (\text{CONC EDGE BREAK-OUT})$$

$$DCR = 8728 / 2,249 = 3.9 > 1.0 \text{ NG}$$

EDGE DISTANCE IS ACTUALLY 1.5 IN, WHICH DOES NOT ALLOW FOR DEVELOPMENT OF SHEAR STRENGTH OF DECK OR THE ANCHOR.

⇒ REPLACE EAST-WEST LEDGERS @ INTERIOR WALLS AND REDUCE ANCHOR SPACING.

CHECK SHEAR TRANSFER @ END WALLS,

$$Q_{UF} = 8,728 \text{ LB}$$

$$Q_{CL} = 12,865 \text{ LB}$$

$$DCR = 8728 / 12865 = 0.68 < 1.0 \text{ OK}$$

BY JAD DATE 5/21/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
CHKD. BY DATE FINISHED WATER P.S. JOB NO. 9865A.00

CHECK DISCONTINUOUS SHEAR WALLS:

1) SOUTH INTERIOR WALL

$$Q_{UD} = (4,648 \text{ PLF}) \left(\frac{48 \text{ FT} + 52 \text{ FT}}{2} \right) = 278,880 \text{ LB}$$

ESTIMATE WALL SHEAR CAPACITY (PER ACI 318, CHPT 21)

$$V_n = A_{cv} (\lambda_c \lambda \sqrt{f'_c} + \rho_e f_y)$$

WALL IS 8" THICK x 250" LONG

$$A_{cv} = (8 \text{ in.}) (250 \text{ in.}) = 2,000 \text{ in.}^2$$

$$h_w / h_w = (22 \times 12) / 250 = 1.06 \quad \lambda_c = 3.0$$

$$\lambda = 1.0 \text{ (NORMAL-WT CONC.)}$$

$$f'_{ce} = 4,000 \text{ PSI} \times 1.5 = 6,000 \text{ PSI}$$

TABLE 10-1
ASCE 41-13

$$f_{ye} = 60,000 \text{ PSI} \times 1.25 = 75,000 \text{ PSI}$$

$$\phi = 1.0$$

$$\phi V_n = (2,000 \text{ in.}^2) \left[(0.30)(1.0) \sqrt{6,000 \text{ PSI}} + (0.00323)(75,000 \text{ PSI}) \right] (1.0) = 530,976 \text{ LB}$$


$$\phi V_n = 1,421 \text{ k}$$

ACCEPTANCE CRITERIA FOR SHEAR,

$$M / Q_{CE} = (2.0)(1.0)(531 \text{ k}) = 1,062 \text{ k}$$

$$DCR = 279 / 1,062 = 0.26 < 1.0 \text{ OK}$$

2) CHECK SHEAR TRANSFER TO CONCL DECK



$$p = \frac{(0.88 \text{ in.}^2)(2)}{(12 \text{ in.})(18 \text{ in.})} = 0.00815$$

BY JAD DATE 5/21/15 SUBJECT WILLAMETTE RIVER WTP SHEET NO. OF
CHKD. BY DATE FINISHED WATER P.S. JOB NO. 9865A.00

$$V_n = A_{cv} (2\lambda \sqrt{f'_{ce}} + \rho_b f_{ye})$$
$$\phi V_n = (12 \text{ in.})(18 \text{ in.}) [2 (1.0) \sqrt{6,000 \text{ psi}} + (0.00815)(75,000 \text{ psi})] (1.0)$$
$$= 165 \text{ k/ft} \quad \text{OK}$$



FSC
www.fsc.org

MIX

Paper from
responsible sources
FSC® C051133



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax:
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

1
 Willamette River WTP
 Seismic Evaluation
 5/26/2015

Specifier's comments: Area 09 - Diaphragm shear transfer to interior shear walls

1 Input data

Anchor type and diameter: HIT-HY 200 + HAS B7 3/4

Effective embedment depth: $h_{ef,act} = 8.000$ in. ($h_{ef,limit} = -$ in.)

Material: ASTM A 193 Grade B7

Evaluation Service Report: ESR-3187

Issued | Valid: 5/1/2014 | 3/1/2016

Proof: Design method ACI 318-11 / Chem

Stand-off installation: $e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.

Anchor plate: $l_x \times l_y \times t = 6.000$ in. \times 12.000 in. \times 0.500 in.; (Recommended plate thickness: not calculated)

Profile: no profile

Base material: cracked concrete, 4000, $f'_c = 4000$ psi; $h = 420.000$ in., Temp. short/long: 32/32 °F


Installation: hammer drilled hole, Installation condition: Dry

Reinforcement: tension: condition B, shear: condition A; no supplemental splitting reinforcement present
 edge reinforcement: none or < No. 4 bar

Seismic loads (cat. C, D, E, or F) Tension load: yes (D.3.3.4.3 (a))
 Shear load: yes (D.3.3.5.3 (c))



Geometry [in.] & Loading [lb, in.lb]





Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 2
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Seismic Evaluation
 Date: 5/26/2015

2 Load case/Resulting anchor forces


Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	0	4250	0	4250
2	0	4250	0	4250

max. concrete compressive strain: - [%]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000): 0 [lb]
 resulting compression force in (x/y)=(0.000/0.000): 0 [lb]



3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{ua} / \phi N_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Bond Strength**	N/A	N/A	N/A	N/A
Sustained Tension Load Bond Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Strength**	N/A	N/A	N/A	N/A

* anchor having the highest loading **anchor group (anchors in tension)



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 3
 Project: Willamette River WTP
 Sub-Project | Pos. No.:
 Date: Seismic Evaluation
 5/26/2015

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_v = V_{ua}/\phi V_n$	Status
Steel Strength*	4250	11414	38	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength (Bond Strength controls)**	8500	9890	86	OK
Concrete edge failure in direction x+**	8500	10246	83	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

$$V_{sa} = \alpha_{V,seis} (n \cdot 0.6 A_{se,v} f_{ula}) \quad \text{refer to ICC-ES ESR-3187}$$

$$\phi V_{steel} \geq V_{ua} \quad \text{ACI 318-11 Table D.4.1.1}$$

Variables

n	$A_{se,v}$ [in. ²]	f_{ula} [psi]	$\alpha_{V,seis}$	$(n \cdot 0.6 A_{se,v} f_{ula})$ [lb]
1	0.33	125000	0.700	25085

Calculations

$$\frac{V_{sa,eq} \text{ [lb]}}{17560}$$

Results

$V_{sa,eq}$ [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
17560	0.650	11414	4250

4.2 Pryout Strength (Bond Strength controls)

$$V_{cp} = k_{cp} \left[\left(\frac{A_{Na}}{A_{Na0}} \right) \psi_{ec1,Na} \psi_{ec2,Na} \psi_{ed,Na} \psi_{cp,Na} N_{ba} \right] \quad \text{ACI 318-11 Eq. (D-41)}$$

$$\phi V_{cp} \geq V_{ua} \quad \text{ACI 318-11 Table (D.4.1.1)}$$

A_{Na} see ACI 318-11, Part D.5.5.1, Fig. RD.5.5.1(b)

$$A_{Na0} = (2 C_{Na})^2 \quad \text{ACI 318-11 Eq. (D-20)}$$

$$C_{Na} = 10 d_a \sqrt{\frac{\tau_{uncr}}{1100}} \quad \text{ACI 318-11 Eq. (D-21)}$$

$$\psi_{ec,Na} = \left(\frac{1}{1 + \frac{e_N}{C_{Na}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-23)}$$

$$\psi_{ed,Na} = 0.7 + 0.3 \left(\frac{C_{a,min}}{C_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-25)}$$

$$\psi_{cp,Na} = \text{MAX} \left(\frac{C_{a,min}}{C_{ac}}, \frac{C_{Na}}{C_{ac}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-27)}$$

$$N_{ba} = \lambda_a \cdot \tau_{k,c} \cdot \alpha_{N,seis} \cdot k_{bond} \cdot \pi \cdot d_a \cdot h_{ef} \quad \text{ACI 318-11 Eq. (D-22)}$$

Variables

k_{cp}	$\tau_{k,c,uncr}$ [psi]	d_a [in.]	h_{ef} [in.]	$C_{a,min}$ [in.]	$\tau_{k,c}$ [psi]
2	1880	0.750	8.000	4.000	1062
$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	C_{ac} [in.]	k_{bond}	λ_a	$\alpha_{N,seis}$
0.000	0.000	13.417	1.00	1.000	0.800

Calculations

$$\frac{C_{Na} \text{ [in.]}}{9.760} \quad \frac{A_{Na} \text{ [in.²]} }{204.15} \quad \frac{A_{Na0} \text{ [in.²]} }{381.00} \quad \frac{\psi_{ed,Na}}{0.823}$$

$$\frac{\psi_{ec1,Na}}{1.000} \quad \frac{\psi_{ec2,Na}}{1.000} \quad \frac{\psi_{cp,Na}}{1.000} \quad \frac{N_{ba} \text{ [lb]}}{16020}$$

Results

V_{cp} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{ductile}$	ϕV_{cp} [lb]	V_{ua} [lb]
14128	0.700	1.000	1.000	9890	8500



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

4
 Willamette River WTP
 Seismic Evaluation
 5/26/2015

4.3 Concrete edge failure in direction x+

$$V_{cbg} = \left(\frac{A_{Vc}}{A_{Vc0}} \right) \psi_{ec,V} \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{parallel,V} V_b \quad \text{ACI 318-11 Eq. (D-31)}$$

$$\phi V_{cbg} \geq V_{ua} \quad \text{ACI 310-11 Table D.4.1.1}$$

A_{Vc} see ACI 318-11, Part D.6.2.1, Fig. RD.6.2.1(b)

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-11 Eq. (D-32)}$$

$$\psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-36)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-11 Eq. (D-38)}$$

$$\psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-11 Eq. (D-39)}$$

$$V_b = 9 \lambda_a \sqrt{f_c} c_{a1}^{1.5} \quad \text{ACI 318-11 Eq. (D-34)}$$

Variables

c_{a1} [in.]	c_{a2} [in.]	e_{cV} [in.]	$\psi_{c,V}$	h_a [in.]
4.000	-	0.000	1.000	420.000
l_a [in.]	λ_a	d_a [in.]	f_c [psi]	$\psi_{parallel,V}$
6.000	1.000	0.750	4000	2.000

Calculations

A_{Vc} [in. ²]	A_{Vc0} [in. ²]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	V_b [lb]
108.00	72.00	1.000	1.000	1.000	4554

Results

V_{cbg} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	ϕV_{cbg} [lb]	V_{ua} [lb]
13661	0.750	1.000	1.000	10246	8500

5 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Design Strengths of adhesive anchor systems are influenced by the cleaning method. Refer to the INSTRUCTIONS FOR USE given in the Evaluation Service Report for cleaning and installation instructions
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-11 Appendix D, Part D.3.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Part D.3.3.4.3 (b), Part D.3.3.4.3 (c), or Part D.3.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Part D.3.3.5.3 (a), Part D.3.3.5.3 (b), or Part D.3.3.5.3 (c).
- Part D.3.3.4.3 (b) / part D.3.3.5.3 (a) requires that the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Part D.3.3.4.3 (c) / part D.3.3.5.3 (b) waives the ductility requirements and requires that the anchors shall be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Part D.3.3.4.3 (d) / part D.3.3.5.3 (c) waives the ductility requirements and requires the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by Ω_0 .
- Installation of Hilti adhesive anchor systems shall be performed by personnel trained to install Hilti adhesive anchors. Reference ACI 318-11, Part D.9.1

Fastening meets the design criteria!



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:


Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

5
 Willamette River WTP
 Seismic Evaluation
 5/26/2015

6 Installation data

Anchor plate, steel: -
 Profile: no profile; 0.000 x 0.000 x 0.000 in.
 Hole diameter in the fixture: $d_f = 0.813$ in.
 Plate thickness (input): 0.500 in.
 Recommended plate thickness: not calculated
 Cleaning: Premium cleaning of the drilled hole is required

Anchor type and diameter: HIT-HY 200 + HAS B7 3/4
 Installation torque: 1200.002 in.lb
 Hole diameter in the base material: 0.875 in.
 Hole depth in the base material: 8.000 in.
 Minimum thickness of the base material: 9.750 in.



Coordinates Anchor in.

Anchor	x	y	C-x	C+X	C-y	C+y
1	0.000	-3.000	4.000	4.000	-	-
2	0.000	3.000	4.000	4.000	-	-



Profis Anchor 2.5.0

www.hilti.us

Company: Carollo Engineers
 Specifier: James Doering
 Address:
 Phone | Fax: |
 E-Mail:

Page: 6
 Project: Willamette River WTP
 Sub-Project | Pos. No.: Seismic Evaluation
 Date: 5/26/2015

7 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Area 11 - Sludge Thickener Stair Housing
ASCE 41 Evaluation

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickeneter JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Seismic

SEISMIC HAZARD LEVEL & BASIC PERFORMANCE OBJECTIVE

Note: **4.1.2 Seismic Hazard Level** The Seismic Hazard Level for the Tier 1 screening shall be BSE-1E per Table 2-1 for the Basic Performance Objective for Existing Buildings (BPOE).

Table 2-1. Basic Performance Objective for Existing Buildings (BPOE)

Risk Category	Tier 1*	Tier 2*	Tier 3	
	BSE-1E	BSE-1E	BSE-1E	BSE-2E
I & II	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Collapse Prevention Structural Performance Nonstructural Performance Not Considered (5-D)
III	See footnote b for Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Limited Safety Structural Performance Nonstructural Performance Not Considered (4-D)
IV	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Life Safety Structural Performance Nonstructural Performance Not Considered (3-D)

*For Tier 1 and 2 assessments, seismic performance for the BSE-2E is not explicitly evaluated.
 *For Risk Category III, the Tier 1 screening checklists shall be based on the Life Safety Performance Level (S-3), except that checklist statements using the Quick Check procedures of Section 4.5.3 shall be based on MS-factors and other limits that are an average of the values for Life Safety and Immediate Occupancy.

BUILDING PERIOD (SECTION 4.5.2.4)

building height, $h_n = 10.50$ ft
 building period adjustment factor, $C_t = 0.020$
 effective viscous damping ratio, $\beta = 0.75$
 fundamental building period, $T = 0.117$ sec

SEISMIC PARAMETERS

Building Type = **C2a** Table 3-1
 modification factor, $C = 1.00$ Table 4-8

Table 4-8. Modification Factor, C

Building Type*	Number of Stories			
	1	2	3	≥4
Wood (W1, W1a, W2)	1.3	1.1	1.0	1.0
Moment frame (S1, S3, C1, PC2a)	1.3	1.1	1.0	1.0
Shear wall (S4, S5, C2, C3, PC1a, PC2, RM2, URMa)	1.4	1.2	1.1	1.0
Braced frame (S2)	1.3	1.1	1.0	1.0
Unreinforced masonry (URM)	1.0	1.0	1.0	1.0
Flexible diaphragms (S1a, S2a, S5a, C2a, C3a, PC1, RM1)	1.0	1.0	1.0	1.0

*Defined in Table 3-1.

spectral acceleration at 1-sec for BSE-1E, $S_{x1} = 0.372$ g USGS Seismic Map
 spectral acceleration at short period for BSE-1E, $S_{xs} = 0.611$ g USGS Seismic Map
 spectral acceleration, $S_a = 0.611$ g $S_a = \frac{S_{x1}}{T}$ but S_a shall not exceed S_{xs} .
 base shear coefficient, $V = 0.611$ W Eq 4-1



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Building Weight & Base Shear

DEAD LOAD (Seismic Weight)

Roof Weight

Roofing = 10.00 psf
 Metal Roof Deck = 3.00 psf
 Miscellaneous (MEP) = 7.00 psf

 Total = 20.00 psf

Roof Length = 34.00 ft
 Roof Width = 20.67 ft

 Total Roof Weight = 14.05 kips

	Thick (in)	Trib Ht (ft)	Length (ft)		
Parapet Wall	8.00	2.00	54.67	=	10.93 kips
Wall Below	8.00	5.25	54.67	=	28.70 kips
				Seismic Weight =	53.69 kips

Seismic Weight & Base Shear

Base Shear Coefficient = 0.611 g
 Total Seismic Weight = 54 kips
 Design Base Shear = 33 kips

LIVE LOAD

Roof Live Load = 30.0 psf



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Shear Stress

SEISMIC LOAD VERTICAL DISTRIBUTION

Wall Shear Stress Check

4.5.3.3 Shear Stress in Shear Walls The average shear stress in shear walls, v_j^{avg} , shall be calculated in accordance with Eq. (4-9).

$$v_j^{avg} = \frac{1}{M_s} \left(\frac{V_j}{A_w} \right) \quad (4-9)$$

where V_j = Story shear at level j computed in accordance with Section 4.5.2.2.

A_w = Summation of the horizontal cross-sectional area of all shear walls in the direction of loading. Openings shall be taken into consideration where computing A_w . For masonry walls, the net area shall be used. For wood-framed walls, the length shall be used rather than the area.

M_s = System modification factor; M_s shall be taken from Table 4-9.

$v_{s,allow} = 126$ psi
 $M_s = 3.0$ <-- Damage Control (between "LS" & "IO")

Table 4-9. M_s Factors for Shear Walls


Wall Type	Level of Performance	
	LS	IO
Reinforced concrete, precast concrete, wood, and reinforced masonry	4.0	2.0
Unreinforced masonry	1.5	1.0

Table 4-10. M_s Factors for Diagonal Braces

Brace Type	d/t^2	Level of Performance	
		LS	IO
Tube ^b	$< 90/(F_y)^{1/2}$	6.0	2.5
	$> 190/(F_y)^{1/2}$	3.0	1.5
Pipe ^b	$< 1500/F_{ye}$	6.0	2.5
	$> 6000/F_{ye}$	3.0	1.5
Tension-only		3.0	1.5
All others		6.0	2.5

^aDepth-to-thickness ratio.
^bInterpolation to be used for tubes and pipes.
 $F_{ye} = 1.25F_y$; expected yield stress.

	t_{wall} (in)	$L_{net, wall}$ (ft)	A_{wall} (in ²)	V (kips)	V_{shear} (psi)	
Walls in NS-Dir	8.00	26.67	2560	33.00	4.30	<= OK
Walls in EW-Dir	8.00	32.34	3105	33.00	3.54	<= OK





Engineers...Working Wonders With Water™


BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in North-South Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1
 seismic modification factors, $C_1C_2 = 1.40$ per Table 7-3
 effective mass factor, $C_m = 1.00$ per Table 7-4
 diaphragm shear, m_1 -factor = 1.625 per Table 9-4 (between "IO" & "LS")
 diaphragm chord, m_2 -factor = 3.625 per Table 9-4 (between "IO" & "LS")
 force-delivery reduction factor, $J = 2.00$ per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

spectral acceleration, $S_a = 0.611$ g
 building seismic weight, $W = 35$ kips roof seismic wt for diaph in transverse dir
 pseudo seismic force, $V = F_d = C_1C_2C_mS_aW = 30$ kips



diaph shear, $Q_{UD1} = 2222$ plf Deck 1 shear
 diaph shear, $Q_{UD2} = 667$ plf Deck 2 shear
 diaph shear, $Q_{UD3} = 1250$ plf Deck 1+Deck 2 shear
 diaph shear, $Q_{UD,max} = 2222$ plf
 allowable diaphragm shear = 1110 plf per IAPMO-ER #0217
 conversion factor for strength design, $C_{buckling} = 1.60$ per IAPMO-ER #0217
 diaph shear capacity, $Q_{CE} = 1776$ plf
 $m_1 * K * Q_{CE} = 2886$ plf

Note: Diaph shear capacity from Verco HSB-36 (20GA; 4'-6" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD1} = 7933$ lbs
 chord force, $Q_{UD2} = 720$ lbs
 chord force, $Q_{UD,max} = 7933$ lbs



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in North-South Direction

strength reduction factor, $\phi = 1.00$
 Number of Bars = 2 bars
 Bar Size = #5
 Yield Stress $f_y = 60,000$ psi
 $A_{s,total} = 0.62$ in²
 Tensile Capacity at Opng, $\phi T_n = 37200$ lbs
 $m_2 * K * Q_{CE} = 134850$ lbs

Masonry & Steel Strength (Tier 2 - Force Controlled)


anchor bolt size, $d_b = 0.750$ in
 anchorage spacing, $s = 24.00$ in
 anchor bolt effective embed, $l_b = 3.50$ in
 anchor bolt yield stress, $f_y = 36.00$ ksi
 masonry compressive strength, $f_m = 1500$ psi

anchor bolt shear, $Q_{E1} = 4444$ lbs /bolt
 anchor bolt shear, $Q_{E2} = 1333$ lbs /bolt
 anchor bolt shear, $Q_{E3} = 2500$ lbs /bolt
 $Q_{UF} = Q_{E,max} / (J * C_1 * C_2) = 1587$ lbs /bolt

projected area of anchor bolt shear, $A_{pv} = 38.48$ in² lbs /bolt
 projected area of anchor bolt tension, $A_{pt} = 76.97$ in² lbs /bolt
 cross section area of anchor bolt, $A_b = 0.44$ in² lbs /bolt

strength reduction factor, $\phi = 1.00$
 $KQ_{CL} = K\phi B_{vnb} = K * \phi * 4 * A_{pv} * (f_m)^{0.5} = 5962$ lbs /bolt
 $KQ_{CL} = K\phi B_{vnpry} = K * \phi * 1050 * (f_m * A_b)^{1/4} = 5327$ lbs /bolt
 $KQ_{CL} = K\phi B_{vnpry} = K * \phi * 8 * A_{pt} * (f_m)^{0.5} = 23848$ lbs /bolt
 $KQ_{CL} = K\phi B_{vns} = K * \phi * 0.6 * A_b * f_y = 15904$ lbs /bolt

masonry breakout
 masonry crushing
 anchor bolt pryout
 steel yielding



Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1873	7,442
16	2093	9,310

effective puddle weld diameter = 0.500 in
 puddle weld spacing = 12.00 in



Engineers...Working Wonders With Water™

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in North-South Direction

puddle weld shear, $Q_{E1} =$ 2222 lbs /weld
 puddle weld shear, $Q_{E2} =$ 667 lbs /weld
 puddle weld shear, $Q_{E3} =$ 1250 lbs /weld
 $Q_{UF} = Q_{E,max} / (J * C_1 * C_2) =$ 794 lbs /weld

allowable strength of weld = 1257 lbs /weld
 conversion factor for strength design, $C_{WELD} =$ 1.65 per IAPMO- allowable multiplied by 1.4 for
 $KQ_{CL} =$ 2074 lbs /weld

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.77	<--	<u>OK</u>	diaphragm shear
<u>demand capacity ratio, DCR =</u>	0.06	<--	<u>OK</u>	diaphragm chord
<u>demand capacity ratio, DCR =</u>	0.27	<--	<u>OK</u>	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.30	<--	<u>OK</u>	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.07	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.10	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.38	<--	<u>OK</u>	puddle weld strength




BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in East-West Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1
 seismic modification factors, $C_1 C_2 = 1.40$ per Table 7-3
 effective mass factor, $C_m = 1.00$ per Table 7-4
 diaphragm shear, m_1 -factor = 1.625 per Table 9-4 (between "IO" & "LS")
 diaphragm chord, m_2 -factor = 3.625 per Table 9-4 (between "IO" & "LS")
 force-delivery reduction factor, $J = 2.00$ per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

spectral acceleration, $S_a = 0.611 g$
 building seismic weight, $W = 32$ kips roof seismic wt for diaph in longitudinal dir
 pseudo seismic force, $V = F_d = C_1 C_2 C_m S_a W = 27$ kips



diaph shear, $Q_{UD1} = 628$ plf Deck 1 shear
 diaph shear, $Q_{UD2} = 1039$ plf Deck 2 shear
 diaph shear, $Q_{UD,max} = 1039$ plf
 allowable diaphragm shear = 1110 plf per IAPMO-ER #0217
 conversion factor for strength design, $C_{buckling} = 1.60$ per IAPMO-ER #0217
 diaph shear capacity, $Q_{CE} = 1776$ plf
 $m_1 * K * Q_{CE} = 2886$ plf

Note: Diaph shear capacity from Verco HSB-36 (20GA; 4'-6" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD1} = 705$ lbs
 chord force, $Q_{UD2} = 1940$ lbs
 chord force, $Q_{UD,max} = 1940$ lbs



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in East-West Direction

strength reduction factor, $\phi = 1.00$
 Number of Bars = 2 bars
 Bar Size = #5
 Yield Stress $f_y = 60,000$ psi
 $A_{s,total} = 0.62$ in²
 Tensile Capacity at Opng, $\phi T_n = 37200$ lbs
 $m_2 * K * Q_{CE} = 134850$ lbs


Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, $d_b = 0.750$ in
 anchorage spacing, $s = 24.00$ in
 anchor bolt effective embed, $l_b = 3.50$ in
 anchor bolt yield stress, $f_y = 36.00$ ksi
 masonry compressive strength, $f_m = 1500$ psi

anchor bolt shear, $Q_{E1} = 1256$ lbs /bolt
 anchor bolt shear, $Q_{E2} = 2079$ lbs /bolt
 $Q_{UF} = Q_{E,max} / (J * C_1 * C_2) = 742$ lbs /bolt

projected area of anchor bolt shear, $A_{pv} = 38.48$ in² lbs /bolt
 projected area of anchor bolt tension, $A_{pt} = 76.97$ in² lbs /bolt
 cross section area of anchor bolt, $A_b = 0.44$ in² lbs /bolt

strength reduction factor, $\phi = 1.00$
 $KQ_{CL} = K\phi B_{vnb} = K*\phi*4*A_{pv}*(f'_m)^{0.5} = 5962$ lbs /bolt
 $KQ_{CL} = K\phi B_{vnpry} = K*\phi*1050*(f'_m*A_b)^{1/4} = 5327$ lbs /bolt
 $KQ_{CL} = K\phi B_{vnpry} = K*\phi*8*A_{pt}*(f'_m)^{0.5} = 23848$ lbs /bolt
 $KQ_{CL} = K\phi B_{vns} = K*\phi*0.6*A_b*f_y = 15904$ lbs /bolt



masonry breakout
 masonry crushing
 anchor bolt pryout
 steel yielding

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

effective puddle weld diameter = 0.500 in
 puddle weld spacing = 12.00 in

puddle weld shear, $Q_{E1} = 628$ lbs /weld
 puddle weld shear, $Q_{E2} = 1039$ lbs /weld
 $Q_{UF} = Q_{E,max} / (J * C_1 * C_2) = 371$ lbs /weld



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in East-West Direction

allowable strength of weld = 1257 lbs /weld
 conversion factor for strength design, C_{WELD} = 1.65 per IAPMO- allowable multiplied by 1.4 for
 KQ_{CL} = 2074 lbs /weld

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.36	<--	<u>OK</u>	diaphragm shear
<u>demand capacity ratio, DCR =</u>	0.01	<--	<u>OK</u>	diaphragm chord
<u>demand capacity ratio, DCR =</u>	0.12	<--	<u>OK</u>	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.14	<--	<u>OK</u>	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.03	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.05	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.18	<--	<u>OK</u>	puddle weld strength



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

WALL ANCHORAGE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).



$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$

Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall thickness, t_w = 8.00 in
- wall height to diaphragm, h_w = 10.50 ft
- parapet height, h_p = 2.00 ft
- unit weight of wall, w_p = 150.00 pcf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- anchor bolt spacing = 24.00 in
- wall out-of-plane load = 664 lbs/ ft
- wall anchorage force, T_c = 1329 lbs /bolt

<-- Damage Control (between "LS" & "IO")

Anchor Bolts (Assumed 3.5" Min Embed)



Anchor Bolt Strength Parameters

- anchor bolt diameter, d_a = 0.75 in
- tensile stress area, A_{se} = 0.33 in²
- anchor bolt embed, h_{ef} = 3.50 in minimum embed assumed
- specified anchor bolt strength, f_{uta} = 58,000 psi
- concrete strength, f'_c = 4,000 psi



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

$k_c = 17.00$
 $\lambda = 1.00$
 $N_b = 7,040 \text{ lbs /bolt}$

$A_{Nc} = 110.25 \text{ in}^2$
 $A_{Nco} = 110.25 \text{ in}^2$

$\Psi_{ed,N} = 1.00$
 $\Psi_{c,N} = 1.00$
 $\Psi_{CP,N} = 1.00$

steel strength, $N_{sa} = 19,372 \text{ lbs /bolt}$
 concrete pullout strength, $N_{cb} = 7,040 \text{ lbs /bolt}$
 concrete overstrength factor, $\Omega_{cb} = 2.5$ concrete governed

Ledger Angle

yield strength, $f_y = 36,000 \text{ psi}$
 ledger angle thick, $t = 0.31 \text{ in}$
 moment arm, $l_{arm} = 1.19 \text{ in}$ distance from top of ledger to center of AB
 effective width, $b = 3.00 \text{ in}$
 section modulus, $S = 0.0488 \text{ in}^3$

 shear stress = $1,418 \text{ psi}$

 moment = $1,581 \text{ lb-in}$
 flexural stress = $32,387 \text{ psi}$

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR</u> =	0.07	<--	OK	steel strength
<u>demand capacity ratio, DCR</u> =	0.47	<--	OK	concrete strength
<u>demand capacity ratio, DCR</u> =	0.04	<--	OK	ledger shear
<u>demand capacity ratio, DCR</u> =	0.90	<--	OK	ledger flexural




BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "IO") - Wall Anchorage at Metal Deck

STEEL DECK PROPERTIES (ASTM A653, Grade 33)

Modulus of Elasticity, E = 29500 ksi

Yield Strength, F_y = 38 ksi

Ultimate Strength, F_u = 52 ksi



Steel Deck = HSB-36

Gage = 20

Deck Span, L = 5.67 ft

Gage	Weight		Section Properties per ft (m) of width		
	Galv psf N/m ²	Painted psf N/m ²	I in. ⁴ mm ⁴	+ S in. ³ mm ³	- S in. ³ mm ³
22	1.9	1.8	0.175	0.187	0.198
	91.0	86.2	238,978	10,054	10,645
20	2.3	2.2	0.216	0.235	0.248
	110.1	105.3	294,967	12,634	13,333
18	2.9	2.8	0.302	0.322	0.335
	138.9	134.1	412,408	17,312	18,011
16	3.5	3.4	0.377	0.411	0.417
	167.6	162.8	514,827	22,097	22,419

DESIGN LOAD (Service Level)

Roof Load, w = 30 psf --- steel deck gravity

Wall Out-of-Plane Load, F = 664 lb/ft --- deck axial load

Design Flexural Moment :

Neutral Axis, y_b = 0.919 in

M_{roof} = 1.447 kip-in /ft --- moment due to gravity load = w * L² / 8

M_{ecc} = 0.436 kip-in /ft --- moment due to wall out-of-plane = (F/1.4) * y_b

M_{total} = 1.883 kip-in /ft

ARC-SPOT WELD (WALL OUT-OF-PLANE)

Effective Weld Size Dia, d_e = 1/2 in

Weld Pattern = 5 per 36/sheet

Allowable Weld Capacity = 2.10 kip/ft <= OK

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

Allowable shear strength for 1/2" effective diameter puddle welds.



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 11 - Sludge Thickener JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "IO") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE COMPRESSION

Effective Length Factor, $K = 1.00$
 Deck Thickness, $t = 0.0359$ in
 Width of Top Flange, $w = 3.50$ in
 Gross Section Area, $A_g = 0.599$ in²/ft
 radius of gyration, $r = 0.601$ in
 $KL/r = 113$
 $\lambda_c = 1.29$
 $F_n = 18.85$ ksi

Effective Width of Top & Bottom Flange Under Compression (Assume Bottom Flange Fully Effective)

$\Omega_c = 1.8$ --- factor of safety
 $k = 4$ $k =$ Plate buckling coefficient
 = 4 for stiffened elements supported by a web on each longitudinal edge.
 Values for different types of elements are given in the applicable sections.
 Poisson's Ratio = 0.300
 $F_{cr} = 11.22$
 $\lambda = 1.296$
 $\rho = 0.641$
 Effective Flange Width, $b = 2.242$ in --- effective flange width = ρw
 Effective Section Area, $A_e = 0.554$ in²/ft --- effective section area
 $P_n / \Omega_c = 5.80$ kip /ft **<= OK** --- $A_e * F_n / \Omega_c$

STEEL DECK ALLOWABLE TENSION

Gross Section Area, $A_g = 0.599$ in²/ft
 $\Omega_{T1} = 1.67$
 $T_{n1} / \Omega_{T1} = 13.63$ kip /ft **<= OK** --- $A_g * F_y / \Omega_{T1}$
 $\Omega_{T2} = 2.00$
 $T_{n2} / \Omega_{T2} = 15.57$ kip /ft **<= OK** --- $A_g * F_u / \Omega_{T2}$

STEEL DECK ALLOWABLE BENDING



BY: C. Che **DATE:** Sep-17 **CLIENT:** Wilamette River WTP **SHEET:** _____
CHKD BY: _____ **DESCRIPTION:** Area 11 - Sludge Thickener **JOB NO.:** 10721A.00
DESIGN TASK: ASCE 41 (Tier 1 Screening "IO") - Wall Anchorage at Metal Deck

$\Omega_b = 1.67$

$S_+ = 0.235 \text{ in}^3/\text{ft}$ --- positive section modulus

$M_n / \Omega_b = 5.35 \text{ kip-in /ft} \leq \text{OK}$ --- $S_+ * F_y / \Omega_b$

COMBINED LOAD INTERACTION

Bending-Tension Interaction:


DCR = 0.401 **$\leq \text{OK}$**

Bending-Compression Interaction:

DCR = 0.467 **$\leq \text{OK}$**

Area 11 - Sludge Thickener Concrete Structures
ACI 350 Evaluation

REV	DATE BY	RECORD DRAWING DESCRIPTION	SCALE	WARNING	DESIGNED BY	CHECKED	SUBMITTED BY	LICENSE NO.	DATE
R	12-02	AP	3/8"=1'-0"	IF THIS DRAWING IS NOT TO SCALE	B. CROOK	B. CROOK			



FOUNDATION PLAN

RECORD DRAWING
 This record drawing has been prepared, entirely or in part, by the City of Wilsonville. It is not to be used for any other project without the written consent of the City of Wilsonville. Any use of this drawing for other than the project for which it was prepared is prohibited. The City of Wilsonville is not responsible for any errors or omissions which may have been incorporated into the document as a result.



CITY OF WILSONVILLE
 WILLAMETTE RIVER WATER TREATMENT PLANT
 SLOUGH STRUCTURAL
 FOUNDATION PLAN

SHEET
 11S-01


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures

Static, Seismic, and Hydrodynamic Seismic Wall Pressures using ACI 350.3-06 and an IBC 2012:

wall connection fixity = **pinned at roof & fixed at floor**

tank unit width perpendicular to EQ., B = 1 ft
 tank inside length in direction of seismic, L = 18.5 ft
 tank wall thickness, t_w = 12 inch
 wall height to underside of roof, H_w = 16 ft

liquid height, H_L = 14 ft
 liquid specific gravity = 1
 liquid density, $\gamma_L = (\text{sp.gr.}) \cdot \gamma_w = 0.0624$ k/ft³
 acceleration due to gravity, g = 32.17 ft/sec²
 liquid mass density, $\rho_L = \gamma_L / g = 0.00194$ k-sec²/ft⁴



WALL SECTION

(wall fixity = pinned at roof & fixed at floor)

Soil Data

The site has no groundwater.


soil height above top of foundation base = 15 ft
 groundwater ht. above foundation base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 saturated soil lateral pressure = 0 k/ft³
 dry soil unit weight = 0.11 k/ft³
 live load lateral surcharge = 0.100 ksf

concrete strength, f'_c = 4 ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, $\rho_c = \gamma_c / g = 0.004663$ k-sec²/ft⁴

Seismic:

Deisgn, 5% damped, spectral response acceleration at the short period of 0.2-second, $S_{DS} = 0.611$ *g
 Deisgn, 5% damped, spectral response acceleration at a period of 1-second, $S_{D1} = 0.656$ *g

Structure Risk Category = 3
 Importance factor, I = 1.25
 Response modification factor, $R_{wi} = 2.72$
 Response modification factor, $R_{wc} = 1.27$



WALL PLAN

Load Cases:

- case 1 = water
- case 2 = water + water seismic + wall seismic
- case 3 = soil + lateral surcharge
- case 4 = soil + soil seismic + wall seismic

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures

Weights:

$$\begin{aligned} \text{unit 1-ft width wall mass, } W_w &= (12/12) * (16) * 0.15 = 2.40 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 16 / 2 = 8.000 \text{ ft} \end{aligned}$$

$$\text{unit width liquid mass, } W_L = (18.5) * (1) * (14) * 32.17 = 16.16 \text{ kip}$$

Seismic:

1). structure stiffness and dynamic property:


Note: per ASCE 7-10 and IBC 2012, the terms S_{ai} and S_{ac} have been appropriately substituted into the seismic equation of ACI 350.

Note: W_i and h_i are impulsive component variables calculated on page 3.

$$\text{wall mass, } m_w = H_w * (t_w / 12) * \rho_c = 0.07460 \text{ k-sec}^2/\text{ft}^2$$

$$\text{liquid mass, } m_i = (W_i / W_L) * (L/2) * H_L * \rho_L = 0.17907 \text{ k-sec}^2/\text{ft}^2$$

$$\text{centroidal distance of masses, } h = (h_w * m_w + h_i * m_i) / (m_w + m_i) = 6.07 \text{ ft}$$



wall fixity condition is pinned at roof & fixed at floor:

wall stiffness is determined using a unit mass load located at the centroidal distance h .

$$\text{wall flexure stiffness, } k = Ec * (tw * Hw / h)^3 / (12 * (4 * Hw - h) * (Hw - h)^2) = 1664.41 \text{ k/ft/ft}$$

$$\omega_i = \sqrt{\frac{k}{m_w + m_i}} = (1664.41 / (0.0746 + 0.1791))^{1/2} = 81.0018 \text{ rad/sec}$$

$$\text{period of tank plus impulsive mass, } T_i = 2\pi / \omega_i = 2\pi / 81.0018 = 0.0776 \text{ sec}$$

(note: acceleration values to be from a maximum considered earthquake response spectra which will produce a factored load)

$$\text{design factored spectral response acceleration for impulsive mass (5\% damping), } S_{ai} = S_{DS} = 0.611 \text{ g}$$

2). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$\lambda = \sqrt{3.16 \text{ g} \tanh\left(3.16 \left(\frac{H_L}{L}\right)\right)} = (3.16 * 32.2 * \tanh(3.16 * (0.7568)))^{1/2} = 9.9984$$

$$\omega_c = \frac{\lambda}{\sqrt{L}} = 9.9984 / (18.5)^{1/2} = 2.3246 \text{ rad/sec,}$$


$$\text{period of the convective mass, } T_c = 2\pi / \omega_c = 2\pi / 2.3246 = 2.7029 \text{ sec}$$

$$\text{Long transition period (from map figure 22-15 ASCE 7), } T_L = 16 \text{ sec}$$

$$\text{design spectral response acceleration for convective mass (0.5\% damping), } S_{ac} = 1.5 * Sd1 / Tc = 0.364 \text{ g}$$

$$\text{effective mass coeff., } \varepsilon = 0.0151 \left(\frac{L}{H_L}\right)^2 - 0.1908 \left(\frac{L}{H_L}\right) + 1.021, \text{ but } \leq 1.0 = 0.7952$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures



$L = 18.5$ ft
 $B = 1$ ft
 $H_L = 14$ ft
 $W_L = 16.16$ kip

$L / H_L = 1.32143$
 $H_L / L = 0.75676$

3). lateral fluid impulsive force: Dynamic Model

W_i = equivalent mass of the impulsive component of liquid.

$$W_i = W_L \left(\frac{\tanh\left(0.866 \frac{L}{H_L}\right)}{0.866 \frac{L}{H_L}} \right) = 16.16 * (\tanh(0.866 * (1.3214)) / 0.866 * (1.3214)) = 11.52 \text{ kip}$$

$$h_i \text{ (EBP)} = H_L * (0.5 - 0.09375 * (L/H_L)) = 14 * (0.5 - 0.09375 * (1.3214)) = 5.266 \text{ ft}$$

$$h_i \text{ (IBP)} = H_L * \left\{ \left(\frac{0.866 * L / H_L}{2 * \tanh(0.866 * L / H_L)} \right) - 1/8 \right\} = 8.068 \text{ ft}$$

$$\text{impulsive force, } P_i = \left(\frac{S_{ai} I}{R_{wi}} \right) W_i = (0.611 * 1.25 / 2.72) * 11.52 = 3.2 \text{ kip}$$

4). lateral fluid convective force:

W_c = equivalent mass of the convective component of liquid.

$$W_c = W_L \left(0.264 \left(\frac{L}{H_L} \right) \tanh \left(3.16 \left(\frac{H_L}{L} \right) \right) \right) = 16.16 * (0.264 * (1.3214) * \tanh(3.16 * (0.7568))) = 5.54 \text{ kip}$$

$$h_c \text{ (EBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 1}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 9.127 \text{ ft}$$

$$h_c \text{ (IBP)} = H_L \left(1 - \frac{\cosh\left(3.16 \left(\frac{H_L}{L}\right)\right) - 2.01}{3.16 \left(\frac{H_L}{L}\right) \sinh\left(3.16 \left(\frac{H_L}{L}\right)\right)} \right) = 10.218 \text{ ft}$$

$$\text{convective force, } P_c = \left(\frac{S_{ac} I}{R_{wc}} \right) W_c = (0.3641 * 1.25 / 1.27) * 5.54 = 2.0 \text{ kip}$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures

5). lateral inertia force of the accelerating wall:

unit width wall mass, $W_w = 2.40$ kip
 wall c.g. relative to base, $h_w = 8.000$ ft

$$\text{wall inertia force, } P_w = \left(\frac{S_{ai} I \varepsilon}{R_{wi}} \right) W_w = (0.611 * 1.25 * 0.7952 / 2.72) * 2.4 = 0.54 \text{ kip}$$

6). maximum wave slosh height displacement:

$$d_{(max)} = \left(\frac{L}{2} \right) \left(\frac{S_{ac}}{1.4} I \right) = (18.5 / 2) * (0.3641 / 1.4 * 1.25) = 3.01 \text{ ft}$$

Wave height is greater than the freeboard of 2-ft. Check possible effects on the roof.


7). vertical acceleration:

design horizontal acceleration, $S_{DS} = 0.611$ *g
 vertical spectral response acceleration (per ACI 350 para 9.4.3), $S_{av} = C_i = 0.4 * S_{DS} = 0.2444$ g

per ASCE 7-10 para. 15.7.7.2(b), use $I = R_i = b = 1.0$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.2444 * 1 * 1 / 1 = 0.2444 \text{ g}$$

8). vertical force distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive:

$$P_i = \frac{P_i \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_i = 3.20$ kip
 $h_i = 5.266$ ft
 at $y = H_L$, $p_{iy} = 0.029$ ksf
 at base $y = 0$, $p_{iy} = 0.199$ ksf

convective:

$$P_c = \frac{P_c \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{2 B H_L^2} =$$

$P_c = 2.00$ kip
 $h_c = 9.127$ ft
 at $y = H_L$, $p_{cy} = 0.137$ ksf
 at base $y = 0$, $p_{cy} = 0.006$ ksf

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures

vertical acceleration:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

$\ddot{u} = 0.2444$
 at $y = H_L$, $p_{vy} = 0.000$ ksf
 at base $y = 0$, $p_{vy} = 0.214$ ksf

wall inertia:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w/12)}{R_{wi}} =$$

$p_{wy} = 0.2233 * \gamma_c * (t_w/12)$
 at $y = H_w$, $p_{wy} = 0.033$ ksf
 at base $y = 0$, $p_{wy} = 0.033$ ksf

hydrostatic:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0.000$ ksf
 at base $y = 0$, $q_{hy} = 0.874$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_y + p_{wy})^2 + p_{cy}^2 + p_w^2} =$$




at $y = H_w$, $p_y = 0.150$ ksf
 at base $y = 0$, $p_y = 0.316$ ksf



resultant dynamic pressures

9). wall design pressures for hydrostatic + dynamic:


wall height, $H_w = 16$ ft
 liquid height, $H_L = 14$ ft



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures

10). wall design pressures for external soil loading:


static soil:



The site has no groundwater.

wall height = 16 ft
 soil height above top of base = 15 ft
 groundwater ht. above base = 0 ft
 dry soil lateral pressure = 0.055 k/ft³
 sat. soil lateral pressure = 0.000 k/ft³
 live load lateral surcharge = 0.100 ksf

equivalent static soil loadings:



LL lateral surcharge, q1 = 0.1000 ksf
 unfactored soil, q2 = 0.8250 ksf
 unfactored soil, q3 = 0.0000 ksf

equivalent soil loadings:


unfactored q5 = 0.1000 ksf
 unfactored q6 = 0.8250 ksf

soil seismic:


resultant factored soil seismic load per foot of wall width, $P_{u(eq)}$ = **3.825** k/ft

centroid location of the resultant soil seismic from the bottom of wall, h_{eq} = **10** ft

The resultant soil seismic load will be resolved into an equivalent pressure loading...



Equivalent factored seismic soil pressure loading & seismic wall loadings...




equivalent soil seismic, q8 = 0.0000 ksf
 equivalent soil seismic, q9 = 0.5100 ksf
 wall seismic (see wall page 5), q10 = 0.0335 ksf
 equivalent soil seismic, q11 = q9 = 0.5100 ksf
 equivalent soil seismic, q12 = q8 - q9 = -0.5100 ksf

unfactored equivalent soil seismic, q8 = 0 / 1.4 = 0.0000 ksf
 unfactored equivalent soil seismic, q9 = 0.51 / 1.4 = 0.3643 ksf
 unfactored wall seismic, q10 = 0.0335 / 1.4 = 0.0239 ksf
 unfactored equivalent soil seismic, q11 = 0.51 / 1.4 = 0.3643 ksf
 unfactored equivalent soil seismic, q12 = -0.51 / 1.4 = -0.3643 ksf


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Wall Pressures

11). Summary of equivalent unfactored pressure loadings for wall load cases 1 thru 4:




Load Cases:
 case 1 = water
 case 2 = water + water seismic + wall seismic
 case 3 = soil + lateral surcharge
 case 4 = soil + soil seismic + wall seismic

a). load case 1: hydrostatic water



wall height = 16 ft
 water depth = 14 ft


b). load case 2: hydrostatic + dynamic:



c). load case 3: static soil + LL surcharge:

wall height = 16 ft
 soil height on wall = 15 ft

equivalent static soil & surcharge loadings...




LL lateral surcharge, q1 = 0.100 ksf
 unfactored soil, q2 = 0.825 ksf
 unfactored soil, q3 = 0.000 ksf

equivalent soil loadings:
 unfactored q5 = 0.100 ksf
 unfactored q6 = 0.825 ksf

d). load case 4: soil seismic: (*note: add static soil pressure q6 & q7 to the seismic soil shown below)
 equivalent seismic soil pressure loading & seismic wall loadings...

wall height = 16 ft
 soil height on wall = 15 ft




unfactored equivalent soil seismic, q8 = 0.000 ksf
 unfactored equivalent soil seismic, q9 = 0.364 ksf
 unfactored equivalent soil seismic, q10 = 0.024 ksf
 unfactored equivalent soil seismic, q11 = 0.364 ksf
 unfactored equivalent soil seismic, q12 = -0.364 ksf


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: North Exterior Wall - Soil EQ

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **1**
 total plate width = $2 * a = 2 * 14.5 = 29$ ft
 plate dimension, a = **14.5** ft
 plate dimension, b = **17** ft
 plate sides ratio, a/b = 0.8529



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , M , or F (ksf, ft-k/ft, k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	15.000	0.825	1.6	1.6
B	100	15.000	0.364	1.4	1.4
C	400	15.000	-0.364	1.4	1.4
D	1		0.025	1.4	1.4

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **14** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00300**
 minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	11"	3"
My bending	11.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: North Exterior Wall - Soil EQ

M _x - Moment Summary													
a = 14.5 b = 17 a / b = 0.8529		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.825	0.364	-0.364	0.025					Final Moments		Reinforcing: (d = 11")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		238.425	105.196	-105.196	7.225								
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0350	0.1466	0.0350	0.2141	8.35	15.42	-3.68	1.55	21.63	31.95	0.68	0.44
0	0.8	0.0367	0.1327	0.0367	0.1815	8.74	13.96	-3.86	1.31	20.16	29.97	0.63	0.44
0	0.6	0.0360	0.1105	0.0360	0.1366	8.58	11.62	-3.78	0.99	17.40	26.08	0.55	0.44
0	0.4	0.0302	0.0755	0.0302	0.0853	7.19	7.95	-3.17	0.62	12.58	19.05	0.40	0.44
0	0.2	0.0143	0.0281	0.0143	0.0298	3.41	2.96	-1.50	0.22	5.08	7.79	0.16	0.25
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25
0.2	0	0.0032	0.0053	0.0032	0.0054	0.76	0.56	-0.33	0.04	1.02	1.58	0.03	0.25
0.4	0	0.0068	0.0136	0.0068	0.0147	1.63	1.43	-0.72	0.11	2.45	3.75	0.08	0.25
0.6	0	0.0096	0.0208	0.0096	0.0232	2.29	2.19	-1.01	0.17	3.63	5.55	0.11	0.25
0.8	0	0.0112	0.0254	0.0112	0.0288	2.68	2.67	-1.18	0.21	4.37	6.66	0.14	0.25
1	0	0.0118	0.0269	0.0118	0.0307	2.81	2.83	-1.24	0.22	4.62	7.03	0.14	0.25
1	0.2	-0.0019	-0.0023	-0.0019	-0.0018	-0.46	-0.24	0.20	-0.01	-0.52	-0.82	-0.02	-0.25
1	0.4	-0.0110	-0.0290	-0.0110	-0.0335	-2.62	-3.05	1.16	-0.24	-4.75	-7.18	-0.15	-0.25
1	0.6	-0.0152	-0.0474	-0.0152	-0.0591	-3.62	-4.99	1.60	-0.43	-7.43	-11.13	-0.23	-0.30
1	0.8	-0.0167	-0.0579	-0.0167	-0.0776	-3.98	-6.09	1.75	-0.56	-8.87	-13.21	-0.27	-0.36
1	1	-0.0177	-0.0657	-0.0177	-0.0911	-4.22	-6.91	1.86	-0.66	-9.93	-14.75	-0.30	-0.41
0.8	1	-0.0158	-0.0594	-0.0158	-0.0827	-3.77	-6.25	1.66	-0.60	-8.95	-13.28	-0.27	-0.36
0.8	0.8	-0.0151	-0.0526	-0.0151	-0.0705	-3.60	-5.53	1.59	-0.51	-8.05	-11.99	-0.25	-0.33
0.8	0.6	-0.0141	-0.0436	-0.0141	-0.0540	-3.36	-4.59	1.48	-0.39	-6.86	-10.27	-0.21	-0.28
0.8	0.4	-0.0105	-0.0272	-0.0105	-0.0310	-2.51	-2.86	1.11	-0.22	-4.48	-6.78	-0.14	-0.25
0.8	0.2	-0.0021	-0.0024	-0.0021	-0.0018	-0.50	-0.25	0.22	-0.01	-0.55	-0.87	-0.02	-0.25

max negative moment, M_{ux}(-) = -14.75 ft-k/ft

max negative steel req'd, A_s(-) = -0.30 in²/ft

minimum steel req'd = -0.41 in²/ft

Use #8@12" (Existing)

max positive moment, M_{ux}(+) = 31.95 ft-k/ft

max positive steel req'd, A_s(+) = 0.68 in²/ft

minimum steel req'd = 0.44 in²/ft

Use #8@6" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: North Exterior Wall - Soil EQ

M _y - Moment Summary													
a = 14.5 b = 17 a / b = 0.8529		Loads: q, M, or F				Boundary Case 1				SUMMARY			
		0.825	0.364	-0.364	0.025					Final Moments		Reinforcing: (d = 11.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		238.425	105.196	-105.196	7.225								
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25
0	0.8	0.0074	0.0265	0.0074	0.0363	1.75	2.79	-0.77	0.26	4.03	5.99	0.12	0.25
0	0.6	0.0072	0.0221	0.0072	0.0273	1.72	2.32	-0.76	0.20	3.48	5.21	0.10	0.25
0	0.4	0.0060	0.0151	0.0060	0.0170	1.44	1.59	-0.64	0.12	2.52	3.82	0.07	0.25
0	0.2	0.0029	0.0056	0.0029	0.0060	0.69	0.59	-0.30	0.04	1.02	1.57	0.03	0.25
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25
0.2	0	0.0159	0.0267	0.0159	0.0272	3.78	2.81	-1.67	0.20	5.12	7.92	0.15	0.25
0.4	0	0.0342	0.0681	0.0342	0.0737	8.15	7.16	-3.60	0.53	12.25	18.78	0.37	0.46
0.6	0	0.0479	0.1039	0.0479	0.1160	11.43	10.94	-5.04	0.84	18.16	27.71	0.56	0.46
0.8	0	0.0561	0.1269	0.0561	0.1440	13.37	13.35	-5.90	1.04	21.86	33.28	0.67	0.46
1	0	0.0588	0.1347	0.0588	0.1536	14.01	14.17	-6.18	1.11	23.11	35.16	0.71	0.46
1	0.2	0.0044	0.0308	0.0044	0.0434	1.06	3.24	-0.47	0.31	4.14	6.01	0.12	0.25
1	0.4	-0.0136	-0.0180	-0.0136	-0.0080	-3.23	-1.90	1.43	-0.06	-3.76	-5.91	-0.12	-0.25
1	0.6	-0.0124	-0.0296	-0.0124	-0.0257	-2.95	-3.11	1.30	-0.19	-4.95	-7.52	-0.15	-0.25
1	0.8	-0.0056	-0.0174	-0.0056	-0.0218	-1.34	-1.83	0.59	-0.16	-2.74	-4.10	-0.08	-0.25
1	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25
1	0.4	-0.0136	-0.0180	-0.0136	-0.0080	-3.23	-1.90	1.43	-0.06	-3.76	-5.91	-0.12	-0.25
0.8	0.4	-0.0131	-0.0174	-0.0131	-0.0077	-3.12	-1.83	1.38	-0.06	-3.63	-5.70	-0.11	-0.25
0.6	0.4	-0.0114	-0.0149	-0.0114	-0.0063	-2.72	-1.57	1.20	-0.05	-3.14	-4.94	-0.10	-0.25
0.4	0.4	-0.0081	-0.0096	-0.0081	-0.0027	-1.92	-1.01	0.85	-0.02	-2.10	-3.32	-0.06	-0.25
0.2	0.4	-0.0021	0.0003	-0.0021	0.0047	-0.51	0.03	0.23	0.03	-0.22	-0.41	-0.01	-0.25

max negative moment, M_{uy}(-) = -7.52 ft-k/ft

max negative steel req'd, A_s(-) = -0.15 in²/ft

minimum steel req'd = -0.25 in²/ft

Use #5@12" (Existing)

max positive moment, M_{uy}(+) = 35.16 ft-k/ft

max positive steel req'd, A_s(+) = 0.71 in²/ft

minimum steel req'd = 0.46 in²/ft

Use #6@6" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: North Exterior Wall - Soil EQ

Shear Summary												
a = 14.5 b = 17 a / b = 0.8529		Loads: q, M, or F				Boundary Case 1				SUMMARY		
		0.825	0.364	-0.364	0.025					Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		14.025	6.188	-6.188	0.425							
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	0.0815	0.5876	0.0815	1.0039	1.14	3.64	-0.50	0.43	4.70	6.81	13.09
0	0.8	0.1587	0.6077	0.1587	0.8663	2.23	3.76	-0.98	0.37	5.37	7.97	13.09
0	0.6	0.1887	0.5637	0.1887	0.6208	2.65	3.49	-1.17	0.26	5.23	7.85	13.09
0	0.4	0.2253	0.4546	0.2253	0.4291	3.16	2.81	-1.39	0.18	4.76	7.30	13.09
0	0.2	0.1295	0.1184	0.1295	0.0877	1.82	0.73	-0.80	0.04	1.78	2.86	13.09
0	0.00	-0.0151	-0.0726	-0.0151	-0.0814	-0.21	-0.45	0.09	-0.03	-0.60	-0.89	13.09
0.2	0	0.1510	0.1259	0.1510	0.0950	2.12	0.78	-0.93	0.04	2.00	3.23	13.09
0.4	0	0.2793	0.3924	0.2793	0.3830	3.92	2.43	-1.73	0.16	4.78	7.48	13.09
0.6	0	0.3480	0.5705	0.3480	0.5911	4.88	3.53	-2.15	0.25	6.51	10.09	13.09
0.8	0	0.3815	0.6680	0.3815	0.7103	5.35	4.13	-2.36	0.30	7.43	11.47	13.09
1	0	0.3915	0.6988	0.3915	0.7487	5.49	4.32	-2.42	0.32	7.71	11.89	13.09

Concrete strength reduction factor for shear, φ = 0.75

d = 11.5 in

maximum shear, V_u = 11.89 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 11.5) / 1000 = 13.09 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrostatic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 12.84 = 25.68$ ft
 plate dimension, a = **12.84** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.8025



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	14.000	0.874	2.25	1.4
B					
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00300**
 minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrostatic

M _x - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.874								Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000				0.00				0.00	0.00	0.00	0.22
0	0.8	0.0137				3.07				3.07	6.91	0.17	0.23
0	0.6	0.0239				5.35				5.35	12.05	0.31	0.36
0	0.4	0.0256				5.72				5.72	12.87	0.33	0.36
0	0.2	0.0137				3.08				3.08	6.92	0.17	0.23
0	0	0.0000				0.00				0.00	0.00	0.00	0.22
0.2	0	0.0029				0.64				0.64	1.44	0.04	0.22
0.4	0	0.0059				1.31				1.31	2.96	0.07	0.22
0.6	0	0.0079				1.76				1.76	3.97	0.10	0.22
0.8	0	0.0090				2.02				2.02	4.55	0.11	0.22
1	0	0.0094				2.09				2.09	4.71	0.12	0.22
1	0.2	-0.0026				-0.58				-0.58	-1.30	-0.03	-0.22
1	0.4	-0.0088				-1.98				-1.98	-4.44	-0.11	-0.22
1	0.6	-0.0091				-2.05				-2.05	-4.60	-0.11	-0.22
1	0.8	-0.0055				-1.22				-1.22	-2.75	-0.07	-0.22
1	1	0.0000				0.00				0.00	0.00	0.00	0.22
0.8	1	0.0000				0.00				0.00	0.00	0.00	0.22
0.8	0.8	-0.0053				-1.19				-1.19	-2.67	-0.07	-0.22
0.8	0.6	-0.0089				-2.00				-2.00	-4.49	-0.11	-0.22
0.8	0.4	-0.0087				-1.96				-1.96	-4.40	-0.11	-0.22
0.8	0.2	-0.0027				-0.61				-0.61	-1.37	-0.03	-0.22

max negative moment, M_{ux}(-) = -4.60 ft-k/ft

max negative steel req'd, A_s(-) = -0.11 in²/ft

minimum steel req'd = -0.22 in²/ft

Use #6@12" (Existing)

max positive moment, M_{ux}(+) = 12.87 ft-k/ft

max positive steel req'd, A_s(+) = 0.33 in²/ft

minimum steel req'd = 0.36 in²/ft

Use #6@12" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrostatic

M _y - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.874								Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000				0.00				0.00	0.00	0.00	0.22
0	0.8	0.0027				0.61				0.61	1.37	0.03	0.22
0	0.6	0.0048				1.06				1.06	2.39	0.06	0.22
0	0.4	0.0051				1.14				1.14	2.55	0.06	0.22
0	0.2	0.0028				0.62				0.62	1.39	0.03	0.22
0	0	0.0000				0.00				0.00	0.00	0.00	0.22
0.2	0	0.0142				3.18				3.18	7.15	0.17	0.23
0.4	0	0.0292				6.54				6.54	14.72	0.35	0.38
0.6	0	0.0395				8.84				8.84	19.88	0.48	0.38
0.8	0	0.0450				10.08				10.08	22.68	0.55	0.38
1	0	0.0468				10.47				10.47	23.55	0.58	0.38
1	0.2	-0.0028				-0.63				-0.63	-1.43	-0.03	-0.22
1	0.4	-0.0184				-4.11				-4.11	-9.24	-0.22	-0.29
1	0.6	-0.0162				-3.62				-3.62	-8.14	-0.19	-0.26
1	0.8	-0.0085				-1.89				-1.89	-4.26	-0.10	-0.22
1	1	0.0000				0.00				0.00	0.00	0.00	0.22
1	0.4	-0.0184				-4.11				-4.11	-9.24	-0.22	-0.29
0.8	0.4	-0.0175				-3.92				-3.92	-8.82	-0.21	-0.28
0.6	0.4	-0.0150				-3.36				-3.36	-7.56	-0.18	-0.24
0.4	0.4	-0.0104				-2.33				-2.33	-5.25	-0.12	-0.22
0.2	0.4	-0.0035				-0.77				-0.77	-1.74	-0.04	-0.22

max negative moment, M_{uy}(-) = -9.24 ft-k/ft

max negative steel req'd, A_s(-) = -0.22 in²/ft

minimum steel req'd = -0.29 in²/ft

Use #7@12" (Existing)

max positive moment, M_{uy}(+) = 23.55 ft-k/ft

max positive steel req'd, A_s(+) = 0.58 in²/ft

minimum steel req'd = 0.38 in²/ft

Use #7@12" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrostatic

Shear Summary												
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V	V _u	φV _c
x/a	y/b	A	B	C	D	A	B	C	D	k/ft	k/ft	k/ft
0	1	-0.0532				-0.74				-0.74	-1.04	10.81
0	0.8	0.0858				1.20				1.20	1.68	10.81
0	0.6	0.1725				2.41				2.41	3.38	10.81
0	0.4	0.2308				3.23				3.23	4.52	10.81
0	0.2	0.1451				2.03				2.03	2.84	10.81
0	0.00	-0.0104				-0.14				-0.14	-0.20	10.81
0.2	0	0.1546				2.16				2.16	3.03	10.81
0.4	0	0.2733				3.82				3.82	5.35	10.81
0.6	0	0.3295				4.61				4.61	6.45	10.81
0.8	0	0.3535				4.94				4.94	6.92	10.81
1	0	0.3600				5.03				5.03	7.05	10.81
0.2	1	-0.0232				-0.32				-0.32	-0.45	10.81
0.4	1	0.0321				0.45				0.45	0.63	10.81
0.6	1	0.0607				0.85				0.85	1.19	10.81
0.8	1	0.0737				1.03				1.03	1.44	10.81
1	1	0.0773				1.08				1.08	1.51	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 7.05 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrodynamic

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 12.84 = 25.68$ ft
 plate dimension, a = **12.84** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.8025



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	14.000	0.874	1.2	1.2
B	100	14.000	0.107	1.4	1.4
C	400	14.000	0.119	1.4	1.4
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in
 concrete strength, f 'c = **4** ksi
 reinforcing steel strength, fy = **60** ksi
 reinforcing clear cover to face of concrete = **2** in
 number of curtains of reinforcing, (1 or 2) = **2**
 Are bars in "x" or "y" direction closest to face of concrete ? **y**
 minimum ratio of horizontal shrinkage-temperature steel = **0.00300**
 minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrodynamic

M _x - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.874	0.107	0.119						Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
0	0.8	0.0137	0.0404	0.0137		3.07	1.11	0.42		4.60	5.82	0.15	0.22
0	0.6	0.0239	0.0636	0.0239		5.35	1.74	0.73		7.82	9.88	0.25	0.33
0	0.4	0.0256	0.0575	0.0256		5.72	1.58	0.78		8.07	10.16	0.26	0.34
0	0.2	0.0137	0.0252	0.0137		3.08	0.69	0.42		4.18	5.24	0.13	0.22
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
0.2	0	0.0029	0.0046	0.0029		0.64	0.13	0.09		0.85	1.06	0.03	0.22
0.4	0	0.0059	0.0105	0.0059		1.31	0.29	0.18		1.78	2.23	0.06	0.22
0.6	0	0.0079	0.0150	0.0079		1.76	0.41	0.24		2.42	3.03	0.08	0.22
0.8	0	0.0090	0.0176	0.0090		2.02	0.48	0.28		2.78	3.49	0.09	0.22
1	0	0.0094	0.0185	0.0094		2.09	0.51	0.28		2.88	3.62	0.09	0.22
1	0.2	-0.0026	-0.0041	-0.0026		-0.58	-0.11	-0.08		-0.77	-0.96	-0.02	-0.22
1	0.4	-0.0088	-0.0204	-0.0088		-1.98	-0.56	-0.27		-2.80	-3.53	-0.09	-0.22
1	0.6	-0.0091	-0.0244	-0.0091		-2.05	-0.67	-0.28		-2.99	-3.78	-0.09	-0.22
1	0.8	-0.0055	-0.0159	-0.0055		-1.22	-0.44	-0.17		-1.82	-2.31	-0.06	-0.22
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
0.8	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
0.8	0.8	-0.0053	-0.0154	-0.0053		-1.19	-0.42	-0.16		-1.77	-2.24	-0.06	-0.22
0.8	0.6	-0.0089	-0.0238	-0.0089		-2.00	-0.65	-0.27		-2.92	-3.69	-0.09	-0.22
0.8	0.4	-0.0087	-0.0201	-0.0087		-1.96	-0.55	-0.27		-2.77	-3.49	-0.09	-0.22
0.8	0.2	-0.0027	-0.0044	-0.0027		-0.61	-0.12	-0.08		-0.82	-1.02	-0.03	-0.22

max negative moment, M_{ux}(-) = -3.78 ft-k/ft

max negative steel req'd, A_s(-) = -0.09 in²/ft

minimum steel req'd = -0.22 in²/ft

Use #6@12" (Existing)

max positive moment, M_{ux}(+) = 10.16 ft-k/ft

max positive steel req'd, A_s(+) = 0.26 in²/ft

minimum steel req'd = 0.34 in²/ft

Use #6@12" (Existing)



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrodynamic

M _y - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.874	0.107	0.119						Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
0	0.8	0.0027	0.0081	0.0027		0.61	0.22	0.08		0.91	1.15	0.03	0.22
0	0.6	0.0048	0.0127	0.0048		1.06	0.35	0.14		1.56	1.97	0.05	0.22
0	0.4	0.0051	0.0115	0.0051		1.14	0.31	0.15		1.60	2.02	0.05	0.22
0	0.2	0.0028	0.0050	0.0028		0.62	0.14	0.08		0.84	1.05	0.02	0.22
0	0	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
0.2	0	0.0142	0.0244	0.0142		3.18	0.67	0.43		4.28	5.36	0.13	0.22
0.4	0	0.0292	0.0528	0.0292		6.54	1.45	0.89		8.88	11.12	0.27	0.35
0.6	0	0.0395	0.0752	0.0395		8.84	2.06	1.20		12.10	15.17	0.37	0.38
0.8	0	0.0450	0.0881	0.0450		10.08	2.41	1.37		13.86	17.39	0.42	0.38
1	0	0.0468	0.0922	0.0468		10.47	2.53	1.42		14.42	18.09	0.44	0.38
1	0.2	-0.0028	0.0035	-0.0028		-0.63	0.10	-0.09		-0.62	-0.75	-0.02	-0.22
1	0.4	-0.0184	-0.0385	-0.0184		-4.11	-1.05	-0.56		-5.72	-7.19	-0.17	-0.23
1	0.6	-0.0162	-0.0467	-0.0162		-3.62	-1.28	-0.49		-5.39	-6.82	-0.16	-0.22
1	0.8	-0.0085	-0.0294	-0.0085		-1.89	-0.81	-0.26		-2.96	-3.76	-0.09	-0.22
1	1	0.0000	0.0000	0.0000		0.00	0.00	0.00		0.00	0.00	0.00	0.22
1	0.4	-0.0184	-0.0385	-0.0184		-4.11	-1.05	-0.56		-5.72	-7.19	-0.17	-0.23
0.8	0.4	-0.0175	-0.0367	-0.0175		-3.92	-1.00	-0.53		-5.46	-6.86	-0.16	-0.22
0.6	0.4	-0.0150	-0.0310	-0.0150		-3.36	-0.85	-0.46		-4.67	-5.87	-0.14	-0.22
0.4	0.4	-0.0104	-0.0209	-0.0104		-2.33	-0.57	-0.32		-3.23	-4.05	-0.10	-0.22
0.2	0.4	-0.0035	-0.0062	-0.0035		-0.77	-0.17	-0.11		-1.05	-1.31	-0.03	-0.22

max negative moment, M_{uy}(-) = -7.19 ft-k/ft

max negative steel req'd, A_s(-) = -0.17 in²/ft

minimum steel req'd = -0.23 in²/ft

Use #7@12" (Existing)

max positive moment, M_{uy}(+) = 18.09 ft-k/ft

max positive steel req'd, A_s(+) = 0.44 in²/ft

minimum steel req'd = 0.38 in²/ft

Use #7@12" (Existing)



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Hydrodynamic

Shear Summary												
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		x / a	y / b	A	B	C	D	A	B	C	D	V k/ft
		0.874	0.107	0.119								
		13.984	1.712	1.904								
		Shear Coefficients				Shears, k/ft						
0	1	-0.0532	-0.1388	-0.0532		-0.74	-0.24	-0.10		-1.08	-1.37	10.81
0	0.8	0.0858	0.3107	0.0858		1.20	0.53	0.16		1.89	2.41	10.81
0	0.6	0.1725	0.5117	0.1725		2.41	0.88	0.33		3.62	4.58	10.81
0	0.4	0.2308	0.4845	0.2308		3.23	0.83	0.44		4.50	5.65	10.81
0	0.2	0.1451	0.1788	0.1451		2.03	0.31	0.28		2.61	3.25	10.81
0	0.00	-0.0104	-0.0541	-0.0104		-0.14	-0.09	-0.02		-0.26	-0.33	10.81
0.2	0	0.1546	0.1660	0.1546		2.16	0.28	0.29		2.74	3.41	10.81
0.4	0	0.2733	0.3910	0.2733		3.82	0.67	0.52		5.01	6.25	10.81
0.6	0	0.3295	0.5150	0.3295		4.61	0.88	0.63		6.12	7.64	10.81
0.8	0	0.3535	0.5727	0.3535		4.94	0.98	0.67		6.60	8.25	10.81
1	0	0.3600	0.5892	0.3600		5.03	1.01	0.69		6.73	8.41	10.81
0.2	1	-0.0232	-0.0006	-0.0232		-0.32	0.00	-0.04		-0.37	-0.45	10.81
0.4	1	0.0321	0.1600	0.0321		0.45	0.27	0.06		0.78	1.01	10.81
0.6	1	0.0607	0.2379	0.0607		0.85	0.41	0.12		1.37	1.75	10.81
0.8	1	0.0737	0.2718	0.0737		1.03	0.47	0.14		1.64	2.08	10.81
1	1	0.0773	0.2812	0.0773		1.08	0.48	0.15		1.71	2.18	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 8.41 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil Static

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 12.84 = 25.68$ ft
 plate dimension, a = **12.84** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.8025



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	15.000	0.825	2.25	1.6
B	100	15.000	0.100	2.25	1.6
C					
D					

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00300**

minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil Static

M _x - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.825	0.100							Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		211.200	25.600										
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
0	0.8	0.0160	0.0449			3.37	1.15			4.52	10.18	0.26	0.34
0	0.6	0.0271	0.0671			5.72	1.72			7.44	16.74	0.43	0.36
0	0.4	0.0279	0.0590			5.89	1.51			7.40	16.65	0.43	0.36
0	0.2	0.0145	0.0255			3.07	0.65			3.72	8.37	0.21	0.28
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
0.2	0	0.0030	0.0046			0.63	0.12			0.75	1.68	0.04	0.22
0.4	0	0.0062	0.0107			1.31	0.27			1.58	3.56	0.09	0.22
0.6	0	0.0084	0.0153			1.77	0.39			2.16	4.86	0.12	0.22
0.8	0	0.0097	0.0180			2.04	0.46			2.50	5.63	0.14	0.22
1	0	0.0100	0.0189			2.11	0.48			2.60	5.84	0.15	0.22
1	0.2	-0.0027	-0.0041			-0.56	-0.11			-0.67	-1.51	-0.04	-0.22
1	0.4	-0.0097	-0.0210			-2.04	-0.54			-2.58	-5.81	-0.15	-0.22
1	0.6	-0.0104	-0.0257			-2.19	-0.66			-2.85	-6.41	-0.16	-0.22
1	0.8	-0.0063	-0.0176			-1.34	-0.45			-1.79	-4.03	-0.10	-0.22
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
0.8	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
0.8	0.8	-0.0062	-0.0171			-1.30	-0.44			-1.74	-3.91	-0.10	-0.22
0.8	0.6	-0.0101	-0.0251			-2.14	-0.64			-2.78	-6.26	-0.16	-0.22
0.8	0.4	-0.0096	-0.0206			-2.02	-0.53			-2.55	-5.74	-0.14	-0.22
0.8	0.2	-0.0028	-0.0044			-0.60	-0.11			-0.71	-1.60	-0.04	-0.22

max negative moment, M_{ux}(-) = -6.41 ft-k/ft

max negative steel req'd, A_s(-) = -0.16 in²/ft

minimum steel req'd = -0.22 in²/ft

Use #6@12" (Existing)

max positive moment, M_{ux}(+) = 16.74 ft-k/ft

max positive steel req'd, A_s(+) = 0.43 in²/ft

minimum steel req'd = 0.36 in²/ft

Use #6@12" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil Static

M _y - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.825	0.100							Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		211.200	25.600										
		Moment Coefficients											
x / a	y / b	A	B	C	D	A	B	C	D	M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
0	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
0	0.8	0.0032	0.0090			0.67	0.23			0.90	2.02	0.05	0.22
0	0.6	0.0054	0.0134			1.14	0.34			1.48	3.34	0.08	0.22
0	0.4	0.0055	0.0118			1.17	0.30			1.47	3.31	0.08	0.22
0	0.2	0.0029	0.0051			0.61	0.13			0.74	1.67	0.04	0.22
0	0	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
0.2	0	0.0148	0.0241			3.13	0.62			3.74	8.42	0.20	0.27
0.4	0	0.0308	0.0536			6.51	1.37			7.89	17.74	0.43	0.38
0.6	0	0.0420	0.0767			8.87	1.96			10.83	24.38	0.60	0.38
0.8	0	0.0481	0.0900			10.17	2.31			12.47	28.06	0.69	0.38
1	0	0.0500	0.0943			10.57	2.41			12.98	29.21	0.72	0.38
1	0.2	-0.0022	0.0045			-0.47	0.12			-0.35	-0.79	-0.02	-0.22
1	0.4	-0.0197	-0.0384			-4.16	-0.98			-5.15	-11.58	-0.28	-0.37
1	0.6	-0.0187	-0.0492			-3.94	-1.26			-5.20	-11.70	-0.28	-0.37
1	0.8	-0.0104	-0.0346			-2.19	-0.89			-3.07	-6.91	-0.16	-0.22
1	1	0.0000	0.0000			0.00	0.00			0.00	0.00	0.00	0.22
1	0.4	-0.0197	-0.0384			-4.16	-0.98			-5.15	-11.58	-0.28	-0.37
0.8	0.4	-0.0188	-0.0366			-3.97	-0.94			-4.91	-11.04	-0.26	-0.35
0.6	0.4	-0.0161	-0.0308			-3.39	-0.79			-4.18	-9.40	-0.22	-0.30
0.4	0.4	-0.0111	-0.0205			-2.34	-0.53			-2.87	-6.45	-0.15	-0.22
0.2	0.4	-0.0036	-0.0057			-0.76	-0.15			-0.91	-2.04	-0.05	-0.22

max negative moment, M_{uy}(-) = -11.70 ft-k/ft

max negative steel req'd, A_s(-) = -0.28 in²/ft

minimum steel req'd = -0.37 in²/ft

Use #7@12" (Existing)

max positive moment, M_{uy}(+) = 29.21 ft-k/ft

max positive steel req'd, A_s(+) = 0.72 in²/ft

minimum steel req'd = 0.38 in²/ft

Use #7@12" (Existing)
 DCR = 0.72 / (0.6 / 0.9) = 1.08



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil Static

Shear Summary												
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY		
		Shear Coefficient Multipliers								Final Shears		
		Shear Coefficients				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		x/a	y/b	A	B	C	D	A	B			
0	1	-0.0616	-0.1465			-0.81	-0.23			-1.05	-1.68	10.81
0	0.8	0.1066	0.3754			1.41	0.60			2.01	3.21	10.81
0	0.6	0.2004	0.5354			2.65	0.86			3.50	5.60	10.81
0	0.4	0.2474	0.4831			3.27	0.77			4.04	6.46	10.81
0	0.2	0.1462	0.1756			1.93	0.28			2.21	3.54	10.81
0	0.00	-0.0134	-0.0555			-0.18	-0.09			-0.27	-0.43	10.81
0.2	0	0.1546	0.1630			2.04	0.26			2.30	3.68	10.81
0.4	0	0.2806	0.3916			3.70	0.63			4.33	6.93	10.81
0.6	0	0.3419	0.5194			4.51	0.83			5.34	8.55	10.81
0.8	0	0.3684	0.5796			4.86	0.93			5.79	9.26	10.81
1	0	0.3757	0.5968			4.96	0.95			5.91	9.46	10.81
0.2	1	-0.0231	0.0284			-0.30	0.05			-0.26	-0.42	10.81
0.4	1	0.0411	0.2053			0.54	0.33			0.87	1.39	10.81
0.6	1	0.0737	0.2891			0.97	0.46			1.44	2.30	10.81
0.8	1	0.0883	0.3253			1.17	0.52			1.69	2.70	10.81
1	1	0.0925	0.3352			1.22	0.54			1.76	2.81	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 9.46 k/ft

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

OK

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation


Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil EQ

Rectangular Plate:

plate boundary condition case number (1, 2, 3, 4, or 5) = **2**
 total plate width = $2 * a = 2 * 12.84 = 25.68$ ft
 plate dimension, a = **12.84** ft
 plate dimension, b = **16** ft
 plate sides ratio, a/b = 0.8025



Available Loading Selections - (loads 1 thru 9 , 100 , or 400)



Choice of Available Loadings					
load conditions (4 max)	load type	load height, (ft)	unfactored loads: q , or M (ksf, ft-k/ft)	concrete load factors	
	Loading Selection Number	...only for custom loads 100 or 400		for moment	for shear
A	400	15.000	0.825	1.6	1.6
B	100	15.000	0.364	1.4	1.4
C	400	15.000	-0.364	1.4	1.4
D	1		0.025	1.4	1.4

- Notes: 1). Load 100 = uniform load of any load height $\geq b/3$; Load 400 = triangular load of any load height $\geq b/6$.
 2). load height must be less than or equal to "b", and uniform load height $\geq b / 3$, and triangular load height $\geq b / 6$.
 3). loads may be positive or negative.

plate thickness, h = **12** in

concrete strength, f 'c = **4** ksi

reinforcing steel strength, fy = **60** ksi

reinforcing clear cover to face of concrete = **2** in

number of curtains of reinforcing, (1 or 2) = **2**

Are bars in "x" or "y" direction closest to face of concrete ? **y**

minimum ratio of horizontal shrinkage-temperature steel = **0.00300**

minimum ratio of vertical shrinkage-temperature steel = **0.00300**

bar locations	d (in)	d' (in)
Mx bending	9"	3"
My bending	9.5"	2.5"



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil EQ

M _x - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.825	0.364	-0.364	0.025					Final Moments		Reinforcing: (d = 9")	
		Moment Coefficient Multipliers				M _x Moments, ft-k/ft				M _x ft-k/ft	M _{ux} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
0	0.8	0.0160	0.0449	0.0160	0.0493	3.37	4.18	-1.49	0.32	6.38	9.61	0.24	0.32
0	0.6	0.0271	0.0671	0.0271	0.0701	5.72	6.26	-2.53	0.45	9.90	15.01	0.38	0.36
0	0.4	0.0279	0.0590	0.0279	0.0597	5.89	5.50	-2.60	0.38	9.17	14.02	0.36	0.36
0	0.2	0.0145	0.0255	0.0145	0.0255	3.07	2.37	-1.35	0.16	4.25	6.57	0.16	0.22
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
0.2	0	0.0030	0.0046	0.0030	0.0046	0.63	0.43	-0.28	0.03	0.81	1.26	0.03	0.22
0.4	0	0.0062	0.0107	0.0062	0.0107	1.31	0.99	-0.58	0.07	1.79	2.77	0.07	0.22
0.6	0	0.0084	0.0153	0.0084	0.0155	1.77	1.43	-0.78	0.10	2.52	3.88	0.10	0.22
0.8	0	0.0097	0.0180	0.0097	0.0182	2.04	1.68	-0.90	0.12	2.94	4.52	0.11	0.22
1	0	0.0100	0.0189	0.0100	0.0191	2.11	1.76	-0.93	0.12	3.06	4.71	0.12	0.22
1	0.2	-0.0027	-0.0041	-0.0027	-0.0041	-0.56	-0.39	0.25	-0.03	-0.73	-1.13	-0.03	-0.22
1	0.4	-0.0097	-0.0210	-0.0097	-0.0214	-2.04	-1.96	0.90	-0.14	-3.24	-4.94	-0.12	-0.22
1	0.6	-0.0104	-0.0257	-0.0104	-0.0269	-2.19	-2.40	0.97	-0.17	-3.79	-5.75	-0.14	-0.22
1	0.8	-0.0063	-0.0176	-0.0063	-0.0193	-1.34	-1.64	0.59	-0.12	-2.51	-3.78	-0.09	-0.22
1	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
0.8	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
0.8	0.8	-0.0062	-0.0171	-0.0062	-0.0187	-1.30	-1.59	0.57	-0.12	-2.44	-3.67	-0.09	-0.22
0.8	0.6	-0.0101	-0.0251	-0.0101	-0.0262	-2.14	-2.34	0.94	-0.17	-3.70	-5.61	-0.14	-0.22
0.8	0.4	-0.0096	-0.0206	-0.0096	-0.0209	-2.02	-1.92	0.89	-0.13	-3.19	-4.86	-0.12	-0.22
0.8	0.2	-0.0028	-0.0044	-0.0028	-0.0044	-0.60	-0.41	0.26	-0.03	-0.78	-1.21	-0.03	-0.22

max negative moment, M_{ux}(-) = -5.75 ft-k/ft

max negative steel req'd, A_s(-) = -0.14 in²/ft

minimum steel req'd = -0.22 in²/ft

Use #6@12" (Existing)

max positive moment, M_{ux}(+) = 15.01 ft-k/ft

max positive steel req'd, A_s(+) = 0.38 in²/ft

minimum steel req'd = 0.36 in²/ft

Use #6@12" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil EQ

M _y - Moment Summary													
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY			
		0.825	0.364	-0.364	0.025					Final Moments		Reinforcing: (d = 9.5")	
		Moment Coefficient Multipliers				M _y Moments, ft-k/ft				M _y ft-k/ft	M _{uy} ft-k/ft	A _{s(req'd)} in ² /ft	A _{s(min)} in ² /ft
		Moment Coefficients				A	B	C	D				
x / a	y / b	A	B	C	D	A	B	C	D				
0	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
0	0.8	0.0032	0.0090	0.0032	0.0099	0.67	0.84	-0.30	0.06	1.27	1.92	0.04	0.22
0	0.6	0.0054	0.0134	0.0054	0.0140	1.14	1.25	-0.50	0.09	1.98	3.00	0.07	0.22
0	0.4	0.0055	0.0118	0.0055	0.0120	1.17	1.10	-0.52	0.08	1.83	2.80	0.07	0.22
0	0.2	0.0029	0.0051	0.0029	0.0051	0.61	0.47	-0.27	0.03	0.85	1.31	0.03	0.22
0	0	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
0.2	0	0.0148	0.0241	0.0148	0.0233	3.13	2.25	-1.38	0.15	4.14	6.42	0.15	0.22
0.4	0	0.0308	0.0536	0.0308	0.0538	6.51	4.99	-2.87	0.34	8.98	13.87	0.33	0.38
0.6	0	0.0420	0.0767	0.0420	0.0774	8.87	7.14	-3.91	0.50	12.60	19.41	0.47	0.38
0.8	0	0.0481	0.0900	0.0481	0.0911	10.17	8.39	-4.49	0.58	14.65	22.55	0.55	0.38
1	0	0.0500	0.0943	0.0500	0.0955	10.57	8.79	-4.66	0.61	15.31	23.54	0.58	0.38
1	0.2	-0.0022	0.0045	-0.0022	0.0055	-0.47	0.42	0.21	0.03	0.19	0.18	0.00	0.22
1	0.4	-0.0197	-0.0384	-0.0197	-0.0377	-4.16	-3.58	1.84	-0.24	-6.15	-9.44	-0.22	-0.30
1	0.6	-0.0187	-0.0492	-0.0187	-0.0512	-3.94	-4.58	1.74	-0.33	-7.11	-10.74	-0.26	-0.34
1	0.8	-0.0104	-0.0346	-0.0104	-0.0401	-2.19	-3.22	0.96	-0.26	-4.70	-7.02	-0.17	-0.22
1	1	0.0000	0.0000	0.0000	0.0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22
1	0.4	-0.0197	-0.0384	-0.0197	-0.0377	-4.16	-3.58	1.84	-0.24	-6.15	-9.44	-0.22	-0.30
0.8	0.4	-0.0188	-0.0366	-0.0188	-0.0358	-3.97	-3.41	1.75	-0.23	-5.85	-8.99	-0.21	-0.29
0.6	0.4	-0.0161	-0.0308	-0.0161	-0.0300	-3.39	-2.87	1.50	-0.19	-4.96	-7.62	-0.18	-0.24
0.4	0.4	-0.0111	-0.0205	-0.0111	-0.0197	-2.34	-1.91	1.03	-0.13	-3.35	-5.16	-0.12	-0.22
0.2	0.4	-0.0036	-0.0057	-0.0036	-0.0051	-0.76	-0.53	0.33	-0.03	-0.99	-1.54	-0.04	-0.22

max negative moment, M_{uy}(-) = -10.74 ft-k/ft

max negative steel req'd, A_s(-) = -0.26 in²/ft

minimum steel req'd = -0.34 in²/ft

Use #7@12" (Existing)

max positive moment, M_{uy}(+) = 23.54 ft-k/ft

max positive steel req'd, A_s(+) = 0.58 in²/ft

minimum steel req'd = 0.38 in²/ft

Use #7@12" (Existing)



BY: C. Che DATE: Aug-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: South Exterior Wall - Soil EQ

Shear Summary												
a = 12.84 b = 16 a / b = 0.8025		Loads: q, or M				Boundary Case 2				SUMMARY		
		0.825	0.364	-0.364	0.025					Final Shears		
		Shear Coefficient Multipliers				Shears, k/ft				V k/ft	V _u k/ft	φV _c k/ft
		13.200	5.824	-5.824	0.400							
		Shear Coefficients										
x / a	y / b	A	B	C	D	A	B	C	D			
0	1	-0.0616	-0.1465	-0.0616	-0.1528	-0.81	-0.85	0.36	-0.06	-1.37	-2.08	10.81
0	0.8	0.1066	0.3754	0.1066	0.4464	1.41	2.19	-0.62	0.18	3.15	4.69	10.81
0	0.6	0.2004	0.5354	0.2004	0.5528	2.65	3.12	-1.17	0.22	4.82	7.27	10.81
0	0.4	0.2474	0.4831	0.2474	0.4726	3.27	2.81	-1.44	0.19	4.83	7.41	10.81
0	0.2	0.1462	0.1756	0.1462	0.1718	1.93	1.02	-0.85	0.07	2.17	3.42	10.81
0	0.00	-0.0134	-0.0555	-0.0134	-0.0558	-0.18	-0.32	0.08	-0.02	-0.44	-0.66	10.81
0.2	0	0.1546	0.1630	0.1546	0.1596	2.04	0.95	-0.90	0.06	2.15	3.42	10.81
0.4	0	0.2806	0.3916	0.2806	0.3894	3.70	2.28	-1.63	0.16	4.51	7.05	10.81
0.6	0	0.3419	0.5194	0.3419	0.5196	4.51	3.03	-1.99	0.21	5.75	8.96	10.81
0.8	0	0.3684	0.5796	0.3684	0.5816	4.86	3.38	-2.15	0.23	6.33	9.83	10.81
1	0	0.3757	0.5968	0.3757	0.5994	4.96	3.48	-2.19	0.24	6.49	10.07	10.81
0.2	1	-0.0231	0.0284	-0.0231	0.0631	-0.30	0.17	0.13	0.03	0.02	-0.03	10.81
0.4	1	0.0411	0.2053	0.0411	0.2562	0.54	1.20	-0.24	0.10	1.60	2.35	10.81
0.6	1	0.0737	0.2891	0.0737	0.3457	0.97	1.68	-0.43	0.14	2.37	3.51	10.81
0.8	1	0.0883	0.3253	0.0883	0.3839	1.17	1.89	-0.51	0.15	2.70	4.01	10.81
1	1	0.0925	0.3352	0.0925	0.3943	1.22	1.95	-0.54	0.16	2.79	4.15	10.81

Concrete strength reduction factor for shear, φ = 0.75

d = 9.5 in

maximum shear, V_u = 10.07 k/ft

OK

$$\phi V_c = \phi * 2 * (f'c)^{1/2} * b * d = (0.75 * 2 * (4000)^{1/2} * 12 * 9.5) / 1000 = 10.81 \text{ k/ft}$$

Reference:

"Moments and Reactions for Rectangular Plates"
 Engineering Monograph No. 27
 By: W. T. Moody, United States Bureau of Reclamation

Notes:

Quadratic interpolation is used for intermediate values within the Moody tables and between Moody figures.
 The positive sign convention for moments M_x and M_y is tension on the loaded face of the plate.
 The M_x moment is in the direction of the x-axis and the M_y moment is in the direction of the y-axis by plate sign convention.


BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

Hydrostatic and Hydrodynamic Seismic Analysis of a Circular Tank per ASCE 7-10 and the 2012 IBC code:

Does groundwater exist in which to consider buoyancy? **No Groundwater**

tank inside diameter, D =	35	ft	(Note: Response spectra values shall be strength level.)
tank inside radius, R =	17.5	ft	tank wall mass, W _w =
tank wall thickness, t _w =	12	inch	231.9
tank wall height to underside of roof =	13.67	ft	kip
roof thickness =	0	inch	wall c.g. relative to base, h _w =
misc roof weights included with seismic =	0	ksf	6.835
			ft
			tank roof weight =
			0.0
			kip
			total misc roof weight =
			0.0
			kip
			total roof mass, W _r =
			0.0
			kip
			roof c.g. relative to base, h _r =
			0.000
			ft
liquid height, H _L =	12	ft	liquid mass, W _L = πR ² * H _L * γ _L =
liquid specific gravity =	1		720.4
liquid density, γ _L = (sp.gr.)*γ _w =	0.0624	k/ft ³	kip
acceleration due to gravity, g =	32.17	ft/sec ²	
liquid mass density, ρ _L = γ _L / g =	0.00194	k-sec ² /ft ⁴	

concrete strength, f'_c = **4** ksi
 concrete density, γ_c = 0.150 k/ft³
 concrete modulus of elasticity, E_c = 3605.0 ksi
 concrete mass density, ρ_c = γ_c / g = 0.00466 k-sec²/ft⁴



tank inside diameter, D = 35 ft

Seismic:
 Structure Risk Category = **3**
 Importance factor, I = **1.25**
 Response modification factor, R_i = **2**
 Response modification factor, R_c = **1.5**
 (acceleration values from a maximum considered earthquake)
 Design, 5% damped, spectral response acceleration at the short period of 0.2-second, S_{DS} = **0.611** *g
 Design, 5% damped, spectral response acceleration at a period of 1-second, S_{D1} = **0.656** *g

1). Dynamic properties, Spectral amplification factors, and Effective mass coefficient:

$$C_w = 0.09375 + 0.2039 \left(\frac{H_L}{D} \right) - 0.1034 \left(\frac{H_L}{D} \right)^2 - 0.1253 \left(\frac{H_L}{D} \right)^3 + 0.1267 \left(\frac{H_L}{D} \right)^4 - 0.03186 \left(\frac{H_L}{D} \right)^5 = 0.14805$$

$$C_1 = C_w * 10 * \left(\frac{t_w}{12} / R \right)^{1/2} = 0.1481 * 10 * (12/12/17.5)^{1/2} = 0.3539$$

$$\omega_1 = C_1 * 12 / H_L * (E_c / \rho_c)^{1/2} = 0.3539 * 12 / 12 * (3605 / 0.00466)^{1/2} = 311.1948 \text{ rad/sec}$$

$$\text{impulsive period of oscillation, } T_1 = 2\pi / \omega_1 = 2\pi / 311.1948 = 0.0202 \text{ sec}$$

design factored spectral response acceleration for impulsive mass (5% damping), S_{ai} = S_{DS} = 0.611 g

$$\lambda = \sqrt{3.68 \text{ g} \tanh \left(3.68 \left(\frac{H_L}{D} \right) \right)} = (3.68 * 32.17 * \tanh(3.68 * (12/35)))^{1/2} = 10.0404$$

convective circular frequency, $\omega_c = \frac{\lambda}{\sqrt{D}} = 10.0404 / (35)^{1/2} = 1.6971 \text{ rad/sec}$


convective period of sloshing, T_c = 2π / ω_c = 2π / 1.6971 = 3.7022 sec

Long transition period (from map figure 22-12 ASCE 7), T_L = **16** sec.

design spectral response acceleration for convective mass (0.5% damping), S_{ac} = 1.5 * S_{d1} / T_c = 0.2658 g

effective mass coeff., ε = 0.0151 $\left(\frac{D}{H_L} \right)^2 - 0.1908 \left(\frac{D}{H_L} \right) + 1.021$, but ≤ 1.0 = 0.5930

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case



D = 35 ft
 HL = 12 ft
 WL = 720.4 kip
 D / HL = 2.91667
 HL / D = 0.34286

Dynamic Model

2). lateral fluid impulsive force:

equivalent impulsive mass component, $W_i = W_L \left(\frac{\tanh\left(0.866 \frac{D}{H_L}\right)}{0.866 \frac{D}{H_L}} \right) = 281.6 \text{ kip}$

height above base to the impulsive lateral force, $h_i \text{ (EBP)} = H_L * 0.375 = 4.5 \text{ ft}$
 $h_i \text{ (IBP)} = H_L * \left\{ \frac{(0.866 * D / H_L)}{(2 * \tanh(0.866 * D / H_L))} - 1/8 \right\} = 13.850 \text{ ft}$

impulsive force, $P_i = \left(\frac{S_{ai} I}{R_i} \right) W_i = (0.611 * 1.25 / 2) * 281.6 = 107.5 \text{ kip}$

impulsive force moment excluding bottom pressure, $M_{i(EBP)} = P_i * h_{i(EBP)} = 107.5 * 4.5 = 483.8 \text{ ft-k}$
 impulsive force moment including bottom pressure, $M_{i(IBP)} = P_i * h_{i(IBP)} = 107.5 * 13.85 = 1488.9 \text{ ft-k}$

3). lateral fluid convective force:

equivalent convective mass component, $W_c = W_L \left(0.23 \left(\frac{D}{H_L} \right) \tanh\left(3.68 \left(\frac{H_L}{D} \right) \right) \right) = 411.5 \text{ kip}$

height above base to convective lateral force, $h_{c(EBP)} = H_L \left(1 - \frac{\cosh\left(3.68 \left(\frac{H_L}{D} \right) \right) - 1}{3.68 \left(\frac{H_L}{D} \right) \sinh\left(3.68 \left(\frac{H_L}{D} \right) \right)} \right) = 6.687 \text{ ft}$

$h_{c(IBP)} = H_L \left(1 - \frac{\cosh\left(3.68 \left(\frac{H_L}{D} \right) \right) - 2.01}{3.68 \left(\frac{H_L}{D} \right) \sinh\left(3.68 \left(\frac{H_L}{D} \right) \right)} \right) = 12.601 \text{ ft}$

convective force, $P_c = \left(\frac{S_{ac} I}{R_c} \right) W_c = (0.2658 * 1.25 / 1.5) * 411.5 = 91.1 \text{ kip}$

convective force moment excluding bottom pressure, $M_{c(EBP)} = P_c * h_{c(EBP)} = 91.1 * 6.687 = 609.2 \text{ ft-k}$
 convective force moment including bottom pressure, $M_{c(IBP)} = P_c * h_{c(IBP)} = 91.1 * 12.601 = 1148.0 \text{ ft-k}$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

4). lateral inertia force of the accelerating wall:

$$\begin{aligned} \text{tank wall mass, } W_w &= 231.9 \text{ kip} \\ \text{wall c.g. relative to base, } h_w &= 6.835 \text{ ft} \\ \text{wall inertia force, } P_w &= \left(\frac{S_{ai} I \varepsilon}{R_i} \right) W_w = (0.611 * 1.25 * 0.593 / 2) * 231.9 = 52.5 \text{ kip} \\ \text{wall inertia force moment, } M_w &= P_w * h_w = 52.5 * 6.835 = 358.8 \text{ ft-k} \end{aligned}$$

5). lateral inertia force of the accelerating roof:

$$\begin{aligned} \text{total roof mass, } W_r &= 0.0 \text{ kip} \\ \text{roof c.g. relative to base, } h_r &= 0.0 \text{ ft} \\ \text{roof inertia force, } P_r &= \left(\frac{S_{ai} I}{R_i} \right) W_r = (0.611 * 1.25 / 2) * 0 = 0.0 \text{ kip} \\ \text{roof inertia force moment, } M_r &= P_r * h_r = 0 * 0 = 0.0 \text{ ft-k} \end{aligned}$$

6). total base shear:

$$\begin{aligned} V &= \sqrt{(P_i + P_w + P_r)^2 + P_c^2} \\ V &= ((107.5 + 52.5 + 0)^2 + (91.1)^2)^{1/2} = 184.1 \text{ kip} \end{aligned}$$

7). total moment at the base excluding bottom pressure (EBP):

$$\begin{aligned} M_b &= \sqrt{(M_i + M_w + M_r)^2 + M_c^2} \\ M_b &= ((483.8 + 358.8 + 0)^2 + (609.2)^2)^{1/2} = 1039.8 \text{ ft-k} \end{aligned}$$

8). total moment at the base including bottom pressure (IBP):

$$\begin{aligned} M_o &= \sqrt{(M_i + M_w + M_r)^2 + M_c^2} \\ M_o &= ((1488.9 + 358.8 + 0)^2 + (1148)^2)^{1/2} = 2175.3 \text{ ft-k} \end{aligned}$$

9). maximum wave slosh height displacement: (see ASCE-10, 15.7.6.1 notes c and d)

$$\begin{aligned} (\text{Risk Category} = 3) \quad I &= 1.25, \text{ use TL} = 4, \text{ Sd1} = 0.656, \text{ Tc} = 3.7022 \\ S_{ac} &= 1.5 * S_{d1} / T_c = 0.2658 * g \end{aligned}$$

$$\begin{aligned} d_{(\max)} &= 0.42 (D) (S_{ac} I) = 0.42 * (35) * (0.2658 * 1.25) = 4.88 \text{ ft} \\ (\text{minimum freeboard see table 15.7-3 of ASCE 7}), \quad d_{(\min)} &= 0.7 * d_{(\max)} = 3.42 \text{ ft} \end{aligned}$$

Wave height is greater than the freeboard of 1.67-ft. Check effects of wave spillage.


10). Vertical acceleration:

$$\begin{aligned} \text{design horizontal acceleration, } S_{DS} &= 0.611 * g \\ \text{period of vibration, } T_v &= 2\pi * (\gamma_L * D * H_L^2 / (24g * t_w * E_c))^{1/2} = 0.0193 \text{ sec} \\ T_s &= S_{D1} / S_{DS} = 0.656 / 0.611 = 1.0736 \text{ sec} \\ \text{vertical acceleration (per ACI 350 para 9.4.3), for } T_v \leq T_s \text{ then } C_t &= S_{DS}, \text{ for } T_v > T_s \text{ then } C_t = \frac{S_{D1}}{T_v} \\ \text{therefore, vertical spectral response acceleration, } S_{av} &= C_t = 0.6110 * g \\ \text{per ASCE 7-10 para. 15.7.7.2(b), use } I &= R_i = b = 1.0 \end{aligned}$$

$$\text{Design vertical acceleration, } \ddot{u} = \frac{S_{av} I b}{R_i} = 0.611 * 1 * 1 / 1 = 0.6110 \text{ g}$$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

12). vertical pressure distribution on a unit width using the linear distribution of ACI 350 sec 5.3:



impulsive pressure:

$$p_{iy} = \frac{2 \left(\frac{P_i}{2} \right) \left[4H_L - 6h_i - (6H_L - 12h_i) \left(\frac{y}{H_L} \right) \right]}{\pi R H_L^2} \cos \theta =$$

use $\theta = 0^\circ$ impulsive force, $P_i = 107.5$ kip
 $h_i = 4.5$ ft
 at $y = H_L$, $p_{iy} = 0.041$ ksf
 at base $y = 0$, $p_{iy} = 0.285$ ksf

convective pressure:

$$p_{cy} = \frac{16 \left(\frac{P_c}{2} \right) \left[4H_L - 6h_c - (6H_L - 12h_c) \left(\frac{y}{H_L} \right) \right]}{9 \pi R H_L^2} \cos \theta =$$

use $\theta = 0^\circ$ convective force, $P_c = 91.1$ kip
 $h_c = 6.687$ ft
 at $y = H_L$, $p_{cy} = 0.165$ ksf
 at base $y = 0$, $p_{cy} = 0.081$ ksf

vertical acceleration pressure:

$$p_{vy} = \ddot{u} \gamma_L (H_L - y) =$$

vertical acceleration, $\ddot{u} = 0.611$ g
 at $y = H_L$, $p_{vy} = 0$ ksf
 at base $y = 0$, $p_{vy} = 0.458$ ksf

wall inertia pressure:

$$p_{wy} = \frac{S_{ai} I \varepsilon \gamma_c (t_w / 12)}{R_i} =$$

$p_{wy} = 0.2264 * (\gamma_c * t_w)$
 at $y = H_w$, $p_{wy} = 0.034$ ksf
 at base $y = 0$, $p_{wy} = 0.034$ ksf

hydrostatic pressure:


$$q_{hy} = \gamma_L (H_L - y) =$$

at $y = H_L$, $q_{hy} = 0$ ksf
 at base $y = 0$, $q_{hy} = 0.749$ ksf

combine the effects of the dynamic pressures on the wall:

$$p_y = \sqrt{(p_{iy} + p_{wy})^2 + p_{cy}^2 + p_{vy}^2} =$$

at $y = H_w$, $p_y = 0.181$ ksf
 at base $y = 0$, $p_y = 0.564$ ksf
 (unfactored load = $0.181 / 1.4 = 0.129$ ksf)
 (unfactored load = $0.564 / 1.4 = 0.403$ ksf)





resultant dynamic pressures

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

13). load cases:

a). hydrostatic water load case:





triangular pressure = 0.749 ksf

Concrete load factor for hoop forces for the hydrostatic load case = **3.86**
 Concrete load factor for moments for the hydrostatic load case = **2.25**
 Concrete load factor for shears for the hydrostatic load case = **1.4**


b). seismic load case:

equivalent unfactored dynamic + static pressure loadings...


equivalent loading (unfactored)



+



=



Concrete load factor for hoop forces for the seismic load case = **1.4**
 Concrete load factor for moments for the seismic load case = **1.4**
 Concrete load factor for shears for the seismic load case = **1.4**

14). concrete design data:

Reinforcement yield strength, f_y = **60** ksi
 No. of reinforcing curtains, (1 or 2) = **2**
 Depth to vert reinforcing, $d = tw-3$ = **9** in.
 minimum gross hoop steel ratio, ρ = **0.00300**
 min gross vert shrinkage/ temperature steel ratio, ρ = **0.00300**
 ϕ , Bending = **0.9**
 ϕ for shear is dependent upon the load factors used. See code. (typically 0.85 or 0.75), ϕ , Shear = **1**

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

$$H^2 / (D \cdot t_w) = 4.114$$



pressure loading
 triangular pressure = 0.749 ksf
 tank radius, R = 17.5
 fluid depth, H = 12
 wall thickness, t_w = 12

$$A_{(req'd)} = \frac{T_u}{\phi f_y}$$

$$R_u = \frac{M_u}{\phi b d^2}$$

$$A_s = \frac{0.85 f'_c b d}{f_y} \left(1 - \sqrt{1 - \frac{2 R_u}{0.85 f'_c}} \right)$$

STEEL TYPE	DISTANCE FROM TOP OF FLUID		*** HYDROSTATIC LOAD CASE ***				
	Distance (% H)	Distance (feet)	Coefficient triangular loading	Concrete Tensile stress (ksi)	unfactored Hoop Tension, T (kip / ft)	factored Hoop Tension, T _u (kip / ft)	Hoop Steel Req'd. (in ² / ft)
HOOP STEEL	0.0 H	0.00	0.0604	0.009	0.792	3.057	0.06
	0.1 H	1.20	0.1605	0.023	2.103	8.116	0.15
	0.2 H	2.40	0.2547	0.037	3.338	12.885	0.24
	0.3 H	3.60	0.3403	0.049	4.459	17.211	0.32
	0.4 H	4.80	0.4065	0.059	5.326	20.560	0.38
	0.5 H	6.00	0.4355	0.063	5.707	22.031	0.41
	0.6 H	7.20	0.4166	0.060	5.459	21.073	0.39
	0.7 H	8.40	0.3421	0.050	4.483	17.303	0.32
	0.8 H	9.60	0.2160	0.032	2.830	10.923	0.20
	0.9 H	10.80	0.0751	0.011	0.984	3.800	0.07
1.0 H	12.00	0.0000	0.000	0.000	0.000	0.00	
VERT STEEL	0.0 H	0.00	0.00000	0.000	0.000		0.00
	0.1 H	1.20	0.00029	0.031	0.070		0.00
	0.2 H	2.40	0.00141	0.152	0.342		0.01
	0.3 H	3.60	0.00264	0.285	0.641		0.02
	0.4 H	4.80	0.00445	0.480	1.081		0.03
	0.5 H	6.00	0.00634	0.684	1.538		0.04
	0.6 H	7.20	0.00747	0.805	1.812		0.04
	0.7 H	8.40	0.00678	0.731	1.644		0.04
	0.8 H	9.60	0.00238	0.256	0.577		0.01
	0.9 H	10.80	-0.00772	-0.833	-1.874		0.05
1.0 H	12.00	-0.02622	-2.827	-6.361		0.16	

Critical Wall Shear	V = 1.550 kip / ft , (shear at a distance "d" from the bottom of the wall)
Factored Critical Wall Shear	V _u = 2.170 kip / ft
Base Horz Wall Reaction	Reaction = 2.094 kip / ft , tri press coef = 0.2330
Foundation Ring Tension	F = 36.64 kip F _u = 141.44 kip , A _s (in ²) = 2.62

nominal design shear strength, $\phi V_c = \phi * 2 * f'_c \sqrt{bd} = 13.661 \text{ k / ft}$

- notes: 1). Reference: "Circular Concrete Tanks without Prestressing", Portland Cement Association, 1993.
 2). Intermediate coefficient values from the PCA reference are found by quadratic interpolation to enhance accuracy.
 3). Maximum allowable concrete tensile stress, $0.1 * f'_c = 0.400 \text{ ksi}$
 4). Concrete tension, $f_c = (C * E_s * A_s + T) / (A_c + n * A_s)$, use C=0.0003
 5). T = coef*(tri. pressure)*R , M = coef*(tri. pressure)*H²

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

$H^2 / (D \cdot t_w) = 4.114$



pressure loading
 triangular pressure = 0.749 ksf
 tank radius, R = 17.5
 fluid depth, H = 12
 wall thickness, $t_w = 12$

STEEL TYPE	DISTANCE FROM TOP OF FLUID		*** HYDROSTATIC LOAD CASE *** PINNED BASE CIRCULAR WALL				
	Distance (% H)	Distance (feet)	Coefficient triangular loading	Concrete Tensile stress (ksi)	unfactored Hoop Tension, T (kip / ft)	factored Hoop Tension, T_u (kip / ft)	Hoop Steel Req'd. (in^2 / ft)
HOOP STEEL	0.0 H	0.00	0.0130	0.002	0.171	0.659	0.01
	0.1 H	1.20	0.1338	0.020	1.753	6.766	0.13
	0.2 H	2.40	0.2506	0.037	3.284	12.678	0.23
	0.3 H	3.60	0.3658	0.053	4.794	18.505	0.34
	0.4 H	4.80	0.4693	0.068	6.150	23.738	0.44
	0.5 H	6.00	0.5476	0.079	7.176	27.698	0.51
	0.6 H	7.20	0.5842	0.084	7.655	29.547	0.55
	0.7 H	8.40	0.5599	0.080	7.336	28.319	0.52
	0.8 H	9.60	0.4540	0.065	5.949	22.964	0.43
	0.9 H	10.80	0.2606	0.038	3.415	13.181	0.24
1.0 H	12.00	0.0000	0.000	0.000	0.000	0.00	
VERT STEEL	0.0 H	0.00	0.00000	0.000	0.000		0.00
	0.1 H	1.20	0.00008	0.009	0.020		0.00
	0.2 H	2.40	0.00061	0.065	0.147		0.00
	0.3 H	3.60	0.00146	0.157	0.353		0.01
	0.4 H	4.80	0.00306	0.330	0.742		0.02
	0.5 H	6.00	0.00540	0.582	1.309		0.03
	0.6 H	7.20	0.00796	0.859	1.932		0.05
	0.7 H	8.40	0.01051	1.134	2.551		0.06
	0.8 H	9.60	0.01149	1.238	2.786		0.07
	0.9 H	10.80	0.00902	0.973	2.188		0.05
1.0 H	12.00	0.00000	0.000	0.000	0.00	0.2052432	

$A_{(req'd)} = \frac{T_u}{\phi f_y}$

$R_u = \frac{M_u}{\phi b d^2}$

$A_s = \frac{0.85 f'_c b d}{f_y} \left(1 - \sqrt{1 - \frac{2 R_u}{0.85 f'_c}} \right)$


Critical Wall Shear	V = 0.668 kip / ft , (shear at a distance "d" from the bottom of the wall)
Factored Critical Wall Shear	$V_u = 0.936$ kip / ft
Base Horz Wall Reaction	Reaction = 1.212 kip / ft , tri press coef = 0.1349
Foundation Ring Tension	F = 21.22 kip $F_u = 81.89$ kip , $A_s (in^2) = 1.52$

nominal design shear strength, $\phi V_c = \phi * 2 * f'_c \sqrt{bd} = 13.661$ k / ft

- notes: 1). Reference: "Circular Concrete Tanks without Prestressing", Portland Cement Association, 1993.
 2). Intermediate coefficient values from the PCA reference are found by quadratic interpolation to enhance accuracy.
 3). Maximum allowable concrete tensile stress, $0.1 * f'_c = 0.400$ ksi
 4). Concrete tension, $f_c = (C * E_s * A_s + T) / (A_c + n * A_s)$, use C=0.0003
 5). $T = \text{coef} * (\text{tri. pressure}) * R$, $M = \text{coef} * (\text{tri. pressure}) * H^2$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

$H^2 / (D \cdot t_w) = 4.114$



pressure loadings
 triangular = 1.022 ksf
 uniform = 0.129 ksf
 radius, R = 17.5
 fluid, H = 12
 wall thk., $t_w = 12$

$A_{(req'd)} = \frac{T_u}{\phi f_y}$

STEEL TYPE	DISTANCE FROM TOP OF FLUID		*** SEISMIC LOAD CASE ***					
	Distance (% H)	Distance (feet)	Coefficients		Concrete Tensile stress (ksi)	unfactored Hoop Tension, T (kip / ft)	factored Hoop Tension, T_u (kip / ft)	Hoop Steel Req'd. (in ² / ft)
			triangular loading	uniform loading				
HOOP STEEL	0.0 H	0.00	0.0604	1.0785	0.030	3.521	4.930	0.09
	0.1 H	1.20	0.1605	1.0692	0.045	5.290	7.405	0.14
	0.2 H	2.40	0.2547	1.0558	0.059	6.946	9.724	0.18
	0.3 H	3.60	0.3403	1.0310	0.071	8.419	11.787	0.22
	0.4 H	4.80	0.4065	0.9823	0.080	9.493	13.290	0.25
	0.5 H	6.00	0.4355	0.8954	0.082	9.816	13.743	0.25
	0.6 H	7.20	0.4166	0.7563	0.077	9.163	12.828	0.24
	0.7 H	8.40	0.3421	0.5622	0.062	7.391	10.347	0.19
	0.8 H	9.60	0.2160	0.3288	0.039	4.607	6.449	0.12
	0.9 H	10.80	0.0751	0.1077	0.013	1.587	2.222	0.04
1.0 H	12.00	0.0000	0.0000	0.000	0.000	0.000	0.00	
VERT STEEL	0.0 H	0.00	0.00000	0.00000	0.000	0.000	0.000	0.00
	0.1 H	1.20	0.00029	0.00037	0.049	0.069	0.069	0.00
	0.2 H	2.40	0.00141	0.00140	0.234	0.327	0.327	0.01
	0.3 H	3.60	0.00264	0.00311	0.447	0.626	0.626	0.02
	0.4 H	4.80	0.00445	0.00499	0.748	1.048	1.048	0.03
	0.5 H	6.00	0.00634	0.00660	1.056	1.479	1.479	0.04
	0.6 H	7.20	0.00747	0.00733	1.236	1.730	1.730	0.04
	0.7 H	8.40	0.00678	0.00530	1.096	1.534	1.534	0.04
	0.8 H	9.60	0.00238	-0.00102	0.331	0.463	0.463	0.01
	0.9 H	10.80	-0.00772	-0.01392	-1.396	-1.954	-1.954	0.05
1.0 H	12.00	-0.02622	-0.03557	-4.521	-6.330	-6.330	0.32	

$R_u = \frac{M_u}{\phi b d^2}$

$A_s = \frac{0.85 f'_c b d}{f_y} \left(1 - \sqrt{1 - \frac{2 R_u}{0.85 f'_c}} \right)$

0.410651


Critical Wall Shear	V = 1.027 kip / ft , (shear at a distance "d" from the bottom of the wall)
Factored Critical Wall Shear	$V_u = 1.438$ kip / ft
Base Horz Wall Reaction	Reaction = 3.273 kip / ft , tri press coef = 0.2330 , uniform press coef = 0.2674
Foundation Ring Tension	F = 57.28 kip $F_u = 80.19$ kip , A_s (in ²) = 1.48

nominal design shear strength, $\phi V_c = \phi * 2 * f'_c \sqrt{bd} = 13.661$ k / ft

- notes: 1). Reference: "Circular Concrete Tanks without Prestressing", Portland Cement Association, 1993.
 2). Intermediate coefficient values from the PCA reference are found by quadratic interpolation to enhance accuracy.
 3). Maximum allowable concrete tensile stress. For $0.1 * f'_c = 0.400$ ksi static X 1.33 = 0.532 ksi seismic conditions, engineer may consider up to 1.33 x static.
 4). Concrete tension, $f_c = (C * E_s * A_s + T) / (A_c + n * A_s)$, use C=0.0003
 5). $T = \text{coef} * (\text{tri. pressure}) * R + \text{coef} * (\text{uni. pressure}) * R$, $M = \text{coef} * (\text{tri. pressure}) * H^2 + \text{coef} * (\text{uni. pressure}) * H^2$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

$$H^2 / (D \cdot t_w) = 4.114$$



pressure loadings
 triangular = 1.022 ksf
 uniform = 0.129 ksf
 radius, R = 17.5
 fluid, H = 12
 wall thk., t_w = 12

$$A_{(req'd)} = \frac{T_u}{\phi f_y}$$

$$R_u = \frac{M_u}{\phi b d^2}$$

$$A_s = \frac{0.85 f'_c b d}{f_y} \left(1 - \sqrt{1 - \frac{2 R_u}{0.85 f'_c}} \right)$$

0.205243

STEEL TYPE	DISTANCE FROM TOP OF FLUID		*** SEISMIC LOAD CASE *** PINNED BASE CIRCULAR WALL					
	Distance (% H)	Distance (feet)	Coefficients		Concrete Tensile stress (ksi)	unfactored Hoop Tension, T (kip / ft)	factored Hoop Tension, T_u (kip / ft)	Hoop Steel Req'd. (in ² / ft)
			triangular loading	uniform loading				
HOOP STEEL	0.0 H	0.00	0.0130	1.0130	0.021	2.525	3.536	0.07
	0.1 H	1.20	0.1338	1.0338	0.040	4.732	6.625	0.12
	0.2 H	2.40	0.2506	1.0506	0.058	6.861	9.605	0.18
	0.3 H	3.60	0.3658	1.0658	0.075	8.955	12.538	0.23
	0.4 H	4.80	0.4693	1.0693	0.091	10.814	15.139	0.28
	0.5 H	6.00	0.5476	1.0476	0.102	12.165	17.031	0.32
	0.6 H	7.20	0.5842	0.9842	0.106	12.675	17.745	0.33
	0.7 H	8.40	0.5599	0.8599	0.100	11.960	16.744	0.31
	0.8 H	9.60	0.4540	0.6540	0.081	9.600	13.441	0.25
	0.9 H	10.80	0.2606	0.3606	0.046	5.477	7.668	0.14
1.0 H	12.00	0.0000	0.0000	0.000	0.000	0.000	0.00	
VERT STEEL	Distance (% H)	Distance (feet)	Coefficients		unfactored Moment M (ft-kip / ft)	factored Moment M_u (ft-kip / ft)	Vertical Steel Req'd. for Bending (in ² /ft)	
			triangular loading	uniform loading				
	0.0 H	0.00	0.00000	0.00000	0.000	0.000	0.00	
	0.1 H	1.20	0.00008	0.00008	0.014	0.019	0.00	
	0.2 H	2.40	0.00061	0.00061	0.100	0.141	0.00	
	0.3 H	3.60	0.00146	0.00146	0.241	0.338	0.01	
	0.4 H	4.80	0.00306	0.00306	0.507	0.710	0.02	
	0.5 H	6.00	0.00540	0.00540	0.895	1.253	0.03	
	0.6 H	7.20	0.00796	0.00796	1.320	1.848	0.05	
	0.7 H	8.40	0.01051	0.01051	1.743	2.440	0.06	
0.8 H	9.60	0.01149	0.01149	1.904	2.666	0.07		
0.9 H	10.80	0.00902	0.00902	1.495	2.094	0.05		
1.0 H	12.00	0.00000	0.00000	0.000	0.000	0.21		

Critical Wall Shear	V = 1.122 kip / ft , (shear at a distance "d" from the bottom of the wall)
Factored Critical Wall Shear	V_u = 1.570 kip / ft
Base Horz Wall Reaction	Reaction = 1.864 kip / ft , tri press coef = 0.1349 , uniform press coef = 0.1349
Foundation Ring Tension	F = 32.62 kip F_u = 45.67 kip , A_s (in ²) = 0.85

$$\text{nominal design shear strength, } \phi V_c = \phi * 2 * f'_c \sqrt{bd} = 13.661 \text{ k / ft}$$

- notes: 1). Reference: "Circular Concrete Tanks without Prestressing", Portland Cement Association, 1993.
 2). Intermediate coefficient values from the PCA reference are found by quadratic interpolation to enhance accuracy.
 3). Maximum allowable concrete tensile stress. For $0.1 * f'_c = 0.400$ ksi static X 1.33 = 0.532 ksi seismic conditions, engineer may consider up to 1.33 x static.
 4). Concrete tension, $f_c = (C * E_s * A_s + T) / (A_c + n * A_s)$, use C=0.0003
 5). $T = \text{coef}*(\text{tri. pressure}) * R + \text{coef}*(\text{uni. pressure}) * R$, $M = \text{coef}*(\text{tri. pressure}) * H^2 + \text{coef}*(\text{uni. pressure}) * H^2$

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Interior Liquid Load Case

$$\text{hoop } A_{s(\text{req'd})} = T_u / (\phi * f_y) \quad A_{s(\text{min})} = \rho * b * t_w$$

SUMMARY OF HOOP & VERTICAL STEEL REQUIREMENTS THE INTERNAL WATER LOADING CASES

HOOP STEEL	Distance from top of fluid (ft)	Hydrostatic Case		Seismic Case		controlling $A_{s(\text{req'd})}$ (in ² /ft)	$A_{s(\text{min})}$ (in ² /ft)	Bar number	Bar spacing (in)	total for 2 curtains $A_{s(\text{provided})}$ (in ² /ft)
		Fixed Base	Pinned Base	Fixed Base	Pinned Base					
		T_u (kip / ft)	T_u (kip / ft)	T_u (kip / ft)	T_u (kip / ft)					
0.00	3.057	0.659	4.930	3.536	0.09	0.43	5	12	0.62	
1.20	8.116	6.766	7.405	6.625	0.15	0.43	5	12	0.62	
2.40	12.885	12.678	9.724	9.605	0.24	0.43	5	12	0.62	
3.60	17.211	18.505	11.787	12.538	0.34	0.43	5	12	0.62	
4.80	20.560	23.738	13.290	15.139	0.44	0.43	5	12	0.62	
6.00	22.031	27.698	13.743	17.031	0.51	0.43	5	12	0.62	
7.20	21.073	29.547	12.828	17.745	0.55	0.43	5	12	0.62	
8.40	17.303	28.319	10.347	16.744	0.52	0.43	5	12	0.62	
9.60	10.923	22.964	6.449	13.441	0.43	0.43	5	12	0.62	
10.80	3.800	13.181	2.222	7.668	0.24	0.43	5	12	0.62	
12.00	0.000	0.000	0.000	0.000	0.00	0.43	5	12	0.62	

VERT STEEL	Distance from top of fluid (ft)	Hydrostatic Case		Seismic Case		controlling $A_{s(\text{req'd})}$ (in ² /ft)	$A_{s(\text{min})}$ (in ² /ft)	Bar number	Bar spacing (in)	each face $A_{s(\text{provided})}$ (in ² /ft)
		Fixed Base	Pinned Base	Fixed Base	Pinned Base					
		M_u (ft-kip / ft)	M_u (ft-kip / ft)	M_u (ft-kip / ft)	M_u (ft-kip / ft)					
0.00	0.000	0.000	0.000	0.000	0.00	0.22	5	12	0.31	
1.20	0.070	0.020	0.069	0.019	0.00	0.22	5	12	0.31	
2.40	0.342	0.147	0.327	0.141	0.01	0.22	5	12	0.31	
3.60	0.641	0.353	0.626	0.338	0.02	0.22	5	12	0.31	
4.80	1.081	0.742	1.048	0.710	0.03	0.22	5	12	0.31	
6.00	1.538	1.309	1.479	1.253	0.04	0.22	5	12	0.31	
7.20	1.812	1.932	1.730	1.848	0.05	0.22	5	12	0.31	
8.40	1.644	2.551	1.534	2.440	0.06	0.22	5	12	0.31	
9.60	0.577	2.786	0.463	2.666	0.07	0.22	5	12	0.31	
10.80	-1.874	2.188	-1.954	2.094	0.05	0.22	5	12	0.31	
12.00	-6.361	0.000	-6.330	0.000	0.16	0.22	5	6	0.62	

SUMMARY OF FOUNDATION HOOP STEEL REQUIRED

Foundation Hoop Forces	Foundation Ring Tension				$A_{(\text{req'd})} = \frac{F_u}{\phi f_y}$ maximum $A_{s(\text{req'd})}$ (in ²)	Bar number	total number of Bars in 2 layers	$A_{s(\text{provided})}$ (in ²)
	Hydrostatic Case		Seismic Case					
	Fixed Base (kip)	Pinned Base (kip)	Fixed Base (kip)	Pinned Base (kip)				
Foundation Ring Tension, $F =$	36.64	21.22	57.28	32.62	2.62	5	10	3.10
$F_u = (\text{load factor}) * F =$	141.44	81.89	80.19	45.67				



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: External Soil Load Case

External Soil Compression Loading:

uniform soil surcharge pressure =	0.100	ksf	Concrete load factor for hoop compression =	1.6
soil height from base, H _s =	7	ft.	Concrete load factor for moments =	2.25
lateral at-rest soil density =	0.055	k / ft ³	Concrete load factor for shears =	1.6
max triangular soil pressure =	0.385	ksf	Depth to vert reinforcing, d =tw-3 =	9 in.
Tank diameter, D =	35	ft.	Reinforcement strength, f _y =	60 ksi
Tank wall height, H =	13.67	ft.	Concrete strength, f'c =	4 ksi
Wall thickness, t _w =	12	in.		

H_s² / (D*t_w) = 1.400

*** FORCES RESULTING FROM EXTERNAL SOIL COMPRESSION ***								
STEEL TYPE	DISTANCE FROM TOP OF SOIL		FIXED BASE CIRCULAR WALL					
	Distance (% H _s)	Distance (feet)	Coefficients		unfactored Hoop Compression, P (kip / ft)	factored Hoop Compression, P _u (kip / ft)	Ultimate Hoop Compression ϕP _u = 0.85ϕ(0.85 f'c *A _g) (kip / ft)	
H O O P C O M P R E S S I O N			triangular loading	uniform loading				
	0.0 H _s	0.00	0.2756	1.2429	4.032	6.451	291.31	
	0.1 H _s	0.70	0.2713	1.1170	3.782	6.052	291.31	
	0.2 H _s	1.40	0.2621	0.9814	3.483	5.574	291.31	
	0.3 H _s	2.10	0.2516	0.8476	3.179	5.086	291.31	
	0.4 H _s	2.80	0.2303	0.7051	2.785	4.456	291.31	
	0.5 H _s	3.50	0.2028	0.5613	2.348	3.757	291.31	
	0.6 H _s	4.20	0.1630	0.4143	1.823	2.917	291.31	
	0.7 H _s	4.90	0.1161	0.2696	1.254	2.007	291.31	
	0.8 H _s	5.60	0.0635	0.1391	0.671	1.074	291.31	
0.9 H _s	6.30	0.0194	0.0396	0.200	0.320	291.31		
1.0 H _s	7.00	0.0000	0.0000	0.000	0.000	291.31		
V E R T I C A L S T E E L			triangular loading	uniform loading	unfactored Moment M (ft-kip / ft)	factored Moment M _u (ft-kip / ft)	Vertical Steel Req'd. for Bending (in ² /ft)	minimum flexural steel at max face (in ² /ft)
	0.0 H _s	0.00	0.00000	0.00000	0.000	0.000	0.00	0.22
	0.1 H _s	0.70	0.00115	0.00100	0.027	0.060	0.00	0.22
	0.2 H _s	1.40	0.00421	0.00323	0.095	0.214	0.01	0.22
	0.3 H _s	2.10	0.00766	0.00521	0.170	0.383	0.01	0.22
	0.4 H _s	2.80	0.01065	0.00576	0.229	0.516	0.01	0.22
	0.5 H _s	3.50	0.01178	0.00365	0.240	0.540	0.01	0.22
	0.6 H _s	4.20	0.01026	-0.00325	0.178	0.400	0.01	0.22
	0.7 H _s	4.90	0.00424	-0.01525	0.005	0.012	0.00	0.22
	0.8 H _s	5.60	-0.00761	-0.03549	-0.317	-0.714	-0.02	0.22
0.9 H _s	6.30	-0.02675	-0.06538	-0.825	-1.856	-0.05	0.22	
1.0 H _s	7.00	-0.05500	-0.10089	-1.532	-3.447	-0.09	0.22	

Note: P = coef*(tri. pressure)*R + coef*(uni. pressure)*R , M = coef*(tri. pressure)*H_s² + coef*(uni. pressure)*H_s²

Critical Wall Shear	V = 1.238 kip / ft , (shear at a distance "d" from the bottom of the wall)
Factored Critical Wall Shear	V _u = 1.980 kip / ft , ϕV _c = 10.25
Base Horz Wall Reaction	Reaction = 1.185 kip / ft , soil coef = 0.3275 , uniform press coef = 0.4315
Foundation Ring Compression	F = 20.7 kip



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: External Soil Load Case

$H_s^2 / (D \cdot t_w) = 1.400$ soil height, $H_s = 7$ ft

*** FORCES RESULTING FROM EXTERNAL SOIL COMPRESSION ***									
STEEL TYPE	DISTANCE FROM TOP OF SOIL		PINNED BASE CIRCULAR WALL						
	Distance (% H_s)	Distance (feet)	Coefficients		unfactored Hoop Compression, P (kip / ft)	factored Hoop Compression, P_u (kip / ft)	Ultimate Hoop Compression $\phi P_u = 0.85\phi(0.85 f'_c A_g)$ (kip / ft)		
H O O P C O M P R E S S I O N			triangular loading	uniform loading					
		0.0 H_s	0.00	0.3089	1.3089	4.372	6.995	291.31	
		0.1 H_s	0.70	0.3279	1.2279	4.358	6.973	291.31	
		0.2 H_s	1.40	0.3510	1.1510	4.379	7.007	291.31	
		0.3 H_s	2.10	0.3659	1.0659	4.330	6.929	291.31	
		0.4 H_s	2.80	0.3716	0.9716	4.204	6.727	291.31	
		0.5 H_s	3.50	0.3631	0.8631	3.957	6.331	291.31	
		0.6 H_s	4.20	0.3350	0.7305	3.535	5.657	291.31	
		0.7 H_s	4.90	0.2854	0.5854	2.947	4.715	291.31	
		0.8 H_s	5.60	0.2095	0.4095	2.128	3.405	291.31	
		0.9 H_s	6.30	0.1109	0.2109	1.116	1.786	291.31	
	1.0 H_s	7.00	0.0000	0.0000	0.000	0.000	291.31		
V E R T I C A L S T E E L	Distance (% H_s)	Distance (feet)	Coefficients		unfactored Moment M (ft-kip / ft)	factored Moment M_u (ft-kip / ft)	Vertical Steel Req'd. for Bending (in ² /ft)	minimum flexural steel at max face (in ² /ft)	
			triangular loading	uniform loading					
		0.0 H_s	0.00	0.00000	0.00000	0.000	0.000	0.00	0.22
		0.1 H_s	0.70	0.00139	0.00139	0.033	0.074	0.00	0.22
		0.2 H_s	1.40	0.00506	0.00506	0.120	0.271	0.01	0.22
		0.3 H_s	2.10	0.01008	0.01008	0.239	0.539	0.01	0.22
		0.4 H_s	2.80	0.01609	0.01609	0.382	0.860	0.02	0.22
		0.5 H_s	3.50	0.02154	0.02154	0.512	1.152	0.03	0.22
		0.6 H_s	4.20	0.02571	0.02571	0.611	1.375	0.03	0.22
		0.7 H_s	4.90	0.02749	0.02749	0.653	1.470	0.04	0.22
		0.8 H_s	5.60	0.02470	0.02470	0.587	1.321	0.03	0.22
	0.9 H_s	6.30	0.01623	0.01623	0.386	0.868	0.02	0.22	
	1.0 H_s	7.00	0.00000	0.00000	0.000	0.000	0.00	0.22	

Note: $P = \text{coef}(\text{tri. pressure}) \cdot R + \text{coef}(\text{uni. pressure}) \cdot R$, $M = \text{coef}(\text{tri. pressure}) \cdot H_s^2 + \text{coef}(\text{uni. pressure}) \cdot H_s^2$

Critical Wall Shear	$V = 2.919$ kip / ft , (shear at a distance "d" from the bottom of the wall)
Factored Critical Wall Shear	$V_u = 4.671$ kip / ft $\phi V_c = 10.25$
Base Horz Wall Reaction	Reaction = 0.735 kip / ft , soil coef = 0.2119 , uniform press coef = 0.2119
Foundation Ring Compression	$F = 12.9$ kip

Check maximum buckling load using a short cylinder of length "L" with radial critical buckling load P_{cr} :

$t_w = 1$ ft $R = 17.5$ ft , use L as the soil loaded shell height, $L = 7$ ft $E = 3605.0$ ksi
 poisson ratio, $\nu = 0.2$ use a factor of safety of 2.5 for buckling, see Roark 6th ed. Table 35 case 19
 $P_{cr} = \{ 0.807 \cdot E \cdot t_w^2 / (L \cdot R) \cdot ((1 / (1 - \nu^2))^{3/4} \cdot (t_w^2 / R^2))^{1/4} \} / 2.5 = 337.17$ k/ft
 max fixed base hoop compressive load, $P = 4.032$ k/ft < 337.17 OK
 max pinned hoop base compressive load, $P = 4.379$ k/ft < 337.17 OK



BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: External Soil Load Case

vertical steel required for the external soil loading...

depth the the vertical steel, $d = 9$ in
 min gross vert shrinkage/ temperature steel ratio, $\rho = 0.00300$


$$M_u = 2.25 * M$$

SUMMARY OF VERTICAL STEEL REQUIREMENTS FOR THE EXTERNAL SOIL LOADING CASE										
VERT S T E E L	Distance from top of soil (ft)	External Soil Loading				controlling A_s (req'd) (in ² /ft)	A_s (min) (in ² /ft)	Bar number	Bar spacing (in)	each face A_s (provided) (in ² /ft)
		Fixed Base M (ft-kip / ft)	Fixed Base M_u (ft-kip / ft)	Pinned Base M (ft-kip / ft)	Pinned Base M_u (ft-kip / ft)					
		0.00	0.000	0.000	0.000					
0.70	0.027	0.060	0.033	0.074	0.00	0.22	5	12	0.31	
1.40	0.095	0.214	0.120	0.271	0.01	0.22	5	12	0.31	
2.10	0.170	0.383	0.239	0.539	0.01	0.22	5	12	0.31	
2.80	0.229	0.516	0.382	0.860	0.02	0.22	5	12	0.31	
3.50	0.240	0.540	0.512	1.152	0.03	0.22	5	12	0.31	
4.20	0.178	0.400	0.611	1.375	0.03	0.22	5	12	0.31	
4.90	0.005	0.012	0.653	1.470	0.04	0.22	5	12	0.31	
5.60	-0.317	-0.714	0.587	1.321	0.03	0.22	5	12	0.31	
6.30	-0.825	-1.856	0.386	0.868	0.05	0.22	5	12	0.31	
7.00	-1.532	-3.447	0.000	0.000	0.09	0.22	5	12	0.31	

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Ring Foundation

Ringwall Foundation Design:

- foundation projection on each side of wall, $L_{fp} = 1.95$ ft
- max foundation thickness on the soil side, $t_{fs} = 14$ inch
- foundation slope on the water side (i.e. 1:12) = 4 :12
- soil density = 0.110 k / ft³
- allowable soil bearing pressure = 2 ksf
- min foundation thickness on water side, $t_{fw} = 6.20$ inch
- total foundation length, $L = 2*(1.95)+(12/12) = 4.900$ ft
- tank wall thickness, $t_w = 12$ in
- tank wall height = 13.67 ft
- water height above top of foundation = 12 ft
- soil height above top of foundation = 7 ft



foundation loads:

wall wt. = 13.67*(12/12)*0.15 =	2.051	kip/ft	
foundation slab wt. = 4.9*(14/12)*0.15 =	0.858	kip/ft	
laundry slab, wall, tough, grout	= 0.27	kip/ft	} miscellaneous
water in trough	= 0.0624	kip/ft	
dome roof DL	= 0.48	kip/ft	
dome roof snow	= 1.995	kip/ft	

$P_1 = \text{wall} + \text{foundation} + \text{misc} = 5.716$ kip/ft

$w_2 = \text{water on foundation projection} = 0.0624 * 12 = 0.749$ ksf

$P_2 = \text{total water on foundation projection} = 0.7488 * 1.95 = 1.460$ kip/ft

$w_3 = \text{soil on foundation projection} = 0.11 * 7 = 0.770$ ksf

$P_3 = \text{total soil on foundation projection} = 0.77 * 1.95 = 1.502$ kip/ft

Conservatively design for the max wall moment for the fixed base wall and require that the full length of the foundation have contact with soil bearing (i.e. the kern fall within the middle third of the foundation, or other words $e(\text{max}) = L / 6$). Load cases of water and soil are checked independently of each other.


Refer to the circular wall and buried wall design tables for the max wall moments.

$M_o = \text{moment at center wall} = (\text{max wall moment}) - (L_{fp} + t_w)/2 * (P_2 \text{ or } P_3)$

$P_o = P_1 + (P_2 \text{ or } P_3)$

$e = M_o / P_o$

kern = $L / 6 = 0.8167$ ft



$q_{1,2} = \frac{P_o}{L} * \left(1 \pm \frac{6 e}{L} \right)$

$M_o = \text{moment at center wall for the static water case} =$	$2.827 - ((1.95+1)/2)*(1.46) =$	0.673	ft-k/ft
$M_o = \text{moment at center wall for the static water + seismic case} =$	$4.521 - ((1.95+1)/2)*(1.46) =$	2.367	ft-k/ft
$M_o = \text{moment at center wall for the soil + LL surcharge case} =$	$1.532 - ((1.95+1)/2)*(1.502) =$	-0.683	ft-k/ft

BY: C. Che DATE: Sep-17 CLIENT: Willamette River WTP SHEET: _____
 CHKD: _____ DESCRIPTION: Area 11 - Sludge Thickener JOB NO: 10721A.10
 DESIGN TASK: Ring Foundation

foundation moments & shears...


$$q_{1,2} = \frac{P_o}{L} * \left(1 \pm \frac{6 e}{L} \right)$$

$$L = 4.9 \text{ ft}$$

$$e = M_o / P_o$$

$$L_{(min)} = 6 * e_{(max)} = 6 * 0.33 = 1.979 \text{ ft}$$

$$\text{kern} = L / 6 = 0.8167 \text{ ft}$$



Soil Bearing Pressures at Maximum, Minimum, and Face of Wall Locations

Load Case	M _o (ft-k/ft)	P _o (k/ft)	e (ft)	pressure q ₁ (ksf)	pressure at face of wall on "q ₁ " side = q _{x1} (ksf)	pressure at face of wall on "q ₂ " side = q _{x2} (ksf)	pressure q ₂ (ksf)
static water	0.673	7.177	0.094 e < kern	1.633	1.499	1.430	1.296
static water + seismic	2.367	7.177	0.330 e < kern	2.056	1.585	1.344	0.873
soil + LL surcharge	-0.683	7.218	-0.095 e < kern	1.644	1.508	1.438	1.302

net soil bearing pressures, q_{net} = q_{gross} - insitu soil overburden. insitu soil overburden = **0.7** ksf


net soil bearing pressures, q_{net} = 2.056 - 0.7 = 1.356 ksf

Max net soil bearing is less than the allowable of 2 ksf, Okay.

moments and shears on the foundation projections:

$$M = \left(\frac{q_1}{3} + \frac{q_{x1}}{6} - \frac{w}{2} \right) (L_{fp})^2$$

$$V = \left(\frac{q_1 + q_{x1}}{2} - w \right) L_{fp}$$



Example of Foundation Toe Projection Freebody

for water and soil cases on toe side, w = foundation wt = 0.175 = 0.175 ksf } toe

for the water cases on heel side, w = water above foundation + foundation wt = 0.749 + 0.175 = 0.924 ksf } heel

for the soil case on heel side, w = soil above foundation + foundation wt = 0.77 + 0.175 = 0.945 ksf }

Foundation Moments and Shears

Load Case	foundation projection (ft)	unfactored pressures					unfactored moments and shears			
		q ₁ (ksf)	q _{x1} (ksf)	q _{x2} (ksf)	q ₂ (ksf)	w (toe or heel) (ksf)	toe side		heel side	
							M (ft-k/ft)	V (k/ft)	M (ft-k/ft)	V (k/ft)
static water	1.950	1.633	1.499	1.430	1.296	0.175	2.687	2.712	0.793	0.857
						0.924				
static water + seismic	1.950	2.056	1.585	1.344	0.873	0.175	3.278	3.209	0.202	0.360
						0.924				
soil + LL surcharge	1.950	1.644	1.508	1.438	1.302	0.175	2.706	2.731	0.766	0.829
						0.945				

Area 12 - Sludge Dewatering Building
ASCE 41 Evaluation



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Seismic

SEISMIC HAZARD LEVEL & BASIC PERFORMANCE OBJECTIVE

Note: **4.1.2 Seismic Hazard Level** The Seismic Hazard Level for the Tier 1 screening shall be BSE-1E per Table 2-1 for the Basic Performance Objective for Existing Buildings (BPOE).

Table 2-1. Basic Performance Objective for Existing Buildings (BPOE)

Risk Category	Tier 1*	Tier 2*	Tier 3	
	BSE-1E	BSE-1E	BSE-1E	BSE-2E
I & II	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Collapse Prevention Structural Performance Nonstructural Performance Not Considered (5-D)
III	See footnote b for Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Limited Safety Structural Performance Nonstructural Performance Not Considered (4-D)
IV	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Life Safety Structural Performance Nonstructural Performance Not Considered (3-D)

*For Tier 1 and 2 assessments, seismic performance for the BSE-2E is not explicitly evaluated.
 *For Risk Category III, the Tier 1 screening checklists shall be based on the Life Safety Performance Level (S-3), except that checklist statements using the Quick Check procedures of Section 4.5.3 shall be based on MS-factors and other limits that are an average of the values for Life Safety and Immediate Occupancy.

BUILDING PERIOD (SECTION 4.5.2.4)

building height, $h_n = 31.00$ ft
 building period adjustment factor, $C_t = 0.020$
 effective viscous damping ratio, $\beta = 0.75$
 fundamental building period, $T = 0.263$ sec

SEISMIC PARAMETERS

Building Type = **C2** Table 3-1
 modification factor, $C = 1.20$ Table 4-8

Table 4-8. Modification Factor, C

Building Type*	Number of Stories			
	1	2	3	≥4
Wood (W1, W1a, W2)	1.3	1.1	1.0	1.0
Moment frame (S1, S3, C1, PC2a)	1.4	1.2	1.1	1.0
Shear wall (S4, S5, C2, C3, PC1a, PC2, RM2, URMa)	1.0	1.0	1.0	1.0
Braced frame (S2)				
Unreinforced masonry (URM)				
Flexible diaphragms (S1a, S2a, S5a, C2a, C3a, PC1, RM1)				

*Defined in Table 3-1.

spectral acceleration at 1-sec for BSE-1E, $S_{x1} = 0.372$ g USGS Seismic Map
 spectral acceleration at short period for BSE-1E, $S_{xs} = 0.611$ g USGS Seismic Map
 spectral acceleration, $S_a = 0.611$ g $S_a = \frac{S_{x1}}{T}$ but S_a shall not exceed S_{xs} .
 base shear coefficient, $V = 0.733$ W Eq 4-1



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Building Weight & Base Shear

DEAD LOAD (Seismic Weight)

Roof Weight

Roofing	=	10.00	psf
Metal Roof Deck	=	3.00	psf
Steel Joist	=	7.00	psf
Miscellaneous (MEP)	=	10.00	psf
Total =			30.00 psf

Roof Length	=	34.00	ft
Roof Width	=	20.67	ft
Total Roof Weight =			21.08 kips

	Thick (in)	Trib Ht (ft)	Length (ft)		
Parapet Wall	8.00	1.50	112.00	=	16.80 kips
Wall Below	8.00	6.92	112.00	=	77.50 kips

Roof Seismic Weight = 115.38 kips

2nd Floor

12" Concrete Slab	=	150.00	psf
Miscellaneous (MEP)	=	10.00	psf
Low Roof Weight =			160.00 psf

Floor Length	=	34.00	ft
Floor Width	=	20.67	ft
Total Floor Weight =			112.43 kips

3-Centrifuges (35 kips each) 105.00 kips

	Thick (in)	Trib Ht (ft)	Length (ft)		
Wall Above	8.00	6.92	112.00	=	77.50 kips
Wall Below	12.00	9.00	70.67	=	95.40 kips

2nd Floor Seismic Weight = 390.33 kips

Seismic Weight & Base Shear

Base Shear Coefficient	=	0.733	g
Total Seismic Weight	=	506	kips
Design Base Shear	=	371	kips

LIVE LOAD

Roof Live Load	=	30.0	psf
----------------	---	------	-----



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Center of Mass

DEAD LOAD (Seismic Weight)

Roof Weight

<u>Roof Items</u>	unif wt (psf)	Width (ft)	Length (ft)	W (kips)	x-C.M (ft)	y-C.M (ft)	W*x (kip-ft)	W*y (kip-ft)
Roof DL	30.00	20.67	34.00	21.08	17.67	11.00	373	232
<u>Walls</u>	trib height (ft)	thick (ft)	length (ft)					
Parapet	1.50	0.67	112.00	16.80	17.67	11.00	297	185
Walls Below	6.92	0.67	112.00	77.50	17.67	11.00	1369	853
$\Sigma =$				115.39			2039	1269

Origin at NW-Corner, x-C.M. = 17.67 ft
 Origin at NW-Corner, y-C.M. = 11.00 ft

2nd Floor


<u>Floor Items</u>	unif wt (psf)	Width (ft)	Length (ft)	W (kips)	x-C.M (ft)	y-C.M (ft)	W*x (kip-ft)	W*y (kip-ft)
12" Concrete Slab	150.00	20.67	34.00	105.42	17.67	11.00	1863	1160
Misc (MEP)	10.00	20.67	34.00	7.03	17.67	11.00	124	77
Floor Open 1	-150.00	5.00	12.00	-9.00	5.17	11.17	-47	-101
Floor Open 2	-150.00	1.83	1.83	-0.50	11.33	8.58	-6	-4
Floor Open 3	-150.00	1.83	1.83	-0.50	19.83	8.58	-10	-4
Floor Open 4	-150.00	1.83	1.83	-0.50	28.33	8.58	-14	-4
Cover Plate	20.17	5.00	12.00	1.21	5.17	11.17	6	14
<u>Centrifuges</u>								
Centrifuge 1				35.00	11.33	9.75	397	341
Centrifuge 2				35.00	19.83	9.75	694	341
Centrifuge 3				35.00	28.33	9.75	992	341
<u>Walls</u>	trib height (ft)	thick (ft)	length (ft)					
Wall (above)	6.92	0.67	112.00	77.89	17.67	11.00	1376	857
Wall (below)	9.00	1.00	70.67	95.40	17.67	11.00	1686	1049
North Wall Opng	4.00	-0.67	1.00	-0.40	0.33	5.83	0	-2
North Wall Opng	4.00	-0.67	1.00	-0.40	0.33	16.17	0	-6
Sout Wall Opng	4.00	-0.67	1.00	-0.40	35.00	5.83	-14	-2
Sout Wall Opng	1.33	-0.67	1.33	-0.18	35.00	11.00	-6	-2
Sout Wall Opng	4.00	-0.67	1.00	-0.40	35.00	16.17	-14	-6
E-Wall Opng	7.17	-0.67	3.33	-2.40	2.67	21.67	-6	-52
$\Sigma =$				377.25			7020	3995

Origin at NW-Corner, x-C.M. = 18.61 ft
 Origin at NW-Corner, y-C.M. = 10.59 ft




BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Relative Rigidity


SOFT STORY CHECK (Relative Rigidity for Story Drift)




NORTH ELEVATION



WEST ELEVATION



SOUTH ELEVATION



EAST ELEVATION



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Relative Rigidity

- P = 1000 kip – applied unit force
- f_c = 4000 psi – concrete compressive strength
- E_{mc} = 519119.5 ksf – modulus of elasticity
- E_v = 207647.8 ksf – shear modulus

Cantilever at Top of Each Floor:

$$\delta_c = \frac{4P}{Et} \left[\left(\frac{H}{L} \right)^3 + 0.75 \frac{H}{L} \right]$$

Fixed at Openings:

$$\delta_f = \frac{P}{Et} \left[\left(\frac{H}{L} \right)^3 + 3 \frac{H}{L} \right]$$

	Thick (in)	Height (ft)	Length (ft)	I (ft ³)	Δ (in)	R 1/Δ	Δ _{net}	R _{story}	
South Elevation									
2nd - Roof opening(-)	8.00	13.83	22.00	592	0.0998		0.07		cantilever
	-8.00	6.5	22.00	-592	-0.0316				
wall(+)	8.00	4	5.33	8	0.0927	10.79	0.02		fix-fix
	8.00	4	9.33	45	0.0473	21.13			
	8.00	4	5.33	8	0.0927	10.79			
					ΣR =	42.70			
wall(+)	8.00	1.33	10.33	61	0.0135	74.26	0.01		fix-fix
	8.00	1.33	10.33	61	0.0135	74.26			
					ΣR =	148.51			
wall(+)	8.00	1.17	22.00	592	0.0055	180.59	0.01		fix-fix
						Wall Rigidity =>	0.10	9.62	
1st - 2nd	423.96	18	1.00	3	15.2986	0.07	15.30	0.07	cantilever
						Stiffness Ratio: 1st to 2nd =		1%	<--- NG
North Elevation									
2nd - Roof opening(-)	8.00	13.83	22.00	592	0.0998		0.07		cantilever
	-8.00	6.5	22.00	-592	-0.0316				
wall(+)	8.00	4	5.33	8	0.0927	10.79	0.02		fix-fix
	8.00	4	9.33	45	0.0473	21.13			
	8.00	4	5.33	8	0.0927	10.79			
					ΣR =	42.70			
wall(+)	8.00	2.5	22.00	592	0.0119	84.23	0.01		fix-fix
						Wall Rigidity =>	0.10	9.66	
1st - 2nd	423.96	18	1.00	3	15.2986	0.07	15.30	0.07	cantilever
						Stiffness Ratio: 1st to 2nd =		1%	<--- NG



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Relative Rigidity

West Elevation									
2 nd - Roof	8.00	13.83	35.33	2450	0.0490	20.39	0.05	20.39	cantilever
	1 st - 2 nd	12.00	18	35.33	3675	0.0476	21.03	0.05	21.03
Stiffness Ratio: 1st to 2nd =								103%	<--- OK
East Elevation									
2 nd - Roof	8.00	13.83	35.33	2450	0.0490				cantilever
	opening(-)	-8.00	7.17	35.33	-2450	-0.0214		0.03	fix-fix
wall(+)	8.00	7.17	31.00	1655	0.0245	40.84	0.02		fix-fix
	Wall Rigidity =>							0.05	19.18
1 st - 2 nd	12.00	18	35.33	3675	0.0476	21.03	0.05	21.03	cantilever
	Stiffness Ratio: 1st to 2nd =								110%



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Weak Story

WEAK STORY CHECK

$f_c =$ 4000 psi

Longitudinal Direction						
Gridline	1st Floor			2nd Floor		
	t_w (in)	L_{net} (ft)	$2(f_c)^{0.5}t_wL_{net}$ (kips)	t_w (in)	L_{net} (ft)	$2(f_c)^{0.5}t_wL_{net}$ (kips)
E-Wall	12.00	35.33	644	8.00	32.00	389
W-Wall	12.00	35.33	644	8.00	35.33	429
	Total =		1287	Total =		818

wall shear strength ratio of lower level to upper level = 157% <--- **OK**

Transverse Direction						
Gridline	1st Floor			2nd Floor		
	t_w (in)	L_{net} (ft)	$2(f_c)^{0.5}t_wL_{net}$ (kips)	t_w (in)	L_{net} (ft)	$2(f_c)^{0.5}t_wL_{net}$ (kips)
N-Wall	0.00	22.00	0	8.00	20.00	243
S-Wall	0.00	22.00	0	8.00	18.67	227
	Total =		0	Total =		470

wall shear strength ratio of lower level to upper level = 0% <--- **NG**



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Center of Rigidity

CENTER OF RIGIDITY (Net Rigidity for Transfer of Diaphragm Forces to Bottom of Wall)

Origin at Outside of N-W Wall Corner

x = Distance in N-S direction

y = Distance in E-W direction

Δ = Story drift per unit force

δ = Total Displacement per unit force

R_{Δ} = Rigidity of story drift

R_{δ} = Rigidity of Displacement

	R_{story} (1/in)	Δ_{story} (in)	δ (in)	$R_{x,wall}$	$R_{y,wall}$	x (N-S) (ft)	y (E-W) (ft)	$x \cdot R_{wall}$	$y \cdot R_{wall}$
South Elevation									
Roof	9.62	0.104	15.403	0.1	-	35.000	-	2.3	-
2nd	0.07	15.299	15.299	0.1	-	17.665	-	1.2	-
North Elevation									
Roof	9.66	0.104	15.402	0.1	-	0.330	-	0.0	-
2nd	0.07	15.299	15.299	0.1	-	17.665	-	1.2	-
West Elevation									
Roof	20.39	0.049	0.097	-	10.4	-	0.330	-	3.4
2nd	21.03	0.048	0.048	-	21.0	-	0.500	-	10.5
East Elevation									
Roof	19.18	0.052	0.100	-	10.0	-	21.670	-	217.4
2nd	21.03	0.048	0.048	-	21.0	-	21.500	-	452.1

Σ 2nd = 0.1 20.4 2.3 220.8
 Σ 1st = 0.1 42.1 2.3 462.6

C.R x-dir C.R y-dir
(ft) (ft)
Roof Diaphragm= 17.665 10.832
2nd Floor Diaphragm= 17.665 11.000



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Shear Stress

SEISMIC LOAD VERTICAL DISTRIBUTION

$C_s = 0.733$ g -- base shear coefficient
 $T = 0.263$ sec -- building period
 $k = 1.00$ -- building height exponential coefficient

Floors Level	Diaphragm Forces					Story Forces		
	w_x	h_x	$w_x \cdot h_x^k$	$\frac{w_x \cdot h_x^k}{\sum w_x \cdot h_x^k}$	F_x / W_x	$F_x = C \cdot v_x \cdot V$	V_x	M_x
	(kips)	(ft)	(kip-ft)			(kips)	(kips)	(kip-ft)
Roof	115	30.83	3546	0.36	1.14	132	0	0
2nd	390	16.50	6435	0.64	0.61	239	132	1885
1st							370	7993
Σ	505		9981	1.00		370		

Wall Shear Stress Check (Life Safety)

4.5.3.3 Shear Stress in Shear Walls The average shear stress in shear walls, v_j^{avg} , shall be calculated in accordance with Eq. (4-9).

$$v_j^{avg} = \frac{1}{M_j} \left(\frac{V_j}{A_w} \right) \quad (4-9)$$

where V_j = Story shear at level j computed in accordance with Section 4.5.2.2.

A_w = Summation of the horizontal cross-sectional area of all shear walls in the direction of loading. Openings shall be taken into consideration where computing A_w . For masonry walls, the net area shall be used. For wood-framed walls, the length shall be used rather than the area.

M_j = System modification factor; M_j shall be taken from Table 4-9.

Table 4-9. M_s Factors for Shear Walls

Wall Type	Level of Performance	
	LS	IO
Reinforced concrete, precast concrete, wood, and reinforced masonry	4.0	2.0
Unreinforced masonry	1.5	1.0

Table 4-10. M_s Factors for Diagonal Braces

Brace Type	d/t^*	Level of Performance	
		LS	IO
Tube ^a	$< 90/(F_y)^{1/2}$	6.0	2.5
	$> 190/(F_y)^{1/2}$	3.0	1.5
Pipe ^b	$< 1500/F_y^*$	6.0	2.5
	$> 6000/F_y^*$	3.0	1.5
Tension-only		3.0	1.5
All others		6.0	2.5

^aDepth-to-thickness ratio.
^bInterpolation to be used for tubes and pipes.
 $F_y^* = 1.25F_y$; expected yield stress.

$2 \cdot (f_c)^{1/2} = 2 \cdot (4000)^{1/2} = 126$ psi
 M_s ("IO") = 3.0 <-- Damage Control (between "LS" & "IO")

		t_{wall} (in)	L_{wall} (ft)	A_{wall} (in ²)	V_{shear} (psi)	
2nd Floor	N-Wall	8.00	20.00	1920	-	
	S-Wall	8.00	18.17	1744	-	
	Σ			3664	11.96	<= OK
2nd Floor	E-Wall	8.00	32.00	3072	-	
	W-Wall	8.00	35.33	3392	-	
	Σ			6464	6.78	<= OK
1st Floor	N-Wall	0.00	0.00	0	-	
	S-Wall	0.00	0.00	0	-	
	Σ			0	#####	<= NG
1st Floor	E-Wall	12.00	32.00	4608	-	
	W-Wall	12.00	35.33	5088	-	
	Σ			9696	12.73	<= OK



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in Transverse Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1
 seismic modification factors, $C_1 C_2 = 1.40$ per Table 7-3
 effective mass factor, $C_m = 1.00$ per Table 7-4
 diaphragm shear, m_1 -factor = 1.625 per Table 9-4 (between "IO" & "LS")
 diaphragm chord, m_2 -factor = 3.625 per Table 9-4 (between "IO" & "LS")
 force-delivery reduction factor, $J = 2.00$ per Sec. 7.5.2.1.2

Seismic Load Vertical Distribution

spectral acceleration, $S_a = 0.611$ g
 pseudo seismic coefficient, $C_s = C_1 C_2 C_m S_a = 0.855$ g
 building period, $T = 0.263$ sec
 building height exponential coefficient, $k = 1.00$

Floors Level	Diaphragm Force Distribution						Story Forces	
	w_x	h_x	$w_x^k h_x^k$	$\frac{w_x^k h_x^k}{\sum w_x^k h_x^k}$	F_x / W_x	$F_x = C_{vx} * V$	V_x	M_x
	(kips)	(ft)	(kip-ft)			(kips)	(kips)	(kip-ft)
Roof	78	30.83	2405	0.29	1.38	108	0	0
2nd	356	16.50	5874	0.71	0.74	263	108	1546
1st							371	7671
Σ	434		8279	1.00		371		

Roof Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} = 34.00$ ft
 diaphragm depth, $L_{diaph} = 20.67$ ft
 roof diaphragm force = 108 kips
 diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) = 2613$ plf
 allowable diaphragm shear = 1069 plf per IAPMO-ER #0217
 conversion factor for strength design, $C_{buckling} = 1.60$ per IAPMO-ER #0217
 diaph shear capacity, $Q_{CE} = 1710$ plf
 $m_1 * K * Q_{CE} = 2779$ plf

Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) = 22210$ lbs
 strength reduction factor, $\phi = 1.00$
 Number of Bars = 4 bars
 Bar Size = $\#5$
 Yield Stress $f_y = 60,000$ psi



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in Transverse Direction

$$A_{s,total} = 1.24 \text{ in}^2$$

$$\text{Tensile Capacity at Opng, } \phi T_n = 74400 \text{ lbs}$$

$$m_2 * K * Q_{CE} = 269700 \text{ lbs}$$

Masonry & Steel Strength (Tier 2 - Force Controlled)

$$\text{anchor bolt size, } d_b = 0.750 \text{ in}$$

$$\text{anchorage spacing, } s = 24.00 \text{ in}$$

$$\text{anchor bolt effective embed, } l_b = 3.50 \text{ in}$$

$$\text{anchor bolt yield stress, } f_y = 36.00 \text{ ksi}$$

$$\text{masonry compressive strength, } f_m = 1500 \text{ psi}$$

$$\text{anchor bolt shear, } Q_E = V_{bolt} = (V / 2L_{diaph}) * (s/12) = 5226 \text{ lbs /bolt}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 1866 \text{ lbs /bolt}$$

$$\text{projected area of anchor bolt shear, } A_{pv} = 38.48 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{projected area of anchor bolt tension, } A_{pt} = 76.97 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{cross section area of anchor bolt, } A_b = 0.44 \text{ in}^2 \quad \text{lbs /bolt}$$


$$\text{strength reduction factor, } \phi = 1.00$$

$$KQ_{CL} = K\phi B_{vnb} = K * \phi * 4 * A_{pv} * (f_m)^{0.5} = 5962 \text{ lbs /bolt}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 1050 * (f_m * A_b)^{1/4} = 5327 \text{ lbs /bolt}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 8 * A_{pt} * (f_m)^{0.5} = 23848 \text{ lbs /bolt}$$

$$KQ_{CL} = K\phi B_{vns} = K * \phi * 0.6 * A_b * f_y = 15904 \text{ lbs /bolt}$$



masonry breakout
 masonry crushing
 anchor bolt pryout
 steel yielding

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1873	7,442
16	2093	9,310

$$\text{effective puddle weld diameter} = 0.500 \text{ in}$$

$$\text{puddle weld spacing} = 12.00 \text{ in}$$

$$\text{puddle weld shear, } Q_E = V_{bolt} = (V / 2L_{diaph}) * (s/12) = 2613 \text{ lbs /weld}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 933 \text{ lbs /weld}$$

$$\text{allowable strength of weld} = 1257 \text{ lbs /weld}$$

$$\text{conversion factor for strength design, } C_{WELD} = 1.65 \quad \text{per IAPMO-ER \#0217}$$

$$KQ_{CL} = 2074 \text{ lbs /weld}$$



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in Transverse Direction

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.94	<--	<u>OK</u>	diaphragm shear
<u>demand capacity ratio, DCR =</u>	0.08	<--	<u>OK</u>	diaphragm chord
<u>demand capacity ratio, DCR =</u>	0.31	<--	<u>OK</u>	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.35	<--	<u>OK</u>	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.08	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.12	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.45	<--	<u>OK</u>	puddle weld strength



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Concrete Diaph in Transverse Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1

diaphragm shear, m_1 -factor = 1.375 per Table 10-13 (between "IO" & "LS")

diaphragm chord, m_2 -factor = 1.625 per Table 10-13 (between "IO" & "LS")

Roof Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} = 34.00$ ft

diaphragm depth, $L_{diaph} = 20.67$ ft

concrete diaphragm force = 263 kips

diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) = 6.36$ kips

$f'_c = 4000$ psi

diaph thick, $t = 12$ in

concrete shear capacity, $Q_{CE} = 18.21$ kips

$m_1 * K * Q_{CE} = 25.05$ kips

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) = 54.08$ kips

strength reduction factor, $\phi = 1.00$

Number of Bars = 4 bars

Bar Size = #5

Yield Stress $f_y = 60$ ksi

$A_{s,total} = 1.24$ in²

Tensile Capacity at Opng, $\phi T_n = 74.40$ kips

$m_2 * K * Q_{CE} = 120.90$ kips

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

demand capacity ratio, DCR = 0.25 <-- **OK** diaphragm shear

demand capacity ratio, DCR = 0.45 <-- **OK** diaphragm chord



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in Longitudinal Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1
 seismic modification factors, $C_1 C_2 = 1.40$ per Table 7-3
 effective mass factor, $C_m = 1.00$ per Table 7-4
 diaphragm shear, m_1 -factor = 1.625 per Table 9-4 (between "IO" & "LS")
 diaphragm chord, m_2 -factor = 3.625 per Table 9-4 (between "IO" & "LS")
 force-delivery reduction factor, $J = 2.00$ per Sec. 7.5.2.1.2

Seismic Load Vertical Distribution

spectral acceleration, $S_a = 0.611$ g
 pseudo seismic coefficient, $C_s = C_1 C_2 C_m S_a = 0.855$ g
 building period, $T = 0.263$ sec
 building height exponential coefficient, $k = 1.00$

Floors Level	Diaphragm Force Distribution					Story Forces		
	w_x	h_x	$w_x^*h_x^k$	$\frac{w_x^*h_x^k}{\sum w_x^*h_x^k}$	F_x / W_x	$F_x = C_{vx} * V$	V_x	M_x
	(kips)	(ft)	(kip-ft)			(kips)	(kips)	(kip-ft)
Roof	56	30.83	1727	0.26	1.41	79	0	0
2nd	302	16.50	4983	0.74	0.75	227	79	1130
1st							306	6182
Σ	358		6710	1.00		306		

Roof Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} = 20.67$ ft
 diaphragm depth, $L_{diaph} = 34.00$ ft
 roof diaphragm force = 79.00 kips
 diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) = 1162$ plf
 allowable diaphragm shear = 1069 plf per IAPMO-ER #0217
 conversion factor for strength design, $C_{buckling} = 1.60$ per IAPMO-ER #0217
 diaph shear capacity, $Q_{CE} = 1710$ plf
 $m_1 * K * Q_{CE} = 2779$ plf

Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) = 6003$ lbs
 strength reduction factor, $\phi = 1.00$
 Number of Bars = 4 bars
 Bar Size = #5
 Yield Stress $f_y = 60,000$ psi



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in Longitudinal Direction

$$A_{s,total} = 1.24 \text{ in}^2$$

$$\text{Tensile Capacity at Opng, } \phi T_n = 74400 \text{ lbs}$$

$$m_2 * K * Q_{CE} = 269700 \text{ lbs}$$

Masonry & Steel Strength (Tier 2 - Force Controlled)

$$\text{anchor bolt size, } d_b = 0.750 \text{ in}$$

$$\text{anchorage spacing, } s = 24.00 \text{ in}$$

$$\text{anchor bolt effective embed, } l_b = 3.50 \text{ in}$$

$$\text{anchor bolt yield stress, } f_y = 36.00 \text{ ksi}$$

$$\text{masonry compressive strength, } f_{rm} = 1500 \text{ psi}$$

$$\text{anchor bolt shear, } Q_E = V_{bolt} = (V / 2L_{diaph}) * (s/12) = 2324 \text{ lbs /bolt}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 830 \text{ lbs /bolt}$$

$$\text{projected area of anchor bolt shear, } A_{pv} = 38.48 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{projected area of anchor bolt tension, } A_{pt} = 76.97 \text{ in}^2 \quad \text{lbs /bolt}$$

$$\text{cross section area of anchor bolt, } A_b = 0.44 \text{ in}^2 \quad \text{lbs /bolt}$$


$$\text{strength reduction factor, } \phi = 1.00$$

$$KQ_{CL} = K\phi B_{vnb} = K * \phi * 4 * A_{pv} * (f'_m)^{0.5} = 5962 \text{ lbs /bolt}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 1050 * (f'_m * A_b)^{1/4} = 5327 \text{ lbs /bolt}$$

$$KQ_{CL} = K\phi B_{vnpry} = K * \phi * 8 * A_{pt} * (f'_m)^{0.5} = 23848 \text{ lbs /bolt}$$

$$KQ_{CL} = K\phi B_{vns} = K * \phi * 0.6 * A_b * f_y = 15904 \text{ lbs /bolt}$$



masonry breakout
 masonry crushing
 anchor bolt pryout
 steel yielding

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1873	7,442
16	2093	9,310

$$\text{effective puddle weld diameter} = 0.500 \text{ in}$$

$$\text{puddle weld spacing} = 12.00 \text{ in}$$

$$\text{puddle weld shear, } Q_E = V_{bolt} = (V / 2L_{diaph}) * (s/12) = 1162 \text{ lbs /weld}$$

$$Q_{UF} = Q_E / (J * C_1 * C_2) = 415 \text{ lbs /weld}$$

$$\text{allowable strength of weld} = 1257 \text{ lbs /weld}$$

$$\text{conversion factor for strength design, } C_{WELD} = 1.65$$

$$KQ_{CL} = 2074 \text{ lbs /weld}$$

per IAPMO- allowable multiplied by 1.4 for



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Roof Diaph Shear in Longitudinal Direction

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.42	<--	<u>OK</u>	diaphragm shear
<u>demand capacity ratio, DCR =</u>	0.02	<--	<u>OK</u>	diaphragm chord
<u>demand capacity ratio, DCR =</u>	0.14	<--	<u>OK</u>	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.16	<--	<u>OK</u>	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.03	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.05	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.20	<--	<u>OK</u>	puddle weld strength



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Concrete Diaph in Longitudinal Direction

DIAPHRAGM IN-PLANE SHEAR & CONNECTION

Knowledge factor, $K = 1.00$ per Table 6-1

diaphragm shear, m_1 -factor = 1.375 per Table 10-13 (between "IO" & "LS")

diaphragm chord, m_2 -factor = 1.625 per Table 10-13 (between "IO" & "LS")

Roof Diaphragm Shear (Tier 2 - Deformation Controlled)

diaphragm span, $L_{span} = 34.00$ ft

diaphragm depth, $L_{diaph} = 20.67$ ft

concrete diaphragm force = 227 kips

diaph shear, $Q_{UD} = F_d / (2 * L_{diaph}) = 5.49$ kips

$f'_c = 4000$ psi

diaph thick, $t = 12$ in

concrete shear capacity, $Q_{CE} = 18.21$ kips

$m_1 * K * Q_{CE} = 25.05$ kips

Chord Force (Tier 2 - Deformation Controlled)

chord force, $Q_{UD} = (F_d * L_{span}) / (8 * L_{diaph}) = 46.68$ kips

strength reduction factor, $\phi = 1.00$

Number of Bars = 4 bars

Bar Size = #5

Yield Stress $f_y = 60$ ksi

$A_{s,total} = 1.24$ in²

Tensile Capacity at Opng, $\phi T_n = 74.40$ kips

$m_2 * K * Q_{CE} = 120.90$ kips

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

demand capacity ratio, DCR = 0.22 <-- **OK** diaphragm shear

demand capacity ratio, DCR = 0.39 <-- **OK** diaphragm chord



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Joist Supports

WALL ANCHORAGE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).



$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$

Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall thickness, t_w = 8.00 in
- wall height to diaphragm, h_w = 13.83 ft
- parapet height, h_p = 1.50 ft
- unit weight of wall, w_p = 150.00 pcf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- beam spacing = 5.67 ft
- wall out-of-plane load = 771 lbs/ ft
- wall anchorage force, T_c = 4370 lbs

<-- Damage Control (between "LS" & "IO")

Anchor Bolts



Steel Strength

$$V_{sa} = A_{se,V} f_{uta}$$

$$\phi V_{steel} \geq V_{ua}$$

$A_{se,V}$ [in. ²]	f_{uta} [psi]	V_{sa} [lb]
0.31	65000	19955



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Joist Supports

Pryout Strength

$$V_{cpg} = k_{cp} \left[\left(\frac{A_{Nc}}{A_{Ncn}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right]$$

A_{Nc} [in. ²]	A_{Ncn} [in. ²]	$\psi_{ec,N}$	$\psi_{ed,N}$	$\psi_{c,N}$	$\psi_{cp,N}$	N_b [lb]	V_{cpg} [lb]
192.00	324.00	1.000	1.000	0.833	1.000	22308	22033

Concrete edge failure in direction x+

$$V_{cbg} = \left(\frac{A_{Vc}}{A_{Vcd}} \right) \psi_{ec,V} \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{parallel,V} V_b$$

A_{Vc} [in. ²]	A_{Vcd} [in. ²]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	V_b [lb]	V_{cbg} [lb]
108.00	72.00	1.000	1.000	1.000	4554	6831

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

$V_{sa} = 39,910$ lbs steel shear strength for 2-bolts
 $V_{cpg} = 22,033$ lbs pryout strength
 $V_{cbg} = 6,831$ lbs concrete edge failure

pryout overstrength factor, $\Omega_{cpg} = 2.5$ concrete governed
 concrete edge failure overstrength factor, $\Omega_{cbg} = 2.5$ concrete governed

demand capacity ratio, DCR = 0.11 <-- **OK** steel shear strength
demand capacity ratio, DCR = 0.50 <-- **OK** pryout strength
demand capacity ratio, DCR = 1.60 <-- **NG** concrete edge failure



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

WALL ANCHORAGE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$

Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

wall thickness, t_w = 8.00 in
 wall height to diaphragm, h_w = 13.83 ft
 parapet height, h_p = 1.50 ft



unit weight of wall, w_p = 150.00 pcf
 Ψ ("IO") = 1.50
 S_{XS} = 0.611 g

<-- Damage Control (between "LS" & "IO")

anchor bolt spacing = 24.00 in
 wall out-of-plane load = 771 lbs/ ft

wall anchorage force, T_c = 1542 lbs /bolt

Anchor Bolts (Assumed 3.5" Min Embed)



Anchor Bolt Strength Parameters

anchor bolt diameter, d_a = 0.75 in
 tensile stress area, A_{se} = 0.33 in²
 anchor bolt embed, h_{ef} = 3.50 in

minimum embed assumed

specified anchor bolt strength, f_{uta} = 58,000 psi
 concrete strength, f'_c = 4,000 psi



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

$$k_c = 17.00$$

$$\lambda = 1.00$$

$$N_b = 7,040 \text{ lbs /bolt}$$

$$A_{Nc} = 110.25 \text{ in}^2$$

$$A_{Nco} = 110.25 \text{ in}^2$$

$$\Psi_{ed,N} = 1.00$$

$$\Psi_{c,N} = 1.00$$

$$\Psi_{CP,N} = 1.00$$

$$\text{steel strength, } N_{sa} = 19,372 \text{ lbs /bolt}$$

$$\text{concrete pullout strength, } N_{cb} = 7,040 \text{ lbs /bolt}$$

$$\text{concrete overstrength factor, } \Omega_{cb} = 2.5 \quad \text{concrete governed}$$

Ledger Angle

$$\text{yield strength, } f_y = 36,000 \text{ psi}$$

$$\text{ledger angle thick, } t = 0.31 \text{ in}$$

$$\text{moment arm, } l_{arm} = 1.19 \text{ in} \quad \text{distance from top of ledger to center of AB}$$

$$\text{effective width, } b = 3.00 \text{ in}$$

$$\text{section modulus, } S = 0.0488 \text{ in}^3$$

$$\text{shear stress} = 1,645 \text{ psi}$$

$$\text{moment} = 1,836 \text{ lb-in}$$

$$\text{flexural stress} = 37,592 \text{ psi}$$

Numerical Acceptance Criteria

$$\text{acceptance criteria (max allowable DCR)} = 1.00$$

<u>demand capacity ratio, DCR</u> =	0.08	<--	OK	steel strength
<u>demand capacity ratio, DCR</u> =	0.55	<--	OK	concrete strength
<u>demand capacity ratio, DCR</u> =	0.05	<--	OK	ledger shear
<u>demand capacity ratio, DCR</u> =	1.04	<--	NG	ledger flexural




BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK PROPERTIES (ASTM A653, Grade 33)

Modulus of Elasticity, E = 29500 ksi

Yield Strength, F_y = 38 ksi

Ultimate Strength, F_u = 52 ksi



Steel Deck = HSB-36

Gage = 20

Deck Span, L = 5.67 ft

Gage	Weight		Section Properties per ft (m) of width		
	Galv psf N/m ²	Painted psf N/m ²	I in. ⁴ mm ⁴	+ S in. ³ mm ³	- S in. ³ mm ³
22	1.9	1.8	0.175	0.187	0.198
	91.0	86.2	238,978	10,054	10,645
20	2.3	2.2	0.216	0.235	0.248
	110.1	105.3	294,967	12,634	13,333
18	2.9	2.8	0.302	0.322	0.335
	138.9	134.1	412,408	17,312	18,011
16	3.5	3.4	0.377	0.411	0.417
	167.6	162.8	514,827	22,097	22,419

DESIGN LOAD (Service Level)

Roof Load, w = 30 psf --- steel deck gravity

Wall Out-of-Plane Load, F = 771 lb/ft --- deck axial load

Design Flexural Moment :

Neutral Axis, y_b = 0.919 in

M_{roof} = 1.447 kip-in /ft --- moment due to gravity load = w * L² / 8

M_{ecc} = 0.506 kip-in /ft --- moment due to wall out-of-plane = (F/1.4) * y_b

M_{total} = 1.953 kip-in /ft

ARC-SPOT WELD (WALL OUT-OF-PLANE)

Effective Weld Size Dia, d_e = 1/2 in

Weld Pattern = 5 per 36/sheet

Allowable Weld Capacity = 2.10 kip/ft <= OK

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

Allowable shear strength for 1/2" effective diameter puddle welds.



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE COMPRESSION

Effective Length Factor, $K = 1.00$
 Deck Thickness, $t = 0.0359$ in
 Width of Top Flange, $w = 3.50$ in
 Gross Section Area, $A_g = 0.599$ in²/ft
 radius of gyration, $r = 0.601$ in
 $KL/r = 113$
 $\lambda_c = 1.29$
 $F_n = 18.85$ ksi

Effective Width of Top & Bottom Flange Under Compression (Assume Bottom Flange Fully Effective)

$\Omega_c = 1.8$ --- factor of safety
 $k = 4$ $k =$ Plate buckling coefficient
 = 4 for stiffened elements supported by a web on each longitudinal edge.
 Values for different types of elements are given in the applicable sections.
 Poisson's Ratio = 0.300
 $F_{cr} = 11.22$
 $\lambda = 1.296$
 $\rho = 0.641$
 Effective Flange Width, $b = 2.242$ in --- effective flange width = ρw
 Effective Section Area, $A_e = 0.554$ in²/ft --- effective section area
 $P_n / \Omega_c = 5.80$ kip /ft **<= OK** --- $A_e * F_n / \Omega_c$

STEEL DECK ALLOWABLE TENSION

Gross Section Area, $A_g = 0.599$ in²/ft
 $\Omega_{T1} = 1.67$
 $T_{n1} / \Omega_{T1} = 13.63$ kip /ft **<= OK** --- $A_g * F_y / \Omega_{T1}$
 $\Omega_{T2} = 2.00$
 $T_{n2} / \Omega_{T2} = 15.57$ kip /ft **<= OK** --- $A_g * F_u / \Omega_{T2}$



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Area 12 - Sludge Dewatering Building JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE BENDING

$$\Omega_b = 1.67$$

$$S_+ = 0.235 \text{ in}^3/\text{ft} \quad \text{--- positive section modulus}$$

$$\frac{M_n}{\Omega_b} = 5.35 \text{ kip-in /ft} \quad \leq \text{OK} \quad \text{--- } S_+ * F_y / \Omega_b$$

COMBINED LOAD INTERACTION

Bending-Tension Interaction:

$$\text{DCR} = 0.422 \quad \leq \text{OK}$$

Bending-Compression Interaction:

$$\text{DCR} = 0.498 \quad \leq \text{OK}$$

Areas 13, 18, 19 - Chemical / Admin / Ozone Building
ASCE 41 Evaluation

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Seismic

SEISMIC HAZARD LEVEL & BASIC PERFORMANCE OBJECTIVE

Note: **4.1.2 Seismic Hazard Level** The Seismic Hazard Level for the Tier 1 screening shall be BSE-1E per Table 2-1 for the Basic Performance Objective for Existing Buildings (BPOE).

Table 2-1. Basic Performance Objective for Existing Buildings (BPOE)

Risk Category	Tier 1*	Tier 2*	Tier 3	
	BSE-1E	BSE-1E	BSE-1E	BSE-2E
I & II	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Life Safety Structural Performance Life Safety Nonstructural Performance (3-C)	Collapse Prevention Structural Performance Nonstructural Performance Not Considered (5-D)
III	See footnote b for Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Damage Control Structural Performance Position Retention Nonstructural Performance (2-B)	Limited Safety Structural Performance Nonstructural Performance Not Considered (4-D)
IV	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Immediate Occupancy Structural Performance Position Retention Nonstructural Performance (1-B)	Life Safety Structural Performance Nonstructural Performance Not Considered (3-D)

*For Tier 1 and 2 assessments, seismic performance for the BSE-2E is not explicitly evaluated.
 *For Risk Category III, the Tier 1 screening checklists shall be based on the Life Safety Performance Level (S-3), except that checklist statements using the Quick Check procedures of Section 4.5.3 shall be based on MS-factors and other limits that are an average of the values for Life Safety and Immediate Occupancy.

BUILDING PERIOD (SECTION 4.5.2.4)

building height, h_n = 16.00 ft
 building period adjustment factor, C_t = 0.020
 effective viscous damping ratio, β = 0.75
 fundamental building period, T = 0.160 sec

SEISMIC PARAMETERS

Building Type = RM1 Table 3-1
 modification factor, C = 1.00 Table 4-8

Table 4-8. Modification Factor, C

Building Type*	Number of Stories			
	1	2	3	≥4
Wood (W1, W1a, W2)	1.3	1.1	1.0	1.0
Moment frame (S1, S3, C1, PC2a)	1.3	1.1	1.0	1.0
Shear wall (S4, S5, C2, C3, PC1a, PC2, RM2, URMa)	1.4	1.2	1.1	1.0
Braced frame (S2)	1.3	1.1	1.0	1.0
Unreinforced masonry (URM)	1.0	1.0	1.0	1.0
Flexible diaphragms (S1a, S2a, S5a, C2a, C3a, PC1, RM1)	1.0	1.0	1.0	1.0

*Defined in Table 3-1.

spectral acceleration at 1-sec for BSE-1E, S_{x1} = 0.372 g USGS Seismic Map
 spectral acceleration at short period for BSE-1E, S_{xs} = 0.611 g USGS Seismic Map
 spectral acceleration, S_a = 0.611 g $S_a = \frac{S_{x1}}{T}$ but S_a shall not exceed S_{xs} .
 base shear coefficient, V = 0.611 W Eq 4-1



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening) - Building Weight & Base Shear

DEAD LOAD (Seismic Weight)

Roof Weight

Roofing	=	5.00	psf
Metal Roof Deck	=	3.00	psf
Steel Joist	=	7.00	psf
Miscellaneous (MEP)	=	5.00	psf
Total =			20.00 psf

Total Roof Area = 13255.00 sq.ft

Total Roof Weight = 265.10 kips

	UW (psf)	Trib Ht (ft)	Length (ft)		
Area 13	84.00	8.00	209.34	=	140.68 kips
Area 18	84.00	8.00	247.32	=	166.20 kips
Area 19	84.00	8.00	130.00	=	87.36 kips

Roof Seismic Weight = 659.34 kips

Seismic Weight & Base Shear

Base Shear Coefficient	=	0.611	g
Total Seismic Weight	=	659	kips
Design Base Shear	=	403	kips

LIVE LOAD

Roof Live Load = 20.0 psf



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Shear Stress

SEISMIC LOAD VERTICAL DISTRIBUTION

Wall Shear Stress Check

4.5.3.3 Shear Stress in Shear Walls The average shear stress in shear walls, v_j^{avg} , shall be calculated in accordance with Eq. (4-9).

$$v_j^{avg} = \frac{1}{M_s} \left(\frac{V_j}{A_w} \right) \quad (4-9)$$

where V_j = Story shear at level j computed in accordance with Section 4.5.2.2.

A_w = Summation of the horizontal cross-sectional area of all shear walls in the direction of loading. Openings shall be taken into consideration where computing A_w . For masonry walls, the net area shall be used. For wood-framed walls, the length shall be used rather than the area.

M_s = System modification factor; M_s shall be taken from Table 4-9.

$v_{s,allow} = 70$ psi
 $M_s = 3.0$ <-- Damage Control (between "LS" & "IO")

Table 4-9. M_s Factors for Shear Walls

Wall Type	Level of Performance	
	LS	IO
Reinforced concrete, precast concrete, wood, and reinforced masonry	4.0	2.0
Unreinforced masonry	1.5	1.0

Table 4-10. M_s Factors for Diagonal Braces

Brace Type	d/t^*	Level of Performance	
		LS	IO
Tube ^b	$<90/(F_y)^{1/2}$	6.0	2.5
	$>190/(F_y)^{1/2}$	3.0	1.5
Pipe ^b	$<1500/F_{ye}$	6.0	2.5
	$>6000/F_{ye}$	3.0	1.5
Tension-only		3.0	1.5
All others		6.0	2.5

*Depth-to-thickness ratio.
^bInterpolation to be used for tubes and pipes.
 $F_{ye} = 1.25F_y$; expected yield stress.

	t_{wall} (in)	$L_{net, wall}$ (ft)	A_{wall} (in ²)	V (kips)	v_{shear} (psi)	
Walls in NS-Dir	7.63	271.19	24814	403.00	5.41	<= OK
Walls in EW-Dir	7.63	266.00	24339	403.00	5.52	<= OK



Engineers...Working Wonders With Water™

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET
 CHKD BY DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in NS-Dir

DIAPHRAGM IN-PLANE SHEAR CONNECTION

Knowledge factor, K =	1.00	per Table 6-1
seismic modification factors, C ₁ C ₂ =	1.40	per Table 7-3
effective mass factor, C _m =	1.00	per Table 7-4
diaphragm shear, m ₁ -factor =	1.625	per Table 9-4 (between "IO" & "LS")
diaphragm chord, m ₂ -factor =	3.625	per Table 9-4 (between "IO" & "LS")
force-delivery reduction factor, J =	2.00	per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

spectral acceleration, S _a =	0.611 g	
building seismic weight, W =	659 kips	
pseudo seismic force, V = F _d = C ₁ C ₂ C _m S _a W =	564 kips	
total length of diaph support in NS-Dir, L _{support} =	366 ft	"Combined Total Length of Supports"
diaph shear, Q _{UD} = F _d / L _{support} =	1539 plf	
allowable diaphragm shear =	1069 plf	per IAPMO-ER #0217
conversion factor for strength design, C _{buckling} =	1.60	per IAPMO-ER #0217
diaph shear capacity, Q _{CE} =	1710 plf	
m ₁ *K*Q _{CE} =	2779 plf	


Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

Note: Chord force okay by inspection

Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, d _b =	0.750 in	
anchorage spacing, s =	24.00 in	
anchor bolt effective embed, l _b =	3.50 in	
anchor bolt yield stress, f _y =	36.00 ksi	
masonry compressive strength, f _m =	1500 psi	
anchor bolt shear, Q _E = V _{bolt} = (V / L _{support})*(s/12) =	3078 lbs /bolt	
Q _{UF} = Q _E / (J*C ₁ *C ₂) =	1099 lbs /bolt	
projected area of anchor bolt shear, A _{pv} =	38.48 in ²	lbs /bolt
projected area of anchor bolt tension, A _{pt} =	76.97 in ²	lbs /bolt
cross section area of anchor bolt, A _b =	0.44 in ²	lbs /bolt
φB _{vnb} = 1.0*4*A _{pv} *(f _m) ^{0.5} =	5962 lbs /bolt	OK masonry breakout
φB _{vnpry} = 1.0*1050*(f _m *A _b) ^{1/4} =	5327 lbs /bolt	OK masonry crushing
φB _{vnpry} = 1.0*8*A _{pt} *(f _m) ^{0.5} =	23848 lbs /bolt	OK anchor bolt pryout
φB _{vns} = 1.0*0.6*A _b *f _y =	15904 lbs /bolt	OK steel yielding





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in NS-Dir

DIAPHRAGM IN-PLANE SHEAR CONNECTION

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1873	7,442
16	2093	9,310

effective puddle weld diameter = 0.500 in
 puddle weld spacing = 12.00 in

puddle weld shear, $Q_E = V_{\text{bolt}} = (V / L_{\text{support}}) * (s/12) = 1539 \text{ lbs /weld}$
 $Q_{UF} = Q_E / (J * C_1 * C_2) = 550 \text{ lbs /weld}$

allowable strength of weld = 1257 lbs /weld
 conversion factor for strength design, $C_{WELD} = 1.65$ per IAPMO-ER #0217
 strength of puddle weld = 2074 lbs /weld

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.55	<--	OK	diaphragm shear
<u>demand capacity ratio, DCR =</u>	0.18	<--	OK	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.21	<--	OK	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.05	<--	OK	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.07	<--	OK	steel yielding
<u>demand capacity ratio, DCR =</u>	0.26	<--	OK	puddle weld strength



Engineers...Working Wonders With Water™

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET
 CHKD BY DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in EW-Dir

DIAPHRAGM IN-PLANE SHEAR CONNECTION

Knowledge factor, K =	1.00	per Table 6-1
seismic modification factors, C ₁ C ₂ =	1.40	per Table 7-3
effective mass factor, C _m =	1.00	per Table 7-4
diaphragm shear, m ₁ -factor =	1.625	per Table 9-4 (between "IO" & "LS")
diaphragm chord, m ₂ -factor =	3.625	per Table 9-4 (between "IO" & "LS")
force-delivery reduction factor, J =	2.00	per Sec. 7.5.2.1.2

Diaphragm Shear (Tier 2 - Deformation Controlled)

spectral acceleration, S _a =	0.611 g	
building seismic weight, W =	659 kips	
pseudo seismic force, V = F _d = C ₁ C ₂ C _m S _a W =	564 kips	
total length of diaph support in NS-Dir, L _{support} =	291 ft	"Combined Total Length of Supports"
diaph shear, Q _{UD} = F _d / L _{support} =	1937 plf	
allowable diaphragm shear =	1069 plf	per IAPMO-ER #0217
conversion factor for strength design, C _{buckling} =	1.60	per IAPMO-ER #0217
diaph shear capacity, Q _{CE} =	1710 plf	
m ₁ *K*Q _{CE} =	2779 plf	


Note: Diaph shear capacity from Verco HSB-36 (20GA; 6'-0" span; weld pattern 36/5; TSW @ 12")

Chord Force (Tier 2 - Deformation Controlled)

Note: Chord force okay by inspection

Masonry & Steel Strength (Tier 2 - Force Controlled)

anchor bolt size, d _b =	0.750 in	
anchorage spacing, s =	24.00 in	
anchor bolt effective embed, l _b =	3.50 in	
anchor bolt yield stress, f _y =	36.00 ksi	
masonry compressive strength, f _m =	1500 psi	
anchor bolt shear, Q _E = V _{bolt} = (V / L _{support})*(s/12) =	3874 lbs /bolt	
Q _{UF} = Q _E / (J*C ₁ *C ₂) =	1384 lbs /bolt	
projected area of anchor bolt shear, A _{pv} =	38.48 in ²	lbs /bolt
projected area of anchor bolt tension, A _{pt} =	76.97 in ²	lbs /bolt
cross section area of anchor bolt, A _b =	0.44 in ²	lbs /bolt
φB _{vnb} = 1.0*4*A _{pv} *(f _m) ^{0.5} =	5962 lbs /bolt	OK masonry breakout
φB _{vnpry} = 1.0*1050*(f _m *A _b) ^{1/4} =	5327 lbs /bolt	OK masonry crushing
φB _{vnpry} = 1.0*8*A _{pt} *(f _m) ^{0.5} =	23848 lbs /bolt	OK anchor bolt pryout
φB _{vns} = 1.0*0.6*A _b *f _y =	15904 lbs /bolt	OK steel yielding





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 - Damage Control - Diaphragm Shear in EW-Dir

DIAPHRAGM IN-PLANE SHEAR CONNECTION

Boundary Puddle Weld Strength (Tier 2 - Force Controlled)

Arc Spot Welds: Spacing of arc spot welds at collectors parallel to the deck ribs should be based on the shear to be transferred. Table 5 lists allowable shear strength in pounds (newtons) for 1/2 in. (13 mm) effective diameter welds.

Table 5: Allowable Shear Strength per Weld

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1873	7,442
16	2093	9,310

effective puddle weld diameter = 0.500 in
 puddle weld spacing = 12.00 in

puddle weld shear, $Q_E = V_{\text{bolt}} = (V / L_{\text{support}}) * (s/12) = 1937 \text{ lbs /weld}$
 $Q_{UF} = Q_E / (J * C_1 * C_2) = 692 \text{ lbs /weld}$

allowable strength of weld = 1257 lbs /weld
 conversion factor for strength design, $C_{WELD} = 1.65$ per IAPMO-ER #0217
 strength of puddle weld = 2074 lbs /weld

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.70	<--	OK	diaphragm shear
<u>demand capacity ratio, DCR =</u>	0.23	<--	OK	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.26	<--	OK	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.06	<--	OK	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.09	<--	OK	steel yielding
<u>demand capacity ratio, DCR =</u>	0.33	<--	OK	puddle weld strength



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Joist Supports

WALL ANCHORAGE FORCE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$

Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall height to diaphragm, h_w = 16.00 ft
- parapet height, h_p = 2.00 ft
- unit weight of wall, w_p = 84.00 psf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- beam spacing = 6.00 ft
- wall out-of-plane load = 770 lbs/ ft
- wall anchorage force, T_c = 4619 lbs

<-- Damage Control (between "LS" & "IO")

Masonry & Steel Strength

- number of anchor bolts = 2
- anchor bolt size = 0.625 in
- anchor bolt embed = 6.00 in
- anchor bolt edge distance = 3.81 in
- anchorage spacing = 6.00 in
- anchor bolt yield stress, f_y = 36.00 ksi
- masonry compressive strength, f_m = 1500 psi
- projected area of anchor bolt shear, A_{pv} = 46 in²
- projected area of anchor bolt tension, A_{pt} = 137 in²
- cross section area of anchor bolt, A_b = 0.31 in²


$$\phi B_{vnb} = 1.0 * 4 * A_{pv} * (f_m)^{0.5} = 7,074 \text{ lbs}$$

$$\phi B_{vnpry} = 1.0 * 1050 * (f_m * A_b)^{1/4} = 9,726 \text{ lbs}$$

$$\phi B_{vnpry} = 1.0 * 8 * A_{pt} * (f_m)^{0.5} = 42,525 \text{ lbs}$$

$$\phi B_{vns} = 1.0 * 0.6 * A_b * f_y = 13,254 \text{ lbs}$$

- masonry breakout
- masonry crushing
- anchor bolt pryout
- steel yielding





BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Joist Supports

WALL ANCHORAGE FORCE

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.65	<--	OK	masonry breakout
<u>demand capacity ratio, DCR =</u>	0.47	<--	OK	masonry crushing
<u>demand capacity ratio, DCR =</u>	0.11	<--	OK	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.35	<--	OK	steel yielding



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

WALL ANCHORAGE FORCE

4.5.3.7 Flexible Diaphragm Connection Forces The horizontal seismic forces associated with the connection of a flexible diaphragm to either concrete or masonry walls, T_c , shall be calculated in accordance with Eq. (4-13).

$$T_c = \psi S_{XS} w_p A_p \quad (4-13)$$


Where w_p = unit weight of the wall;
 A_p = area of wall tributary to the connection;
 ψ = 1.2 for Life Safety Performance Level and 1.8 for Immediate Occupancy Performance Level; and
 S_{XS} = value specified in Section 4.5.2.3.

- wall height to diaphragm, h_w = 16.00 ft
- parapet height, h_p = 2.00 ft
- unit weight of wall, w_p = 84.00 psf
- Ψ ("IO") = 1.50
- S_{XS} = 0.611 g
- anchor bolts spacing = 24.00 in
- wall out-of-plane load = 770 lbs/ ft
- wall anchorage force, T_c = 1540 lbs /bolt

<-- Damage Control (between "LS" & "IO")

Masonry & Steel Strength

- anchor bolt size = 0.750 in
- anchor bolt embed = 3.50 in
- anchor bolt edge distance = 3.81 in
- anchorage spacing = 6.00 in
- anchor bolt yield stress, f_y = 36.00 ksi
- masonry compressive strength, f_m = 1500 psi
- projected area of anchor bolt tension, A_{pt} = 38 in²
- cross section area of anchor bolt, A_b = 0.44 in²



$$\phi B_{Vnpry} = 1.0 * 4 * A_{pt} * (f_m)^{0.5} = 5,962 \text{ lbs}$$

$$\phi B_{Vns} = 1.0 * A_b * f_y = 15,904 \text{ lbs}$$

anchor bolt pryout
 steel yielding

Ledger Angle

- yield strength, f_y = 36,000 psi
- ledger angle thick, t = 0.31 in
- moment arm, l_{arm} = 1.19 in
- effective width, b = 3.00 in
- section modulus, S = 0.0488 in³

distance from top of ledger to center of AB

- shear stress = 1,642 psi
- moment = 1,832 lb-in
- flexural stress = 37,525 psi



Engineers...Working Wonders With Water™

BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Ledger

WALL ANCHORAGE FORCE

Numerical Acceptance Criteria

acceptance criteria (max allowable DCR) = 1.00

<u>demand capacity ratio, DCR =</u>	0.26	<--	<u>OK</u>	anchor bolt pryout
<u>demand capacity ratio, DCR =</u>	0.10	<--	<u>OK</u>	steel yielding
<u>demand capacity ratio, DCR =</u>	0.05	<--	<u>OK</u>	ledger shear
<u>demand capacity ratio, DCR =</u>	1.04	<--	<u>NG</u>	ledger flexural



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck


STEEL DECK PROPERTIES (ASTM A653, Grade 33)

Modulus of Elasticity, E = 29500 ksi

Yield Strength, F_y = 38 ksi

Ultimate Strength, F_u = 52 ksi

PLB™-36
HSB®-36



Steel Deck = HSB-36

Gage = 20

Deck Span, L = 6 ft

Gage	Weight		Section Properties per ft (m) of width		
	Galv psf N/m ²	Painted psf N/m ²	I in. ⁴ mm ⁴	+ S in. ³ mm ³	- S in. ³ mm ³
22	1.9	1.8	0.175	0.187	0.198
	91.0	86.2	238,978	10,054	10,645
20	2.3	2.2	0.216	0.235	0.248
	110.1	105.3	294,967	12,634	13,333
18	2.9	2.8	0.302	0.322	0.335
	138.9	134.1	412,408	17,312	18,011
16	3.5	3.4	0.377	0.411	0.417
	167.6	162.8	514,827	22,097	22,419

DESIGN LOAD (Service Level)

Roof Load, w = 30 psf --- steel deck gravity

Wall Out-of-Plane Load, F = 770 lb/ft --- deck axial load

Design Flexural Moment :

Neutral Axis, y_b = 0.919 in

M_{roof} = 1.620 kip-in /ft --- moment due to gravity load = w * L² / 8

M_{ecc} = 0.506 kip-in /ft --- moment due to wall out-of-plane = (F/1.4) * y_b

M_{total} = 2.126 kip-in /ft

ARC-SPOT WELD (WALL OUT-OF-PLANE)

Effective Weld Size Dia, d_e = 1/2 in

Weld Pattern = 5 per 36/sheet

Allowable Weld Capacity = 2.10 kip/ft <= OK

Deck Gage	lb	N
22	1047	4,657
20	1257	5,591
18	1673	7,442
16	2093	9,310

Allowable shear strength for 1/2" effective diameter puddle welds.



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE COMPRESSION

Effective Length Factor, $K = 1.00$
 Deck Thickness, $t = 0.0359$ in
 Width of Top Flange, $w = 3.50$ in
 Gross Section Area, $A_g = 0.599$ in²/ft
 radius of gyration, $r = 0.601$ in
 $KL/r = 120$
 $\lambda_c = 1.37$
 $F_n = 17.33$ ksi

Effective Width of Top & Bottom Flange Under Compression (Assume Bottom Flange Fully Effective)

$\Omega_c = 1.8$ --- factor of safety
 $k = 4$ $k =$ Plate buckling coefficient
 = 4 for stiffened elements supported by a web on each longitudinal edge.
 Values for different types of elements are given in the applicable sections.
 Poisson's Ratio = 0.300
 $F_{cr} = 11.22$
 $\lambda = 1.243$
 $\rho = 0.662$
 Effective Flange Width, $b = 2.318$ in --- effective flange width = ρw
 Effective Section Area, $A_e = 0.557$ in²/ft --- effective section area
 $P_n / \Omega_c = 5.36$ kip /ft **<= OK** --- $A_e * F_n / \Omega_c$

STEEL DECK ALLOWABLE TENSION

Gross Section Area, $A_g = 0.599$ in²/ft
 $\Omega_{T1} = 1.67$
 $T_{n1} / \Omega_{T1} = 13.63$ kip /ft **<= OK** --- $A_g * F_y / \Omega_{T1}$
 $\Omega_{T2} = 2.00$
 $T_{n2} / \Omega_{T2} = 15.57$ kip /ft **<= OK** --- $A_g * F_u / \Omega_{T2}$



BY: C. Che DATE Sep-17 CLIENT Wilamette River WTP SHEET _____
 CHKD BY _____ DESCRIPTION Areas 13,18,19 - Buildings JOB NO. 10721A.00
 DESIGN TASK ASCE 41 (Tier 1 Screening "Damage Control") - Wall Anchorage at Metal Deck

STEEL DECK ALLOWABLE BENDING

$$\Omega_b = 1.67$$

$$S_+ = 0.235 \text{ in}^3/\text{ft} \quad \text{--- positive section modulus}$$

$$\frac{M_n}{\Omega_b} = 5.35 \text{ kip-in/ft} \quad \leq \text{OK} \quad \text{--- } S_+ * F_y / \Omega_b$$

COMBINED LOAD INTERACTION

Bending-Tension Interaction:

$$\text{DCR} = 0.454 \quad \leq \text{OK}$$

Bending-Compression Interaction:

$$\text{DCR} = 0.541 \quad \leq \text{OK}$$

Appendix C

SURGE TRANSIENT ANALYSIS AND
PRE-DESIGN RECOMMENDATIONS
TECHNICAL MEMORANDUM



City of Wilsonville & City of Sherwood

Willamette River Water Treatment Plant 2017 Master Plan Update

TECHNICAL MEMORANDUM SURGE TRANSIENT ANALYSIS AND PRE-DESIGN RECOMMENDATIONS

FINAL | January 2018





City of
Wilsonville
in Oregon



City of
Sherwood
Oregon

City of Wilsonville and City of Sherwood
Willamette River Water Treatment Plant
2017 Master Plan Update

TECHNICAL MEMORANDUM
SURGE TRANSIENT ANALYSIS AND
PRE-DESIGN RECOMMENDATIONS



EXPIRES: 12-31-2018



EXPIRES: 07-31-2018

Contents

1.1	Introduction	1
1.1.1	Model Development	1
1.2	Surge Mitigation Devices	2
1.3	Hydraulic Transient Analysis and Results	3
1.3.1	No Sherwood Demand (Scenarios 1 and 2)	3
1.3.2	Hydropneumatic Tank Sizing (Scenarios 3 to 6)	10
1.4	Summary and Recommendations	14

Tables

Table 1	Summary of Hydraulic Transient Analysis Demand Scenarios	1
Table 2	Summary of Hydropneumatic Tank Sizing	10
Table 3	Summary of Budgetary Hydropneumatic Tank Costs (2017\$)	15

Figures

Figure 1	12.5 MGD WRWTP Flow – No Flow to Sherwood	4
Figure 2	15.0 MGD WRWTP Flow – No Flow to Sherwood	5
Figure 3	Pressure History Model Junction 3860 – No Flow to Sherwood	6
Figure 4	Pressure History Model Junction 4116 – No Flow to Sherwood	6
Figure 5	Pressure History Model Junction 4604 – No Flow to Sherwood	7
Figure 6	Pressure History Model Junction 4610 – No Flow to Sherwood	7
Figure 7	Pressure History Model Junction 4618 – No Flow to Sherwood	8
Figure 8	Pressure History Model Junction 4618 – No Flow to Sherwood	8
Figure 9	15.0 MGD WRWTP Flow – (Sherwood Pipeline Disconnected from Wilsonville System)	9
Figure 10	Pressure History Model Junction 3860 – Surge Protection	11
Figure 11	Pressure History Model Junction 4116 – Surge Protection	11
Figure 12	Pressure History Model Junction 4604 – Surge Protection	12
Figure 13	Pressure History Model Junction 4610 – Surge Protection	12
Figure 14	Pressure History Model Junction 4618 – Surge Protection	13
Figure 15	Pressure History Model Junction 4622 – Surge Protection	13
Figure 16	Elevation Profile – Sherwood Transmission Pipeline	14

Abbreviations

cfs	cubic feet per second
ft	Feet
ft ³	Cubic foot
ft/s	Feet per second
HGL	Hydraulic Grade Line
lb-ft ²	Pound force square foot
mgd	million gallons per day
psi	pounds per square inch
WR ²	Rotating Inertia of pump and motor
WRWTP	Willamette River Water Treatment Plant

SURGE TRANSIENT ANALYSIS AND PRE-DESIGN RECOMMENDATIONS

1.1 Introduction

The objective of the transient analysis is to confirm the results identified in the *Hydraulic Transient Analysis – City of Wilsonville* Technical Memorandum prepared by MWH (August 2011) using the City of Wilsonville’s revised distribution model and incorporating current water demand and recent piping network modifications. The 2011 modeling efforts evaluated numerous scenarios with WRWTP flow rates up to 15 million gallons per day (mgd). Modeling results indicated that a minimum 750 cubic foot (ft³) (5,600 gallon) surge tank located at the WRWTP is recommended to prevent negative pressure formation within the distribution system due to power loss at the WRWTP when the City of Wilsonville demand exceeds 10 mgd (Sherwood excluded) and/or 12.5 mgd with Sherwood.

The City of Wilsonville’s 2017 Innowyze Infowater hydraulic model was provided to Stantec for this hydraulic transient analysis. Based upon discussions with the City of Wilsonville, the *2011_MDDW48, Existing Demand with Priority 1 Improvements* Model Scenario was used to model the demand scenarios presented in Table 1 for the analyses. In addition, the model was used to determine if a surge tank is required assuming no Sherwood Demand.

Table 1 Summary of Hydraulic Transient Analysis Demand Scenarios

Scenario	WRWTP Flow Rate (MGD)	Wilsonville Demand (MGD)	Sherwood Demand (MGD)
1	12.5	12.5	0
2	15	15	0
3	15	10	5
4	20	15	5
5	25	17.5	7.5
6	30	22.5	7.5

1.1.1 Model Development

The InfoWater hydraulic model, provided by the City of Wilsonville, was used along with InfoSurge to perform the transient analysis. The transmission main to Sherwood was added to the model utilizing information from the 2011 model and the City of Sherwood Water Supply Improvement Project Transmission Pipeline Drawings prepared by Murray Smith and Associates, dated June 2009. The model file received from the City of Wilsonville included the four existing high service pumps; two additional high service pumps were added to the model at the WRWTP to represent increased pumping capacity for model runs at higher flows. Pump station pipe lengths and elevations were also adjusted in the model to match the WRWTP as-built drawings.

Assumptions and Methodologies

The following general assumptions and boundary conditions were used in the transient model development and throughout the analysis:

- A global wave speed of 3,600 feet per second (ft/s) was applied to the distribution network to represent the average wave speed of rigid pipe materials such as ductile iron pipe, steel, and concrete.
- Pump discharge check valves were modeled with a closing time of 0.01 seconds to provide near instantaneous closure upon flow reversal.
- Pump curves included as part of the model were not verified.
- A total rotating inertia of pump and motor (WR^2) of 277.6 pound force square-foot ($lb-ft^2$) was estimated to represent the combined pump and motor inertia based upon the pump curve provided in the model.
- Surge mitigation devices will be sized to maintain positive pressures in the distribution system during the downsurge in order to minimize potential contaminant intrusion.
- Utilized model demand scenario 2011_MDDW48, Existing Demand with Priority 1 Improvements.
- Base model demands were scaled to meet the proposed demands provided in Table 1. Demands were not adjusted or biased geographically within the distribution system.
- Simultaneous power failure of all pumps occur 10 seconds into the model run in order to establish steady state conditions.
- The Sherwood Pipeline is hydraulically connected to the Wilsonville Distribution Network for all model scenarios, even when there is no flow to Sherwood.

1.2 Surge Mitigation Devices

Surge mitigation devices considered for this analysis included hydropneumatic tank(s) and vacuum relief valves. Surge anticipation valves were not recommended because they will not prevent vapor cavity formation and collapse in the system resulting from the downsurge. Pump flywheels were not considered since the existing pumps are close coupled vertical turbine pumps, which would not accept a flywheel.

A hydropneumatic tank, also known as surge arrestor or surge tank, is a pressurized tank with the lower portion of the tank filled with water and the upper portion containing pressurized air. When a power failure occurs at the pumps, water begins to flow from the hydropneumatic tank into the system to make up for the drop in flow at the pumps. The compressed air in the hydropneumatic tank begins to expand as the water level in the tank drops. Because air is compressible, the corresponding drop in pressure within the tank is not as large as at the pumps. Water is delivered from the tank until the water column in the system comes to rest, the flow then reverses and flows back into the tank raising the pressure and compressing the air until flow stops. If the pressure in the tank is larger than the system, the air then expands delivering water back into the system. The pressure and flow continue to cycle until they are damped by friction.

A polytropic gas constant of 1.2 was used to represent actual expansion and contraction of the hydropneumatic tank's air volume. The air volume set point in the tank typically ranges from 40 to 60 percent of the total volume of the tank. The minimum water volume of the tank during the downsurge was assumed to be limited to 15 to 20 percent of the total tank volume to ensure a wet seal over the tank outlet pipe during the transient event.

Vacuum relief valves are used to allow air to enter the pipeline whenever the pipeline pressure falls below atmospheric pressure. The vacuum valve is fitted with an external air release valve to exhaust air from the pipeline at a controlled rate when the pipeline regains pressure. Vacuum

relief valves were considered as a secondary mitigation device since they would allow other potential contaminants to enter the system when activated during a surge event.

1.3 Hydraulic Transient Analysis and Results

1.3.1 No Sherwood Demand (Scenarios 1 and 2)

The 2011 transient analysis indicated that a hydropneumatic tank was recommended when the City of Wilsonville demand exceeds 10.0 mgd (No Sherwood Demand). Therefore, the hydraulic transient model was first analyzed at demands of 12.5 mgd and 15 mgd to determine the maximum City of Wilsonville distribution system demand that would require a hydropneumatic tank to mitigate transients resulting from power loss at the WRWTP.

The minimum calculated pressure during a power loss event for 12.5 mgd and 15 mgd system demands are presented in Figures 1 and 2, respectively. Results show that minimum downsurge pressures fall below 20 pounds per square inch (psi) along the west and northwest sections of the Wilsonville distribution network and along the Sherwood pipeline for a 12.5 mgd demand; and the affected area within the Wilsonville distribution network increases at a 15 mgd demand. Although these areas are affected by the downsurge, it is important to determine the magnitude and duration of the downsurge. Pressure history following power loss for Model Junctions 3860, 4116, 4604, 4610, 4618, and 4622 are presented for both the 12.5 and 15 mgd demands in Figures 3 through 8. Model Junction 3860 is located along the future Wilsonville pipeline to the future Wilsonville Reservoir; Model Junction 4116 is located within the Wilsonville distribution system along SW Graham's Ferry Rd. Model Junctions 4604, 4610, 4618, and 4622 represent high points along the Sherwood Transmission Pipeline (at existing vacuum valve locations). Full vacuum conditions were calculated at Model Junction 3860 (future Wilsonville pipeline to future reservoir) and downsurge pressure approaching zero is estimated at Model Junction 4116. Results also show that the existing vacuum valves at Model Junctions 4604, 4610, 4618, and 4622 mitigate the downsurge along the Sherwood pipeline.

Even though there is no flow to Sherwood under Scenarios 1 and 2, the Sherwood Pipeline remains hydraulically connected to the Wilsonville transmission and distribution system via the setup of the operational controls for the Sherwood Pipeline, and is therefore subject to downsurge during hydraulic transients. Initial operational testing of the 24-inch control valve at the Tooze Road vault (which controls flow into the Sherwood pipeline) resulted in only a 3 psi differential, which was inadequate to provide water to Sherwood. Therefore, the control valve was operationally set to remain open in order to maintain adequate pressure and flow in the Sherwood Pipeline. Actual rate of flow is currently controlled by an Altitude Valve on the Sherwood Pipeline near the Snyder Park Reservoir. However, the current operational control strategy was established before the final segment of the Wilsonville Transmission pipeline was in place, and the weak pressure differential driving the control strategy was a differential between the Wilsonville distribution system pressure and the Sherwood pipeline.

Now that the Wilsonville Transmission line (operating at a higher pressure) is in place and connected, an operational change to the control valve setup at Tooze Road (i.e. control valve remains fully closed when no flow is being sent to Sherwood) was evaluated using the hydraulic transient model by assuming the Sherwood pipeline was disconnected from the Wilsonville distribution system. The effect of the downsurge on the Wilsonville distribution system was evaluated assuming a 15 mgd demand in the Wilsonville distribution system with the Tooze Rd control valve closed. The results are presented in Figure 9 and show that large sections of the

Wilsonville distribution system are affected by the downsurge resulting from power loss at the WRWTP. Results confirmed that a hydropneumatic tank is recommended as system demands approach 12.5 mgd (no Sherwood demand).




Figure 1 12.5 MGD WRWTP Flow – No Flow to Sherwood




Figure 2 15.0 MGD WRWTP Flow – No Flow to Sherwood

Junction 3860 (Future Wilsonville Pipeline to Future Reservoir) - No Sherwood Flow




Figure 3 Pressure History Model Junction 3860 – No Flow to Sherwood

Junction 4116 (Wilsonville Distribution Network) - No Sherwood Flow




Figure 4 Pressure History Model Junction 4116 – No Flow to Sherwood

Junction 4604 (Sherwood Pipeline) - No Sherwood Flow




Figure 5 Pressure History Model Junction 4604 – No Flow to Sherwood

Junction 4610 (Sherwood Pipeline) - No Sherwood Flow




Figure 6 Pressure History Model Junction 4610 – No Flow to Sherwood




Figure 7 Pressure History Model Junction 4618 – No Flow to Sherwood




Figure 8 Pressure History Model Junction 4618 – No Flow to Sherwood




Figure 9 15.0 MGD WRWTP Flow – (Sherwood Pipeline Disconnected from Wilsonville System)

1.3.2 Hydropneumatic Tank Sizing (Scenarios 3 to 6)

A hydropneumatic tank was recommended to mitigate the downsurge resulting from power failure at the WRWTP for demands of 12.5 mgd or greater. Therefore, the model was used to determine the size of hydropneumatic tank required for each scenario identified in Table 1. For each scenario, model runs were evaluated varying the tank volume, air volume, and size of the connecting pipe until an optimized solution was achieved. Hydropneumatic tank sizing was evaluated assuming a 24-inch diameter pipe connected to the upstream end of the discharge header and air volume assumed to be 50 percent of the total volume. Table 2 summarizes the findings of the analysis.

Table 2 Summary of Hydropneumatic Tank Sizing

Scenario	WRWTP Flow Rate (mgd)	Wilsonville Demand (mgd)	Sherwood Demand (mgd)	Minimum Tank Size (ft ³)
1	12.5	12.5	0	N/A ¹
2	15	15	0	N/A ¹
3	15	10	5	750
4	20	15	5	1,000
5	25	17.5	7.5	1,250
6	30	22.5	7.5	1,500

Notes:

(1) Scenario was evaluated to determine maximum demand before surge mitigation is recommended.

Results for the same model junctions identified in the previous section (Model Junctions 3860 and 4116 for Wilsonville, and 4604, 4610, 4618, and 4622 for Sherwood) are provided for Scenarios 3 to 6 in Figures 10 to 15. As shown in Figures 10 and 11, the proposed tank sizing (identified in Table 2) adequately protects the Wilsonville Distribution System. Distribution system maps showing the results with surge tank in place were not presented since the proposed hydropneumatic tank was sized to protect the distribution system.

Results presented in Figures 12 to 15 show that the existing vacuum valves along with the proposed surge tank sizing mitigate the downsurge along the Sherwood pipeline. Figure 16 presents the minimum HGL along the Sherwood pipeline during the downsurge for Scenario 6. It should be noted that utilizing vacuum valves to mitigate the downsurge allows air and potential contaminants to enter the transmission pipeline during the surge event; in addition, trapped air must be exhausted through the air release valves in order to restore the operational capacity of the pipeline. This potential operational risk should be discussed with the City of Sherwood.

Junction 3860 (Future Wilsonville Pipeline to Future Reservoir)




Figure 10 Pressure History Model Junction 3860 – Surge Protection

Junction 4116 (Wilsonville Distribution Network)




Figure 11 Pressure History Model Junction 4116 – Surge Protection

Junction 4604 (Sherwood Pipeline)




Figure 12 Pressure History Model Junction 4604 – Surge Protection

Junction 4610 (Sherwood Pipeline)




Figure 13 Pressure History Model Junction 4610 – Surge Protection

Junction 4618 (Sherwood Pipeline)




Figure 14 Pressure History Model Junction 4618 – Surge Protection

Junction 4622 (Sherwood Pipeline)




Figure 15 Pressure History Model Junction 4622 – Surge Protection




Figure 16 Elevation Profile – Sherwood Transmission Pipeline

1.4 Summary and Recommendations

Modeling results determined that a hydropneumatic tank located at the WRWTP is recommended when the City of Wilsonville’s demand approaches 12.5 mgd, confirming the results from previous studies.

The hydraulic transient model was used to size the hydropneumatic tank required for each scenario identified in Table 1. Results are summarized in Table 2 and show that a 750 ft³ hydropneumatic tank is recommended for a WRWTP flow of 15 mgd; recommended tank sizing increases by 250 ft³ with each 5 mgd increase in flow at the WRWTP to 1500 ft³ at 30 mgd. Hydropneumatic tank sizing was evaluated assuming a 24-inch diameter pipe connected to the upstream end of the discharge header and air volume 50 percent of the total tank volume.

The hydropneumatic tank can be configured in either a vertical or horizontal position; or as a conventional or bladder type tank. In a conventional hydropneumatic tank, the air is in direct contact with the water and an air compressor is required to regulate the air volume during operation. A bladder type tank stores the water within an expandable NSF 61-approved bladder. The bladder prevents the air from dissolving into the water and generally requires periodic inspection to verify the correct air precharge pressure in the tank and does not require a dedicated air compressor. The minimum water volume remaining in the tank during the downsurge should be limited to 15 to 20 percent of the tank volume to prevent potential extrusion of the bladder from the tank. The bladder requires periodic inspection and may need replacement every 15 to 20 years. It should be noted that a conventional tank also requires periodic inspection, maintenance, and electrical costs associated with the operation of the air compressor.

Budgetary equipment costs for various hydropneumatic tank sizes with comments are summarized in Table 3. Because the cost to provide a 1,500 ft³ tank is only 35 percent more than a 750 ft³ tank, installation of the 1,500 ft³ tank is recommended. This will provide enhanced near-

term surge protection and eliminate the need for additional construction in the future as demands increase.

Table 3 Summary of Budgetary Hydropneumatic Tank Costs (2017\$)

Size	Budgetary Cost (\$)	Comments
500 ft ³	100,000	Would be implemented with a 1,000 ft ³ tank when demands exceed 20 mgd.
750 ft ³	145,000	Could implement two 750 ft ³ tanks. Would want to install both today to protect demands exceeding 15 mgd.
1000 ft ³	170,000	Could implement single tank and build additional storage in the future.
1500 ft ³	195,000	Allows protection under build-out conditions. Incremental initial cost increase compared to other alternatives.

The proposed tank sizing adequately protects the Wilsonville Distribution system for each demand scenario; the existing vacuum valves along with the proposed surge tank sizing mitigate the downsurge along the Sherwood pipeline. Utilizing vacuum valves to mitigate the downsurge allows air and potential contaminants to enter the transmission pipeline during the surge event. Trapped air must be exhausted through the air release valves in order to restore the operational capacity of the pipeline. This potential operational risk should be discussed with the City of Sherwood.

Based upon the findings of the hydraulic transient analysis, surge mitigation recommendations for the WRWTP and City of Wilsonville Distribution System and Sherwood Pipeline include:

- A 1,500 ft³ (11,220 gallon) hydropneumatic tank connected to the station discharge header by a 24-inch diameter pipe. A 1,500 ft³ hydropneumatic tank is recommended based upon the budgetary costs provided above.
- Initial gas set point of 50 percent of total tank volume (750 ft³).
- A bladder-style tank is recommended to reduce need for additional air piping and handling equipment to be routed to surge tank; will help minimize operations and maintenance impacts.
- Potential tank sizes (1,500 ft³) include 10.0-ft diameter by 20.0-ft long; 11.0-ft diameter by 16.0-ft long; or 12.0-ft diameter by 13.5-ft long; the tank can be oriented in either the horizontal or vertical position. A horizontal, 11.0-ft diameter tank was carried forward in initial design to minimize vertical impact and to avoid extending too far horizontally away from the building. Upon review of the initial design, it was decided to revise the tank to a vertical configuration due to space considerations in the context of future build-out capacity.

Appendix D

CAPITAL COSTS ESTIMATES

- *Opinion-of-Probable-Construction Cost (OPCC)*
- *Cost Factoring Workbook*
- *Technical Memorandum – Modifications to OPCC*

Project Overview

Project	Willamette River WTP Master Plan			OPCC Completed	30-Nov-17	Total OPCC Cost-USD	VARIES BY CIP SCOPE
Location	Wilsonville, OR			Project Number	30503765	Prime Contractor	GENERAL CONTRACTOR as CM
Overview	Capacity upgrades, R&R, seismic/life safety retrofits, & electrical			Cost Code Number	61000001	Project Bid & Delivery	BID/BUILD
Contact	Eric Ward	Avg Daily Flow (MGD)	15.00	OPCC Prepared By	Jim Ward	Pre-Construction	INCLUDED
Phone	(503) 220-5431	Max Daily Flow (MGD)	30.00	OPCC Version #	002	Construction Duration	TBD

OPCC Modeling Philosophy & Methodology

This proprietary model, developed on an Excel platform, is the primarily tool for preparing class 4-5 Opinion-of-Probable-Construction-Cost (OPCC) estimates, and follows the general principles within the AACE, International Recommended Practices publication # 18R-97. The absence of mature design deliverables and a comprehensive scope identity as typically encountered early in a project pursuit or design effort has driven the establishment of this model which continues to provide historically reliable and surprisingly detailed cost estimates through a "BASIS-OF-ESTIMATE" and "FORCED DETAIL" methodology of building an initial foundation of "estimatable" scope. After generating this "go-by" work, the model internally produces baseline costs through utilization of cost-analyses and parametric functions, manipulation of both historical and equipment size/capacity data, and traditional unit-cost methodologies using values of quantity, count, dimension, service, productivity, and/or end-use. These bare costs are then further "conditionalized" and "localized" based upon a combination of both perceived and known site/work issues as chosen within an "ASSUMPTIONS" section particular to each division of work. These subsequent direct costs are initially determined for the three primary installation elements of labor (MH\$), materials & construction equipment (M&CE\$), and major process/procured equipment items (EQ\$), and are summarized into a user-defined work breakdown structure for adjustment with select burdens & mark-ups. All supporting costs needed for completing the estimate are also applied, with the valuation based upon years of observed and proven ratios and/or percentages.

Glossary of Potential OPCC Sheets

BASIS-OF-ESTIMATE CHECKLIST: Matrix identifying the primary OPCC scope & project delivery issues, with an initial indication of either being included or excluded in the OPCC
BASIS-OF-ESTIMATE CLARIFICATIONS: Clarifications/ exceptions related specifically to the project scope and issues concerning content, execution, & constructability
OPCC MODEL CLARIFICATIONS: Clarifications/exceptions related specifically to the OPCC modeling & internal functionality
MODEL LABOR RATE STANDARDS: Development of the DIV manhour rates based on the initial baseline source, add-ons, anticipated tradesmen ratios, and work schedule
WORK BREAKDOWN STRUCTURE: Breakdown of the project OPCC in either requested or arbitrary area/scope levels and presented in both direct costs and cost-of-work (i.e. to Owner)
WBS DIRECT COST DISTRIBUTION: Report presenting the OPCC direct costs (i.e. divs 1-17 sheet costs) by both WBS and CSI division categories
WBS COST-OF-WORK DISTRIBUTION: Report presenting the OPCC cost-of-work (i.e. fully burdened costs) by both WBS and CSI division categories
WBS MANHOURS DISTRIBUTION: Report presenting the OPCC installation manhours by both WBS and CSI division categories
WBS QUANTITY-OF-WORK DISTRIBUTION: Report presenting the OPCC major construction quantities by both WBS and CSI division categories
OPCC SUMMARY: Where cost-of work build-up occurs (i.e. installing Contractor's market price), along with the Prime Contractor's costs including staff, fee, insurance, engineering, and bonds
WBS COST BUILD-UP SUMMARY: Another view of how the overall project cost is built-up & developed starting from the Prime and Subcontractor(s) direct costs
PRELIMINARY SCHEDULE: Basic bar-chart presentation of the WBS line items, along with monthly projections of the cashflow and construction manpower loading
INSTALLATION OVERVIEW: Assignments of the construction baseline standards, assumptions, and localizing factors, including a bare cost roll-up of the CSI worksheets
DIV 1 (01) PRIME CONTRACTOR STAFF: Development of the anticipated Prime Contractor staff labor, travel/living needs, and camp costs (where applicable)
DIV 1 (01) GENERAL REQUIREMENTS: Development of the anticipated general conditions needs and tradesmen camp costs (where applicable)
DIV 2 (02 & 31-35) COMMON SITEWORK: Development of the "common" (i.e. typically self-performed) site/civil construction items by type, dimension, & quantity, along with allowances
DIV 2 (02 & 31-35) SPECIALTY SITEWORK: Development of the "specialty" (i.e. typically subcontracted) site/civil construction items by type, dimension, & quantity, along with allowances
DIV 2 (33) WELL WORK: Development of the subcontracted well construction items by type, dimension, & quantity, along with allowances
DIV 3 (03) CONCRETE: Development of the cast-in-place concrete construction items by type, dimension, & quantity, along with CY, tons of rebar, & allowances
DIV 4 (04) MASONRY: Development of the CMU work items by type, dimension, & quantity, along with SF & allowances
DIV 5 (05) MISCELLANEOUS METALS: Development of the misc metal items by type, dimension, & quantity, along with tons & allowances
DIVS 5-8 (05-08) BUILDINGS & COMPONENTS: Development of building and/or component structures by type, dimension, & quantity, along with tons, SF, & allowances
DIVS 9-10 (09-10) FINISHES: Development of the field-applied finishes by type, dimension, & quantity, along with SF & allowances
DIVS 13 (33) FIELD-ERECTED TANKS: Development of the field-erected metal tanks & components by type, dimension, & quantity, along with tons, SF, gallons, & allowances
DIVS 13 (33) SHOP-FABRICATED TANKS: Development of the shop-fabricated metal tanks & components by type, dimension, & quantity, along with tons, gallons, & allowances
DIVS 11-17 (40-45) PROCESS EQUIPMENT: Development of the project-specific process & mechanical equipment breakdown, including all related items, by size/capacity & quantity
DIV 15 (21-23) MECHANICAL INSTALLATION: Development of the mechanical installation work by parametrics, dimension, & quantity data, along with allowances
DIVS 16-17 (25-28 & 33) ELECTRICAL INSTALLATION: Development of the electrical installation by parametrics, dimension, & quantity data, along with allowances
DIVS 16-17 (25-28 & 33) ELECTRICAL EQUIPMENT: Development of the electrical equipment including switchboards, MCC's, transformers, control panels, and process control systems
MODEL COMMODITY STANDARDS: Construction commodity items listing with costs currently utilized in the OPCC model and based on monthly updates from ENR
O&M FORECAST CLARIFICATIONS: Clarifications/ exceptions related specifically to both the cost development and basis of the operation & maintenance details
O&M FORECAST SUMMARY: Roll-up of the initial operations & electrical power basis forecasts and development of the subsequent life cycle costs and net present value
O&M FORECAST DETAIL - OPERATIONS: Development of the process & mechanical operating costs for the OPCC project scope including an initial life-cycle cost
O&M FORECAST DETAIL - ELECTRICAL POWER: Development of the electrical operating KWH and cost for the OPCC project scope including an initial life-cycle cost



BASIS-OF-ESTIMATE CHECKLIST

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

	Project Name	Location	Estimator	Version	Date	Job #
	Willamette River WTP Master Plan	Wilsonville, OR	Jim Ward	002	30-Nov-17	30503765
Basis-of-Estimate Items						
#	Work Scope & Estimate Content			INCLUDED As OPCC Scope	EXCLUDED But By Others	EXCLUDED Or Not Required
<i>OPCC Status</i>						
1	<i>This OPCC version # 002 replaces all previous estimates in their entirety for this specific project and/or scope</i>			✓		
2	<i>Estimator review of the project site and/or work area, either via a physical walk-through or photographic/video records</i>					✓
3	<i>Class 4 Opinion-of-Probable-Operating-Cost (OPOC) estimate with operating & maintenance forecasts</i>					✓
4	<i>July 2017 Means Construction Cost Indexes for Portland, OR utilized for initial baselining of local costs</i>			✓		
5	<i>September 2017 ENR Construction Economics data utilized for initial baselining of commodity costs</i>			✓		
6	<i>Labor rates established by the current STATE prevailing wages website for Wilsonville, OR</i>			✓		
7	<i>15% ESTIMATE contingency for potential issues related to Estimator judgements, take-offs, omissions, etc.</i>			✓		
8	<i>15% SCOPE contingency for potential growth related to design changes, preferences, regulatory issues, etc.</i>			✓		
9	<i>OPCC based upon a physical notice-to-proceed construction start on or about July 2018</i>			✓		
10	<i>Composite escalation to mid-point of construction established per individual APR's for MH, M&CE, and EQ</i>				✓	
11	<i>Taxes, including (but not limited to) sales, gross-receipts, professional, use, and/or Value-Added</i>					✓
12	<i>General conditions allowances in DIV 1 for the work reasonably anticipated but not currently quantifiable</i>			✓		
13	<i>General allowances in DIVS 2-17 for the related support work reasonably anticipated but not currently quantifiable</i>			✓		
14	<i>Duties, tariffs, and/or import & export fees including any related expenses</i>					✓
15	<i>Commissions and/or royalties including any related expenses</i>					✓
16	<i>Liquidated damages including any related expenses</i>					✓
17	<i>Prime Contractor to be a GENERAL CONTRACTING & CM firm</i>			✓		
18	<i>Prime Contractor solicited, bid, & contracted based upon BID/BUILD with PRE-CONSTRUCTION</i>			✓		
19	<i>Prime Contractor to pre-plan work sequencing, equipment pre-purchase, and/or early site mobilization as needed</i>			✓		
20	<i>Prime Contractor to provide staff (re: DIV 1) for the project management & construction oversight needs</i>			✓		
21	<i>Prime Contractor to self-perform select construction work and/or equipment procurement scope</i>			✓		
22	<i>Prime Contractor to provide Construction Manager-at-Risk (i.e. CMAR) services</i>			✓		
23	<i>Prime Contractor to provide Guaranteed Maximum Pricing (i.e. GMP)</i>			✓		
24	<i>Prime Contractor to have direct contractual & reporting responsibilities to OWNER or OWNER'S Rep</i>			✓		
25	<i>Prime Contractor to provide a safety program including management, training, reporting, & mitigation responsibilities</i>			✓		
26	<i>Prime Contractor to provide a QA/QC program including testing, inspecting, reporting, & mitigation responsibilities</i>			✓		
27	<i>Oversight/management of the Prime Contractor by OWNER'S 2nd-party representative</i>					✓
28	<i>Oversight/management of the Prime Contractor by OWNER'S 2nd-party safety and/or QC professional</i>					✓
29	<i>Local market cost increase allowance due to anticipated issues with the regional economy and bid conditions</i>					✓
30	<i>Construction fair market pricing that anticipates competitive market conditions (i.e. 4+ qualified bidders)</i>			✓		
31	<i>Construction labor primarily at local Prevailing Wage/Davis Bacon rates</i>			✓		
32	<i>40-hour work week, based upon an anticipated schedule of (5)-8 hr days Mon-Fri</i>			✓		
33	<i>Multiple-shift construction schedule</i>					✓
34	<i>Reduction of the construction duration due to an overtime work schedule</i>					✓
35	<i>Installation manhour rate adjustments due to anticipated issues with labor pool, location, and/or work conditions</i>					✓
36	<i>Installation manpower productivity adjustments due to anticipated issues with labor pool, location, and/or work conditions</i>					✓
37	<i>Installation manhour productivity adjustments due to PHASED Demo & Rehab Project</i>			✓		
38	<i>Remote site rotation allowance for eligible tradesmen, supervision, & Prime Contractor field staff</i>					✓
39	<i>Remote travel & camp allowance for eligible tradesmen, supervision, and/or Prime Contractor staff</i>					✓
40	<i>Project engineering & design services</i>			✓		
41	<i>Geotechnical testing, engineering, & design services</i>			✓		
42	<i>Engineering support services during construction & start-up</i>			✓		
43	<i>Supply & installation per standards typically anticipated for Municipal/Governmental work</i>			✓		
44	<i>OCIP (i.e. Owner-controlled-insurance-program) covering all insurance & bond costs at all tiers for this project</i>					✓

BASIS-OF-ESTIMATE CHECKLIST

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Estimator	Version	Date	Job #
Willamette River WTP Master Plan	Wilsonville, OR	Jim Ward	002	30-Nov-17	30503765
Basis-of-Estimate Items					
#	Work Scope & Estimate Content	OPCC Status			
		INCLUDED As OPCC Scope	EXCLUDED But By Others	EXCLUDED Or Not Required	
45	Property acquisitions, leases, easements, right-of-ways, and related fees, costs, & schedule impacts				✓
46	Financing, leasing, legal services, and related fees, costs, & schedule impacts				✓
47	Work permits, inspections, and related fees, costs, & schedule impacts				✓
48	Water-use permits, inspections, and related fees, costs, & schedule impacts				✓
49	Environmental/ecological permits, inspections, and related fees, costs, & schedule impacts				✓
50	Cultural/preservation work permits, inspections, and related fees, costs, & schedule impacts				✓
51	Effluent discharge (i.e. NPDES, POTW, etc.) permits, inspections, and related fees, costs, & schedule impacts	✓			
52	Water/wastewater/air sampling, collection, analysis, and/or pilot treatability studies				✓
53	Building and trades-work construction permits, inspections, and related fees & costs	✓			
54	Work anticipated within an existing treatment area assessed to have Above & Below Grade Issues	✓			
55	Consideration for both moderate congestion and moderate spread of existing yard and/or systems infrastructure	✓			
56	Hazardous materials/work conditions requiring personal protection and equipment				✓
57	High-work conditions requiring personal fall protection equipment				✓
58	Clean-room work conditions requiring personal protection and equipment				✓
59	Underwater work requiring diver(s) with surface support team and equipment				✓
60	Weather (i.e. precipitation) and/or temperature considerations during execution of the work	✓			
61	Disadvantaged and/or minority business enterprise considerations for select work	✓			
62	System/process oversight of operations and maintenance during start-up & training	✓			
63	System/process operations and maintenance during functional and/or performance testing			✓	
64	System/process operations and maintenance from commissioning & forward			✓	
65	Supply and/or procurement of major EQ items within DIVS 5-15	✓			
66	Domestic (US) overland shipping of procured items to project site	✓			
67	Stretch-wrapping of select EQ (excluding permanent materials) for shipping and/or on-site storage	✓			
68	Crating of select EQ (excluding permanent materials) for shipping and/or on-site storage				✓
69	Containerization of select EQ (excluding permanent materials) for shipping and/or on-site storage				✓
70	Primary excavation issue of Dust Control considered within the construction area(s)	✓			
71	Secondary excavation issue of Unstable Soil considered within the construction area(s)	✓			
72	0.40-0.80 (x G) Peak acceleration consideration for construction of buildings & structures	✓			
73	Category IV - Essential facility risk consideration for construction of buildings & structures	✓			
74	Zone II - 160 MPH wind consideration for construction of buildings & structures	✓			
75	Minimum of 1,800 PSF uniform soil-bearing capacity in construction area(s)			✓	
76	Minimum of 200 PCI uniform soil modulus of subgrade in construction area(s)			✓	
77	Maximum of 0.500 INCH uniform soil settlement potential in construction area(s)			✓	
78	Maximum of 0.250 INCH differential soil settlement potential in construction area(s)			✓	
79	Slurry walls for select areas, excavation, and/or structures				✓
80	Deep foundations for select structures				✓
81	Soil pre-loading and/or over-excavation with recompaction (of excavated material) for select areas				✓
82	Shoring, lagging, and/or cribbing for select areas, excavations, and/or structures	✓			
83	Steel sheet piling for select areas, excavations, and/or structures				✓
84	Saw-cutting and/or core-drilling within select areas	✓			
85	Potholing and/or utility locating within select areas	✓			
86	Traffic controls within select areas	✓			
87	Erosion controls within select areas	✓			
88	Dewatering due to excessive surface run-on, aquifers/springs, and/or high water table within select areas	✓			



BASIS-OF-ESTIMATE CHECKLIST

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Estimator	Version	Date	Job #
Willamette River WTP Master Plan	Wilsonville, OR	Jim Ward	002	30-Nov-17	30503765
Basis-of-Estimate Items					
#	Work Scope & Estimate Content	OPCC Status			
		INCLUDED As OPCC Scope	EXCLUDED But By Others	EXCLUDED Or Not Required	
89	Removal/disposal of existing native topsoil, vegetation, trees, and/or fencing within select areas	✓			
90	Removal/disposal of existing EQ, piping, electrical, structures, rubble, and/or debris within select areas	✓			
91	Relocation of existing utilities, ductbank, utilidors, chases/tunnels, pipe, and/or conduit/wiring				✓
92	Remediation due to hazardous materials within select areas				✓
93	Remediation due to cultural (i.e. historical, archaeological, etc.) content within select areas				✓
94	Landscaping, irrigation, seeding, sodding, mulching, plantings, and/or restoration within select areas				✓
95	Temporary fencing system for safety/security/privacy purposes around select site/construction areas	✓			
96	Permanent fencing system for safety/security/privacy purposes around select system/project areas				✓
97	Asphalt paving, patching, and/or repairing of select road, parking, and miscellaneous areas				✓
98	Curb & gutter system for select road, parking, and/or landscaping areas				✓
99	Outdoor lighting units for select areas	✓			
100	Concrete-filled steel pipe bollards/guardposts for protecting select equipment, area(s), and/or structure(s)				✓
101	Secondary containment for select areas, tanks, and/or structures				✓
102	Secondary containment of select piping systems				✓
103	Emergency diesel generator(s) including automatic transfer switching and on-board fuel system(s)	✓			
104	Emergency power sized only for idling select critical processes, freeze protection, & minimum lighting	✓			
105	Paralleling gear for multiple emergency generators				✓
106	Double-walled bulk diesel storage tank system with level indication and transfer pumping	✓			
107	Sealing, waterproofing, and/or chemical-resistant finish for select field-constructed surfaces	✓			
108	Coating and/or galvanizing of select steel building and canopy structural components	✓			
109	LEED construction (with certification) of select building structures and/or components				✓
110	Usage cost of utilities (i.e. electric, water, natural gas, sewerage, etc.) utilized during construction			✓	
111	Assistance in removal, abatement, and/or disposal of existing fluids, sludges, and residuals			✓	
112	PPE stations and placarding of project hazards including noise, moving machinery, and chemicals	✓			
113	Heat, light, ventilation, entry switches, utility outlets, and/or sump pumps for select vault structures				✓
114	Fire protection systems, materials, equipment, and/or placarding within select areas				✓
115	Grounding and/or lightning protection systems, materials, and/or equipment within select areas	✓			
116	Concrete strength (28 day minimum) provided at 4,500 PSI (7-8 sacks/CY)	✓			
117	Type II (lo heat & sulfate resist) cement utilized in structural concrete	✓			
118	A615-Plain Steel (qty in tons) reinforcement bar utilized in structural concrete	✓			
119	Aluminum Structure & Grate primarily utilized for personnel accessways	✓			
120	Piping and/or wiring supports primarily utilizing 304 SS Strut & Structural Shapes	✓			
121	Local safety disconnect switches for select motorized equipment	✓			
122	Local HOA and/or ON-OFF control stations for select equipment	✓			
123	Combination eyewash and shower stations (including tempered water system/supply) in select areas	✓			
124	ADA (Americans with Disabilities Act) accessibility in select areas				✓
125	Valved end-connections and/or by-passes for select in-line instrumentation and control valves				✓
126	Solenoid-controlled water stations for select sealwater and/or flushwater systems	✓			
127	Stairway access & perimeter handrailing for select building interior elevated spaces				✓
128	Ductwork system for select equipment and/or tankage				✓
129	Ductwork system for select areas and/or structures				✓
130	Coating of select pipe, fittings, and valves	✓			
131	Heat-tracing of select pipe, fittings, & valves				✓
132	Insulation & jacketing of select pipe, fittings, & valves				✓

BASIS-OF-ESTIMATE CHECKLIST

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Estimator	Version	Date	Job #
Willamette River WTP Master Plan	Wilsonville, OR	Jim Ward	002	30-Nov-17	30503765

Basis-of-Estimate Items

#	Work Scope & Estimate Content	OPCC Status		
		INCLUDED As OPCC Scope	EXCLUDED But By Others	EXCLUDED Or Not Required
133	Heat-tracing of select tankage			✓
134	Insulation of select tankage			✓
135	Architectural treatments and/or finishes similar for all building structures	✓		
136	Permanent overhead crane/hoist system(s) that are stand-alone and/or integrated to select structure(s)			✓
137	Field-erected tank(s) with either field-applied coating(s) or factory-applied finish(es)			✓
138	Scope-wide safety management system with communications/PA and health & safety monitoring			✓
139	Scope-wide security management system with access controls and intrusion monitoring			✓
140	Scope-wide surveillance management system with video monitoring & archiving			✓
141	Access to the work area considered as Slightly Difficult throughout the project execution	✓		
142	Patching, repairing, and/or restoring of select existing local infrastructure utilized during work	✓		
143	Location for stockpiling, spreading, and/or disposal of surplus soil < 5 mile radius from ISBL	✓		
144	Location for stockpiling, spreading, and/or disposal of clearing & grubbing waste < 5 mile radius from ISBL	✓		
145	Location for stockpiling, spreading, or disposal of demolition waste < 5 mile radius from ISBL	✓		
146	Payment of fee(s) associated with soil and waste stockpiling, spreading, and/or disposal	✓		
147	Continuous free & clear access, easement, and/or right-of-way to work area		✓	
148	Oversize, overweight, and/or drop-deck trailer accessibility to work area		✓	
149	Public and/or main access roads which are suitable and available throughout construction		✓	
150	Material and equipment laydown, staging, and/or storage area(s) within 100' of work area		✓	
151	Parking area(s) for installation personnel within 100' of work area		✓	
152	15 KV primary power supply/tie-in location (with sufficient ampacity) within 100' of work area		✓	
153	15 KV back-up power supply/tie-in location (with sufficient ampacity) within 100' of work area			✓
154	Hydro-test water supply (with sufficient pressure & volume) or tie-in location within 100' of work area		✓	
155	Disposal location for hydro-test fluids within 100' of work area		✓	
156	Potable water supply (with sufficient pressure & volume) or tie-in location within 100' of work area		✓	
157	Utility and/or fire protection water supply (with sufficient pressure & volume) or tie-in location within 100' of work area		✓	
158	Sanitary waste piping tie-in location (with sufficient capacity) within 100' of work area			✓
159	Compressed and/or instrument air supply (with sufficient pressure & volume) or tie-in location within 100' of work area			✓
160	Steam and/or fossil fuel supply (with sufficient pressure & volume) or tie-in location within 100' of work area			✓
161	Influent and/or effluent piping (of sufficient size) or tie-in location within 100' of work area			✓
162	Return and/or recycle piping (of sufficient size) or tie-in location within 100' of work area			✓
163	Treatment chemical supply (of sufficient size & concentration) or tie-in location within 100' of work area		✓	
164	Landline and/or high-speed internet service (of sufficient bandwidth) or tie-in location within 100' of work area		✓	
165	High-speed wireless internet service availability (with sufficient speed & bandwidth) within 100' of work area		✓	
166	Integration of existing power, process, and site (i.e. safety, security, and/or surveillance) controls to new systems		✓	
167	Integration of new power controls to existing systems	✓		
168	Integration of new process controls to existing systems	✓		
169	Integration of new site controls (i.e. safety, security, and/or surveillance) to existing systems			✓
170	Remote monitoring, alarm, & control of new process and/or site management systems			✓
171	Local set-aside of equipment and/or piping, electrical, metals, and miscellaneous materials subject to demolition	✓		
172	Salvaging/recovery of equipment and/or piping, electrical, metals, and miscellaneous materials subject to demolition		✓	
END				



BASIS-OF-ESTIMATE CLARIFICATIONS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Estimator	Date	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	Jim Ward	30-Nov-17	002	30503765

B-O-E Clarifications

1	This OPCC has been assigned a Class 4 (i.e. SCREENING or FEASIBILITY) level status per our judgment of the level of project definition, expected accuracy range, and other characteristics per AACE International Recommended Practice # 18R-97. The estimating methodologies primarily utilized within a class 4 OPCC typically involves equipment and size factoring, parametrics, and complex modeling techniques
2	NOTE: The accuracy range limits for this specific OPCC class are defined by AACE International as follow: Low = (-)15% to (-)30%, and High = (+)20% to (+)50%, with a 90% confidence that the actual cost will fall within the bounds of these ranges after application of the appropriate contingencies.
3	This OPCC, including any evaluation of the Client's project budget, represents our best judgment as a professional familiar with the construction industry. Unless and to the extent otherwise indicated by us, such opinion or evaluation is based upon current market rates for labor, materials and equipment. Furthermore, this OPCC is based on stable market conditions that exhibit predictable supply/demand relationships and does not attempt to capture the impacts of hyper-inflationary or deflationary market cycles. Client further acknowledges that this OPCC is a "snapshot in time" and that the reliability of the OPCC will degrade over time.
4	NOTE: A combination of "ESTIMATE" and "SCOPE" contingencies has been included in this OPCC for covering not only the potential issues related to any Estimator judgements, take-offs, or omissions, but also providing for the potential project growth due to design changes/revisions, undefined regulatory considerations, Owner preferences, and general unknowns that could arise over the duration of the project.
5	<p>The following scope deliverable(s) provided by Others form the initial basis of the cost development in this current OPCC version:</p> <ul style="list-style-type: none"> a. Carollo WTP Expansion Cost Estimate Excel spreadsheet and 20/30 MGD planning summaries received via email 16Oct17 b. MWH Record project drawings (335 PDF sheets) dated January 2003 received via email file link 26Oct17 c. Carollo PowerPoint Workshop # 3 received via email file link 26Oct17 d. Carollo PowerPoint Workshop # 5 received via email file link 26Oct17 e. Carollo Electrical Upgrade Figures (5 PDF sheets) received via email 01Nov17 f. Carollo Site Utilidor Figure (1 PDF sheet) received via email 01Nov17 g. Carollo Cost Estimate Comments containing Item Additions and Item Confirmation spreadsheets received via email 17Nov17 h. Various scope clarification emails, telecons, and/or discussions up through 20Nov17
6	<p>The Prime Contractor is anticipated to self-perform the following installation scope in this OPCC:</p> <ul style="list-style-type: none"> a. DIV 1 General Conditions b. DIV 1 Site Staffing for Project Management & Construction Oversight c. DIV 2 Common Sitework d. DIV 3 Concrete e. DIV 4 Masonry f. DIV 5 Install Miscellaneous Metals EQ g. DIVS 5-8 Buildings & Components
7	<p>Additionally, the Prime Contractor is anticipated to procure the following buy-outs direct from the Fabricators, Manufacturers, and/or Vendors:</p> <ul style="list-style-type: none"> a. DIV 5 Miscellaneous Metals Items b. DIVS 11-15 Process and Mechanical Equipment Items
8	<p>Specific items that have been provided in the OPCC include the following:</p> <ul style="list-style-type: none"> a. Cost items presume a significant amount will be executed together/simultaneously (especially seismic) and therefore reflect the appropriate Prime burdens b. Process mechanical items being replaced are anticipated to have the local valves, I&C, and electrical wiring/controls replaced as well c. The entire FWPS roof membrane & insulation is removed for adding the E-W wall roof anchors, and is fully replaced as part of the deficient decking replacement d. The following structures are anticipated for the 30 MGD expansion: <ul style="list-style-type: none"> i. (1) 19' wide ActiFlo flow channel and end gallery ii. (1) 10' wide ozonation flow channel and 14½' wide parallel/shared gallery (for future 2nd flow channel) iii. (2) 20' x 23' filter cells and 16' wide common/shared gallery
9	<p>The primary change(s) reflected in this current OPCC from the previous version include:</p> <ul style="list-style-type: none"> a. Added (16) CIP items per an "Additions" spreadsheet b. Confirmation that installation labor rates are per Oregon BOLI July 2017 publication data for Clackamas County and Estimator's best judgement thereof c. Adjustment of Prime Contractor's staffing forecast d. Contingency increased from 20% to 30% (15% estimate +15% scope) e. Added (16) CIP items per an "Additions" spreadsheet f. The strainers added to (17) chemical metering pump suctions are 1½" Ø clear PVC Y-strainers with tru-union connections g. Ventilation improvements are currently represented with gross allowances based on SF pending further scope identification/definition h. Dry chlorine handling and mix/transfer system anticipates reusing existing in-place storage tanks, feed pumps, and related piping/I&C i. All existing site lighting upgrades involve replacing the lighting head as well as the pole (where applicable) k. The following scope items have been deleted from the OPCC: <ul style="list-style-type: none"> i. GAC filter media replacements (4 at 4X) ii. Chemical metering pump replacements (17 at 2X)
10	END



OPCC MODEL CLARIFICATIONS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Estimator	Date	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	Jim Ward	30-Nov-17	002	30503765

Model Clarifications

1	NOTE: If utilized in this OPCC, prevailing wage rates and/or overtime work are in anticipation of securing the highest quality/skilled tradesmen for this project, and considers that the availability of this talent could otherwise be compromised depending on the current labor market conditions of the area.
2	The MODEL LABOR RATE STANDARDS sheet is provided to highlight the methodology behind development of the single blended rate which is then applied within each CSI division. The fringe benefits rate is anticipated to cover those paid by the employer and/or union such as vacation, pension, training, advancement funds, and health & welfare contributions. For any overtime work, the applicable overtime factor (i.e. multiplier) is applied to the MH base rate, while the fringe benefits cost is applied straight-up against each MH worked.
3	The designation of the PRIME CONTRACTOR has a direct bearing on the final OPCC cost, so both the identification and a consensus regarding this entity in the OPCC is important. For example, a "typical" General Contractor as PRIME will require a cost structure that differs from that for other firms such as an EPCM provider.
4	The "Assumptions" section at the top of each DIV sheet should be referenced for identifying a portion of the "forced-detail" in the OPCC, including both perceived and known issues such as specific components, materials of construction, site concerns, and working conditions that could impact the cost basis of this OPCC.
5	The "General Conditions Allowances" section in the DIV 1 sheet, and the "General Allowances" section at the bottom of the DIVS 2-17 sheets, are all comprised of "potential" cost items initially based on the type & quantity of work occurring within each CSI division, with the intention of covering items that could be reasonably anticipated but cannot yet be defined and/or quantified. NOTE: The individual allowance section totals should be considered as more reliable and representative of an overall reserve being allowed rather than detailed consideration of each line item cost (or absence thereof) comprising these totals, any of which may or may not eventually be needed.
6	The manhours developed for each work item reflects the total, whether it be executed by an "individual" or "crew", with the manhour rates depicted throughout the OPCC having been developed to reflect a blend of the anticipated trade labor and supervision for each CSI division. If the MODEL LABOR RATE STANDARDS sheet is provided, the overall composite rate is provided for informational purposes only and reflects the weighting effect due to the actual divisions of work comprising the project. The individual blended DIV rates utilized include adjustments for any overtime and/or shift work identified in the INSTALLATION OVERVIEW sheet.
7	The BASIS-OF-ESTIMATE CHECKLIST sheet is provided as a quick reference of those scope, execution, and cost items <i>INCLUDED</i> in the OPCC, those <i>EXCLUDED</i> from the OPCC but anticipated as necessary and the responsibility of Others, and those <i>EXCLUDED</i> from the OPCC because they are believed to be unnecessary.
8	The DIV 1 costs are split up into separate sheets, with the DIV 1 PRIME CONTRACTOR STAFF sheet carried as part of the "Prime Contractor" section of the OPCC SUMMARY sheet, while the DIV 1 GENERAL REQUIREMENTS sheet costs are carried as part of the direct cost subtotal line within the "Cost-of-Work" section of the OPCC SUMMARY sheet. These separate DIV 1 sheet totals are also included as a line item in the WORK BREAKDOWN STRUCTURE sheet. This split is due to the anticipation that the general conditions would primarily be executed utilizing trades labor, construction tools/equipment, and consumable materials.
9	When multiple options or alternatives are presented in the WORK BREAKDOWN STRUCTURE sheet, these are solely for purposes of making a screening/feasibility decision based upon a ROM (i.e. rough order-of-magnitude) cost comparison. NOTE: These costs are not to be considered as the final/true cost indicator of any individual option or alternative.
10	The arbitrary allocation (per the check-mark indicator) in the WORK BREAKDOWN STRUCTURE sheet is performed primarily because the line items being allocated are typically not conducive to being accurately partitioned to any specific/individual WBS item, area, or process. Distribution of these allocations is dependent upon the WBS items selected to receive them, with those being excluded marked with an "X" indicator.
11	The DIV 15 sheet piping and DIVS 16-17 sheet raceway material selection drop-downs (1 thru 5) at the top, along with the anticipated percentage of utilization within the total installation, are intended to represent a generalized materials profile anticipated to occur across the project.
12	There may be instances where highly un-symmetrical or complex structures will be dimensionally and/or geometrically "smoothed" to establish more-simplified units that comply with the OPCC input cell templates, all in an attempt to maintain the overall component aspect ratios and overall size. This typically occurs in the DIV sheets utilizing dimensional data inputs.
13	The PRELIMINARY SCHEDULE sheet, if provided, attempts to present all the forecast and WBS totals in a means approximating the anticipated "normal" distribution over the job duration. Typically, the overall construction duration should be considered as more accurate than the individual WBS item durations.
14	The DIVS 5-8 BUILDINGS & COMPONENTS sheet includes a composite cost of all the structure scope required for the building shell and/or roof structure identified. All other building-related construction scope is costed elsewhere as required, such as sitework & excavation (re: DIV 2), concrete & foundations (re: DIV 3), masonry (re: DIV 4), miscellaneous metals (re: DIV 5), finishes (re: DIVS 9-10), mechanical, HVAC, fire protection, utilities, & plumbing (re: DIV 15), and electrical, HVAC, fire protection, utilities, & lighting (re: DIVS 16-17).
15	With exception of those process equipment budget costs provided by Others, all buy-out equipment costs in the DIVS 11-17 sheets are anticipated to be of US origin and have been derived either through best judgement of the Estimator or extrapolation of similar items from an independent equipment quote/purchase database. NOTE: Skidded equipment packages have been anticipated as assembled, pre-piped, pre-valved, pre-wired, pre-switched, and pre-painted by the Manufacturer to the fullest extent possible, and typically requiring only re-assembly of the required shipping breakdown, off-skid piping/wiring homeruns, and touch-up paint.
16	The DIVS 11-17 EQUIPMENT sheets provide equipment line-item breakdowns of the subtotal for the "Process Equipment Installation Summary" sections at the top of the DIV 15 and DIVS 16-17 sheets. Each field-installed process/mechanical equipment item within the DIVS 11-17 EQUIPMENT sheets provides parametric costing for all necessary DIV 15 mechanical work such as off-load, handle, set, anchor, grout, and needed hangars/brackets/supports, pipe, fittings, manual valves, check valves, pressure gauges, and sample ports, and for all necessary DIVS 16-17 electrical equipment such as off-load, handle, set, anchor, grout, and needed hangars/brackets/supports, disconnect/safety switches, raceway, flex-conduit, fittings, wire, terminations, and grounding.
17	Percentages applied for the indirect costs are estimates based upon the scope of work, anticipated schedule, and risk allocation deemed necessary at the time of this submittal.
18	END
19	
20	
21	
22	
23	
24	

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions

Labor Classification Rate Basis <table border="1" style="width: 100%;"> <tr><td>Prevailing Wage/Davis Bacon</td><td></td></tr> <tr><td>MH Avg Burden for Fringes</td><td style="text-align: center;">51%</td></tr> <tr><td>MH Adder for Supervision</td><td style="text-align: center;">\$2.00</td></tr> <tr><td>Allowance for Incidental OT</td><td></td></tr> <tr><td>MH Allowance for Other</td><td style="text-align: center;">\$0.00</td></tr> </table>	Prevailing Wage/Davis Bacon		MH Avg Burden for Fringes	51%	MH Adder for Supervision	\$2.00	Allowance for Incidental OT		MH Allowance for Other	\$0.00	Construction Work Schedule <div style="border: 1px solid black; padding: 2px; display: inline-block;">(5)-8 hr days Mon-Fri</div>	MH Rate Overtime Factors Work Day Schedule <table border="1" style="width: 100%;"> <tr> <th>Hours = 8</th> <th>Hours > 8</th> </tr> <tr> <td>Monday-Friday 1X Base</td> <td>1½X Base</td> </tr> <tr> <td>Saturday 1½X Base</td> <td>2X Base</td> </tr> <tr> <td>Sunday 2X Base</td> <td>3X Base</td> </tr> </table>	Hours = 8	Hours > 8	Monday-Friday 1X Base	1½X Base	Saturday 1½X Base	2X Base	Sunday 2X Base	3X Base	Composite MH Rate (for information only) Weighted Rate by Scope & Schedule <table border="1" style="width: 100%;"> <tr> <th></th> <th>Straight</th> <th>Overtime</th> </tr> <tr> <td>Direct Rate</td> <td style="text-align: center;">\$52.28</td> <td></td> </tr> <tr> <td>Fringes *</td> <td style="text-align: center;">\$17.66</td> <td></td> </tr> <tr> <td>Base Rate</td> <td style="text-align: center;">\$34.62</td> <td></td> </tr> </table>		Straight	Overtime	Direct Rate	\$52.28		Fringes *	\$17.66		Base Rate	\$34.62	
Prevailing Wage/Davis Bacon																																	
MH Avg Burden for Fringes	51%																																
MH Adder for Supervision	\$2.00																																
Allowance for Incidental OT																																	
MH Allowance for Other	\$0.00																																
Hours = 8	Hours > 8																																
Monday-Friday 1X Base	1½X Base																																
Saturday 1½X Base	2X Base																																
Sunday 2X Base	3X Base																																
	Straight	Overtime																															
Direct Rate	\$52.28																																
Fringes *	\$17.66																																
Base Rate	\$34.62																																
Base Labor Rate Source <input type="checkbox"/> MEANS Construction Cost Indexing of 30-City Rates <input type="checkbox"/> MEANS Annual Prevailing Labor Rates Publication <input checked="" type="checkbox"/> STATE Prevailing Wage Determination Website																																	

* Fringes are anticipated as those benefits paid by the employer and/or union such as vacation, pension, training, advancement funds, and health & welfare contributions

Labor Rates by DIV

DIVS 1-2: General Requirements & Sitework					DIV 3: Concrete					DIV 4: Masonry				
Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL	Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL	Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL
Operator (crane)	2	\$57.99	\$57.99	\$115.98	Carpenter	4	\$52.88	\$52.88	\$211.52	Bricklayer	6	\$55.62	\$55.62	\$333.72
Operator (medium)	2	\$52.09	\$52.09	\$104.18	Rodman	4	\$60.87	\$60.87	\$243.48	Stone Mason	2	\$55.62	\$55.62	\$111.24
Driver (heavy)	2	\$27.70	\$27.70	\$55.40	Cement Finisher	3	\$51.12	\$51.12	\$153.36	Operator (light)	1	\$50.94	\$50.94	\$50.94
Operator (mechanic)	1	\$57.99	\$57.99	\$57.99	Operator (crane)	1	\$57.99	\$57.99	\$57.99	Helper/Apprentice	2	\$39.87	\$39.87	\$79.74
Operator (oiler)	1	\$49.86	\$49.86	\$49.86	Operator (medium)	1	\$52.09	\$52.09	\$52.09	Laborer	2	\$42.68	\$42.68	\$85.36
Helper/Apprentice	1	\$39.87	\$39.87	\$39.87	Helper/Apprentice	2	\$39.87	\$39.87	\$79.74					
Laborer	2	\$42.68	\$42.68	\$85.36	Laborer	2	\$42.68	\$42.68	\$85.36					
Supervision	2	\$59.99	\$59.99	\$119.98	Supervision	3	\$62.87	\$62.87	\$188.61	Supervision	2	\$41.87	\$41.87	\$83.74
Totals	13			\$628.62	Totals	20			\$1,072.15	Totals	15			\$744.73
Blended Rate Applied in these DIVS = \$48.36					Blended Rate Applied in this DIV = \$53.61					Blended Rate Applied in this DIV = \$49.65				
DIV 5: Miscellaneous Metals					DIVS 5-8: Buildings					DIVS 9-10: Finishes				
Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL	Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL	Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL
Welder/SS Worker	5	\$60.87	\$60.87	\$304.35	Welder/SS Worker	1	\$60.87	\$60.87	\$60.87	Painter (structural)	5	\$39.43	\$39.43	\$197.15
Operator (crane)	1	\$57.99	\$57.99	\$57.99	Operator (crane)	4	\$57.99	\$57.99	\$231.96	Tile Layers	1	\$37.13	\$37.13	\$37.13
Operator (medium)	3	\$52.09	\$52.09	\$156.27	Operator (medium)	1	\$52.09	\$52.09	\$52.09	Plasterer	1	\$47.37	\$47.37	\$47.37
Boilermaker	2	\$57.26	\$57.26	\$114.52	Sheetmetal Worker	2	\$59.20	\$59.20	\$118.40	Painter (ordinary)	3	\$35.38	\$35.38	\$106.14
Helper/Apprentice	2	\$39.87	\$39.87	\$79.74	Glazier	1	\$54.97	\$54.97	\$54.97	Lather	1	\$52.88	\$52.88	\$52.88
					Roofer (composition)	2	\$48.32	\$48.32	\$96.64	Helper/Apprentice	1	\$39.87	\$39.87	\$39.87
					Sprinkler Installer	1	\$59.13	\$59.13	\$59.13					
					Helper/Apprentice	2	\$39.87	\$39.87	\$79.74					
Supervision	2	\$59.26	\$59.26	\$118.52	Supervision	2	\$61.13	\$61.13	\$122.26	Supervision	2	\$41.87	\$41.87	\$83.74
Totals	15			\$831.39	Totals	16			\$876.06	Totals	14			\$564.27
Blended Rate Applied in this DIV = \$55.43					Blended Rate Applied in these DIVS = \$54.75					Blended Rate Applied in these DIVS = \$40.31				

MODEL LABOR RATE STANDARDS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Labor Rates by DIV														
DIV 13: Field & Shop Tanks					DIV 15: Piping & Mechanical					DIVS 16-17: Power and I&C				
Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL	Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL	Potential Labor Trades	Anticipated Work Ratio	Initial State Prevail Rate	Final OPCC Direct Rate	TOTAL
Welder/SS Worker					Millwright	1	\$40.00	\$40.00	\$40.00	Electrician	8	\$63.58	\$63.58	\$508.64
Operator (crane)					Steamfitter/Pipefitter	7	\$69.85	\$69.85	\$488.95	Operator (light)	1	\$50.94	\$50.94	\$50.94
Operator (medium)					Plumber	2	\$69.85	\$69.85	\$139.70	Helper/Apprentice	2	\$39.87	\$39.87	\$79.74
Boilermaker					Boilermaker	1	\$57.26	\$57.26	\$57.26					
Helper/Apprentice					Insulator	1	\$66.67	\$66.67	\$66.67					
					Operator (medium)	2	\$52.09	\$52.09	\$104.18					
					Welder/SS Worker	1	\$60.87	\$60.87	\$60.87					
					Helper/Apprentice	2	\$39.87	\$39.87	\$79.74					
Supervision					Supervision	3	\$59.26	\$59.26	\$177.78	Supervision	2	\$65.58	\$65.58	\$131.16
					Totals	20			\$1,215.15	Totals	13			\$770.48
					Blended Rate Applied in this DIV = \$60.76					Blended Rate Applied in these DIVS = \$59.27				

Overview of Composite Labor Rates Based on Work Schedule

#	Weekly Schedule	Monday thru Friday				Saturday				Sunday				Summary		
		Workday = 8 Hours		Workday > 8 Hours		Workday = 8 Hours		Workday > 8 Hours		Workday = 8 Hours		Workday > 8 Hours		TOTAL MH per Week	Composite MH Cost per Hour	
		MH per Week	MH Cost per Week	Added MH per Week	Added MH \$ per Week	MH per Week	MH Cost per Week	Added MH per Week	Added MH \$ per Week	MH per Week	MH Cost per Week	Added MH per Week	Added MH \$ per Week			
1	(4)-10 hr days Mon-Fri (w/o OT)	40	\$2,091	0	\$0	0	\$0	0	\$0	0	\$0	0	\$0	40	\$2,091	\$52.28
2	(5)-8 hr days Mon-Fri	40	\$2,091	0	\$0	0	\$0	0	\$0	0	\$0	0	\$0	40	\$2,091	\$52.28
3	(5)-8 hr days Mon-Fri + Incidental OT	40	\$2,091	0	\$0	0	\$0	0	\$0	0	\$0	0	\$0	40	\$2,091	\$52.28
4	(4)-10 hr days Mon-Fri (with OT)	32	\$1,673	8	\$557	0	\$0	0	\$0	0	\$0	0	\$0	40	\$2,229	\$55.74
5	(6)-8 hr days Mon-Sat	40	\$2,091	0	\$0	8	\$557	0	\$0	0	\$0	0	\$0	48	\$2,648	\$55.16
6	(4)-12 hr days Mon-Fri	32	\$1,673	16	\$1,113	0	\$0	0	\$0	0	\$0	0	\$0	48	\$2,786	\$58.04
7	(5)-10 hr days Mon-Fri	40	\$2,091	10	\$696	0	\$0	0	\$0	0	\$0	0	\$0	50	\$2,787	\$55.74
8	(7)-8 hr days Mon-Sun	40	\$2,091	0	\$0	8	\$557	0	\$0	8	\$695	0	\$0	56	\$3,343	\$59.69
9	(5)-10 hr days Mon-Fri + 8 hrs Sat	40	\$2,091	10	\$696	8	\$557	0	\$0	0	\$0	0	\$0	58	\$3,344	\$57.65
10	(5)-12 hr days Mon-Fri	40	\$2,091	20	\$1,392	0	\$0	0	\$0	0	\$0	0	\$0	60	\$3,483	\$58.04
11	(6)-10 hr days Mon-Sat	40	\$2,091	10	\$696	8	\$557	2	\$174	0	\$0	0	\$0	60	\$3,517	\$58.62
12	(5)-12 hr days Mon-Fri + 8 hrs Sat	40	\$2,091	20	\$1,392	8	\$557	0	\$0	0	\$0	0	\$0	68	\$4,039	\$59.40
13	(6)-10 hr days Mon-Sat + 8 hrs Sun	40	\$2,091	10	\$696	8	\$557	2	\$174	8	\$695	0	\$0	68	\$4,212	\$61.95
14	(7)-10 hr days Mon-Sun	40	\$2,091	10	\$696	8	\$557	2	\$174	8	\$695	2	\$243	70	\$4,455	\$63.65
15	(6)-12 hr days Mon-Sat	40	\$2,091	20	\$1,392	8	\$557	4	\$348	0	\$0	0	\$0	72	\$4,387	\$60.93
16	(6)-12 hr days Mon-Sat + 8 hrs Sun	40	\$2,091	20	\$1,392	8	\$557	4	\$348	8	\$695	4	\$486	80	\$5,082	\$63.53
17	(7)-12 hr days Mon-Sun	40	\$2,091	20	\$1,392	8	\$557	4	\$348	8	\$695	4	\$486	84	\$5,568	\$66.29

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions	
<i>Project Delivery & Bid Scope</i>	BID/BUILD with PRE-CONSTRUCTION
<i>Prime Contractor</i>	GENERAL CONTRACTOR as CM
<i>Construction Execution</i>	PRIME with 63% of Direct Cost by SUBS
<i>Payroll Deductions & Workers Compensation</i>	32.00%
<i>Small Tools & Personal Safety Gear</i>	3.50%
<i>Tax Type & Categories Applied</i>	TAX EXCLUDED and/or EXEMPT
<i>Tax Rate Applied (Wilsonville, OR)</i>	
<i>Builders Risk Insurance - Carried by PRIME</i>	0.70%
<i>Liability Insurances - SUBS</i>	0.55%
<i>Umbrella & Vehicle Insurances - SUBS</i>	0.25%
<i>Bonds (payment-performance-supply) - SUBS</i>	1.30%
<i>Overhead & General Conditions - SUBS</i>	5.00%
<i>Profit - SUBS</i>	10.00%
<i>EQ Inspections & Start-Up Assistance</i>	2.00%
<i>EQ Spare Parts & Special Tools/Supplies</i>	1.87% for both Start-Up & 1-Year Supply
<i>Packing & Freight Categories</i>	EQ (excluding permanent materials)
<i>Packing & Freight</i>	3.50%
<i>Labor Escalation - BY OTHERS</i>	
<i>Materials Escalation - BY OTHERS</i>	
<i>Equipment Escalation - BY OTHERS</i>	
<i>Years of Escalation - NOT APPLICABLE</i>	
<i>Estimate Contingency</i>	15.00%
<i>Scope Contingency</i>	15.00%
<i>Local Market Issues - EXCLUDED</i>	
<i>Anticipated Construction Duration</i>	TBD
<i>Special Project Consideration</i>	PHASED Demo & Rehab Project

Build-Up to Cost-of-Work

Description	Work Self-Performed by Prime Contractor				Work Performed by Subcontractors				TOTAL
	Install MH	MH \$	M&CE \$	EQ \$	Install MH	MH \$	M&CE \$	EQ \$	
<i>Direct Cost (i.e. DIVS 1-17 less DIV 1 Staff cost)</i>	43,121	\$2,261,111	\$1,980,874	\$5,442,024	24,018	\$1,424,220	\$2,743,720	\$3,845,335	\$17,697,284
<i>Payroll Deductions & Workers Compensation</i>		\$479,176				\$301,821			\$780,997
<i>Small Tools & Personal Safety Gear</i>		\$52,410				\$33,012			\$85,422
<i>EQ Inspections & Start-Up Assistance - VENDORS</i>				\$108,840				\$76,907	\$185,747
<i>EQ Spare Parts & Special Tool/Materials - VENDORS</i>				\$205,346				\$145,098	\$350,444
<i>EQ Packing & Freight - VENDORS</i>				\$190,471				\$134,587	\$325,058
<i>SALES TAX - NOT APPLICABLE</i>									
Subtotal A	43,121	\$2,792,697	\$1,980,874	\$5,946,681	24,018	\$1,759,053	\$2,743,720	\$4,201,927	\$19,424,951
<i>Overhead & General Conditions - SUBS</i>						\$87,953	\$137,186	\$210,096	\$435,235
<i>Profit - SUBS</i>						\$184,701	\$288,091	\$441,202	\$913,993
Subtotal B	43,121	\$2,792,697	\$1,980,874	\$5,946,681	24,018	\$2,031,706	\$3,168,996	\$4,853,225	\$20,774,179
<i>Builders Risk Insurance (re: PRIME CONTRACTOR below)</i>									
<i>Liability Insurance - SUBS</i>						\$11,174			\$11,174
<i>Umbrella & Vehicle Insurances - SUBS</i>						\$5,079	\$7,922		\$13,002
<i>Bonds (payment, performance, & supply) - SUBS</i>						\$26,623	\$41,300	\$63,092	\$131,015
Subtotal C	43,121	\$2,792,697	\$1,980,874	\$5,946,681	24,018	\$2,074,583	\$3,218,218	\$4,916,317	\$20,929,371
<i>Escalation - BY OTHERS</i>									
<i>Estimate Contingency</i>	6,468	\$418,905	\$297,131	\$892,002	3,603	\$311,188	\$482,733	\$737,448	\$3,139,406
<i>Scope Contingency</i>	6,468	\$418,905	\$297,131	\$892,002	3,603	\$311,188	\$482,733	\$737,448	\$3,139,406
<i>Local Market Issues - EXCLUDED</i>									
Subtotal D	56,057	\$3,630,507	\$2,575,136	\$7,730,685	31,224	\$2,696,958	\$4,183,684	\$6,391,212	\$27,208,182
<i>GROSS RECEIPTS TAX - NOT APPLICABLE</i>									
Subtotal - Cost-of-Work	56,057	\$3,630,507	\$2,575,136	\$7,730,685	31,224	\$2,696,958	\$4,183,684	\$6,391,212	\$27,208,182

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765
Prime Contractor Cost, Burdens, & Mark-Ups					
Description	Basis	TOTAL			
Project Staff Labor	DIV 1 PRIME CONTRACTOR STAFF sheet	\$2,823,055			
Project Staff Travel, Living, & Other	DIV 1 PRIME CONTRACTOR STAFF sheet	\$171,722			
Project Staff Camp Allowance - NOT APPLICABLE					
Tradesmen & Supervision Camp Allowance - NOT APPLICABLE					
(TBD)					
Subtotal E					\$2,994,777
Escalation - BY OTHERS					
Insurances (i.e. builders risk, liability, umbrella, & vehicle)	1.51% of Subtotal B above	\$312,885			
Subtotal F					\$3,307,662
General & Administrative	5% of Cost-of-Work Subtotal & Subtotal F above	\$1,525,792			
Profit	10% of Cost-of-Work Subtotal & Subtotal F above	\$3,051,584			
Project Engineering including Geotechnical, Design, Permitting, & Support during Construction	15% of Cost-of-Work Subtotal	\$4,081,227			
(TBD)					
Subtotal G					\$11,966,266
Bonds (payment, performance, & supply)	0.89% of Cost-of-Work Subtotal & Subtotal G above	\$349,639			
Subtotal H					\$12,315,905
GROSS RECEIPTS TAX - NOT APPLICABLE					
Subtotal - Prime Contractor Burdens & Mark-Ups					\$12,315,905
Pass-Through Scope					
Description	Basis	TOTAL			
(EQ TBD)					
EQ Inspections & Start-Up Assistance - NOT APPLICABLE					
EQ Extra Materials & Spare Parts - NOT APPLICABLE					
Packing & Freight - NOT APPLICABLE					
SALES TAX - NOT APPLICABLE					
Subtotal I					
Escalation - NOT APPLICABLE					
Estimate Contingency - NOT APPLICABLE					
Scope Contingency - NOT APPLICABLE					
Subtotal J					
Bonds (payment, performance, & supply)					
Subtotal K					
GROSS RECEIPTS TAX - NOT APPLICABLE					
Subtotal - Pass-Through Scope					
OPCC Summary Total					
OPCC GRAND TOTAL					\$39,524,088

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Glossary of OPCC Summary Terms

PROJECT DELIVERY & BID SCOPE: Identifies the bid & installation work scope approach (i.e. Bid/Build or Design/Build), which subsequently establishes the baseline burdens and add-on rates.
PRIME CONTRACTOR: Identifies the entity having the overall construction oversight and/or construction management responsibilities, which adjusts a portion of the assigned burden & add-ons.
CONSTRUCTION EXECUTION: Identifies the entity actually performing the supply/install work scope, which finalizes the balance of the assigned burden and add-on rates.
PAYROLL DEDUCTIONS & WORKERS COMP: Percent applied to the supply/install Contractor(s) base MH rate (i.e. excluding fringes) to cover the payroll taxes (FICA, FUTA, & SUTA), payroll insurances, pension contributions, union assessments, bonus programs (excluding profit sharing), training funds, industry/administrative funds, and state workers compensation insurance.
SMALL TOOLS & PERSONAL SAFETY GEAR: Percent applied to the supply/install Contractor(s) base MH rate (i.e. excluding fringes) to cover the supply and/or replacement of the small "expendable" items (i.e. hand tools, hand-held power tools, etc.), and personal protection equipment, with any single item value anticipated to be no greater than \$250.
TAX TYPE & CATEGORIES APPLIED: Identifies the type of tax and the MH, M&CE, and/or EQ cost categories to which the tax percentage assigned below shall apply.
TAX RATE: Percent applied to the categories identified above which calculates the supply/install or Prime Contractor(s) tax burden.
BUILDERS RISK INSURANCE: Percent applied to the direct MH, M&CE, & EQ costs to cover the capital and installation risk insurance carried either by the Owner or Prime Contractor (carried under the Prime section).
LIABILITY INSURANCES: Percent applied to the supply/install Subcontractor(s) direct MH cost for the general liability insurances.
UMBRELLA & VEHICLE INSURANCES: Percent applied to the supply/install Subcontractor(s) direct MH & M&CE costs for the umbrella & vehicle insurances.
PAYMENT, PERFORMANCE, & SUPPLY BONDS: Percent applied to the supply/install Subcontractor(s) applicable direct MH, M&CE, & EQ costs for the bonds to ensure satisfactory completion and payment to the suppliers, Vendors, & Subcontractors.
OVERHEAD & GENERAL CONDITIONS: Percent applied to the supply/install Subcontractor(s) direct MH, M&CE, & EQ costs for direct & indirect field overhead expenses, the indirect home office expenses, and all general conditions incurred during execution of the installation.
PROFIT: Percent applied to the supply/install Subcontractor(s) direct MH, M&CE, & EQ costs for the profit.
EQ INSPECTIONS & START-UP ASSISTANCE: Percent applied to the direct EQ costs for the tax-exempt services provided by the Manufacturer/Vendor, such as installation inspections and start-up assistance, including all related T&L costs.
EQ EXTRA MATERIALS & SPARE PARTS: Identifies the additional buy-out EQ supplies to be provided by either the Manufacturer or Vendor, such as special tools, lubricants, & spare parts.
PACKING & FREIGHT CATEGORIES: Identifies the EQ and/or M&CE cost categories to which the freight percentage assigned below is applied.
PACKING & FREIGHT: Percent applied to the categories identified above for the supply/install Contractor(s) freight costs for packing, shrink-wrapping, crating, containerization and/or shipping expenses.
LABOR ESCALATION APR: Annual percentage rate applied to all direct labor and Prime Contractor staff travel and living costs, which is then pro-rated to the projected duration from the date of this OPCC to mid-point of construction.
MATERIALS ESCALATION APR: Annual percentage rate applied to all direct costs for construction materials, consumables, and construction equipment (M&CE), which is then pro-rated to the projected duration from the date of this OPCC to mid-point of construction.
EQUIPMENT ESCALATION APR: Annual percentage rate applied to all direct costs for process and buy-out equipment (EQ), which is then pro-rated to the projected duration from the date of this OPCC to mid-point of construction.
YEARS OF ESCALATION: Identifies the "life" of this OPCC (starting from the completion date of the OPCC), over which the APR escalation rates identified above will be applied, and reflecting the overall time anticipated to pass for executing pre-con issues that could include sampling, surveys/testing, bench tests, design development, Contractor solicitations/negotiations, Prime and/or Subcontractor site staffing, site set-up, submittals/approvals, early/long-lead equipment procurement, and planning/coordination for any special demolition, phasing, and/or shut-downs.
ESTIMATE CONTINGENCY: Percent applied to the direct MH, M&CE, & EQ costs for the purpose of covering the potential Estimator errors/omissions, variability with the take-off and quantification efforts, and misinterpretation of the design documents.
SCOPE CONTINGENCY: Percent applied to the direct MH, M&CE, & EQ costs for covering the potential growth due to design changes/revisions, Owner preferences, and unknown regulatory requirements.
LOCAL MARKET ISSUES: Percent applied to the supply/install Contractor(s) direct MH & M&CE costs for the local construction/bid climate issues such as bidder quantity, bidder quality, contractor risk appetite, project size/complexity, bonding capacity, availability of labor, materials, and/or equipment, local governmental/bureaucratic mandates, and perceived project execution issues.
ANTICIPATED CONSTRUCTION DURATION: Identifies the total construction duration (from physical notice-to-proceed mobilization through to substantial completion) either in weeks, months, or years for the project with the labor headcount and production efficiency assigned in this OPCC, and excluding time for testing & final completion/sign-off.
SPECIAL PROJECT CONSIDERATION: Identifies the anticipated special project considerations for demolition, rehabilitation, phasing, personal protective equipment (PPE), or combination of these.

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765
PROJECT STAFF LABOR: The costs attributable to the labor hours generated by all the Prime Contractor's on-site and home-office based personnel directly billable to the project.					
PROJECT STAFF TRAVEL, LIVING, & OTHER: The costs attributable to the travel, living, & miscellaneous related costs generated by all the Prime Contractor's on-site and home-office based personnel directly billable to the project.					
PROJECT STAFF CAMP ALLOWANCE: The anticipated total cost for providing all Tradesmen and Supervision with travel to/from a remote work site, as well as the establishment & maintenance of a remote camp					
TRADESMEN & SUPERVISION CAMP ALLOWANCE: The anticipated total cost for providing all Tradesmen and Supervision with travel to/from a remote work site, as well as the establishment & maintenance of a remote camp.					
ESCALATION: The anticipated increase in the Prime Contractor's Pre-Construction & Construction Staff labor, travel/living, and camp costs due to the project duration (i.e. years of escalation) and escalation APR's indicated above.					
INSURANCES: An allowance for the overall project builders risk insurance, as well as the miscellaneous umbrella, vehicle, and liability insurances carried by the Prime Contractor.					
GENERAL & ADMINISTRATIVE: The costs attributable to the Prime Contractor's indirect costs that are attributable to labor, supplies, materials, equipment, tools, facilities and/or overheads, both field and home office, during execution of the project.					
PROJECT & CONSTRUCTION MANAGEMENT FEE: The anticipated profit for the Prime Contractor in executing and/or managing the project.					
PROJECT ENGINEERING: The forecasted cost of the project engineering effort, which may include geotechnical testing and design, detailed project design, and/or support and oversight during construction.					
BONDS: Percent applied to the applicable overall project MH, M&CE, & EQ costs for the bonds to ensure satisfactory completion (to the Owner) and payment to the suppliers, Vendors, & Subcontractors.					

WBS COST BUILD-UP SUMMARY

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Introduction

This MAP presents another view of how the OPCC goes from DIRECT COSTS to COST-OF-WORK, and identifies the development of the overall project cost build-up. NOTE: The dollar amounts reflect the OPCC while the percentages are provided for general informational purposes only and do not represent how the individual costs were established.

CATEGORY	WBS	DESCRIPTION	INSTALLATION COSTS		TOTAL COST	%	OPCC SOURCE
			Prime Contractor	Subcontractors			
INSTALLING CONTRACTOR(S) DIRECT COSTS	1	General Conditions	\$1,408,927	\$0	\$1,408,927	8.0%	INSTALLATION OVERVIEW & DIVS 1-17
	2	General Allowances	\$55,459	\$49,683	\$105,142	0.6%	
	3	Process Control EQ	\$0	\$328,569	\$328,569	1.9%	
	4	20 MGD CAPACITY UPGRADES					
	5	Extend Chem Lines & Utilidor-CHEM	\$135,554	\$83,671	\$219,225	1.2%	
	6	Procure Shelf-Spare Solids/Sand Pump (1)-ACT	\$18,500		\$18,500	0.1%	
	7	Install 2nd Flash Mix Pump (1)-ACT	\$27,744	\$40,979	\$68,723	0.4%	
	8	Install Shelf-Spare Mix Pump (1)-SOL		\$40,227	\$40,227	0.2%	
	9	Replace 4 MGD Pump with 7.5 MGD (1)-FWPS	\$331,800	\$172,039	\$503,839	2.8%	
	10	Replace Switchgear-ELEC		\$1,539,287	\$1,539,287	8.7%	
	11	Rewire to Support BU Power Supply-ELEC	\$0	\$106,273	\$106,273	0.6%	
	12	Replace 1 MW Genset with 2 MW (1)-ELEC	\$108,671	\$1,402,889	\$1,511,560	8.5%	
	13	20 MGD REPAIR & REPLACE		\$0	\$0	0.0%	
	14	Replace Polymer Unit PLC (1)-CHEM	\$7,500	\$1,662	\$9,162	0.1%	
	15	DELETED: Replace Meter Pumps (17)-CHEM	\$0	\$0	\$0	0.0%	
	16	Replace Actiflo System PLC (1)-ACT	\$20,000	\$5,541	\$25,541	0.1%	
	17	Replace Sample Pumps (2)-ACT	\$3,000	\$14,523	\$17,523	0.1%	
	18	Replace Tube Modules in Settle Tanks (2)-ACT	\$90,250	\$13,721	\$103,971	0.6%	
	19	DELETED: Replace GAC Media (3X)-FILT	\$0	\$0	\$0	0.0%	
	20	Upgrade/Replace Existing Wiring-FILT		\$88,560	\$88,560	0.5%	
	21	Chem Line Support Mods-WWEO	\$0	\$16,076	\$16,076	0.1%	
	22	Replace VFD Units (3)-FWPS		\$334,948	\$334,948	1.9%	
	23	20 MGD LIFE SAFETY		\$0	\$0	0.0%	
	24	Replace Faded NFPA Signage-CHEM		\$3,265	\$3,265	0.0%	
	25	Add Exit Door Panic Hardware (3)-CHEM	\$4,449	\$0	\$4,449	0.0%	
	26	Change Door Swing Direction (1)-O3	\$2,157		\$2,157	0.0%	
	27	Add Exit Area Containment Pans (2)-CHEM	\$1,795	\$2,744	\$4,539	0.0%	
	28	Add Exit Emergency Shut-Off (2)-O3		\$4,297	\$4,297	0.0%	
	29	Replace Guardrail (20 LF)-ACT	\$2,626	\$0	\$2,626	0.0%	
	30	Seal & Waterstop Corner Leaks (2)-ACT	\$14,753		\$14,753	0.1%	
	31	Add Exit Door Panic Hardware (2)-ACT	\$2,966	\$0	\$2,966	0.0%	
	32	Add West Guardrail Kickplate (20 LF)-ACT	\$950		\$950	0.0%	
	33	Upgrade Outlets to GFI's (8)-ACT	\$0	\$874	\$874	0.0%	
	34	Replace Guardrail (20 LF)-OZ	\$2,626		\$2,626	0.0%	
	35	Upgrade Outlets to GFI's (8)-CHEM	\$0	\$874	\$874	0.0%	
	36	Replace Guardrail (20 LF)-FILT	\$2,626		\$2,626	0.0%	
	37	Seal & Waterstop Corner Leaks (2)-FILT	\$14,156	\$0	\$14,156	0.1%	
	38	Add Ladder Pit Kickplate (20 LF)-FILT	\$950		\$950	0.0%	
	39	Upgrade Outlets to GFI's (16)-FILT	\$0	\$1,748	\$1,748	0.0%	
	40	Add Exit Door Panic Hardware (2)-FWPS	\$2,966		\$2,966	0.0%	
	41	Install Scupper & Downspout (1)-DEW	\$3,771	\$0	\$3,771	0.0%	
	42	Seal & Waterstop Corner Leaks (2)-OZ	\$18,213		\$18,213	0.1%	
	43	20 MGD SEISMIC RETROFITS		\$0	\$0	0.0%	
	44	Add Pipe Bracing-CHEM/O3/LOX		\$13,291	\$13,291	0.1%	
	45	Add Destruct Pipe Bracing: OZ	\$0	\$4,344	\$4,344	0.0%	
	46	Add N & S Wall Beams & Columns (3)-WWEO	\$88,141		\$88,141	0.5%	
	47	Add Basin Width Beams & Columns (3)-WWEO	\$79,036	\$0	\$79,036	0.4%	
	48	Add W & E Wall Roof Anchors (23)-FWPS	\$60,200		\$60,200	0.3%	
	49	Replace Deficient Deck Sections (1,966 SF)-FW	\$56,084	\$0	\$56,084	0.3%	
	50	Strengthen Chord Connections (44)-FWPS	\$4,965		\$4,965	0.0%	
	51	Add Shear Wall Plates & Anchors (46)-FWPS	\$36,400		\$36,400	0.2%	
	52	Add Cable Tray Bracing-FWPS		\$5,245	\$5,245	0.0%	
	53	Install E Side Frame Braces for 2nd Floor (1)-DE	\$20,761	\$0	\$20,761	0.1%	

WBS COST BUILD-UP SUMMARY

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Introduction

*This MAP presents another view of how the OPCC goes from DIRECT COSTS to COST-OF-WORK, and identifies the development of the overall project cost build-up. **NOTE: The dollar amounts reflect the OPCC while the percentages are provided for general informational purposes only and do not represent how the individual costs were established.***

INSTALLATION COSTS						
CATEGORY	WBS	DESCRIPTION	Prime Contractor	Subcontractors	TOTAL COST	% OPCC SOURCE
	54	Add E & W Wall Roof Anchors (6)-DEW	\$26,751		\$26,751	0.2%
	55	Tie Floor Slab to Walls (2)-DEW	\$11,056		\$11,056	0.1%
	56	Install Space Heater Braces (8)-SITE		\$4,116	\$4,116	0.0%
	57	30 MGD CAPACITY UPGRADES	\$0	\$0	\$0	0.0%
	58	Install New Ozone Generator (1)-O3	\$400,773	\$107,638	\$508,411	2.9%
	59	Install New Flow Channel & Gallery (1)-ACT	\$1,510,141	\$502,560	\$2,012,702	11.4%
	60	Install New Flow Channel & Gallery (1)-OZ	\$900,213	\$467,702	\$1,367,916	7.7%
	61	Install New Thickener (1)-SOL	\$230,402	\$127,610	\$358,012	2.0%
	62	Install New Cells (2) & Gallery-FILT	\$1,182,064	\$525,142	\$1,707,206	9.6%
	63	Replace 7.5 MGD Pumps with 12 MGD (3)-FWF	\$1,301,400	\$727,231	\$2,028,631	11.5%
	64	Install 5th 7.5 MGD Pump (1)-FWPS	\$331,800	\$162,369	\$494,169	2.8%
	65	Replace 7.5 MGD Pumps with 15 MGD (2)-RWF	\$354,300	\$365,472	\$719,772	4.1%
	66	Install 3rd Centrifuge & Solids Pump (1)-DEW	\$474,744	\$222,699	\$697,444	3.9%
	67	30 MGD REPAIR & REPLACE	\$0	\$0	\$0	0.0%
	68	DELETED: Replace Meter Pumps (17)-CHEM				
	69	Replace Flash Mix Pumps (2)-ACT	\$55,000	\$96,196	\$151,196	0.9%
	70	Replace Thickener Drive (1)-SOL	\$20,000	\$25,598	\$45,598	0.3%
	71	DELETED: Replace GAC Media (1X)-FILT	\$0	\$0	\$0	0.0%
	72	Replace Solids Transfer Pumps (2)-DEW	\$30,000	\$93,906	\$123,906	0.7%
	73		\$0	\$0	\$0	0.0%
	74	ADDERS per 17NOV17 Email				
	75	20 MGD CAPACITY UPGRADES	\$0	\$0	\$0	0.0%
	76	Add Hypochlorite Vent Return Line-CHEM		\$2,501	\$2,501	0.0%
	77	Add Meter Pump Strainers (17)-CHEM	\$2,465	\$1,804	\$4,269	0.0%
	78	Upgrade Sitewide Lighting to LED-SITE		\$58,947	\$58,947	0.3%
	79	Replace Rental LOX Tank with Larger (1)-O3	\$0	\$32,491	\$32,491	0.2%
	80	20 MGD LIFE SAFETY				
	81	Improve Bldg/Gallery Ventilation-ACT	\$0	\$12,511	\$12,511	0.1%
	82	Replace Stairwell Door with Fire Door-FILT	\$1,484	\$25	\$1,509	0.0%
	83	Improve Blower Room Ventilation-FILT	\$0	\$16,404	\$16,404	0.1%
	84	Improve SWGR Room Ventilation-FWPS		\$30,920	\$30,920	0.2%
	85	Add SWGR Door Panic Hardware (2)-FWPS	\$2,966	\$0	\$2,966	0.0%
	86	Improve South Stairwell Ventilation-OZ		\$3,960	\$3,960	0.0%
	87	Add Fall Protection to Plate Hatches (10)-SITE	\$18,326	\$0	\$18,326	0.1%
	88	Add Ladder Fall Restraint to Basin-WWEQ	\$3,209		\$3,209	0.0%
	89	Improve Room/Bldg Ventilation-WWEQ	\$0	\$13,264	\$13,264	0.1%
	90	20 MGD REPAIR & REPLACE				
	91	Replace Security Camera & Computer (1)-MISC	\$0	\$8,922	\$8,922	0.1%
	92	30 MGD CAPACITY UPGRADES				
	93	Convert Wet NaOCl System to Dry-CHEM	\$157,365	\$105,768	\$263,133	1.5%
	94	Storage Room Mods for Added Space-CHEM	\$41,550	\$22,185	\$63,735	0.4%
	95		\$0	\$0	\$0	0.0%
	96					
	97		\$0	\$0	\$0	0.0%
	98					
	99		\$0	\$0	\$0	0.0%
		Direct Costs Subtotal	\$9,684,009	\$8,013,275	\$17,697,284	
		Payroll Deducts & Workers Comp	\$479,176	\$301,821	\$780,997	4.4%
		Small Tools & Personal Safety Gear	\$52,410	\$33,012	\$85,422	0.5%
		Vendor Inspections & Start-Up Assistance	\$108,840	\$76,907	\$185,747	1.0%
		Vendor Spare Parts & Special Tools	\$205,346	\$145,098	\$350,444	2.0%
		Vendor Packing & Freight	\$190,471	\$134,587	\$325,058	1.8%
		Sales Tax				

WBS COST BUILD-UP SUMMARY

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Introduction

This MAP presents another view of how the OPCC goes from DIRECT COSTS to COST-OF-WORK, and identifies the development of the overall project cost build-up. **NOTE: The dollar amounts reflect the OPCC while the percentages are provided for general informational purposes only and do not represent how the individual costs were established.**

INSTALLATION COSTS							
CATEGORY	WBS	DESCRIPTION	Prime Contractor	Subcontractors	TOTAL COST	%	
INSTALLING CONTRACTOR(S) BURDENS & MARK-UPS		Overhead & General Conditions		\$435,235	\$435,235	2.5%	
		Profit		\$913,993	\$913,993	5.2%	
		Builders Risk Insurance		\$0	\$0	0.0%	
		Liability Insurance		\$11,174	\$11,174	0.1%	
		Umbrella & Vehicle Insurances		\$13,002	\$13,002	0.1%	
		Bonds		\$131,015	\$131,015	0.7%	
		Burdens & Mark-Ups Subtotal		\$1,036,243	\$2,195,844	\$3,232,087	18.3%
		Running Total		\$10,720,252	\$10,209,119	\$20,929,371	
ESTIMATOR GROSS ADJUSTMENTS		Escalation		\$0	\$0	0.0%	
		Estimate Contingency	\$1,608,038	\$1,531,368	\$3,139,406	15.0%	
		Scope Contingency	\$1,608,038	\$1,531,368	\$3,139,406	15.0%	
		Local Market Issues					
		Gross Receipts Tax		\$0	\$0	0.0%	
		Gross Adjustments Subtotal	\$3,216,076	\$3,062,736	\$6,278,811	30.0%	
	Running Total		\$13,936,327	\$13,271,855	\$27,208,182		
PRIME CONTRACTOR COSTS		Field Staff Labor	\$2,823,055		\$2,823,055	10.4%	
		Field Staff Travel & Living	\$171,722		\$171,722	0.6%	
		Remote Camp (Field Staff & Tradesmen)			\$0	0.0%	
		Escalation			\$0	0.0%	
		Insurances	\$312,885		\$312,885	1.1%	
		General & Administration	\$1,525,792		\$1,525,792	5.6%	
		Profit	\$3,051,584		\$3,051,584	11.2%	
		Project Engineering	\$4,081,227		\$4,081,227	15.0%	
		Bonds	\$349,639		\$349,639	1.3%	
		Gross Receipts Tax					
	Prime Contractor Subtotal	\$12,315,905	\$0	\$12,315,905	45.3%		
GRAND TOTAL			\$26,252,233	\$13,271,855	\$39,524,088		



WORK BREAKDOWN STRUCTURE

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

WBS Items																	
WBS	Description	ALLOCATED to OTHER WBS	CIP SCOPE ASSIGNMENT	EXCLUDE from ALLOCATIONS	ALLOCATED to CIP SCOPES	Direct Costs				Cost-of-Work							
						Costs are compilations of WBS coded items in DIVS 1-17 sheets				Build-up methodology of Direct Costs to these costs is demonstrated in OPCC SUMMARY sheet							
						MH	MH \$	M&CE \$	EQ \$	DIRECT COST TOTAL	MH	MH \$	M&CE \$	EQ \$	COST-OF-WORK (C-O-W) TOTAL	C-O-W TOTAL after PROPORTIONAL ALLOCATION of CHECKED WBS ITEMS (at left)	CIP SCOPE TOTAL with ALLOCATION of CHECKED CIP SCOPE ITEMS (at left)
0	Prime Contractor	✓				40,964	\$2,823,055	\$171,722		\$2,994,777					\$12,315,905		
1	General Conditions	✓				5,820	\$281,427	\$1,127,500		\$1,408,927	7,566	\$451,868	\$1,465,750		\$1,917,618		
2	General Allowances	✓				974	\$51,010	\$36,526	\$17,607	\$105,142	1,266	\$86,658	\$51,145	\$29,090	\$166,893		
3	Process Control EQ	✓				1,375	\$81,477	\$84,194	\$162,898	\$328,569	1,787	\$154,288	\$128,381	\$270,748	\$553,417		
4	20 MGD CAPACITY UPGRADES		1			0	\$0	\$0	\$0	\$0	0	\$0	\$0	\$0	\$0	\$0	\$10,542,965
5	Extend Chem Lines & Utilidor-CHEM		1			2,423	\$130,421	\$49,413	\$39,391	\$219,225	3,151	\$227,230	\$69,136	\$55,957	\$352,323	\$566,752	
6	Procure Shelf-Spare Solids/Sand Pump (1)-ACT		1						\$18,500	\$18,500				\$26,280	\$26,280	\$42,275	
7	Install 2nd Flash Mix Pump (1)-ACT		1			160	\$9,607	\$30,517	\$28,600	\$68,723	208	\$18,140	\$46,518	\$40,893	\$105,551	\$169,791	
8	Install Shelf-Spare Mix Pump (1)-SOL		1			154	\$9,223	\$29,904	\$1,100	\$40,227	200	\$17,465	\$45,598	\$1,828	\$64,891	\$104,385	
9	Replace 4 MGD Pump with 7.5 MGD (1)-FWPS		1			455	\$27,296	\$73,642	\$402,900	\$503,839	591	\$51,689	\$112,292	\$589,513	\$753,493	\$1,212,081	
10	Replace Switchgear-ELEC		1			2,661	\$157,738	\$120,649	\$1,260,900	\$1,539,287	3,460	\$298,699	\$183,968	\$2,095,703	\$2,578,370	\$4,147,606	
11	Rewire to Support BU Power Supply-ELEC		1			720	\$42,673	\$63,600		\$106,273	936	\$80,806	\$96,979		\$177,785	\$285,988	
12	Replace 1 MW Genset with 2 MW (1)-ELEC		1			1,641	\$93,778	\$82,981	\$1,334,800	\$1,511,560	2,133	\$168,807	\$121,315	\$2,205,246	\$2,495,368	\$4,014,088	
13	20 MGD REPAIR & REPLACE		2			0	\$0	\$0	\$0	\$0	0	\$0	\$0	\$0	\$0	\$0	\$1,551,738
14	Replace Polymer Unit PLC (1)-CHEM		2			24	\$1,422	\$240	\$7,500	\$9,162	31	\$2,694	\$366	\$10,654	\$13,714	\$22,060	
	DELETED: Replace Meter Pumps (17)-CHEM		2														
16	Replace Actiflo System PLC (1)-ACT		2			80	\$4,741	\$800	\$20,000	\$25,541	104	\$8,978	\$1,220	\$28,411	\$38,609	\$62,108	
17	Replace Sample Pumps (2)-ACT		2			100	\$6,022	\$8,501	\$3,000	\$17,523	131	\$11,404	\$12,962	\$4,262	\$28,628	\$46,051	
18	Replace Tube Modules in Settle Tanks (2)-ACT		2			160	\$9,721	\$4,000	\$90,250	\$103,971	208	\$18,408	\$6,099	\$128,205	\$152,713	\$245,656	
	DELETED: Replace GAC Media (3X)-FILT		2														
20	Upgrade/Replace Existing Wiring-FILT		2			600	\$35,560	\$53,000		\$88,560	780	\$67,339	\$80,816		\$148,154	\$238,323	
21	Chem Line Support Mods-WWEQ		2			100	\$6,076	\$10,000		\$16,076	130	\$11,505	\$15,248		\$26,753	\$43,036	
22	Replace VFD Units (3)-FWPS		2			206	\$12,210	\$25,238	\$297,500	\$334,948	268	\$23,122	\$38,484	\$494,465	\$556,071	\$894,504	
23	20 MGD LIFE SAFETY		3			0	\$0	\$0	\$0	\$0	0	\$0	\$0	\$0	\$0	\$0	\$220,366
24	Replace Faded NFPA Signage-CHEM		3			50	\$2,015	\$1,250		\$3,265	65	\$3,816	\$1,906		\$5,722	\$9,205	
25	Add Exit Door Panic Hardware (3)-CHEM		3			24	\$1,314	\$210	\$2,925	\$4,449	31	\$2,110	\$273	\$4,155	\$6,538	\$10,517	
26	Change Door Swing Direction (1)-O3		3			12	\$657	\$300	\$1,200	\$2,157	16	\$1,055	\$390	\$1,705	\$3,150	\$5,067	
27	Add Exit Area Containment Pans (2)-CHEM		3			32	\$1,944	\$800	\$1,795	\$4,539	42	\$3,682	\$1,220	\$2,549	\$7,451	\$11,985	
28	Add Exit Emergency Shut-Off (2)-O3		3			32	\$1,897	\$2,400		\$4,297	42	\$3,591	\$3,660		\$7,251	\$11,664	
29	Replace Guardrail (20 LF)-ACT		3			27	\$1,510	\$124	\$992	\$2,626	35	\$2,425	\$161	\$1,410	\$3,995	\$6,427	
30	Seal & Waterstop Corner Leaks (2)-ACT		3			212	\$10,746	\$4,007		\$14,753	276	\$17,255	\$5,209		\$22,464	\$36,136	
31	Add Exit Door Panic Hardware (2)-ACT		3			16	\$876	\$140	\$1,950	\$2,966	21	\$1,407	\$182	\$2,770	\$4,359	\$7,011	
32	Add West Guardrail Kickplate (20 LF)-ACT		3			10	\$529	\$124	\$298	\$950	12	\$849	\$161	\$423	\$1,433	\$2,305	
33	Upgrade Outlets to GFIs (8)-ACT		3			8	\$474	\$400		\$874	10	\$898	\$610		\$1,508	\$2,425	
34	Replace Guardrail (20 LF)-OZ		3			27	\$1,510	\$124	\$992	\$2,626	35	\$2,425	\$161	\$1,410	\$3,995	\$6,427	



WORK BREAKDOWN STRUCTURE

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

WBS Items																	
WBS	Description	ALLOCATED TO OTHER WBS	CIP SCOPE ASSIGNMENT	EXCLUDE from ALLOCATIONS	ALLOCATED to CIP SCOPE	Direct Costs				Cost-of-Work							
						Costs are compilations of WBS coded items in DIVS 1-17 sheets				Build-up methodology of Direct Costs to these costs is demonstrated in OPCC SUMMARY sheet							
						MH	MH \$	M&CE \$	EQ \$	DIRECT COST TOTAL	MH	MH \$	M&CE \$	EQ \$	COST-OF-WORK (C-O-W) TOTAL	C-O-W TOTAL after PROPORTIONAL ALLOCATION of CHECKED WBS ITEMS (at left)	CIP SCOPE TOTAL with ALLOCATION of CHECKED CIP SCOPE ITEMS (at left)
35	Upgrade Outlets to GFI's (8)-CHEM		3			8	\$474	\$400		\$874	10	\$898	\$610		\$1,508	\$2,425	
36	Replace Guardrail (20 LF)-FILT		3			27	\$1,510	\$124	\$992	\$2,626	35	\$2,425	\$161	\$1,410	\$3,995	\$6,427	
37	Seal & Waterstop Corner Leaks (2)-FILT		3			210	\$10,680	\$3,476		\$14,156	273	\$17,148	\$4,519		\$21,667	\$34,854	
38	Add Ladder Pit Kickplate (20 LF)-FILT		3			10	\$529	\$124	\$298	\$950	12	\$849	\$161	\$423	\$1,433	\$2,305	
39	Upgrade Outlets to GFI's (16)-FILT		3			16	\$948	\$800		\$1,748	21	\$1,796	\$1,220		\$3,016	\$4,851	
40	Add Exit Door Panic Hardware (2)-FWPS		3			16	\$876	\$140	\$1,950	\$2,966	21	\$1,407	\$182	\$2,770	\$4,359	\$7,011	
41	Install Scupper & Downspout (1)-DEW		3			36	\$1,971	\$1,800		\$3,771	47	\$3,165	\$2,340		\$5,505	\$8,855	
42	Seal & Waterstop Corner Leaks (2)-OZ		3			256	\$12,977	\$5,237		\$18,213	333	\$20,836	\$6,808		\$27,644	\$44,468	
43	20 MGD SEISMIC RETROFITS		4			0	\$0	\$0	\$0	\$0	0	\$0	\$0	\$0	\$0	\$0	\$996,607
44	Add Pipe Bracing-CHEM/O3/LOX		4			120	\$7,291	\$6,000		\$13,291	156	\$13,806	\$9,149		\$22,955	\$36,926	
45	Add Destruct Pipe Bracing: OZ		4			32	\$1,944	\$2,400		\$4,344	42	\$3,682	\$3,660		\$7,341	\$11,809	
46	Add N & S Wall Beams & Columns (3)-WWEQ		4			1,330	\$71,323	\$16,818		\$88,141	1,730	\$114,519	\$21,863		\$136,382	\$219,386	
47	Add Basin Width Beams & Columns (3)-WWEQ		4			1,210	\$64,850	\$14,186		\$79,036	1,573	\$104,126	\$18,442		\$122,568	\$197,164	
48	Add W & E Wall Roof Anchors (23)-FWPS		4			686	\$37,573	\$22,627		\$60,200	892	\$60,329	\$29,415		\$89,744	\$144,364	
49	Replace Deficient Deck Sections (1,966 SF)-FWPS		4			310	\$16,955	\$39,129		\$56,084	403	\$27,223	\$50,868		\$78,091	\$125,618	
50	Strengthen Chord Connections (44)-FWPS		4			66	\$3,614	\$1,351		\$4,965	86	\$5,802	\$1,756		\$7,559	\$12,159	
51	Add Shear Wall Plates & Anchors (46)-FWPS		4			428	\$23,446	\$12,954		\$36,400	557	\$37,646	\$16,840		\$54,486	\$87,647	
52	Add Cable Tray Bracing-FWPS		4			48	\$2,845	\$2,400		\$5,245	62	\$5,387	\$3,660		\$9,047	\$14,553	
53	Install E Side Frame Braces for 2nd Floor (1)-DEW		4			160	\$8,761	\$12,000		\$20,761	208	\$14,066	\$15,600		\$29,666	\$47,722	
54	Add E & W Wall Roof Anchors (6)-DEW		4			253	\$13,870	\$12,881		\$26,751	329	\$22,270	\$16,745		\$39,016	\$62,761	
55	Tie Floor Slab to Walls (2)-DEW		4			58	\$3,157	\$7,898		\$11,056	75	\$5,069	\$10,268		\$15,337	\$24,672	
56	Install Space Heater Braces (8)-SITE		4			48	\$2,916	\$1,200		\$4,116	62	\$5,523	\$1,830		\$7,352	\$11,827	
57	30 MGD CAPACITY UPGRADES		5			0	\$0	\$0	\$0	\$0	0	\$0	\$0	\$0	\$0	\$0	\$24,054,666
58	Install New Ozone Generator (1)-O3		5			401	\$24,083	\$84,328	\$400,000	\$508,411	521	\$45,443	\$128,538	\$568,221	\$742,202	\$1,193,917	
59	Install New Flow Channel & Gallery (1)-ACT		5			10,598	\$576,038	\$523,899	\$912,765	\$2,012,702	13,777	\$961,821	\$757,784	\$1,304,637	\$3,024,243	\$4,864,843	
60	Install New Flow Channel & Gallery (1)-OZ		5			13,142	\$708,624	\$508,604	\$150,687	\$1,367,916	17,084	\$1,172,362	\$727,521	\$226,763	\$2,126,646	\$3,420,955	
61	Install New Thickener (1)-SOL		5			1,620	\$88,233	\$120,321	\$149,459	\$358,012	2,106	\$150,983	\$177,836	\$212,314	\$541,133	\$870,475	
62	Install New Cells (2) & Gallery-FILT		5			10,834	\$593,709	\$514,901	\$598,596	\$1,707,206	14,084	\$999,469	\$743,912	\$858,355	\$2,601,737	\$4,185,194	
63	Replace 7.5 MGD Pumps with 12 MGD (3)-FWPS		5			1,543	\$92,582	\$256,349	\$1,679,700	\$2,028,631	2,006	\$175,317	\$390,886	\$2,477,469	\$3,043,672	\$4,896,098	
64	Install 5th 7.5 MGD Pump (1)-FWPS		5			361	\$21,666	\$69,603	\$402,900	\$494,169	469	\$41,027	\$106,133	\$589,513	\$736,672	\$1,185,023	
65	Replace 7.5 MGD Pumps with 15 MGD (2)-RWPS		5			990	\$59,639	\$163,634	\$496,500	\$719,772	1,287	\$112,934	\$249,512	\$739,648	\$1,102,095	\$1,772,847	
66	Install 3rd Centrifuge & Solids Pump (1)-DEW		5			795	\$47,701	\$148,142	\$501,600	\$697,444	1,033	\$90,277	\$225,876	\$719,095	\$1,035,248	\$1,665,316	
67	30 MGD REPAIR & REPLACE		6			0	\$0	\$0	\$0	\$0	0	\$0	\$0	\$0	\$0	\$0	\$808,553
	Replace Meter Pumps (17)-CHEM		6														
69	Replace Flash Mix Pumps (2)-ACT		6			452	\$27,148	\$66,848	\$57,200	\$151,196	588	\$51,409	\$101,931	\$81,787	\$235,127	\$378,229	

INSTALLATION OVERVIEW

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions			
<i>Project and Owner Market</i>	Municipal/Governmental		<i>Project Site Condition</i>
<i>Installation Labor Classification</i>	Prevailing Wage/Davis Bacon		<i>Site Condition Assessment</i>
<i>Installation Labor Work Schedule</i>	(5)-8 hr days Mon-Fri		<i>Work Area Congestion</i>
<i>Installation Labor Work Shifts</i>	1 Shift (daylight)		<i>Work Area Spread</i>
<i>Installation Shift Differential Pay</i>			<i>Pipe & Raceway Layouts</i>
<i>Installation Labor Productivity</i>	90% (7.2 hrs production/8 hrs)		<i>Pipe & Raceway Supports</i>
<i>Bldg & Structure Risk Category</i>	Category IV - Essential facility		<i>High Work</i>
<i>Site Seismic Consideration</i>	0.40-0.80 (x G) Peak acceleration		<i>Clean Room Work</i>
<i>Site Frost Depth Consideration</i>	5"-10"		<i>Hazardous Work</i>
<i>Site Wind Speed Consideration</i>	Zone II - 160 MPH		<i>Hot Weather Work</i>
<i>Site Location Accessibility</i>	Slightly Difficult		<i>Cold Weather Work</i>
<i>Owner's Project Representative</i>	None (i.e. direct contract with GC)		<i>Rain or Snow Work</i>
<i>Maximum Pipe Size & Flow Rates</i>	72"Ø: 25,370(g)-91,510(p) GPM		<i>Night Work</i>
<i>(un-assigned)</i>			<i>DBE & MBE Work</i>

Work Self-Performed by Prime Contractor		
<input checked="" type="checkbox"/> DIV 1 Site Mgmt & Oversight Staff	<input checked="" type="checkbox"/> DIV 4 Masonry	<input type="checkbox"/> DIVS 11-15 INSTALL EQ: Process and Mechanical
<input checked="" type="checkbox"/> DIV 1 General Conditions	<input checked="" type="checkbox"/> DIV 5 SUPPLY EQ: Miscellaneous Metals	<input type="checkbox"/> DIV 13 Field-Erected Tanks
<input checked="" type="checkbox"/> DIV 2 Common Site Work	<input checked="" type="checkbox"/> DIV 5 INSTALL EQ: Miscellaneous Metals	<input type="checkbox"/> DIV 13 Shop-Fabricated Tanks
<input type="checkbox"/> DIV 2 Specialty Site Work	<input checked="" type="checkbox"/> DIVS 5-8 Buildings & Components	<input type="checkbox"/> DIVS 16-17 INSTALL EQ: Process & Mechanical
<input type="checkbox"/> DIV 2 Well Work	<input type="checkbox"/> DIVS 9-10 Finishes	<input type="checkbox"/> DIVS 16-17 SUPPLY EQ: Electrical and I&C
<input checked="" type="checkbox"/> DIV 3 Concrete	<input checked="" type="checkbox"/> DIVS 11-15 SUPPLY EQ: Process & Mechanical	<input type="checkbox"/> DIVS 16-17 INSTALL EQ: Electrical and I&C

Direct Cost Roll-Up of DIVS 1-17 Sheets										
CSI 1995	CSI 2004	Description (NIS = not in scope)	SF	CY	TON	MH	MH \$	M&CE \$	EQ \$	TOTAL
DIV 1	01	General Conditions				5,820	\$281,427	\$1,127,500		\$1,408,927
DIV 2	02 & 31-35	Common Site Work				4,445	\$214,947	\$166,305		\$381,252
DIV 2	02 & 31-35	Specialty Site Work - NIS								
DIV 2	33	Well Work - NIS								
DIV 3	03	Concrete		1,718		29,146	\$1,562,423	\$528,269		\$2,090,692
DIV 4	04	Masonry	680			265	\$13,141	\$9,977		\$23,118
DIV 5	05	EQ: Miscellaneous Metals			9.0				\$144,539	\$144,539
DIV 5	05	Miscellaneous Metals Installation				1,008	\$55,880	\$18,066		\$73,946
DIVS 5-8	05-08	Buildings & Components	1,882			2,437	\$133,294	\$130,756		\$264,050
DIVS 9-10	09-10	Finishes	3,120			698	\$28,136	\$15,629		\$43,765
DIV 13	33	Tanks: Field Erected - NIS								
DIV 13	33	Tanks: Shop Fabricated - NIS								
DIVS 11-15	40-45	EQ: Process & Mechanical							\$5,297,485	\$5,297,485
DIVS 11-15	21-23	Process & Mechanical Installation				9,368	\$569,182	\$1,343,963		\$1,913,145
DIVS 16-17	25-28 & 33	EQ: Electrical and I&C							\$3,845,335	\$3,845,335
DIVS 16-17	25-28 & 33	Electrical and I&C Installation				13,952	\$826,902	\$1,384,128		\$2,211,029
DIVS 1-17 DIRECT COST TOTAL						67,139	\$3,685,331	\$4,724,593	\$9,287,359	\$17,697,284

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions	
"Trips" Destination: <input type="text" value="Local Only"/>	Lodging (short vs. long): <input type="text"/>
Per-Diem Option: <input type="text"/>	Vehicle (short vs. long): <input type="text" value="\$50 vs. \$17 per Day"/>
Meetings Coverage: <input type="text" value="Managers & Start-Up"/>	Fuel-Oil-Maintenance: <input type="text" value="\$15 per Day"/>
Baggage Fees: <input type="text"/>	Ride Sharing: <input type="text"/>
Airport Parking: <input type="text"/>	Meals (excludes meetings): <input type="text" value="\$45 per Day"/>
Personal Mileage: <input type="text"/>	Incidentals: <input type="text" value="\$10 per Day"/>

Prime Contractor Staff

Site Management & Oversight Labor Allowances

Anticipated Project Construction Duration

TBD

Labor During both Pre-Construction & Construction

Labor Category Allowance	Project Director	Project Manager	Construction Manager	Construction Superintendents	Construction & Safety Engineers	Scheduling & Estimating	Contracts & Procurement	Start-Up, Test & Commission	Clerical & Administrative
Head Count		1.0	1.0	2.0	6.0			1.5	1.5
Multiple Shift Coverage		NA	NA	NA	NA			NA	NA
Travel & Living Classification		VEHICLE +	VEHICLE	VEHICLE	VEHICLE			VEHICLE	EXEMPT
Work Hours per Week		40	40	40	40			40	40
Base Rate + Benefits at 38%		\$114	\$99	\$83	\$61			\$76	\$30
Meals/Meetings Coverage		Included	Excluded	Excluded	Excluded			Excluded	Excluded
Travel & Living Cycle in Days		1	1	1	1			1	
Travel & Living Frequency		100%	100%	100%	100%			100%	
Construction Coverage		115.0%	115.0%	112.5%	112.5%			30.0%	115.0%

Labor Summary

Labor Metric	Project Director	Project Manager	Construction Manager	Construction Superintendents	Construction & Safety Engineers	Scheduling & Estimating	Contracts & Procurement	Start-Up, Test & Commission	Clerical & Administrative
LABOR Hours		3,496	3,496	6,840	20,520			1,368	5,244
LABOR Cost		\$398,020	\$344,950	\$571,072	\$1,245,974			\$103,831	\$159,208

Labor Total		Labor Assignment by WBS			
Labor Hours	Labor Cost	WBS	%	WBS Hours	WBS Cost
40,964	\$2,823,055				

DAY-BASED Travel & Living Allowances

Expenses During both Pre-Construction & Construction

DAILY Expense Allowance	Project Director	Project Manager	Construction Manager	Construction Superintendents	Construction & Safety Engineers	Scheduling & Estimating	Contracts & Procurement	Start-Up, Test & Commission	Clerical & Administrative
Per-Diem Option									
Meals/Meetings		\$56							
Vehicle		\$17	\$17	\$17	\$17			\$17	
Fuel-Oil-Maintenance (FOM)		\$15	\$15	\$15	\$15			\$15	
Incidentals		\$10							

Travel & Living Summary

Travel & Living Metric	Project Director	Project Manager	Construction Manager	Construction Superintendents	Construction & Safety Engineers	Scheduling & Estimating	Contracts & Procurement	Start-Up, Test & Commission	Clerical & Administrative
DAY Cost		\$98	\$32	\$32	\$32			\$32	
DAY Count		437	437	855	2,565			171	
DAYS Cost		\$42,826	\$13,984	\$27,360	\$82,080			\$5,472	

Day Travel & Living Total		Day Travel & Living Assignment by WBS			
Day Count	Day Cost	WBS	%	WBS Cost	
4,465	\$171,722				

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Glossary of Travel & Living Terms

<p>CONSTRUCTION DURATION COVERAGE: Any durations in excess of 100% indicates Pre-Construction time</p>
<p>SHORT VS. LONG: Identifies the anticipated short-term higher cost "rental" usually applying for (1) month or less, versus a longer term and less expensive "lease" option</p>
<p>EXEMPT: Personnel originating LOCAL to the project site who do not have a need or expectation of generating travel & living expenses.</p>
<p>HO: Home office personnel (i.e. Denver, CO based) originating either LOCAL or REMOTE to the project site who typically would not generate any travel & living expenses.</p>
<p>VEHICLE: Personnel originating LOCAL to the project site who are reimbursed 100% for the eligible daily expenses of a vehicle and related fuel-oil-maintenance throughout the individual's project time (re: "Construction Coverage").</p>
<p>VEHICLE +: Personnel originating LOCAL to the project site who are reimbursed 100% for the eligible daily expenses of meals, potential meetings coverage, and incidentals, all in addition to the vehicle and related fuel-oil-maintenance throughout the individual's project time (re: "Construction Coverage").</p>
<p>MIXED: Personnel originating LOCAL to the project site who are reimbursed 100% for the eligible daily expenses of a vehicle and related fuel-oil-maintenance, miscellaneous & incidental costs, and meals and potential meetings coverage (depending on staff position) at the indicated duration (re: "Travel & Living Cycle in Days"), as well as the eligible travel expenses to & from the home office location (i.e. Denver, CO based) at the indicated frequency (re: "Travel & Living Frequency") and project time (re: "Construction Coverage").</p>
<p>TRIPS: Personnel originating REMOTE to the project site who are reimbursed 100% for the eligible travel expenses to & from their remote home/home office location (i.e. Denver, CO based) at the indicated frequency (re: "Travel & Living Frequency") and durations (re: "Travel & Living Cycle in Days") throughout the individual's project time (re: "Construction Coverage").</p>
<p>PER-DIEM: Personnel originating REMOTE to the project site who receive a negotiated lump-sum daily stipend intended to cover 100% of the living costs for a full-time project area residence, as well as the travel expenses to & from their home/home office location (i.e. Denver, CO based) at the indicated/negotiated frequency throughout the individual's project time (re: "Construction Coverage").</p>
<p>REMOTE: Personnel originating REMOTE to the project site who are reimbursed 100% for the eligible living expenses related to a full-time project area residence, as well as the eligible travel expenses to & from their home/home office location (i.e. Denver, CO based) at the indicated frequency (re: "Travel & Living Cycle in Days") throughout the individual's project time (re: "Construction Coverage").</p>

DIV 1 (01) GENERAL REQUIREMENTS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions	
General Conditions Level Standard	(un-assigned) ▼

General Requirements

General Conditions Allowances

Anticipated Project Construction Duration

TBD

Temporary Construction Facilities

Prime Staff Trailers	Subcontractor Trailers	Owner/Rep Trailers	Meeting/Kitchen Trailers	Decon/Change Trailers	Material/Storage Containers	Equipment/Tool Containers	Portable Toilets	First-Aid & Sanitize Stations
2	2				2	2	3	3

Temporary Site & Project Conditions

WBS	Category	Potential Sub-Categories	Trades MH	MH @ \$48	M&CE \$	TOTAL
	Mobilization	Site occupancy and delivery/layout/staging coordination of facilities, utilities, equipment, & materials	360	\$17,408	\$11,600	\$29,008
	Field Office: Facilities	Lease, deliver, and set-up trailers, containers, toilets, & first-aid/sanitize stations	120	\$5,803	\$89,600	\$95,403
	Field Office: Carpentry	Supply/install facility decks, porches, canopies, ramps, stairways, landings, & misc accessways	60	\$2,901	\$9,500	\$12,401
	Field Office: Utilities	Install & connect electric, water (potable, utility, and/or fire), gas/propane, telecommunications, & internet	70	\$3,385	\$20,400	\$23,785
	Field Office: Equipment	Desks, chairs, tables, file cabinets, drawing racks, shelving, water coolers, refrigerators, & microwaves	30	\$1,451	\$14,100	\$15,551
	Field Office: Tools	Landline phones, computers, software, faxes, printers, copiers, & coffee makers	80	\$3,868	\$70,400	\$74,268
	Field Office: Supplies	Copy & printer paper, ink cartridges, pens/markers, coffee, tea, hot chocolate, bottled water, & cups	20	\$967	\$23,500	\$24,467
	Field Office: Incidentals	Petty cash, lockboxes, postage, Fedex, reproduction, meetings, meals, workshops, & janitorial services	510	\$24,661	\$17,000	\$41,661
	Field Staff: Safety	Training, certifications, personal protection equipment (>\$250), celebrations, events, & awards			\$12,800	\$12,800
	Field Staff: Communications	Cell phones, I-Pads, portable radios, LAN, pagers, docking/charging stations, & batteries			\$24,400	\$24,400
	Field Staff: Public Relations	Advertising, solicitations, public notices, MBE programs, community service/outreach, & progress meetings			\$29,700	\$29,700
	Construction: Accessibility	Bridges, cross-overs, scaffolds, decking, ramps, platforms, landings, docks, & stairways	160	\$7,737	\$16,200	\$23,937
	Construction: Aids	Large/Specialty hoists, cranes, forklifts, front-end loaders, trucks, conveyors, & elevators	900	\$43,520	\$231,100	\$274,620
	Construction: Aids Support	Mats, dunnage, spreaders, slings, rollers, dollies, maintenance, & FOG (fuel-oil-grease)	110	\$5,319	\$115,600	\$120,919
	Construction: Permitting	Applications, inspections, notifications, approvals, fees, & support documentation			\$46,200	\$46,200
	Construction: QA & QC	Samples, tests, inspections, & certifications, & miscellaneous consultants/subcontractors	640	\$30,947	\$169,700	\$200,647
	Construction: Utilities	Gensets, lights, heaters, fans, compressors, pumps, welders, & miscellaneous appliances	320	\$15,474	\$21,200	\$36,674
	Work Area: Accessibility	Road re-routes, turn-arounds, overpasses, haul routes, scaffolds, sidewalks, & parking/staging areas	100	\$4,836	\$6,400	\$11,236
	Work Area: Protection	Lighting, visual barriers, fencing, barricades, & protection for existing trees, plants, and/or structures	150	\$7,253	\$9,800	\$17,053
	Work Area: Safety & Health	Signage, fall/debris nets, ventilation blowers, fire extinguishers, first-aid supplies, water, ice, & cups	90	\$4,352	\$5,800	\$10,152
	Work Area: Passive Security	Guard shacks, work-time entry/exit guards, & video surveillance & recording system				
	Work Area: Active Security	24-hour watchman & monitoring of video surveillance system				
	Work Area: Transportation	Golf carts, remote parking facilities, & daily transportation to/from remote parking				
	Work Area: Housekeeping	Handling of waste dunnage & crating, general trash collection, waste containers, & tipping/disposal fees	240	\$11,605	\$14,900	\$26,505
	Controls: Site	Surveys, layouts, benchmarks, monuments, aerial & progress photos/videos, & GPS			\$27,000	\$27,000
	Controls: Environmental	Stormwater, erosion, dirt, mud, dust, noise, ice, snow, excessive cold/heat, pollution, & pest	130	\$6,286	\$4,300	\$10,586
	Controls: EQ & Materials	Handling, transport, storage, staging, maintenance, & damage/loss management	160	\$7,737	\$8,500	\$16,237
	Controls: Passive Traffic	Barriers, cones, steel cover plates, traffic control signage/flashers, & long-term detours	150	\$7,253	\$7,400	\$14,653
	Controls: Active Traffic	Day flagmen & nightly changes in barriers, traffic control signage/flashers, & short-term detours				
	Startup: Initial	Installation punchlisting, alignments, gross adjustments, 1st fill of oils & lubricants, and functional testing	160	\$7,737	\$3,800	\$11,537
	Startup: Clean & Disinfect	Pipe, tank, and equipment flushing, cleaning, disinfecting & fluids/waste handling & disposal	220	\$10,638	\$6,900	\$17,538
	Startup: Final	Calibrations, fine adjustments, 1st fill of fuels & chemicals/reagents, & operational training/testing,	130	\$6,286	\$14,200	\$20,486
	Startup: Test & Commission	Functional & operational punchlisting, O&M manuals, on-line interfacing/coordination, & performance testing	160	\$7,737	\$21,700	\$29,437
	Close-Out: Project	Punchlist sign-offs, record/as-built documents, warranty initiation, & bond closure/sign-offs	360	\$17,408	\$57,800	\$75,208
	Close-Out: Site	Disconnect utilities and remove facilities, carpentry, construction equipment/tools, & surplus materials	100	\$4,836	\$11,400	\$16,236
	Demobilization	Remove utilities and vacate site, along with final housekeeping, & area restoration	290	\$14,023	\$4,600	\$18,623
1	Subtotal - General Conditions Allowances		5,820	\$281,427	\$1,127,500	\$1,408,927

DIV 1 (01) GENERAL REQUIREMENTS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Camp Allowances for Tradesmen & Supervision

Considerations During both Pre-Construction & Construction

Travel Metric		Roundtrip Cost		Daily Cost		Daily Cost	
Work Days per Week	0	Air Transportation	\$0	Meals	\$0	Housekeep	\$0
Rotation Cycle - Weeks		Ground Transportation	\$0	Mobility & FOM	\$0	Laundry	\$0
1-Way Travel Time- Hours		Tips, Meals, & Miscellany	\$0	Lodging	\$0	Incidentals	\$0

Camp Summary

Report in OPCC SUMMARY

Camp Cost per Manhour	Eligible Manhours	TOTAL Camp Cost

Camp WBS Assignment

WBS	%	WBS Cost

Miscellaneous Allowances

WBS	Description	Quantity	Trades MH	MH @ \$0	M&CE \$	EQ \$	TOTAL
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
				\$			
Subtotal - Miscellaneous Allowances							

General Requirements Total

	MH	MH @ \$48 (avg)	M&CE \$	Camp \$	EQ \$	TOTAL
DIV 1(g) TOTAL	5,820	\$281,427	\$1,127,500			\$1,408,927



DIV 2 (02 & 31-35) COMMON SITE WORK

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions					
Clearing & Grubbing				Stormwater Control	
Primary Excavation Issue	Dust Control			Temporary Shoring	Shoring (walers & tiebacks)
Secondary Excavation Issue	Unstable Soil			Temporary Dewatering	Full-time Low Point Pumping
Hauling & Disposal Distance	5.1 - 10.0 miles roundtrip			Temporary Erosion Control	(re: General Allowances)
Base, Bed, & Fill Supply	100% Import			Temporary Traffic Control	(re: General Allowances)
General Excavations				Saw-Cutting	(re: General Allowances)
General Excavation Base & Fill				Core-Drilling	(re: General Allowances)
Structural Excavations	Excavate & Fill w/ Partial Haul			Pot-Holing	(re: General Allowances)
Structural Excavation Base	Crushed Stone ¾"-1½"			Liners & Geo-Materials	
Trench Excavations				Random Base & Fill	Crushed Stone ¾"-1½"
Trench Excavation Bed & Fill				General Allowances	Low

Common Site Work Scope

Structural Excavations														
WBS	Description	Qty	Type	Lng-Iss	Wd-Bse	Deep	Cut °	CY	TON	MH	MH @ \$48	M&CE \$	TOTAL	
12	New GEN slab	1	1.30	45.0	22.5	2.0	45	85	109	27	\$1,311	\$422	\$1,733	
	Compacted Base	25%	1.2	1.6	3.0			21	29	4	\$195	\$439	\$634	
12	New GEN diesel storage tank slab	1	1.30	49.0	27.0	2.0	45	110	141	35	\$1,677	\$542	\$2,218	
	Compacted Base	25%	1.2	1.6	3.0			27	37	5	\$250	\$563	\$813	
61	New SOL thickener	1	1.30	0.0	45.0	11.0	90	648	831	186	\$8,977	\$3,111	\$12,087	
	Compacted Base	5%	1.2	1.6	3.0			29	40	5	\$250	\$606	\$855	
62	New FILT cells	1	1.30	85.0	40.0	13.0	90	1,637	2,100	379	\$18,314	\$7,433	\$25,747	
	Compacted Base	4%	1.2	1.6	3.0			63	85	9	\$459	\$1,295	\$1,754	
60	New OZ channel & gallery	1	1.30	74.0	25.5	14.0	90	978	1,255	262	\$12,683	\$4,612	\$17,296	
	Compacted Base	4%	1.2	1.6	3.0			35	47	6	\$282	\$719	\$1,001	
59	New ACT channel & gallery	1	1.30	85.0	35.0	14.0	90	1,543	1,978	365	\$17,650	\$7,043	\$24,693	
	Compacted Base	4%	1.2	1.6	3.0			55	74	8	\$408	\$1,133	\$1,541	
5	Utilidor	1	1.30	300.0	6.0	3.5	45	373	478	113	\$5,445	\$1,818	\$7,263	
	Compacted Base	14%	1.2	1.6	3.0			53	72	10	\$469	\$1,096	\$1,566	
30	ACT corner leak area	2	1.30	6.0	6.0	20.0	90	53	68	17	\$828	\$265	\$1,093	
	Compacted Base	3%	1.2	1.6	3.0			1	2		\$12	\$27	\$40	
37	FILT corner leak area	2	1.30	6.0	6.0	18.0	90	48	62	15	\$746	\$238	\$984	
	Compacted Base	3%	1.2	1.6	3.0			1	2		\$12	\$27	\$40	
42	OZ corner leak area	2	1.30	6.0	6.0	24.0	90	64	82	21	\$993	\$318	\$1,311	
	Compacted Base	2%	1.2	1.6	3.0			1	2		\$12	\$27	\$40	
		0	0.00	0.0	0.0	0.0	0.0							
		0%	0.0	0.0	0.0									
Subtotal - Structural Excavations								5,539	7,104	1,468	\$70,974	\$31,734	\$102,708	

Temporary Shoring														
WBS	Description	Qty	Type	Long	Wide/Ø	Deep	Comm	SF	LF	MH	MH @ \$48	M&CE \$	TOTAL	
61	New SOL thickener area	1	16.0		50.0	11.0	1.00	1,728	157	181	\$8,746	\$4,041	\$12,787	
62	New FILT cells area	1	16.0	85.0	40.0	13.0	2.00	3,250	250	340	\$16,450	\$8,325	\$24,775	
		0	0.0	0.0	0.0	0.0	0.00							
60	New OZ channel & gallery area	1	16.0	90.0	40.0	14.0	2.00	3,640	260	381	\$18,424	\$9,729	\$28,153	
		0	0.0	0.0	0.0	0.0	0.00							
59	New ACT channel & gallery area	1	16.0	85.0	35.0	14.0	2.00	3,360	240	352	\$17,007	\$8,981	\$25,988	
		0	0.0	0.0	0.0	0.0	0.00							
30	ACT corner leak area	2	16.0	6.0	6.0	20.0	2.00	960	48	100	\$4,859	\$3,207	\$8,067	
		0	0.0	0.0	0.0	0.0	0.00							
37	FILT corner leak area	2	16.0	6.0	6.0	18.0	2.00	864	48	90	\$4,373	\$2,694	\$7,067	
		0	0.0	0.0	0.0	0.0	0.00							
42	OZ corner leak area	2	16.0	6.0	6.0	24.0	2.00	1,152	48	121	\$5,831	\$4,362	\$10,193	
		0	0.0	0.0	0.0	0.0	0.00							
		0	0.0	0.0	0.0	0.0	0.00							
Subtotal - Temporary Shoring								14,954	1,051	1,565	\$75,692	\$41,339	\$117,030	



DIV 2 (02 & 31-35) COMMON SITE WORK

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name		Location				Date	Estimator	Version	Job #	
Willamette River WTP Master Plan		Wilsonville, OR				30-Nov-17	Jim Ward	002	30503765	
<i>Temporary Dewatering</i>										
WBS	Description	Qty	Type	Long	Wide/Ø	SF	MH	MH @ \$48	M&CE \$	TOTAL
61	New SOL thickener area	1	2.0		50.0	1,963	125	\$6,058	\$10,768	\$16,826
62	New FILT cells area	1	2.0	85.0	40.0	3,400	217	\$10,490	\$18,647	\$29,136
		0	0.0	0	0					
60	New OZ channel & gallery area	1	2.0	90.0	40.0	3,600	230	\$11,107	\$19,744	\$30,850
		0	0.0	0	0					
59	New ACT channel & gallery area	1	2.0	85.0	35.0	2,975	190	\$9,179	\$16,316	\$25,494
		0	0.0	0.0	0.0					
5	Utilidor area	1	2.0	300.0	6.0	1,800	115	\$5,553	\$9,872	\$15,425
		0	0.0	0	0					
30	ACT corner leak area	2	2.0	6.0	6.0	72	5	\$222	\$395	\$617
		0	0.0	0.0	0.0					
37	FILT corner leak area	2	2.0	6.0	6.0	72	5	\$222	\$395	\$617
		0	0.0	0.0	0.0					
42	OZ corner leak area	2	2.0	6.0	6.0	72	5	\$222	\$395	\$617
		0	0.0	0	0					
		0	0.0	0	0					
Subtotal - Temporary Dewatering						13,954	890	\$43,053	\$76,531	\$119,584
<i>General Allowances</i>										
<p>This summary category is intended to provide coverage of the minor DIV 2 sitework and/or related items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.</p>										
WBS						MH	MH @ \$48	M&CE \$	TOTAL	
2	Subtotal - General Allowances					522	\$25,229	\$16,701	\$41,930	
Common Site Work Total										
						MH	MH @ \$48	M&CE \$	TOTAL	
DIV 2(c) TOTAL						4,445	\$214,947	\$166,305	\$381,252	

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions

Cement Type	Type II (lo heat & sulfate resist)	Footer Width	2x Foundation Width
Mix Additives	I Admixture (generic)	Slope of Haunch Foundation	45° from horizontal
Mix Strength	4,500 PSI (7-8 sacks/CY)	Base Slab Cantilever for Walls	1' Past Wall (all sides)
ACI Install Code	ACI 350R (environmental)	Elevated Channels & Troughs	
Reinforcement	A615-Plain Steel (qty in tons)	Embedments	Typical Types & Densities
Foundation Style	Monolithic Perimeter Haunch	Rebar Density Above Grade	Normal
Foundation Width	18" (excludes haunch slope)	Rebar Density Below Grade	Normal
Foundation Depth	2' with top-mount (TS) slab	General Allowances	Low

CIP Concrete Scope

Column Structures

WBS	Description	Qty	Type	Long	Wd-Ø	PC	TON	CY	Component	Hi-Thk	MH	MH @ \$54	M&CE \$	TOTAL
46	WWEQ N/S wall beam supports	3	5.0	1.0	1.0			1.9	Rect Column	17.00	297	\$15,925	\$1,598	\$17,523
									Spread Footer	1.00	25	\$1,352	\$181	\$1,533
								2.0	Rect Column	18.00	313	\$16,754	\$1,687	\$18,440
								2.0	Spread Footer	1.00	25	\$1,352	\$181	\$1,533
		0	0.0	0.0	0.0					0.00				
		0	0.0	0.0	0.0					0.00				
Subtotal - Columns							0.7	4.8			660	\$35,383	\$3,647	\$39,030

Beam & Bulkhead Structures

WBS	Description	Qty	Type	Struct	Long	Wd-Ø	PC	TON	CY	Component	Hi/Thk	MH	MH @ \$54	M&CE \$	TOTAL
46	WWEQ N/S wall brace beams	3	5.0	6	41.5	1.0		0.63	6.9	Beam	1.50	558	\$29,923	\$3,788	\$33,712
		0	0.0	0	0.0	0.0					0.00				
47	WWEQ W wall brace beams	3	5.0	6	35.0	1.0		0.53	5.8	Beam	1.50	512	\$27,446	\$3,318	\$30,764
		0	0.0	0	0.0	0.0					0.00				
		0	0.0	0	0.0	0.0					0.00				
		0	0.0	0	0.0	0.0					0.00				
Subtotal - Beams & Bulkheads							1.2	12.8			1,070	\$57,369	\$7,107	\$64,476	

Lean Fill & Mudmats

WBS	Description	Qty	Type	Long	Wd-Ø	PC	CY	Component	Thick	MH	MH @ \$54	M&CE \$	TOTAL
59	New ACT structure settler	1	5.0	19.0	19.0		33.4	Conc w/o Rebar	2.50	48	\$2,581	\$3,560	\$6,140
		0	0.0	0.0	0.0				0.00				
		0	0.0	0.0	0.0				0.00				
		0	0.0	0.0	0.0				0.00				
Subtotal - Lean Fill & Mudmats							33.4			48	\$2,581	\$3,560	\$6,140

Housekeeping Pad & Sidewalk Structures

WBS	Description	Qty	Type	Long	Wd-Ø	Sides	Clear	TON	CY	Component	Thick	MH	MH @ \$54	M&CE \$	TOTAL
62	FILT control console	1	5.0	4.0	3.0	4.0	0.00	0.01	0.2	Rectangular Pad	0.5	4	\$238	\$86	\$324
		0	0.0	0.0	0.0	0.0	0.00				0.00				
59	ACT sand/sludge pumps	2	5.0	4.0	1.5	4.0	0.00	0.01	0.2	Rectangular Pad	0.5	4	\$229	\$84	\$312
		0	0.0	0.0	0.0	0.0	0.00				0.00				
58	O3 generator skid	1	5.0	6.0	5.0	4.0	0.00	0.02	0.6	Rectangular Pad	0.5	11	\$564	\$209	\$773
		0	0.0	0.0	0.0	0.0	0.00				0.00				
7	ACT flash mix pump	1	5.0	4.5	2.0	4.0	0.00	0.01	0.2	Rectangular Pad	0.5	3	\$180	\$65	\$244
		0	0.0	0.0	0.0	0.0	0.00				0.00				
66	DEW solids transfer pump	1	5.0	6.0	1.5	4.0	0.00	0.01	0.2	Rectangular Pad	0.5	3	\$180	\$65	\$244
		0	0.0	0.0	0.0	0.0	0.00				0.00				
93	CHEM dry NaOCl equip legs	4	5.0	1.5	1.5	4.0	0.00	0.01	0.2	Rectangular Pad	0.5	3	\$153	\$60	\$212
93	CHEM dry NaOCl mix skid	1	5.0	5.0	5.0	4.0	0.00	0.02	0.5	Rectangular Pad	0.5	9	\$477	\$176	\$653
		0	0.0	0.0	0.0	0.0	0.00				0.00				
		0	0.0	0.0	0.0	0.0	0.00				0.00				
		0	0.0	0.0	0.0	0.0	0.00				0.00				
		0	0.0	0.0	0.0	0.0	0.00				0.00				
Subtotal - Housekeeping Pads & Sidewalks							0.1	2.0			38	\$2,020	\$743	\$2,764	



DIV 3 (03) CONCRETE

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name		Location		Date		Estimator		Version		Job #					
Willamette River WTP Master Plan		Wilsonville, OR		30-Nov-17		Jim Ward		002		30503765					
Rectangular Slab Structures															
WBS	Description	Qty	Type	Long	Wide	Fndtn	Factor	CY	Component	Thk/Dp	MH	MH @ \$54	M&CE \$	TOTAL	
12	New GEN slab	1	5.0	40.0	17.5	2	2.00	26	Slab	1.00	156	\$8,361	\$6,485	\$14,846	
	Total \$		\$20,811				TON 2.1	13	Haunch	1.50	61	\$3,290	\$2,675	\$5,965	
	Tot CY		39							0.00					
12	New GEN diesel tank slab	1	5.0	44.0	22.0	2	2.00	36	Slab	1.00	216	\$11,562	\$8,967	\$20,530	
	Total \$		\$27,461				TON 2.9	15	Haunch	1.50	71	\$3,823	\$3,108	\$6,931	
	Tot CY		51							0.00					
										0.00					
										0.00					
										0.00					
										0.00					
Subtotal - Rectangular Slabs								5.0	90		504	\$27,036	\$21,236	\$48,272	
Rectangular Wall & Tank Structures															
WBS	Description	Qty	Type	Long	Wide	SW	To/Bo	Fndtn	CY	Component	Thk/Dp	MH	MH @ \$54	M&CE \$	TOTAL
62	New FILT cells	2	5.0	25.0	23.0	18.2	1.0	3	80	Slab	1.34	400	\$21,453	\$20,484	\$41,937
	Total \$		\$190,503				Cntlvtr 2.00				0.00				
	Tot CY		197				Wall Factor 1.48				0.00				
	TON		15.7				F&F Sides 2.00				0.00				
								117	Wall	1.17	2,128	\$114,087	\$34,479	\$148,566	
62	New FILT influent & gallery	1	5.0	25.0	16.0	21.2	2.0	3	29	Slab	1.34	149	\$7,981	\$7,513	\$15,494
	Total \$		\$133,788				Cntlvtr 2.00				0.00				
	Tot CY		114				Wall Factor 2.00		18	Elevated Slab	1.00	241	\$12,906	\$5,253	\$18,159
	TON		9.7				F&F Sides 2.00				0.00				
								67	Wall	1.00	1,462	\$78,398	\$21,737	\$100,135	
62	New FILT influent channel floor	2	5.0	25.0	16.0			3	30	Elevated Slab	1.00	396	\$21,245	\$8,647	\$29,892
	Total \$		\$29,892				Cntlvtr 0.00				0.00				
	Tot CY		30				Wall Factor 0.00				0.00				
							F&F Sides 0.00				0.00				
											0.00				
62	New FILT influent weir walls	2	5.0	20.0	0.0	4.8	0.0	0							
	Total \$		\$17,454				Cntlvtr 0.00				0.00				
	Tot CY		7				Wall Factor 0.00				0.00				
	TON		0.4				F&F Sides 2.00				0.00				
								7	Wall	1.00	282	\$15,110	\$2,344	\$17,454	
62	New FILT WW gullet	2	5.0	23.0	4.0	14.5	2.0	3	11	Elevated Slab	1.00	149	\$7,967	\$3,243	\$11,210
	Total \$		\$44,832				Cntlvtr 2.00				0.00				
	Tot CY		38				Wall Factor 0.85				0.00				
	TON		2.9				F&F Sides 2.00				0.00				
								26	Wall	1.00	482	\$25,819	\$7,803	\$33,622	
60	New OZ channel & gallery	1	5.0	74.0	25.5	24.0	2.0	3	99	Slab	1.17	514	\$27,574	\$25,958	\$53,532
	Total \$		\$569,805				Cntlvtr 2.00				0.00				
	Tot CY		472				Wall Factor 3.27		77	Elevated Slab	1.00	1,035	\$55,503	\$22,590	\$78,093
	TON		41.8				F&F Sides 2.00				0.00				
								295	Wall	1.00	6,400	\$343,063	\$95,117	\$438,180	
60	New OZ basin baffle walls	2	5.0	10.0	3.0	20.5	2.0	3	4	Elevated Slab	1.00	158	\$8,487	\$1,657	\$10,145
	Total \$		\$76,129				Cntlvtr 2.00				0.00				
	Tot CY		50				Wall Factor 2.00				0.00				
	TON		4.2				F&F Sides 2.00				0.00				
								46	Wall	1.00	961	\$51,501	\$14,483	\$65,985	
60	New OZ basin baffle walls	3	5.0	10.0	0.0	21.0	0.0	0							
	Total \$		\$32,939				Cntlvtr 0.00				0.00				
	Tot CY		23				Wall Factor 0.00				0.00				
	TON		2.0				F&F Sides 2.00				0.00				
								23	Wall	1.00	478	\$25,625	\$7,314	\$32,939	
60	New OZ basin baffle walls	4	5.0	10.0	0.0	18.0	0.0	0							
	Total \$		\$32,157				Cntlvtr 0.00				0.00				
	Tot CY		27				Wall Factor 0.00				0.00				
	TON		2.1				F&F Sides 2.00				0.00				
								27	Wall	1.00	457	\$24,519	\$7,638	\$32,157	

Project Name					Location		Date	Estimator		Version	Job #
Willamette River WTP Master Plan					Wilsonville, OR		30-Nov-17	Jim Ward		002	30503765
42	Seal OZ corner leaks-VLF/EA	24	2	2.3	\$2.81	48		110	\$5,918	\$135	\$6,053
94	CHEM area contain mods-LS	1	1	100	\$2,000	1		100	\$5,361	\$2,000	\$7,361
Subtotal - Miscellaneous Work Allowances								1,210	\$64,852	\$22,619	\$87,471
<i>Demolition & Disposal Allowances</i>											
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$54	M&CE \$	TOTAL	
94	CHEM area contain mods-LS	1	1	40	\$800	1	40	\$2,144	\$800	\$2,944	
Subtotal - Demolition & Disposal Allowances								40	\$2,144	\$800	\$2,944
<i>General Allowances</i>											
<p>This summary category is intended to provide coverage of the minor DIV 3 concrete work and/or related items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.</p>											
WBS						Rebar	CY	MH	MH @ \$54	M&CE \$	TOTAL
2	Subtotal - General Allowances					0.7	9	148	\$7,925	\$2,632	\$10,557
CIP Concrete Total											
						Rebar	CY	MH	MH @ \$54	M&CE \$	TOTAL
DIV 3 TOTAL						135	1,718	29,146	\$1,562,423	\$528,269	\$2,090,692



DIV 4 (04) MASONRY

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions	
Exterior Type & Finish	8" CMU with Paint/Seal Face (2)
Exterior CMU Type/Quality	3-Cell Units
Exterior Cell Fill	Rebar & Concrete-Fill (total)
Exterior Wall Openings	Low density (20%)
Exterior Cavity Treat	
Exterior Architecture Treat	Minimum Enhancement
Insulation & Liner	
Interior Type & Finish	
Interior CMU Type/Quality	
Interior Cell Fill	
Interior Wall Openings	
Interior Cavity Treat	
Interior Architecture Treat	Minimum Enhancement
General Allowances	Low

Masonry Scope

Exterior Masonry Structures																
WBS	Description	Qty	Type	Long	Wide	High	Cell	Open	Cavity	Corner	Gable	SF	MH	MH @ \$50	M&CE \$	TOTAL
59	New ACT building (50%)	1	7	18.7	9.7	12.0	9	5	1	4	0.00	680	261	\$12,947	\$9,830	\$22,776
Subtotal - Exterior Masonry Structures												680	261	\$12,947	\$9,830	\$22,776

Interior Masonry Structures																
WBS	Description	Qty	Type	Long	Wide	High	Cell	Open	Cavity	Corner	Gable	SF	MH	MH @ \$0	M&CE \$	TOTAL
Subtotal - Interior Masonry Structures																

Miscellaneous Work Allowances																
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$0	M&CE \$	TOTAL						
Subtotal - Miscellaneous Work Allowances																

Demolition & Disposal Allowances																
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$0	M&CE \$	TOTAL						
Subtotal - Demolition & Disposal Allowances																

General Allowances																
This summary category is intended to provide coverage of the minor DIV 4 masonry and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.												MH	MH @ \$50	M&CE \$	TOTAL	
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$0	M&CE \$	TOTAL						
2	Subtotal - General Allowances						4	\$194	\$147	\$342						

Masonry Total																
												SF	MH	MH @ \$50	M&CE \$	TOTAL
DIV 4 TOTAL												680	265	\$13,141	\$9,977	\$23,118



DIV 5 (05) MISCELLANEOUS METALS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions					
Supply Responsibility	Prime or Subcontractor			Guardposts & Bollards	
Access Assemblies	Aluminum Structure & Grate			Racks & Bents	
Gratings & Coverplates	Aluminum Structure & Grate			Elevated Decks	
Hatches & Covers	Aluminum			Fabrications Level	Standard
Hoist & Crane Rails				General Allowances	Low

Miscellaneous Metals Scope

Access Stairway & Landing Assemblies

WBS	Description	Qty	Type	Wide	High	Style	Risers	Erect MH	MH @ \$55	M&CE \$	TON	Assembly \$	TOTAL
61	New SOL thickener	1	2.51	3.5	7.0	1.0	11	17	\$961	\$406	0.18	\$3,252	\$4,619
		0	0.00	0.0	0.0	0.0							
62	New FILT cells	1	2.51	3.5	10.0	1.5	15	29	\$1,591	\$741	0.33	\$5,925	\$8,257
62	New FILT cells	1	2.51	3.5	22.0	1.5	33	42	\$2,332	\$1,434	0.73	\$11,471	\$15,236
		0	0.00	0.0	0.0	0.0							
60	New OZ structure	1	2.51	3.5	12.0	1.5	18	32	\$1,782	\$889	0.40	\$7,110	\$9,781
60	New OZ structure	1	2.51	3.5	24.0	1.5	36	46	\$2,544	\$1,564	0.80	\$12,513	\$16,621
		0	0.00	0.0	0.0	0.0							
59	New ACT structure	1	2.51	3.5	7.0	1.5	11	22	\$1,225	\$518	0.23	\$4,147	\$5,891
59	New ACT structure	1	2.51	3.5	22.0	1.5	33	42	\$2,332	\$1,434	0.73	\$11,471	\$15,236
		0	0.00	0.0	0.0	0.0							
		0	0.00	0.0	0.0	0.0							
		0	0.00	0.0	0.0	0.0							
Subtotal - Access Stairway & Landing Assemblies							157	230	\$12,768	\$6,986	3.40	\$55,889	\$75,642

Access Handrail & Toeplate Assemblies

WBS	Description	Qty	Type	Long	Wide/Ø	Style	LF	Erect MH	MH @ \$55	M&CE \$	TON	Assembly \$	TOTAL
61	New FILT cell walkways	2	2.51	24.0	5.0	2.0	116	125	\$6,909	\$633	0.15	\$5,067	\$12,609
61	New FILT cell walkways	2	2.51	22.0	4.0	2.0	104	116	\$6,456	\$580	0.14	\$4,640	\$11,676
		0	0.00	0.0	0.0	0.0							
60	New OZ structure	1	2.51	74.0	25.5	2.0	199	38	\$2,086	\$886	0.26	\$7,091	\$10,063
		0	0.00	0.0	0.0	0.0							
59	New ACT structure	1	2.51	201.0	0.0	2.0	201	38	\$2,107	\$895	0.26	\$7,162	\$10,164
		0	0.00	0.0	0.0	0.0							
29	Replace ACT guardrail	1	2.51	20.0	0.0	2.0	20	27	\$1,510	\$124	0.03	\$992	\$2,626
		0	0.00	0.0	0.0	0.0							
32	Add ACT west guardrail kickplate	1	2.51	20.0	0.0	2.0	20	10	\$529	\$124	0.03	\$298	\$950
		0	0.00	0.0	0.0	0.0							
34	Replace OZ guardrail	1	2.51	20.0	0.0	2.0	20	27	\$1,510	\$124	0.03	\$992	\$2,626
		0	0.00	0.0	0.0	0.0							
36	Replace FILT guardrail	1	2.51	20.0	0.0	2.0	20	27	\$1,510	\$124	0.03	\$992	\$2,626
		0	0.00	0.0	0.0	0.0							
38	Add FILT ladder pit kickplate	1	2.51	20.0	0.0	2.0	20	10	\$529	\$124	0.03	\$298	\$950
		0	0.00	0.0	0.0	0.0							
		0	0.00	0.0	0.0	0.0							
		0	0.00	0.0	0.0	0.0							
Subtotal - Access Handrail & Toeplate Assemblies							720	418	\$23,145	\$3,615	0.95	\$27,532	\$54,292

Grating & Coverplate Assemblies

WBS	Description (NIS = not in scope)	Qty	Type	Long	Wide/Ø	Style	SF	Erect MH	MH @ \$55	M&CE \$	TON	Assembly \$	TOTAL
5	Utilidor structure trench	1	2.51	300.0	2.5	5.0	750	151	\$8,388	\$2,462	3.94	\$39,391	\$50,241
		0	0.00	0.0	0.0	0.0							
		0	0.00	0.0	0.0	0.0							
		0	0.00	0.0	0.0	0.0							
Subtotal - Grating & Coverplate Assemblies							750	151	\$8,388	\$2,462	3.94	\$39,391	\$50,241

Hatch & Cover Assemblies

WBS	Description	Qty	Type	Long	Wide/Ø	Style	SF	Erect MH	MH @ \$55	M&CE \$	TON	Assembly \$	TOTAL
60	New OZ channel & gallery	7	2.51	3.0	3.0	2.0	63	52	\$2,871	\$548	0.28	\$8,767	\$12,186
60	New OZ channel & gallery	1	2.51	4.0	3.0	2.0	12	9	\$524	\$100	0.05	\$1,606	\$2,231
		0	0.00	0.0	0.0	0.0							

DIV 5 (05) MISCELLANEOUS METALS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Date			Estimator		Version	Job #	
Willamette River WTP Master Plan			Wilsonville, OR				30-Nov-17			Jim Ward		002	30503765	
59	<i>New ACT structure</i>	2	2.51	2.0	2.0	2.0	8	8	\$423	\$80	0.04	\$1,284	\$1,787	
59	<i>New ACT structure</i>	4	2.51	3.0	3.0	2.0	36	30	\$1,640	\$313	0.16	\$5,010	\$6,964	
59	<i>New ACT structure</i>	1	2.51	4.0	4.0	2.0	16	12	\$669	\$129	0.06	\$2,058	\$2,855	
59	<i>New ACT structure</i>	1	2.51	4.0	4.5	2.0	18	13	\$740	\$143	0.07	\$2,283	\$3,166	
		0	0.00	0.0	0.0	0.0								
		0	0.00	0.0	0.0	0.0								
		0	0.00	0.0	0.0	0.0								
Subtotal - Hatch & Cover Assemblies							153	124	\$6,867	\$1,313	0.66	\$21,008	\$29,188	
Miscellaneous Work Allowances														
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	MH	MH @ \$55	M&CE \$					TOTAL	
87	<i>Install SITE plate hatch guardrails-LS/E</i>	1	10	6.0	\$300	60	\$3,326	\$3,000					\$6,326	
88	<i>Install WWEQ ladder fall restraint-LS</i>	1	1	20	\$600	20	\$1,109	\$600					\$1,709	
Subtotal - Miscellaneous Work Allowances						80	\$4,434	\$3,600					\$8,034	
General Allowances														
<p style="font-size: small;">This summary category is intended to provide coverage of the minor DIV 5 miscellaneous metals and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.</p>														
WBS						Erect MH	MH @ \$55	M&CE \$	TON	Assembly \$				TOTAL
2	Subtotal - General Allowances					5	\$278	\$90	0.04	\$719				\$1,087
Miscellaneous Metals Total														
						Erect MH	MH @ \$55	M&CE \$	TON	Assembly \$				TOTAL
DIV 5 TOTAL						1,008	\$55,880	\$18,066	8.99	\$144,539				\$218,485



DIVS 5-8 (05-08) BUILDINGS & COMPONENTS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions	
PE Steel Building (SB)	Arched Fabric (AF)
SB Add-On's	AF Services (re: DIVS 15-17)
SB Services (re: DIVS 15-17)	Precast & Tilt-Up System
PE Steel Roof (SR)	Interior Architectural Level
SR Add-On's	Exterior Architectural Level
SR Services (re: DIVS 15-17)	Climate Type for Services
Flat Roof (FR)	(un-assigned)
FR Services (re: DIVS 15-17)	General Allowances

Buildings & Components Scope

Flat Roof Structures												
WBS	Description	Qty	Type	Lng-Wall	Wd-Flrs	Hi-OC	SF-Lev	Watt	MH	MH @ \$50	M&CE \$	TOTAL
62	New FILT gallery area (services only)	1	2	25.0	16.0	13.0	400					
	HV-Light-Plumb	1	6	2.00	1	4	1.15	8				
60	New OZ gallery area (services only)	1	2	74.0	14.5	24.0	1,073					
	HV-Light-Plumb	1	6	2.00	1	4	1.15	8				
59	New ACT gallery area (services only)	1	2	19.0	12.0	13.0	228					
	HV-Light-Plumb	1	6	2.00	1	4	1.15	8				
59	New ACT building (50% of full size)	1	16	18.7	9.7	10.0	181		31	\$1,556	\$3,704	\$5,260
	HV-Light-Plumb	1	6	2.00	1	4	1.15	8				
		0	0	0.0	0.0	0.0						
		0	0	0.00	0	0	0.00	0				
Subtotal - Flat Roof Structures							1,882		31	\$1,556	\$3,704	\$5,260

Miscellaneous Work Allowances

WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$55	M&CE \$	TOTAL
25	Install CHEM door panic hardware-LS/EA	1	3	6.0	\$60	3	18	\$986	\$180	\$1,166
26	Reverse CHEM door open direction-LS	1	1	12.0	\$300	1	12	\$657	\$300	\$957
31	Install ACT door panic hardware-LS/EA	1	2	6.0	\$60	2	12	\$657	\$120	\$777
40	Install FWPS door panic hardware-LS/EA	1	2	6.0	\$60	2	12	\$657	\$120	\$777
41	Install DEW scupper & downspout-LS	1	1	36	\$1,800	1	36	\$1,971	\$1,800	\$3,771
48	4" coated tees-LB/LF	6.5	650	0.010	\$2.25	4,227	42	\$2,315	\$9,511	\$11,826
48	Install & weld to decking & ledger-LS/EA	1	23	18.0	\$200	23	414	\$22,668	\$4,600	\$27,268
48	Drill & install epoxy anchor rods-QTY/EA	2	23	1.50	\$75	46	69	\$3,778	\$3,450	\$7,228
49	New 3" dp-16 guage decking-SF	1	1,966	0.0180	\$4.58	1,966	35	\$1,938	\$8,995	\$10,932
49	New polyiso 3 1/2: board insulation-QTY/SF	2	1,966	0.012	\$2.93	3,932	47	\$2,584	\$11,502	\$14,085
49	New 90 mil EPDM adhered membrane-SF	1	1,966	0.046	\$2.98	1,966	91	\$4,967	\$5,859	\$10,826
49	Insulation for balance of roof-SF	1	1,859	0.012	\$2.93	1,859	22	\$1,221	\$5,436	\$6,657
49	Membrane for balance of roof-SF	1	1,859	0.046	\$2.98	1,859	86	\$4,695	\$5,539	\$10,234
50	Install 16" x 4" x 1/2" chord splice bars-LS/EA	2	22	1.50	\$30.71	44	66	\$3,614	\$1,351	\$4,965
51	Install 16" x 8" x 1/2" shear plates-QTY/EA	2	23	3.0	\$51.33	46	138	\$7,556	\$2,361	\$9,917
51	Drill & install epoxy anchor rods-QTY/EA	2	23	1.50	\$75	46	69	\$3,778	\$3,450	\$7,228
51	Existing wall bush down at plates-QTY/EA	2	23	3.50	\$88	46	161	\$8,815	\$4,025	\$12,840
51	Reinstall roof decking-SF	1	1,859	0.0180	\$0.76	1,859	33	\$1,832	\$1,417	\$3,249
53	Install DEW E Wall Frame Braces-LS	1	1	160	\$12,000	1	160	\$8,761	\$12,000	\$20,761
54	4" coated tees-LB/LF	6.5	132	0.010	\$2.25	858	9	\$470	\$1,931	\$2,400
54	Install & weld to decking & ledger-LS/EA	1	6	18.0	\$200	6	108	\$5,913	\$1,200	\$7,113
54	Drill & install epoxy anchor rods-QTY/EA	2	6	1.50	\$75	12	18	\$986	\$900	\$1,886

DIVS 5-8 (05-08) BUILDINGS & COMPONENTS

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name				Location		Date	Estimator	Version	Job #	
Willamette River WTP Master Plan				Wilsonville, OR		30-Nov-17	Jim Ward	002	30503765	
54	Reinstall roof decking-SF	1	748	0.0180	\$0.76	748	13	\$737	\$570	\$1,308
54	New polyiso 3½" board insulation-QTY/SF	2	748	0.012	\$2.93	1,496	18	\$983	\$4,376	\$5,359
54	New 90 mil EPDM adhered membrane-SF	1	748	0.046	\$2.98	748	35	\$1,890	\$2,229	\$4,119
55	DEW wall/slab anchor 4" angle-SS-LB/LF	9.8	68	0.010	\$6.75	666	7	\$365	\$4,498	\$4,863
55	Drill & install epoxy anchor rods-QTY/EA	2	34	0.750	\$50	68	51	\$2,792	\$3,400	\$6,192
85	Install FWPS door panic hardware-LS/EA	1	2	6.0	\$60	2	12	\$657	\$120	\$777
82	Install FILT stairwell 1-leaf door-LS	1	1	1.50	\$75	1	2	\$82	\$75	\$157
82	Install magnetic door closer/holder-LS	1	1	2.50	\$125	1	3	\$137	\$125	\$262
94	Install CHEM area roll-up door/frame-LS	1	1	16	\$2,300	1	16	\$876	\$2,300	\$3,176
94	Install CHEM area roll-up motor op-LS	1	1	4	\$1,200	1	4	\$219	\$1,200	\$1,419
94	CHEM bldg mods for space-LS	1	1	160	\$8,000	1	160	\$8,761	\$8,000	\$16,761
Subtotal - Miscellaneous Work Allowances						1,978	\$108,316	\$112,940	\$221,256	

<i>Demolition & Disposal Allowances</i>										
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$55	M&CE \$	TOTAL
25	Remove CHEM door open hardware-LS/EA	1	3	2.00	\$10	3	6	\$329	\$30	\$359
31	Remove ACT door open hardware-LS/EA1	1	2	2.00	\$10	2	4	\$219	\$20	\$239
40	Remove FWPS door open hardware-LS/EA	1	2	2.00	\$10	2	4	\$219	\$20	\$239
48	Remove FWPS roof membrane & insulation	1	3,825	0.042	\$1.32	3,825	161	\$8,813	\$5,066	\$13,879
49	Remove FWPS roof decking-SF	1	1,966	0.014	\$0.92	1,966	28	\$1,550	\$1,799	\$3,349
51	Remove FWPS balance of roof decking-SF	1	1,859	0.014	\$0.92	1,859	27	\$1,465	\$1,701	\$3,166
54	Remove DEW roof membrane & insulation-SF	1	748	0.053	\$1.32	748	39	\$2,154	\$991	\$3,145
54	Remove FWPS roof decking-SF	1	748	0.018	\$0.92	748	13	\$737	\$684	\$1,422
85	Remove FWPS door open hardware-LS/EA	1	2	2.0	\$10	2	4	\$219	\$20	\$239
82	Remove FILT stairwell 1-leaf door-LS	1	1	1.0	\$10	1	1	\$55	\$10	\$65
94	Remove CHEM area wall for door-LS	1	1	60	\$1,500	1	60	\$3,285	\$1,500	\$4,785
94	CHEM bldg mods for space-LS	1	1	64	\$1,600	1	64	\$3,504	\$1,600	\$5,104
Subtotal - Demolition & Disposal Allowances						412	\$22,550	\$13,440	\$35,990	

<i>General Allowances</i>					
<p>This summary category is intended to provide coverage of the minor DIVS 5-8 buildings, components, and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.</p>					
WBS		MH	MH @ \$55	M&CE \$	TOTAL
2	Subtotal - General Allowances	16	\$872	\$672	\$1,544

Buildings & Components Total						
		SF	MH	MH @ \$55	M&CE \$	TOTAL
DIVS 5-8 TOTAL		1,882	2,437	\$133,294	\$130,756	\$264,050



DIVS 9-10 (09-10) FINISHES

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions					
CIP Concrete	Blast, Prime, & Epoxy			Buildings - Exterior	
Tanks - Exterior				EIFS Structural System	
Tanks - Interior				EIFS Finish System	
Pipes & Ducts				Finishes Level	Standard
Buildings - Spaces	Varies by Structure			Contain & Clean-Up (C&C)	Minimum
Buildings - Interior	Varies by Space			General Allowances	Low

Finishes Scope

CIP Concrete Finishes													
WBS	Description	Qty	Type	Long	Wide/Ø	Hi/Dp	To/Bo	C&C	SF	MH	MH @ \$40	M&CE \$	TOTAL
60	OZ basin diffuser chamber	1	11.0	10.0	10.0	24.0	2.00	1.2	1,160	234	\$9,449	\$5,117	\$14,567
		0	0.0	0.0	0.0	0.0	0.00	0.0					
5	Utilidor structure trench	1	11.0	300.0	2.5	2.0	1.00	1.2	1,960	322	\$12,969	\$7,023	\$19,992
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
		0	0.0	0.0	0.0	0.0	0.00	0.0					
Subtotal - CIP Concrete Finishes									3,120	556	\$22,418	\$12,140	\$34,558

Miscellaneous Work Allowances													
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$40	M&CE \$	TOTAL			
24	Replace faded CHEM NFPA signs-LS	1	1	50	\$1,250	1	50	\$2,015	\$1,250	\$3,265			
		0	0										
82	Install FILT stairwell door sign-LS	1	1	0.50	\$5.00	1		\$20	\$5	\$25			
		0	0										
94	CHEM area mods coating allowance-SF	400	1	0	\$5.00	400	80	\$3,224	\$2,000	\$5,224			
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
		0	0										
Subtotal - Miscellaneous Work Allowances							131	\$5,260	\$3,255	\$8,515			

General Allowances													
This summary category is intended to provide coverage of the minor DIVS 9-10 finishes and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.													
WBS	Description	Qty	Type	Long	Wide/Ø	Hi/Dp	To/Bo	C&C	SF	MH	MH @ \$40	M&CE \$	TOTAL
2	Subtotal - General Allowances									11	\$458	\$234	\$692

Finishes Total													
WBS	Description	Qty	Type	Long	Wide/Ø	Hi/Dp	To/Bo	C&C	SF	MH	MH @ \$40	M&CE \$	TOTAL
									3,120	698	\$28,136	\$15,629	\$43,765
DIVS 9-10 TOTAL									3,120	698	\$28,136	\$15,629	\$43,765



DIV 15 (21-23) MECHANICAL INSTALLATION

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions					
Piping System Material 1	Class 50 DIP-MJ-Cement Lined	40%		Area & Structure Ductwork	
Piping System Material 2	Sch 40 CS-Butt Weld	20%		Air & Liquid Distributors	Shallow Bed/Tower Filter Manifold
Piping System Material 3	Sch 40 Galv CS-Thread	20%		Face Pipe Assemblies	
Piping System Material 4	Sch 10 316 SS-Butt Weld	10%		Media	Granular: Mono-Media
Piping System Material 5	Sch 80 CPVC-Socket Weld	10%		Media Supports	Shallow Bed Filter/Tower
Pipe Installation Code	ASME B31.3 - Process Piping			Tank Insulation	
Pipe Insulation & Jacketing				Tank Insulation Jacketing	
Pipe Protection & Coating	Enamel or Acrylic Paint			Tank Heat-Tracing	
Equipment & Tank Ductwork				(un-assigned)	
Tagging & Labeling	Standard (plastic & 316SS)			General Allowances	Low

Mechanical Installation Scope

Process Equipment Installation Summary

Breakdown of this section's subtotal by all the major equipment scope items is provided in the DIVS 11-17 PROCESS EQUIPMENT sheets

WBS	Description (NIS = not in scope)	Qty	Type	%	MH	MH @ \$61	M&CE \$	TOTAL
	Rigging & Setting Allowance	1	1.00		1,625	\$98,730	\$85,220	\$183,950
	Piping & Valving Allowance	1	1.00		3,272	\$198,785	\$1,038,553	\$1,237,338
	Piping Insulation NIS	0	0.00	0%				
	Pipe & EQ Coating Allowance	1	1.20	50%	667	\$40,552	\$61,946	\$102,498
	Dynamic Ventilation NIS	0	0.00					
	Static Ventilation NIS	0	0.00					
	Tagging & Labeling Allowance	1			72	\$4,355	\$2,960	\$7,315

Subtotal - Process Equipment Installation Summary	5,636	\$342,423	\$1,188,679	\$1,531,102
--	-------	-----------	-------------	--------------------

DIVS 5-8 Flat Roof Structure Mechanical, HVAC, Fire Protection, & Plumbing

WBS	Description	Qty	Type	Floors	A-Level	Scope	SF	MH	MH @ \$61	M&CE \$	TOTAL
62	New FILT gallery area (services only)	1	6	1	1.00	1.01	400	53	\$3,205	\$4,082	\$7,287
60	New OZ gallery area (services only)	1	6	1	1.00	1.01	1,073	154	\$9,360	\$12,975	\$22,335
59	New ACT gallery area (services only)	1	6	1	1.00	1.01	228	30	\$1,827	\$2,327	\$4,154
59	New ACT building (50% of full size)	1	6	1	1.00	1.01	181	24	\$1,429	\$1,796	\$3,226
0		0	0	0	0.00	0.00					
0		0	0	0	0.00	0.00					
0		0	0	0	0.00	0.00					

Subtotal - DIVS 5-8 Flat Roof Mechanical	1,882		260	\$15,820	\$21,181	\$37,001
---	-------	--	-----	----------	----------	-----------------

Miscellaneous Work Allowances

WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$61	M&CE \$	TOTAL
44	Install CHEM pipe seismic bracing-LS	1	1	120.0	\$6,000	1	120	\$7,291	\$6,000	\$13,291
45	Install OZ destruct pipe seismic bracing-LS	1	1	32.0	\$2,400	1	32	\$1,944	\$2,400	\$4,344
21	Install WVEQ chem line supports-LS	1	1	100.0	\$10,000	1	100	\$6,076	\$10,000	\$16,076
27	Install CHEM exit door contain tray & drain-l	1	2	16.0	\$400	2	32	\$1,944	\$800	\$2,744
18	Install ACT settling tank tubes-LS/EA	1	2	48.0	\$1,200	2	96	\$5,833	\$2,400	\$8,233
56	Install SITE space heater bracing-LS/EA	1	8	6.0	\$150	8	48	\$2,916	\$1,200	\$4,116
5	Utilidor 1" PVC chem pipe & ftgs-LF/EA	410	7	0.20	\$3.00	2,870	574	\$34,875	\$8,610	\$43,485
5	3" PVC contain pipe for open/bldg runs-LF/E	110	7	0.30	\$8.00	770	231	\$14,035	\$6,160	\$20,195
81	Upgrade ACT bldg/gallery HVAC-SF	577	1	0.063	\$8.75	577	36	\$2,189	\$5,045	\$7,234
83	Upgrade FILT bldg/gallery HVAC-SF	756	1	0.063	\$8.75	756	47	\$2,871	\$6,615	\$9,486
84	Upgrade FWPS SWGR room HVAC-SF	1,425	1	0.063	\$8.75	1,425	89	\$5,411	\$12,469	\$17,880



DIV 15 (21-23) MECHANICAL INSTALLATION

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name				Location		Date		Estimator	Version	Job #
Willamette River WTP Master Plan				Wilsonville, OR		30-Nov-17		Jim Ward	002	30503765
86	Upgrade OZ bldg stairwell HVAC-SF	183	1	0.063	\$8.75	183	11	\$693	\$1,597	\$2,290
89	Upgrade WVEQ bldg/room HVAC-SF	611	1	0.063	\$8.75	611	38	\$2,321	\$5,349	\$7,670
76	Install CHEM NaOCl vent return line-LS/EA	1	2	14.0	\$400	2	28	\$1,701	\$800	\$2,501
77	Install CHEM meter pump strainers-LS/EA	1	17	1.50	\$15	17	26	\$1,549	\$255	\$1,804
79	Install larger LOX rental tank-LS	1	1	120	\$12,000	1	120	\$7,291	\$12,000	\$19,291

Subtotal - Miscellaneous Work Allowances	1,628	\$98,941	\$81,699	\$180,640
---	-------	----------	----------	------------------

Demolition & Disposal Allowances

WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$61	M&CE \$	TOTAL
70	Remove SOL thicken drive unit-LS	1	1	16.4	\$169	1	16	\$996	\$169	\$1,165
17	Remove ACT sample pumps/valves-LS/EA	1	2	7.6	\$77	2	15	\$924	\$154	\$1,077
69	Remove ACT flash mix pumps/valves-LS/EA	1	2	38.8	\$1,732	2	78	\$4,715	\$3,463	\$8,178
72	Remove DEW xfer pumps/valves-LS/EA	1	2	23.6	\$1,056	2	47	\$2,868	\$2,112	\$4,979
18	Remove ACT settling tank tubes-LS/EA	1	2	32.0	\$800	2	64	\$3,888	\$1,600	\$5,488
9	Remove FWPS 4 MGD pump/valves-LS/EA	1	1	53.5	\$2,386	1	54	\$3,253	\$2,386	\$5,640
63	Remove FWPS 7.5 MGD pumps/valves-LS	1	3	56.2	\$2,835	3	169	\$10,238	\$8,505	\$18,743
65	Remove RWPS 7.5 MGD pumps/valves-LS	1	2	84.3	\$4,253	2	169	\$10,238	\$8,505	\$18,743
15	Remove 2 gph CHEM pumps/valves-LS/EA		5	2.9	\$38					
15	Remove 6 gph CHEM pumps/valves-LS/EA		3	5.1	\$66					
15	Remove 39 gph CHEM pumps/valves-LS/EA		6	8.7	\$113					
15	Remove 77 gph CHEM pumps/valves-LS/EA		3	10.3	\$132					
15	Remove 1" CHEM flush valve-LS/EA		17	1.5	\$19					
68	Remove 2 gph CHEM pumps/valves-LS/EA		5	2.9	\$38					
68	Remove 6 gph CHEM pumps/valves-LS/EA		3	5.1	\$66					
68	Remove 39 gph CHEM pumps/valves-LS/EA		6	8.7	\$113					
68	Remove 77 gph CHEM pumps/valves-LS/EA		3	10.3	\$132					
68	Remove 1" CHEM flush valve-LS/EA		17	1.5	\$19					
81	Remove ACT bldg/gallery HVAC items-SF	577	1	0.025	\$1.75	577	14	\$876	\$1,009	\$1,885
83	Remove FILT blower room HVAC items-SF	756	1	0.025	\$1.75	756	19	\$1,148	\$1,323	\$2,471
84	Remove FWPS SWGR room HVAC items-SF	1,425	1	0.025	\$1.75	1,425	36	\$2,164	\$2,494	\$4,658
86	Remove OZ bldg stairwell HVAC items-SF	183	1	0.025	\$1.75	183	5	\$277	\$319	\$597
89	Remove WVEQ bldg/room HVAC items-SF	611	1	0.025	\$1.75	611	15	\$929	\$1,070	\$1,998
79	Remove smaller LOX rental tank-LS	1	1	48	\$1,200	1	48	\$2,916	\$1,200	\$4,116
93	Remove un-used CHEM NaOCl pipe-LS	1	1	24	\$600	1	24	\$1,458	\$600	\$2,058
94	Remove CHEM NH3 equip & pipe-LS	1	1	60	\$1,500	1	60	\$3,645	\$1,500	\$5,145

Subtotal - Demolition & Disposal Allowances	832	\$50,534	\$36,409	\$86,943
--	-----	----------	----------	-----------------



DIV 15 (21-23) MECHANICAL INSTALLATION

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name		Location				Date	Estimator	Version	Job #		
Willamette River WTP Master Plan		Wilsonville, OR				30-Nov-17	Jim Ward	002	30503765		
Air & Liquid Distributors (installation only)											
WBS	Description	Qty	Type	Long	Wide/Ø	SF	MH	MH @ \$61	M&CE \$	TOTAL	
19	Filter GAC media replacement # 1		0.00	23.0	20.0						
19	Filter GAC media replacement # 2		0.00	23.0	20.0						
19	Filter GAC media replacement # 3		0.00	23.0	20.0						
			0.00								
71	Filter GAC media replacement # 4		0.00	23.0	20.0						
		0	0.00	0.0	0.0						
62	New GAC filter cells	2	0.75	23.0	20.0	920	177	\$10,764	\$1,275	\$12,039	
		0	0.00	0.0	0.0						
		0	0.00	0.0	0.0						
Subtotal - Air & Liquid Distributors						920	177	\$10,764	\$1,275	\$12,039	
Media (installation only)											
WBS	Description	Qty	Type	Long	Wide/Ø	Deep	CF	MH	MH @ \$61	M&CE \$	TOTAL
19	Filter GAC media replacement # 1	0	0.00	23.0	20.0	7.0					
19	Filter GAC media replacement # 2	0	0.00	23.0	20.0	7.0					
19	Filter GAC media replacement # 3	0	0.00	23.0	20.0	7.0					
0		0	0.00	0.0	0.0	0.0					
71	Filter GAC media replacement # 4	0	0.00	23.0	20.0	7.0					
0		0	0.00	0.0	0.0	0.0					
62	New GAC filter cells	2	2.50	23.0	20.0	7.0	6,440	516	\$31,322	\$7,090	\$38,411
		0	0.00	0.0	0.0	0.0					
		0	0.00	0.0	0.0	0.0					
Subtotal - Media							6,440	516	\$31,322	\$7,090	\$38,411
Media Supports (installation only)											
WBS	Description	Qty	Type	Long	Wide/Ø	GAL/Minute	MH	MH @ \$61	M&CE \$	TOTAL	
19	Filter GAC media replacement # 1	0	0.00	23.0	20.0						
19	Filter GAC media replacement # 2	0	0.00	23.0	20.0						
19	Filter GAC media replacement # 3	0	0.00	23.0	20.0						
0		0	0.00	0.0	0.0						
71	Filter GAC media replacement # 4	0	0.00	23.0	20.0						
0		0	0.00	0.0	0.0						
62	New GAC filter cells	2	0.75	23.0	20.0	920	219	\$13,336	\$2,504	\$15,839	
		0	0.00	0.0	0.0						
		0	0.00	0.0	0.0						
Subtotal - Media Supports							920	219	\$13,336	\$2,504	\$15,839
General Allowances											
<p>This summary category is intended to provide coverage of the minor DIV 15 mechanical, piping, and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the scope items in the "Process & Mechanical EQ Installation" section above.</p>											
WBS							MH	MH @ \$61	M&CE \$	TOTAL	
2	Subtotal - General Allowances						99	\$6,043	\$5,127	\$11,170	
Mechanical Installation Total											
						MH	MH @ \$61	M&CE \$	TOTAL		
DIV 15 TOTAL						9,368	\$569,182	\$1,343,963	\$1,913,145		



DIVS 16-17 (25-28 & 33) ELECTRICAL INSTALLATION

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions					
Raceway System Material 1	Rigid Galv Steel (RGS)	50%	Tagging & Labeling	Standard (plastic & 316SS)	
Raceway System Material 2	Sch 80 PVC	25%	Site Lighting Units	30' FRP Pole w/ Base-400W-LED	
Raceway System Material 3	PVC Coated RGS	15%	Typical Motor Efficiency	90% (average)	
Raceway System Material 4	Electric Metallic Tubing	10%	Local Power Factor	0.80 (anticipated)	
Raceway System Material 5			1Ø Controls Voltage	120V	
Local/Field Switches	HOA (motor & CV) & Disconnects		3Ø Low Voltage	480V	
Equipment Installed	All Electrical Gear & Equipment		3Ø Medium Voltage	4.16KV	
Grounding & Lightning	EQ & Structures		3Ø High Voltage	15KV	
Pipe & EQ Heat-Tracing			General Allowances	Low	

Electrical Installation Scope

Process Equipment Installation Summary

Breakdown of this section's subtotal by all the major equipment scope items is provided in the DIVS 11-17 PROCESS EQUIPMENT sheets

WBS	Description (NIS = not in scope)	Qty	Type	%	MH	MH @ \$59	M&CE \$	TOTAL
	Rigging & Setting Allowance	1	1.00		537	\$31,842	\$7,337	\$39,179
	Wiring & Switching Allowance	1	1.00		3,204	\$189,899	\$765,779	\$955,677
	Grounding & Lightning Allowance	1	6.00		1,359	\$80,546	\$48,952	\$129,498
	Piping Heat-Trace NIS	0	0.00	100%				
	Tagging & Labeling Allowance	1			66	\$3,933	\$2,067	\$6,000
Subtotal - Process Equipment Installation Summary					5,167	\$306,221	\$824,134	\$1,130,354

DIVS 5-8 Flat Roof Structure Electrical, Lighting, HVAC, & Fire Protection

WBS	Description	Qty	Type	Floors	A-Level	Scope	SF	MH	MH @ \$59	M&CE \$	TOTAL
62	New FILT gallery area (services only)	1	6	1	1.00	1.00	400	88	\$5,212	\$4,674	\$9,886
60	New OZ gallery area (services only)	1	6	1	1.00	1.00	1,073	257	\$15,223	\$14,855	\$30,078
59	New ACT gallery area (services only)	1	6	1	1.00	1.00	228	50	\$2,971	\$2,664	\$5,635
59	New ACT building (50% of full size)	1	6	1	1.00	1.00	181	39	\$2,324	\$2,057	\$4,381
		0	0	0	0.00	0.00					
		0	0	0	0.00	0.00					
Subtotal - DIVS 5-8 Flat Roof Electrical							1,882	434	\$25,730	\$24,250	\$49,980

Miscellaneous Work Allowances

WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$59	M&CE \$	TOTAL
14	Replace & test CHEM polymer PLC-LS	1	1	24.0	\$240	1	24	\$1,422	\$240	\$1,662
16	Replace & test ACT master PLC-LS	1	1	80.0	\$800	1	80	\$4,741	\$800	\$5,541
28	Install O3 gen exit emergency stops-LS/EA	1	2	16.0	\$1,200	2	32	\$1,897	\$2,400	\$4,297
33	Replace ACT outlets with GFI's-LS/EA	1	8	1.0	\$50	8	8	\$474	\$400	\$874
35	Replace CHEM outlets with GFI's-LS/EA	1	8	1.0	\$50	8	8	\$474	\$400	\$874
39	Replace FILT outlets with GFI's-LS/EA	1	16	1.0	\$50	16	16	\$948	\$800	\$1,748
52	Install FWPS cable tray bracing-LS	1	1	48.0	\$2,400	1	48	\$2,845	\$2,400	\$5,245
11	Install new system BU power wiring-LS	1	1	480	\$60,000	1	480	\$28,448	\$60,000	\$88,448
20	Install new wiring at existing FILT-LS	1	1	400	\$50,000	1	400	\$23,707	\$50,000	\$73,707
81	Upgrade ACT bldg/gallery HVAC-SF	577	1	0.023	\$3.28	577	14	\$801	\$1,892	\$2,693
83	Upgrade FILT bldg/gallery HVAC-SF	756	1	0.023	\$3.28	756	18	\$1,050	\$2,481	\$3,531
84	Upgrade FWPS SWGR room HVAC-SF	1,425	1	0.023	\$3.28	1,425	33	\$1,979	\$4,676	\$6,655
86	Upgrade OZ bldg stairwell HVAC-SF	183	1	0.023	\$3.28	183	4	\$254	\$599	\$852



DIVS 16-17 (25-28 & 33) ELECTRICAL INSTALLATION

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name				Location		Date		Estimator	Version	Job #
Willamette River WTP Master Plan				Wilsonville, OR		30-Nov-17		Jim Ward	002	30503765
89	Upgrade WVEQ bldg/room HVAC-SF	611	1	0.023	\$3.28	611	14	\$849	\$2,006	\$2,855
91	Replace MISC security camera/comp-LS	1	1	24	\$7,500	1	24	\$1,422	\$7,500	\$8,922
79	Install larger LOX rental tank-LS	1	1	60	\$3,000	1	60	\$3,556	\$3,000	\$6,556
94	Install CHEM area roll-up motor op-LS	1	1	8	\$600	1	8	\$474	\$600	\$1,074
94	CHEM bldg elect mods for space-LS	1	1	40	\$5,000	1	40	\$2,371	\$5,000	\$7,371
Subtotal - Miscellaneous Work Allowances						1,311		\$77,713	\$145,193	\$222,906
Demolition & Disposal Allowances										
WBS	Description	Qty	Each	Unit MH	Unit M&CE \$	Total Units	MH	MH @ \$59	M&CE \$	TOTAL
70	Remove SOL thicken drive power/control-LS	1	1	33.2	\$1,320	1	33	\$1,968	\$1,320	\$3,288
17	Remove ACT sample pump elect-LS/EA	1	2	8.0	\$317	2	16	\$948	\$634	\$1,582
22	Remove FWPS VFD & elect-300 hp-LS	1	1	17.6	\$670	1	18	\$1,043	\$670	\$1,713
22	Remove FWPS VFD & elect-500 hp-LS/EA	1	2	22.6	\$862	2	45	\$2,679	\$1,724	\$4,403
69	Remove ACT flash mix pump elect/I&C-LS/EA	1	2	30.2	\$1,240	2	60	\$3,580	\$2,481	\$6,060
72	Remove DEW xfer pump elect/I&C-LS/EA	1	2	35.0	\$1,438	2	70	\$4,149	\$2,876	\$7,025
9	Remove FWPS 4 MGD pump elect/I&C-LS/EA	1	1	40.1	\$1,653	1	40	\$2,377	\$1,653	\$4,030
63	Remove FWPS 7.5 MGD pump elect/I&C-LS/EA	1	3	52.8	\$2,304	3	159	\$9,394	\$6,912	\$16,306
65	Remove RWPS 7.5 MGD pump elect/I&C-LS/EA	1	2	29.0	\$1,382	2	58	\$3,438	\$2,764	\$6,202
15	Remove 2 gph CHEM pump elect-LS/EA		5	4.2	\$207					
15	Remove 6 gph CHEM pump elect-LS/EA		3	4.3	\$207					
15	Remove 39 gph CHEM pump elect-LS/EA		6	4.6	\$224					
15	Remove 77 gph CHEM pump elect-LS/EA		3	4.9	\$241					
15	Remove 1" CHEM flush valve-LS/EA		17	1.1	\$52					
68	Remove 2 gph CHEM pump elect-LS/EA		5	4.2	\$207					
68	Remove 6 gph CHEM pump elect-LS/EA		3	4.3	\$207					
68	Remove 39 gph CHEM pump elect-LS/EA		6	4.6	\$224					
68	Remove 77 gph CHEM pump elect-LS/EA		3	4.9	\$241					
68	Remove 1" CHEM flush valve elect-LS/EA		17	1.1	\$52					
10	Remove existing SWGR & wiring-LS	1	1	614	\$14,974	1	614	\$36,414	\$14,974	\$51,388
11	Remove existing system BU power wiring-LS	1	1	240	\$3,600	1	240	\$14,224	\$3,600	\$17,824
12	Remove existing 1mW genset system-LS	1	1	273	\$3,911	1	273	\$16,168	\$3,911	\$20,079
20	Remove existing FILT wiring-LS	1	1	200	\$3,000	1	200	\$11,853	\$3,000	\$14,853
81	Remove ACT bldg/gallery HVAC items-SF	577	1	0.009	\$0.66	577	5	\$320	\$378	\$699
83	Remove FILT blower room HVAC items-SF	756	1	0.009	\$0.66	756	7	\$420	\$496	\$916
84	Remove FWPS SWGR room HVAC items-SF	1,425	1	0.009	\$0.66	1,425	13	\$792	\$935	\$1,727
86	Remove OZ bldg stairwell HVAC items-SF	183	1	0.009	\$0.66	183	2	\$101	\$120	\$221

DIVS 16-17 (25-28 & 33) ELECTRICAL INSTALLATION

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name				Location		Date	Estimator	Version	Job #	
Willamette River WTP Master Plan				Wilsonville, OR		30-Nov-17	Jim Ward	002	30503765	
89	Remove WVEQ bldg/room HVAC items-SF	611	1	0.009	\$0.66	611	6	\$340	\$401	\$741
79	Remove smaller LOX rental tank-LS	1	1	30	\$750	1	30	\$1,778	\$750	\$2,528
93	Remove un-used CHEM NaOCl elect-LS	1	1	16	\$400	1	16	\$948	\$400	\$1,348
78	Remove SITE light-20' pole (G)-LS/EA	1	10	4	\$88	10	35	\$2,087	\$880	\$2,968
78	Remove SITE light-10' pole (F)-LS/EA	1	9	2	\$59	9	21	\$1,252	\$528	\$1,781
78	Remove SITE light-Wall (E)-LS/EA	1	13	3	\$78	13	41	\$2,412	\$1,017	\$3,430
94	Remove CHEM NH3 equip elect.I&C-LS	1	1	24	\$600	1	24	\$1,422	\$600	\$2,022
94	CHEM bldg elect mods for space-LS	1	1	16	\$400	1	16	\$948	\$400	\$1,348
Subtotal - Demolition & Disposal Allowances						2,043	\$121,057	\$53,426	\$174,483	
Site Lighting Units										
WBS	Description	Qty	Type	Watts	MH	MH @ \$59	M&CE \$	TOTAL		
59	New ACT flow channel & gallery topside	6	12.0	360	141	\$8,350	\$20,059	\$28,408		
60	New OZ flow channel & gallery topside	8	12.0	480	188	\$11,133	\$26,745	\$37,878		
61	New SOL thickener	2	12.0	120	47	\$2,783	\$6,686	\$9,469		
62	New FILT cells & gallery topside	5	12.0	300	117	\$6,958	\$16,716	\$23,674		
78	Light pole head LED upgrade-20'-175W (G)	10	20.0	600	88	\$5,218	\$12,138	\$17,356		
78	Lightpole head LED upgrade-10'-70W (F)	9	12.0	540	53	\$3,131	\$7,522	\$10,653		
78	Wallpak replacement to LED-70W (E)	13	4.0	975	102	\$6,030	\$16,729	\$22,759		
Subtotal - Site Lighting Units				3,375	736	\$43,603	\$106,594	\$150,198		
General Allowances										
<p style="font-size: small; color: red;">This summary category is intended to provide coverage of the minor DIVS 16-17 electrical, wiring, and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the scope items in the "Divs 11-17 Process Equipment" installation section above.</p>										
WBS						MH	MH @ \$59	M&CE \$	TOTAL	
2	Subtotal - General Allowances					143	\$8,494	\$9,552	\$18,046	
Electrical Installation Total										
						MH	MH @ \$59	M&CE \$	TOTAL	
DIVS 16-17(i) TOTAL						9,834	\$582,818	\$1,163,149	\$1,745,966	

DIVS 16-17 (25-28 & 33) ELECTRICAL EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name	Location	Date	Estimator	Version	Job #
Willamette River WTP Master Plan	Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765

Assumptions

480V EQ Rating	NEMA 1 Gasketed (Std) ▼		120V EQ Rating	NEMA 12 (Std) ▼
4.16KV EQ Rating	NEMA 1 Gasketed (Std) ▼		Process Controls EQ	Utilization of Existing SCADA ▼
15KV EQ Rating	NEMA 1 Gasketed (Std) ▼		Site Controls EQ	▼
SWBRD Main Breakers	All Voltages - (1) Main Only ▼		Process & Site Controls	Local Monitor & Control Only ▼
MCC Main Breakers	All Voltages - (1) Main Only ▼		Power/Controls Siting	Centralized ▼
Walk-IN SWBRD & MCC	▼		General Allowances	Add-On to Existing System ▼

Electrical Equipment Scope

120V Power Equipment

WBS	Description (NIS = not in scope)	Qty	AMP	MH	MH @ \$59	M&CE \$	EQ \$	TOTAL
0	PNLBRD (panelboard) Package with Main Breaker - NIS	0						
0	ON-OFF Local Control Switches - NIS	0						
3	HAND-OFF-AUTO Local Control Switches	65		481	\$28,483	\$43,025	\$4,993	\$76,501
0	LCP (local control panel) Components - NIS	0						
0	Fabrication, Assembly, Testing, & Enclosure(s) - NIS	0						
0	Engineering & Testing - NIS	0						
0	Lightning & Surge Protection Devices - NIS	0						
Subtotal - 120V Power Equipment				481	\$28,483	\$43,025	\$4,993	\$76,501

480V Power Equipment

WBS	Description (NIS = not in scope)	Qty	AMP	KW	MH	MH @ \$59	M&CE \$	EQ \$	TOTAL
10	PNLBRD (panelboard) Package with Main Breaker - NIS	0							
0	GENSET Package with ATS, Integral Fuel System, & Noise Enclosure - NIS	0						\$0	
0	GENSET Paralleling Gear Package - NIS	0							
10	SWBRD (switchboard) Package & Main Breaker(s) Allowance	1			275	\$16,301	\$15,237	\$148,800	\$180,338
10	MCC (motor control center) Package & Main Breaker(s) Allowance - 22 section(s)	1			487	\$28,860	\$21,581	\$329,300	\$379,741
10	XFRMR (transformer) Package & Main Breaker Allowance - 90 KVA	1			81	\$4,820	\$3,605	\$5,300	\$13,725
10	Metering, Monitoring, & Communication Device Allowance	1						\$13,600	\$13,600
10	Lightning & Surge Protection Device Allowance	1						\$6,800	\$6,800
10	Integration Allowance (i.e. this power & control equipment to existing)	1			63	\$3,749	\$3,032	\$18,100	\$24,880
Subtotal - 480V Power Equipment				907	\$53,729	\$43,455	\$521,900	\$619,084	

4.16KV Power Equipment

WBS	Description (NIS = not in scope)	Qty	KW	MH	MH @ \$59	M&CE \$	EQ \$	TOTAL	
0	GENSET Package with ATS, Integral Fuel System, & Noise Enclosure - NIS	0					\$0		
0	GENSET Paralleling Gear Package - NIS	0							
10	SWBRD (switchboard) Package & Main Breaker(s) Allowance	1			187	\$11,098	\$11,412	\$92,100	\$114,610
10	MCC (motor control center) Package & Main Breaker(s) Allowance - 2 section(s)	1			190	\$11,260	\$9,262	\$116,800	\$137,322
10	XFRMR (transformer) Package & Main Breaker Allowance - 5000 KVA	1			407	\$24,101	\$19,825	\$277,500	\$321,426
10	Metering, Monitoring, & Communication Device Allowance	1						\$13,700	\$13,700
10	Lightning & Surge Protection Device Allowance	1						\$6,800	\$6,800
10	Integration Allowance (i.e. this power & control equipment to existing)	1			59	\$3,484	\$3,037	\$18,200	\$24,722
Subtotal - 4.16KV Power Equipment				843	\$49,944	\$43,536	\$525,100	\$618,580	

15KV Power Equipment

WBS	Description (NIS = not in scope)	Qty	KW	MH	MH @ \$59	M&CE \$	EQ \$	TOTAL	
12	GENSET Package with ATS, Integral Fuel System, & Noise Enclosure	1	2,000	671	\$39,766	\$29,737	\$1,278,200	\$1,347,704	
0	GENSET Paralleling Gear Package - NIS	0							
10	SWBRD (switchboard) Package & Main Breaker(s) Allowance	1			230	\$13,645	\$15,306	\$103,800	\$132,752
0	MCC (motor control center) Package & Main Breaker(s) - NIS	0							
0	XFRMR (transformer) Package & Main Breaker - NIS	0							
10	Metering, Monitoring, & Communication Device Allowance	1						\$38,900	\$38,900
10	Lightning & Surge Protection Device Allowance	1						\$19,400	\$19,400
10	Integration Allowance (i.e. this power & control equipment to existing)	1			68	\$4,006	\$3,378	\$51,800	\$59,184
Subtotal - 15KV Power Equipment				969	\$57,418	\$48,422	\$1,492,100	\$1,597,939	



DIVS 16-17 (25-28 & 33) ELECTRICAL EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name		Location	Date	Estimator	Version	Job #	
Willamette River WTP Master Plan		Wilsonville, OR	30-Nov-17	Jim Ward	002	30503765	
Process Controls Equipment							
WBS	Description (NIS = not in scope)	Qty	MH	MH @ \$59	M&CE \$	EQ \$	TOTAL
3	Process Control System, HMI, RTU, & Software Package Allowance	1	832	\$49,297	\$38,297	\$41,655	\$129,249
3	Fabrication, Assembly, Testing, & Indoor (coated steel) Enclosure(s)	1				\$67,325	\$67,325
3	Engineering, Programming, Testing, & Training Allowance	1				\$33,325	\$33,325
3	UPS, RTU, Antenna, Lightning, & Surge Protection Device Allowance	1				\$12,500	\$12,500
3	Integration Allowance (i.e. this process control system to existing)	1	62	\$3,697	\$2,872	\$3,100	\$9,670
Subtotal - Process Controls Equipment			894	\$52,994	\$41,169	\$157,905	\$252,069
Site Controls Equipment							
WBS	Description (NIS = not in scope)	Qty	MH	MH @ \$0	M&CE \$	EQ \$	TOTAL
0	Health & Safety System Components Package - NIS	0					
0	Security System Components Package - NIS	0					
0	Surveillance System Components Package - NIS	0					
0	Remote Transmittance Components Package - NIS	0					
0	Fabrication, Assembly, Testing, & Indoor (coated steel) Enclosure(s)	0					
0	Engineering, Programming, Testing, & Training - NIS	0					
0	UPS, RTU, Antenna, Lightning, & Surge Protection Devices - NIS	0					
0	Integration - NIS	0					
Subtotal - Site Controls Equipment							
General Allowances							
This summary category is intended to provide coverage of the minor DIVS 16-17 electrical equipment and/or related work items that could be needed but are currently either too small to consider or cannot yet be quantified. NOTE: The absence of an assigned WBS code below indicates this allowance cost is being allocated across the identified scope items above when these DIV costs are exported to other worksheets.							
WBS	Description	Qty	MH	MH @ \$59	M&CE \$	EQ \$	TOTAL
2	Subtotal - General Allowances		26	\$1,516	\$1,373	\$16,887	\$19,776
Electrical Equipment Total							
			MH	MH @ \$59	M&CE \$	EQ \$	TOTAL
DIVS 16-17(e) TOTAL			4,118	\$244,084	\$220,979	\$2,718,885	\$3,183,949

DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #		
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765		
Equipment Scope												
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout		DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout		DIVS 16-17 Power and I&C Installation	
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL
<u>New GEN 2MW Genset</u>												
12	2X wall diesel tank package-40K gallon	1	\$55,000	92	\$5,603	\$22,516	\$28,119					
12	Ultrasonic level LIT	1		10	\$607	\$482	\$1,089	\$1,600				
12	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298
<u>New SOL Thickener</u>												
61	Thickener structure-35' Ø (divs 2,3,5)	1		172	\$10,460	\$50,222	\$60,681					
61	Power & control connectivity	1							71	\$4,221	\$11,360	\$15,581
61	Thickener mechanism & weirs	1	\$130,000	125	\$7,591	\$6,021	\$13,612					
61	LCP	1							49	\$2,911	\$7,834	\$10,745
61	480 VAC power (1 hp)	1							31	\$1,834	\$4,936	\$6,770
61	10" PV-motorized-sludge blowdown	1	\$6,500	23	\$1,374	\$5,080	\$6,454					
61	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298
<u>Replace SOL Thickener Drive</u>												
70	Thickener drive assembly	1	\$20,000	33	\$2,024	\$1,606	\$3,630					
70	LCP	1							49	\$2,911	\$7,834	\$10,745
70	480 VAC power (1 hp)	1							31	\$1,834	\$4,936	\$6,770
<u>New FILT Cells (2)</u>												
62	Structure-68' x 25' (divs 2,3,5)	1		229	\$13,886	\$66,674	\$80,560					
62	Power & control connectivity	1							95	\$5,604	\$15,081	\$20,685
62	Control console/panel (1 per 2 cells)	1	\$70,100									
62	Underdrain & air pipe-23' x 20'-460 SF (div 15)	2	\$138,000									
62	Sand media-460 SF-12" deep (div 15)	2	\$9,200									
62	GAC media-460 SF-72" deep (div 15)	2	\$193,200									
62	FRP trough assemblies-3 @ 20 LF	2	\$30,000	58	\$3,542	\$2,810	\$6,352					
62	Ultrasonic level LIT	2		20	\$1,214	\$963	\$2,178	\$3,200				
62	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
62	Diff pressure DPIT (pipe mount w/ valves)	2		23	\$1,374	\$5,080	\$6,454	\$7,000				
62	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
62	Turbidity AIT (pipe mount w/ valves)	2		23	\$1,374	\$5,080	\$6,454	\$10,000				
62	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
62	Particle counter AIT (pipe mount w/ valves)	2		23	\$1,374	\$5,080	\$6,454	\$13,000				
62	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
62	HC C/C sample pump-3 gpm @ 15' (1+0)	1	\$1,500	20	\$1,237	\$4,572	\$5,809					
62	120 VAC power	1							20	\$1,164	\$3,134	\$4,298
62	30" BFV-motorized-WW	2	\$31,000	122	\$7,422	\$27,430	\$34,851					
62	480 VAC power (1 hp)	2							55	\$3,260	\$8,774	\$12,035
62	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373
EQ SHEET TOTAL			\$684,500	972	\$59,084	\$203,613	\$262,697	\$34,800	622	\$36,838	\$99,143	\$135,982
TOTAL: ALL DIVS 11-17 EQ SHEETS			\$5,297,485	5,636	\$342,423	\$1,188,679	\$1,531,102	\$1,126,450	5,167	\$306,221	\$824,134	\$1,130,354



DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #		
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765		
Equipment Scope												
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout	DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout	DIVS 16-17 Power and I&C Installation			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL
62	24" BFV-motorized-BW	2	\$22,000	109	\$6,597	\$24,382	\$30,979					
62	480 VAC power (0.5 hp)	2							55	\$3,260	\$8,774	\$12,035
62	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373
62	20" BFV-motorized-FI	2	\$20,000	95	\$5,773	\$21,334	\$27,107					
62	480 VAC power (0.5 hp)	2							55	\$3,260	\$8,774	\$12,035
62	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373
62	20" BFV-motorized-FE	2	\$20,000	95	\$5,773	\$21,334	\$27,107					
62	480 VAC power (0.5 hp)	2							55	\$3,260	\$8,774	\$12,035
62	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373
62	10" BFV-motorized-AW	2	\$13,000	45	\$2,749	\$10,159	\$12,908					
62	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
	<u>New FILT Media # 1</u>											
19	Sand media-460 SF-12" deep (div 15)											
19	GAC media-460 SF-72" deep (div 15)											
	<u>New FILT Media # 2</u>											
19	Sand media-460 SF-12" deep (div 15)											
19	GAC media-460 SF-72" deep (div 15)											
	<u>New FILT Media # 3</u>											
19	Sand media-460 SF-12" deep (div 15)											
19	GAC media-460 SF-72" deep (div 15)											
	<u>New FILT Media # 4</u>											
71	Sand media-460 SF-12" deep (div 15)											
71	GAC media-460 SF-72" deep (div 15)											
	<u>New OZ Channel & Gallery Structure</u>											
60	Structure-74' x 25½' (divs 2,3,5)	1		243	\$14,788	\$71,003	\$85,791					
60	Power & control connectivity	1							101	\$5,968	\$16,060	\$22,028
60	Ozone diffusers-SS	4	\$8,000	74	\$4,483	\$18,013	\$22,495					
60	Pressure PIT (pipe mount w/ valve)	2		11	\$687	\$2,540	\$3,227	\$2,800				
60	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
60	Diff pressure DPIT (pipe mount w/ valves)	2		23	\$1,374	\$5,080	\$6,454	\$7,000				
60	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
60	Demister unit	2	\$3,000	11	\$687	\$2,540	\$3,227					
60	Ozone concentration meter	8		53	\$3,239	\$2,569	\$5,808	\$20,000				
60	120 VAC power & signal	8							157	\$9,315	\$25,070	\$34,385
60	Ozone concentration meter	8		53	\$3,239	\$2,569	\$5,808	\$20,000				
60	120 VAC power & signal	8							157	\$9,315	\$25,070	\$34,385
EQ SHEET TOTAL			\$86,000	813	\$49,388	\$181,522	\$230,910	\$49,800	772	\$45,731	\$123,077	\$168,809



DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #		
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765		
Equipment Scope												
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout	DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout	DIVS 16-17 Power and I&C Installation			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL
60	Pressure PIT (pipe mount w/ valve)	2		11	\$687	\$2,540	\$3,227	\$2,800				
60	120 VAC power & signal	2							39	\$2,329	\$6,267	\$8,596
60	Ozone destruct skid unit	2	\$50,000	90	\$5,498	\$20,318	\$25,816					
60	LCP	2							49	\$2,911	\$7,834	\$10,745
60	480 VAC power	2							96	\$5,706	\$15,355	\$21,061
<u>New ACT Channel & Gallery</u>												
59	Structure-70.34' x 19' (divs 2,3,5)	1		220	\$13,345	\$64,076	\$77,421					
59	Power & control connectivity	1							91	\$5,385	\$14,494	\$19,879
59	Ultrasonic level LIT	1		10	\$607	\$482	\$1,089	\$1,600				
59	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298
59	High/Low safety float switch assembly	1						\$350	25	\$1,455	\$3,917	\$5,373
59	Vendor Actiflo package-1x10 MGD unit	1	\$800,000									
59	Injection chamber vertical mixer	1		17	\$1,012	\$803	\$1,815					
59	480 VAC power	1							38	\$2,241	\$6,032	\$8,274
59	120 VAC signal	1							12	\$728	\$1,959	\$2,686
59	VFD (7.5 hp)	1						\$6,000	17	\$1,019	\$2,741	\$3,760
59	Anti-vortex baffle assemblies	1		17	\$1,012	\$803	\$1,815					
59	Coag chamber vertical mixer	1		17	\$1,012	\$803	\$1,815					
59	480 VAC power	1							38	\$2,241	\$6,032	\$8,274
59	120 VAC signal	1							12	\$728	\$1,959	\$2,686
59	VFD (7.5 hp)	1						\$6,000	17	\$1,019	\$2,741	\$3,760
59	Anti-vortex baffle assemblies	1		17	\$1,012	\$803	\$1,815					
59	Maturation chamber vertical mixer	1		23	\$1,417	\$1,124	\$2,541					
59	480 VAC power	1							41	\$2,445	\$6,581	\$9,026
59	120 VAC signal	1							12	\$728	\$1,959	\$2,686
59	VFD (10 hp)	1						\$7,000	17	\$1,019	\$2,741	\$3,760
59	Anti-vortex baffle assemblies	1		25	\$1,518	\$1,204	\$2,722					
59	19' Ø scraper assemblies	1		78	\$4,757	\$3,773	\$8,530					
59	480 VAC power	1							34	\$2,038	\$5,484	\$7,522
59	120 VAC signal	1							12	\$728	\$1,959	\$2,686
59	VFD (3 hp)	1						\$5,000	11	\$679	\$1,828	\$2,507
59	Lamella tube module & support sets	1		37	\$2,227	\$1,766	\$3,993					
59	Overflow trough & support sets	1		50	\$3,036	\$2,409	\$5,445					
59	Hydrocyclone assemblies-3" (2+1)	3		54	\$3,299	\$12,191	\$15,490					
59	1/2" flush water solenoid & FS assembly	3		28	\$1,681	\$6,755	\$8,436					
59	120 VAC power & signal	3							59	\$3,493	\$9,401	\$12,894
59	LCP	1							123	\$7,277	\$19,586	\$26,863
59	3' x 3' gates-motorized-SS-influent & effluent	2	\$28,000	65	\$3,947	\$3,131	\$7,078					
59	480 VAC power (0.5 hp)	2							48	\$2,853	\$7,678	\$10,530
59	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373
EQ SHEET TOTAL			\$878,000	758	\$46,067	\$122,980	\$169,047	\$28,750	838	\$49,641	\$133,599	\$183,240

DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #		
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765		
Equipment Scope												
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout	DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout	DIVS 16-17 Power and I&C Installation			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL
59	30" BFV-motorized-effluent	1	\$15,500	61	\$3,711	\$13,715	\$17,426					
59	480 VAC power (1 hp)	1							28	\$1,630	\$4,387	\$6,017
59	120 VAC signal	1							12	\$728	\$1,959	\$2,686
59	HC sand/sludge xfer pump-155 gpm @ 70' (1	2		162	\$9,862	\$39,628	\$49,489					
59	480 VAC power (10 hp)	2							76	\$4,483	\$12,065	\$16,548
59	120 VAC signal	4							40	\$2,364	\$6,363	\$8,728
59	PS & PI assembly (pipe mount w/ valve)	2		7	\$412	\$1,524	\$1,936	\$1,500				
59	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373
59	½" seal water solenoid assembly	2		15	\$897	\$3,603	\$4,499	\$500				
59	120 VAC power	2							15	\$873	\$2,350	\$3,224
59	½" seal water FS	2		5	\$275	\$1,016	\$1,291	\$200				
59	120 VAC FS signal	2							5	\$291	\$783	\$1,075
59	HC C/C sample pump-3 gpm @ 15' (1+0)	1	\$1,500	20	\$1,237	\$4,572	\$5,809					
59	120 VAC power	1							20	\$1,164	\$3,134	\$4,298
59	pH & temperature AIT	1	\$1,200	5	\$304	\$241	\$544					
59	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298
59	Turbidity AIT (pipe mount w/ valves)	1		11	\$687	\$2,540	\$3,227	\$5,000				
59	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298
Upgrade CHEM Polymer PLC												
14	Vendor programmed PLC replacement	1	\$7,500									
Upgrade ACT System PLC												
16	Vendor programmed PLC replacement	1	\$20,000									
Replace ACT Sample Pumps												
17	HC C/C sample pump-3 gpm @ 15' (1+0)	2	\$3,000	30	\$1,822	\$1,445	\$3,267					
17	120 VAC power	2							39	\$2,329	\$6,267	\$8,596
Replace FWPS VFD Units												
22	VFD (300 hp)-free standing-NEMA 4X	1						\$92,500	40	\$2,377	\$6,396	\$8,773
22	VFD (500 hp)-free standing-NEMA 4X	2						\$205,000	103	\$6,111	\$16,448	\$22,559
Add CHEM Door Panic Hardware (3)												
25	Panic hardware package	3	\$2,925									
Reverse Opening Direction to (1) Door												
26	Replacement door hardware	1	\$1,200									
Add ACT Door Panic Hardware (1)												
31	Panic hardware package	2	\$1,950									
Add FWPS Door Panic Hardware (1)												
40	Panic hardware package	2	\$1,950									
Add CHEM Exit Door ContainTrays												
27	SS overhead chem pipe trays w/ drain-4' x 4'	2	\$1,795									
EQ SHEET TOTAL			\$58,520	316	\$19,206	\$68,282	\$87,488	\$304,700	441	\$26,135	\$70,338	\$96,473

DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator		Date	Version	Job #		
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward		30-Nov-17	002	30503765		
Equipment Scope													
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout		DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout		DIVS 16-17 Power and I&C Installation		
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL	
Install New CHEM Ozone Generator													
58	Ozone generator skid package-400 PPD	1	\$400,000	258	\$15,689	\$63,044	\$78,733						
58	LCP	1							74	\$4,366	\$11,752	\$16,118	
58	480 VAC power	1							58	\$3,464	\$9,323	\$12,787	
Procure ACT Shelf Spare Pump													
6	HC solids pump-155 gpm @ 70'-10 hp	1	\$18,500										
Install 2nd ACT Flash Mix Pump													
7	HC flash mix pump-1,000 gpm @ 16' (1+1)	1	\$27,500	68	\$4,123	\$15,239	\$19,362						
7	480 VAC power (7.5 hp)	1							38	\$2,241	\$6,032	\$8,274	
7	120 VAC signal	2							16	\$960	\$2,584	\$3,545	
7	PS & PI assembly (pipe mount w/ valve)	1		3	\$206	\$762	\$968	\$750					
7	120 VAC signal	1							12	\$728	\$1,959	\$2,686	
7	½" seal water solenoid assembly	1		7	\$448	\$1,801	\$2,250	\$250					
7	120 VAC power	1							7	\$437	\$1,175	\$1,612	
7	½" seal water FS	1		2	\$137	\$508	\$645	\$100					
7	120 VAC FS signal	1							2	\$146	\$392	\$537	
Replace ACT Flash Mix Pumps													
69	HC flash mix pump-1,000 gpm @ 16' (1+1)	2	\$55,000	136	\$8,247	\$30,477	\$38,724						
69	480 VAC power (7.5 hp)	2							76	\$4,483	\$12,065	\$16,548	
69	120 VAC signal	4							32	\$1,921	\$5,169	\$7,089	
69	PS & PI assembly (pipe mount w/ valve)	2		7	\$412	\$1,524	\$1,936	\$1,500					
69	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373	
69	½" seal water solenoid assembly	2		15	\$897	\$3,603	\$4,499	\$500					
69	120 VAC power	2							15	\$873	\$2,350	\$3,224	
69	½" seal water FS	2		5	\$275	\$1,016	\$1,291	\$200					
69	120 VAC FS signal	2							5	\$291	\$783	\$1,075	
Install Shelf Spare SOL Mix Pump													
8	HC mix pump-600 gpm @ 6'	1		68	\$4,123	\$15,239	\$19,362						
8	480 VAC power (5 hp)	1							34	\$2,038	\$5,484	\$7,522	
8	120 VAC signal	2							16	\$960	\$2,584	\$3,545	
8	PS & PI assembly (pipe mount w/ valve)	1		3	\$206	\$762	\$968	\$750					
8	120 VAC signal	1							12	\$728	\$1,959	\$2,686	
8	½" seal water solenoid assembly	1		7	\$448	\$1,801	\$2,250	\$250					
8	120 VAC power	1							7	\$437	\$1,175	\$1,612	
8	½" seal water FS	1		2	\$137	\$508	\$645	\$100					
8	120 VAC FS signal	1							2	\$146	\$392	\$537	
Replace DEW Solids Transfer Pumps													
72	PC solids transfer pump-60 gpm @ 70'	2	\$30,000	72	\$4,398	\$16,255	\$20,653						
72	480 VAC power	2							69	\$4,075	\$10,968	\$15,043	
72	120 VAC signal	4							32	\$1,921	\$5,169	\$7,089	
72	VFD (5 hp)	2						\$12,000	34	\$2,037	\$5,483	\$7,520	
72	PS & PI assembly (pipe mount w/ valve)	2		7	\$412	\$1,524	\$1,936	\$1,500					
72	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373	
72	½" seal water solenoid assembly	2		15	\$897	\$3,603	\$4,499	\$500					
72	120 VAC power	2							15	\$873	\$2,350	\$3,224	
72	½" seal water FS	2		5	\$275	\$1,016	\$1,291	\$200					
72	120 VAC FS signal	2							5	\$291	\$783	\$1,075	
Replace ACT Settling Tubes													
18	19' x 19' x 4' deep tube assembly	2	\$90,250										
EQ SHEET TOTAL			\$621,250	680	\$41,331	\$158,680	\$200,011	\$18,600	613	\$36,326	\$97,765	\$134,092	

DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator		Date		Version		Job #	
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward		30-Nov-17		002		30503765	
Equipment Scope														
<i>DIVS 11-17 EQ & Related Components</i>			<i>DIVS 11-15 EQ Buyout</i>		<i>DIV 15 EQ & Piping Installation</i>				<i>DIVS 16-17 EQ Buyout</i>		<i>DIVS 16-17 Power and I&C Installation</i>			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL		
Replace FWPS 4 MGD Pump with 7.5														
9	VT HSPS pump-7.5 MGD @ 312'	1	\$320,000	124	\$7,559	\$27,938	\$35,497							
9	4160 VAC power	1							69	\$4,075	\$10,968	\$15,043		
9	120 VAC signal	2							16	\$960	\$2,584	\$3,545		
9	VFD unit (500 hp)	1						\$70,000	52	\$3,056	\$8,224	\$11,280		
9	PS & PI assembly (pipe mount w/ valve)	1		3	\$206	\$762	\$968	\$750						
9	120 VAC signal	1							12	\$728	\$1,959	\$2,686		
9	½" seal water solenoid assembly	1		7	\$448	\$1,801	\$2,250	\$250						
9	120 VAC power	1							7	\$437	\$1,175	\$1,612		
9	½" seal water FS	1		2	\$137	\$508	\$645	\$100						
9	120 VAC FS signal	1							2	\$146	\$392	\$537		
9	4" air/vacuum release assembly	2	\$4,300	14	\$825	\$3,048	\$3,872							
9	14" BFV-motorized-AW	1	\$7,500	32	\$1,924	\$7,111	\$9,036							
9	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298		
Replace FWPS 7.5 MGD Pumps with 12														
63	VT HSPS pump-12 MGD @ 312'	3	\$1,260,000	390	\$23,680	\$95,156	\$118,836							
63	4160 VAC power	3							237	\$14,060	\$37,840	\$51,900		
63	120 VAC signal	6							49	\$2,881	\$7,753	\$10,634		
63	VFD unit (800 hp)	3						\$375,000	206	\$12,223	\$32,896	\$45,118		
63	PS & PI assembly (pipe mount w/ valve)	3		10	\$618	\$2,286	\$2,904	\$2,250						
63	120 VAC signal	3							37	\$2,183	\$5,876	\$8,059		
63	½" seal water solenoid assembly	3		22	\$1,345	\$5,404	\$6,749	\$750						
63	120 VAC power	3							22	\$1,310	\$3,525	\$4,835		
63	½" seal water FS	3		7	\$412	\$1,524	\$1,936	\$300						
63	120 VAC FS signal	3							7	\$437	\$1,175	\$1,612		
63	4" air/vacuum release assembly	6	\$12,900	41	\$2,474	\$9,143	\$11,617							
63	18" BFV-motorized-AW	3	\$28,500	129	\$7,834	\$28,953	\$36,788							
63	120 VAC power & signal	3							59	\$3,493	\$9,401	\$12,894		
Install 5th FWPS 7.5 MGD Pump														
64	VT HSPS pump-7.5 MGD @ 312'	1	\$320,000	124	\$7,559	\$27,938	\$35,497							
64	4160 VAC power	1							69	\$4,075	\$10,968	\$15,043		
64	120 VAC signal	2							16	\$960	\$2,584	\$3,545		
64	VFD unit (500 hp)	1						\$70,000	52	\$3,056	\$8,224	\$11,280		
64	PS & PI assembly (pipe mount w/ valve)	1		3	\$206	\$762	\$968	\$750						
64	120 VAC signal	1							12	\$728	\$1,959	\$2,686		
64	½" seal water solenoid assembly	1		7	\$448	\$1,801	\$2,250	\$250						
64	120 VAC power	1							7	\$437	\$1,175	\$1,612		
64	½" seal water FS	1		2	\$137	\$508	\$645	\$100						
64	120 VAC FS signal	1							2	\$146	\$392	\$537		
64	4" air/vacuum release assembly	2	\$4,300	14	\$825	\$3,048	\$3,872							
64	14" BFV-motorized-AW	1	\$7,500	32	\$1,924	\$7,111	\$9,036							
64	120 VAC power & signal	1							20	\$1,164	\$3,134	\$4,298		
EQ SHEET TOTAL			\$1,965,000	964	\$58,564	\$224,801	\$283,365	\$520,500	974	\$57,718	\$155,337	\$213,055		



DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #			
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765			
Equipment Scope													
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout		DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout	DIVS 16-17 Power and I&C Installation			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL	
	Replace RWPS 7.5 MGD Pumps with 15												
65	VT pump-15 MGD @ 107"	2	\$350,000	425	\$25,839	\$95,495	\$121,335						
65	480 VAC power	2							131	\$7,743	\$20,839	\$28,583	
65	120 VAC signal	4							32	\$1,921	\$5,169	\$7,089	
65	VFD unit (400 hp)	2						\$140,000	92	\$5,432	\$14,620	\$20,053	
65	PS & PI assembly (pipe mount w/ valve)	2		7	\$412	\$1,524	\$1,936	\$1,500					
65	120 VAC signal	2							25	\$1,455	\$3,917	\$5,373	
65	½" seal water solenoid assembly	2		15	\$897	\$3,603	\$4,499	\$500					
65	120 VAC power	2							15	\$873	\$2,350	\$3,224	
65	½" seal water FS	2		5	\$275	\$1,016	\$1,291	\$200					
65	120 VAC FS signal	2							5	\$291	\$783	\$1,075	
65	4" air/vacuum release assembly	2	\$4,300	14	\$825	\$3,048	\$3,872						
	Replace CHEM Metering Pumps												
15	Hydraulic diaphragm meter pump-2 gph												
15	480 VAC power (0.5hp)												
15	120 VAC signal												
15	Hydraulic diaphragm meter pump-6 gph												
15	480 VAC power (0.5 hp)												
15	120 VAC signal												
15	Hydraulic diaphragm meter pump-39 gph												
15	480 VAC power (1 hp)												
15	120 VAC signal												
15	Hydraulic diaphragm meter pump-77 gph												
15	480 VAC power (1½ hp)												
15	120 VAC signal												
15	1" flush water solenoid assembly												
15	120 VAC power												
	Replace CHEM Metering Pumps												
68	Hydraulic diaphragm meter pump-2 gph												
68	480 VAC power (0.5hp)												
68	120 VAC signal												
68	Hydraulic diaphragm meter pump-6 gph												
68	480 VAC power (0.5 hp)												
68	120 VAC signal												
68	Hydraulic diaphragm meter pump-39 gph												
68	480 VAC power (1 hp)												
68	120 VAC signal												
68	Hydraulic diaphragm meter pump-77 gph												
68	480 VAC power (1½ hp)												
68	120 VAC signal												
68	1" flush water solenoid assembly												
68	120 VAC power												
EQ SHEET TOTAL			\$354,300	465	\$28,248	\$104,685	\$132,933	\$142,200	299	\$17,716	\$47,679	\$65,395	



DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #		
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765		
Equipment Scope												
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout	DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout	DIVS 16-17 Power and I&C Installation			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL
	Add 3rd Solids Pump & Centrifuge											
66	PC solids transfer pump-60 gpm @ 70'	1	\$15,000	59	\$3,586	\$14,410	\$17,996					
66	480 VAC power	1							34	\$2,038	\$5,484	\$7,522
66	120 VAC signal	2							16	\$960	\$2,584	\$3,545
66	VFD (5 hp)	1						\$6,000	17	\$1,019	\$2,741	\$3,760
66	PS & PI assembly (pipe mount w/ valve)	1		3	\$206	\$762	\$968	\$750				
66	120 VAC signal	1							12	\$728	\$1,959	\$2,686
66	½" seal water solenoid assembly	1		7	\$448	\$1,801	\$2,250	\$250				
66	120 VAC power	1							7	\$437	\$1,175	\$1,612
66	½" seal water FS	1		2	\$137	\$508	\$645	\$100				
66	120 VAC FS signal	1							2	\$146	\$392	\$537
66	Centrifuge skid package	1	\$450,000	271	\$16,493	\$60,955	\$77,448					
66	LCP	1							123	\$7,277	\$19,586	\$26,863
66	480 VAC power-Main drive	1							48	\$2,853	\$7,678	\$10,530
66	480 VAC VFD (40 hp)	1						\$12,000	23	\$1,358	\$3,655	\$5,013
66	480 VAC power-Backdrive	1							41	\$2,445	\$6,581	\$9,026
66	480 VAC VFD (15 hp)	1						\$7,000	17	\$1,019	\$2,741	\$3,760
66	SS discharge chute & gate assembly	1	\$9,500	40	\$2,429	\$1,927	\$4,356					
66	120 VAC power	1							20	\$1,164	\$3,134	\$4,298
66	1" flush water solenoid assembly	1		15	\$897	\$3,603	\$4,499	\$350				
66	120 VAC power	1							7	\$437	\$1,175	\$1,612
66	2" flush water solenoid assembly	1		17	\$1,009	\$4,053	\$5,061	\$650				
66	120 VAC power	1							7	\$437	\$1,175	\$1,612
EQ SHEET TOTAL			\$474,500	415	\$25,205	\$88,018	\$113,223	\$27,100	377	\$22,316	\$60,060	\$82,376

DIVS 11-17 (40-45) PROCESS EQUIPMENT

CLASS 4 OPCC - PRIVILEGED & CONFIDENTIAL

Project Name			Location				Estimator	Date	Version	Job #			
Willamette River WTP Master Plan			Wilsonville, OR				Jim Ward	30-Nov-17	002	30503765			
Equipment Scope													
DIVS 11-17 EQ & Related Components			DIVS 11-15 EQ Buyout		DIV 15 EQ & Piping Installation				DIVS 16-17 EQ Buyout	DIVS 16-17 Power and I&C Installation			
WBS	Item (NIS-not in scope)	Qty	TOTAL	MH	MH \$	M&CE \$	TOTAL	TOTAL	MH	MH \$	M&CE \$	TOTAL	
	<u>Balance of 480V Loads for New MCC's</u>												
	2-MCC-A												
10	Main	1											
10	Vent fans, dewatering pumps, & cooling fans	5											
	2-DP-B												
10	Main	1											
10	MOV's	2											
	4-MCC-B												
10	Main	1											
10	Sand pumps	2											
10	Mixers	2											
10	Mixer	1											
10	Destruct unit & MOV's	2											
10	Ozone water pump	1											
10	4-LP-B	1											
	6-DP-B												
10	Main	7											
10	MOV's, Xfrmer, & mix pump	7											
	13-DP-B												
10	Main	1											
10	Ozone generator	1											
10	Compressor, poly feeder, fan, MOV, spares	6											
10	Admin HVAC	1											
10	18-LP-B & 13-LP-B	2											
	19-MCC-A												
10	Main	1											
10	Recycle pumps, solids pumps, MOV, spares	7											
10	Recycle pump, mix pump, thickener	3											
EQ SHEET TOTAL													

VEOLIA COST FACTORING

System Name	Item	Type	Phase	Year In Service	QTY	Veolia Cost Estimate (Total Direct EQ Cost)	JSW Install & Burdens Multiply Factor	JSW OPCC for Installation & Burdens	GRAND TOTAL Veolia Cost + JSW Class 5 OPCC	Estimate Class
Chemical Storage/ Ozone Generation	Confirm Storage durations	Capacity Upgrades	20 MGD	2022						
Chemical Storage/ Ozone Generation	Replace existing chemical lines (Recommend extending utilidoor to southern half of plant. Portion between utilidoors will be run along east wall of WVEQ basin)	Capacity Upgrades	20 MGD	2022						
Chemical Storage/ Ozone Generation	Purchase larger LOX storage tank (12,000 to 15,000 gallons)	Capacity Upgrades	20 MGD	2022	1	\$ 175,000	0.500	\$ 87,500	\$ 262,500	4
Chemical Storage/ Ozone Generation	PLC upgrade on polymer units	Repair & Replace	20 MGD	2022						
Chemical Storage/ Ozone Generation	Chemical metering pump replacement	Repair & Replace	20 MGD	2022						
Chemical Storage/ Ozone Generation	Inspect tanks	Repair & Replace	20 MGD	2022						
Chemical Storage/ Ozone Generation	Replace ozone generators (Recommend upsizing to 400 PPD units)	Repair & Replace	20 MGD	2022	2	\$ 960,000	0.8250	\$ 792,000	\$ 1,752,000	4
Chemical Storage/ Ozone Generation	Provide Seismic bracing of chemical, ozone, and LOX pipes	Seismic Retrofits	20 MGD	2022						
Chemical Storage/ Ozone Generation	Replace faded NFPA signage	Life-Safety Repairs	20 MGD	2022						
Chemical Storage/ Ozone Generation	Provide panic hardware on 3 exterior doors	Life-Safety Repairs	20 MGD	2022						
Chemical Storage/ Ozone Generation	Change swing direction of door between Ozone Generation Room and Admin building	Life-Safety Repairs	20 MGD	2022						
Chemical Storage/ Ozone Generation	Add secondary containment pans over exit routes	Life-Safety Repairs	20 MGD	2022						
Chemical Storage/ Ozone Generation	Install emergency shut-off at other two Ozone Generation Room exits	Life-Safety Repairs	20 MGD	2022						
Chemical Storage/ Ozone Generation	Add third ozone generator	Capacity Upgrades	30 MGD	2036						
Chemical Storage/ Ozone Generation	Purchase of second dry polymer feed	Capacity Upgrades	30 MGD	2032	1	\$ 50,000	3.800	\$ 190,000	\$ 240,000	5
Chemical Storage/ Ozone Generation	Chemical metering pump replacement	Repair & Replace	30 MGD	2036						
Chemical Storage/ Ozone Generation	Replace sodium hypochlorite tank	Repair & Replace	30 MGD	2022	1	\$ 15,000	2.500	\$ 37,500	\$ 52,500	4
Chemical Storage/ Ozone Generation	T-05ME01 Evaporator,LOX 1, North	Equipment - Mechanical		2035		\$ 37,500	0.500	\$ 18,750	\$ 56,250	5
Chemical Storage/ Ozone Generation	T-05ME02 Evaporator,LOX 2, South	Equipment - Mechanical		2035		\$ 37,500	0.500	\$ 18,750	\$ 56,250	5
Chemical Storage/ Ozone Generation	T-13T01 Tank,Caustic Soda	Caustic Soda Feed System		2022		\$ 15,000	2.500	\$ 37,500	\$ 52,500	4
Chemical Storage/ Ozone Generation	T-13T04 Tank,Liquid Alum 4	Liquid Alum System		2022		\$ 15,000	2.500	\$ 37,500	\$ 52,500	4
Chemical Storage/ Ozone Generation	T-13T05 Tank,Liquid Alum 5	Liquid Alum System		2022		\$ 15,000	2.500	\$ 37,500	\$ 52,500	4
Actiflo™	Purchase additional shelf spare solid pump	Capacity Upgrades	20 MGD	2022						
Actiflo™	Vendor PLC upgrade	Repair & Replace	20 MGD	2022						
Actiflo™	Replace Solids pumps	Repair & Replace	20 MGD	2022	5	\$ 200,000	2.200	\$ 440,000	\$ 640,000	4
Actiflo™	Replace flash mix pumps (T-03P02)	Repair & Replace	20 MGD	2022	2	\$ 57,200	5.600	\$ 320,320	\$ 377,520	4
Actiflo™	Install second flash mix pump	Redundancy	20 MGD	2022	1					
Actiflo™	Replace mixers	Repair & Replace	20 MGD	2022	6	\$ 144,000	1.100	\$ 158,400	\$ 302,400	4
Actiflo™	Replace hydrocyclones	Repair & Replace	20 MGD	2019	4	\$ 120,000	1.650	\$ 198,000	\$ 318,000	4
Actiflo™	Replace sample pumps	Repair & Replace	20 MGD	2022						
Actiflo™	Replace guardrail	Life-Safety Repairs	20 MGD	2022						
Actiflo™	Inject sealant into active leaks and apply exterior waterstop on join surface	Life-Safety Repairs	20 MGD	2022						
Actiflo™	Provide panic hardware on exit doors	Life-Safety Repairs	20 MGD	2022						
Actiflo™	Install new kickplate on west guardrail	Life-Safety Repairs	20 MGD	2022						
Actiflo™	Upgrade electrical outlets to GFCIs	Life-Safety Repairs	20 MGD	2022						
Actiflo™	Install one new Actiflo™ basin	Capacity Upgrades	30 MGD	2036						
Actiflo™	Replace flash mix pumps	Repair & Replace	30 MGD	2036						
Actiflo™	Replace mixers	Repair & Replace	30 MGD	2036	6	\$ 144,000	1.475	\$ 212,400	\$ 356,400	5
Actiflo™	Replace hydrocyclones	Repair & Replace	30 MGD	2036	4	\$ 120,000	2.075	\$ 249,000	\$ 369,000	5
Actiflo™	T-13ME01 Dry Polymer Batching System	Equipment - Mechanical		2027		\$ 50,000	2.975	\$ 148,750	\$ 198,750	5
Actiflo™	T-04LCP01 Panel, Local Control,Actiflo, & PLC	Equipment - Electrical		2027		\$ 30,000	1.800	\$ 54,000	\$ 84,000	5

VEOLIA COST FACTORING

System Name	Item	Type	Phase	Year In Service	QTY	Veolia Cost Estimate (Total Direct EQ Cost)	JSW Install & Burdens Multiply Factor	JSW OPCC for Installation & Burdens	GRAND TOTAL Veolia Cost + JSW Class 5 OPCC	Estimate Class
Actiflo™	T-03AIT005 Analyzer, Streaming Current, Actiflo Inlet	Initial Chemical Mixing & Application Sys		2020		\$ 10,000	1.350	\$ 13,500	\$ 23,500	4
Ozonation	Replace diffusers in Ozone basin	Capacity Upgrades	20 MGD	2022	6	\$ 40,000	0.825	\$ 33,000	\$ 73,000	4
Ozonation	Provide seismic bracing of ozone destruct pipe down to concrete deck	Seismic Retrofits	20 MGD	2022						
Ozonation	Replace settling tubes	Repair & Replace	20 MGD	2022						
Ozonation	Replace guardrail	Life-Safety Repairs	20 MGD	2022						
Ozonation	Inject sealant into active leaks and apply exterior waterstop on joint surface	Life-Safety Repairs	20 MGD	2022						
Ozonation	Upgrade electrical outlets to GFCIs	Life-Safety Repairs	20 MGD	2022						
Ozonation	Confirm if ventilation is sufficient	Life-Safety Repairs	20 MGD	2022						
Ozonation	Construct one new ozonation basin	Capacity Upgrades	30 MGD	2036						
Solids/Gravity Thickener	Install shelf spare mixing pump	Capacity Upgrades	20 MGD	2022						
Solids/Gravity Thickener	Replace sludge mixing pumps	Repair & Replace	20 MGD	2017	2	\$ 65,000	3.000	\$ 195,000	\$ 260,000	4
Solids/Gravity Thickener	Install spare mixing pump and centrifuge	Repair & Replace	20 MGD	2022						
Solids/Gravity Thickener	Construct one new gravity thickener	Capacity Upgrades	30 MGD	2036						
Solids/Gravity Thickener	Replace thickener drive	Repair & Replace	30 MGD	2036						
Solids/Gravity Thickener	Replace sludge mixing pumps and centrifuges	Repair & Replace	30 MGD	2032	2	\$ 65,000	3.000	\$ 195,000	\$ 260,000	5
Filters	Filtration pilot	Capacity Upgrades	20 MGD	2022						
Filters	GAC changeouts every 4 years	Repair & Replace	20 MGD	2022						
Filters	GAC changeouts every 4 years	Repair & Replace		2026						
Filters	GAC changeouts every 4 years	Repair & Replace		2030						
Filters	GAC changeouts every 4 years	Repair & Replace	30 MGD	2034						
Filters	Replace air scour blowers and motors	Repair & Replace	20 MGD	2022	2	\$ 120,000	1.925	\$ 231,000	\$ 351,000	4
Filters	Electrical wiring upgrade	Repair & Replace	20 MGD	2022						
Filters	Replace guardrail	Life-Safety Repairs	20 MGD	2022						
Filters	Inject sealant into active leaks and apply exterior waterstop on joint surface	Life-Safety Repairs	20 MGD	2022						
Filters	Install new kickplate on top side of ladder pit	Life-Safety Repairs	20 MGD	2022						
Filters	Upgrade electrical outlets to GFCIs	Life-Safety Repairs	20 MGD	2022						
Filters	Construct two new filters	Capacity Upgrades	30 MGD	2036						
Filters	Replace air scour blowers and motors	Repair & Replace	30 MGD	2036	2	\$ 120,000	2.350	\$ 282,000	\$ 402,000	5
Filters	T-06FILT01 Filter 1	Equipment - Mechanical		2032		\$ 62,500.00				
Filters	T-06FILT02 Filter 2	Equipment - Mechanical		2032		\$ 62,500.00				
Filters	T-06FILT03 Filter 3	Equipment - Mechanical		2032		\$ 62,500.00				
Filters	T-06FILT04 Filter 4	Equipment - Mechanical		2032		\$ 62,500.00				
Filters	T-06FCW01 Weir, Filter Control	Equipment - Electrical		2035		\$ 25,000.00				
Filters	T-06MCC-A MCC, Filter Gallery	Equipment - Mechanical		2035		\$ 25,000	1.800	\$ 45,000	\$ 70,000	5
WWEQ Basin	Replace recycle pumps	Repair & Replace	20 MGD	2017	3	\$ 75,000	3.000	\$ 225,000	\$ 300,000	4
WWEQ Basin	Modifications to support chemical lines along western basin wall	Repair & Replace	20 MGD	2022						
WWEQ Basin	3 concrete braces on N and S walls w/ intermediate column support	Seismic Retrofits	20 MGD	2022						
WWEQ Basin	3 concrete braces across width of basin w/ intermediate column support	Seismic Retrofits	20 MGD	2022						
WWEQ Basin	Verify fall restraint provisions when using ladder	Life-Safety Repairs	20 MGD	2022						
WWEQ Basin	Replace recycle pumps	Repair & Replace	30 MGD	2032	3	\$ 75,000	1.200	\$ 90,000	\$ 165,000	5
Finished Water Pump Station	Replace 4 MGD pump with 7.5 MGD	Capacity Upgrades	20 MGD	2022						

VEOLIA COST FACTORING

System Name	Item	Type	Phase	Year In Service	QTY	Veolia Cost Estimate (Total Direct EQ Cost)	JSW Install & Burdens Multiply Factor	JSW OPCC for Installation & Burdens	GRAND TOTAL Veolia Cost + JSW Class 5 OPCC	Estimate Class
Finished Water Pump Station	Install second 4 MGD pump	Capacity Upgrades	20 MGD	2022	1	\$ 400,000	2.450	\$ 980,000	\$ 1,380,000	4
Finished Water Pump Station	Replace VFDs	Repair & Replace	20 MGD	2022						
Finished Water Pump Station	Replace flowmeter (plant-wide)	Repair & Replace	20 MGD	2022	3	\$ 46,000	0.800	\$ 36,800	\$ 82,800	4
Finished Water Pump Station	New wall anchorage along W and E walls midway between existing roof joists	Seismic Retrofits	20 MGD	2022						
Finished Water Pump Station	Replace deficient deck sections w/ 16 GA corrugated steel decking	Seismic Retrofits	20 MGD	2022						
Finished Water Pump Station	Strengthen existing chord connections	Seismic Retrofits	20 MGD	2022						
Finished Water Pump Station	Add new top plate over interior shear walls w/ epoxied anchors	Seismic Retrofits	20 MGD	2022						
Finished Water Pump Station	Provide longitudinal seismic bracing for cable trays	Seismic Retrofits	20 MGD	2022						
Finished Water Pump Station	Provide panic hardware on exit doors	Life-Safety Repairs	20 MGD	2022						
Finished Water Pump Station	Replace three 7.5 MGD pumps with three 12 MGD pumps	Capacity Upgrades	30 MGD	2036						
Finished Water Pump Station	Install fifth pump for low-flow redundancy	Capacity Upgrades	30 MGD	2036						
Finished Water Pump Station	Replace all pumps by 30 MGD expansion. Recommend two 7.5 MGD and three 12 MGD pumps	Repair & Replace	30 MGD	2036						
Finished Water Pump Station	Replace flowmeter (plant-wide)	Repair & Replace	30 MGD	2036	3	\$ 46,000	1.200	\$ 55,200	\$ 101,200	5
Finished Water Pump Station	T-09VFD01 VFD, High Service Pump 1	Equipment - Electrical		2027		\$ 120,000	1.825	\$ 219,000	\$ 339,000	5
Finished Water Pump Station	T-09VFD02 VFD, High Service Pump 2	Equipment - Electrical		2027		\$ 120,000	1.825	\$ 219,000	\$ 339,000	5
Finished Water Pump Station	T-09VFD03 - Soft Start Controller, High Service Pump 3	Equipment - Electrical		2027		\$ 30,000	1.800	\$ 54,000	\$ 84,000	5
Finished Water Pump Station	T-09VFD04 VFD, High Service Pump 4	Equipment - Electrical		2027		\$ 30,000	1.800	\$ 54,000	\$ 84,000	5
Finished Water Pump Station	T-07P01 Pump, Backwash Supply 1	Equipment - Mechanical		2032		\$ 300,000	2.300	\$ 690,000	\$ 990,000	5
Finished Water Pump Station	T-07P02 Pump, Backwash Supply 2	Equipment - Mechanical		2032		\$ 300,000	2.300	\$ 690,000	\$ 990,000	5
Raw Water Pump Station	Replace 4 MGD pump & VFD with 7.5 MGD pump & VFD	Capacity Upgrades	20 MGD	2022	1	\$ 175,000	2.800	\$ 490,000	\$ 665,000	4
Raw Water Pump Station	Replace VFDs	Repair & Replace	20 MGD	2022	3	\$ 41,000	1.375	\$ 56,375	\$ 97,375	4
Raw Water Pump Station	Replace flowmeter (plant-wide)	Repair & Replace	20 MGD	2022	1	\$ 18,000	0.825	\$ 14,850	\$ 32,850	4
Raw Water Pump Station	Replace two 7.5 MGD pumps & VFD's and two 15 MGD pumps & VFD's	Capacity Upgrades	30 MGD	2036						
Raw Water Pump Station	Replace remaining constant speed 7.5 MGD pump with new 7.5 MGD pump & VFD	Repair & Replace	30 MGD	2036	1	\$ 175,000	2.900	\$ 507,500	\$ 682,500	5
Raw Water Pump Station	T-01ME01 Compressor, Air Burst 1	Equipment - Mechanical		2027		\$ 50,000	2.950	\$ 147,500	\$ 197,500	5
Raw Water Pump Station	T-01ME02 Compressor, Air Burst 2	Equipment - Mechanical		2027		\$ 50,000	2.950	\$ 147,500	\$ 197,500	5
Raw Water Pump Station	T-02P05 Pump,Sump,Raw Water	Intake Pump St Bldg - Mechanical		2017		\$ 25,000	3.000	\$ 75,000	\$ 100,000	4
Raw Water Pump Station	T-01LCP01 Panel,Local Control,Air Burst & PLC	Equipment - Electrical		2027		\$ 15,000	1.825	\$ 27,375	\$ 42,375	5
Solids Dewatering/Treatment	Steel braced frames at east-side exterior that braces second floor	Seismic Retrofits	20 MGD	2022						
Solids Dewatering/Treatment	Add new wall anchorage along E and W walls mid-way between existing roof joists	Seismic Retrofits	20 MGD	2022						
Solids Dewatering/Treatment	Tie existing floor slab to walls w/ stainless steel angles and epoxy anchors	Seismic Retrofits	20 MGD	2022						
Solids Dewatering/Treatment	Cut out notch in parapet wall and install a scupper and downspout	Life-Safety Repairs	20 MGD	2022						
Solids Dewatering/Treatment	Install third centrifuge and connected solids transfer pump	Capacity Upgrades	30 MGD	2036						
Solids Dewatering/Treatment	Replace centrifuges	Repair & Replace	30 MGD	2027	2	\$ 1,400,000	1.500	\$ 2,100,000	\$ 3,500,000	5
Solids Dewatering/Treatment	Replace solids transfer pumps	Repair & Replace	30 MGD	2036						
Solids Dewatering/Treatment	T-12ME03 Conveyor, Screw, Dewatered Sludge	Equipment - Mechanical		2022		\$ 30,000	1.900	\$ 57,000	\$ 87,000	4
Solids Dewatering/Treatment	T-12LCP01 Panel,Local Control,Centrifuge 1, & PLC	Equipment - Electrical		2027		\$ 15,000	1.800	\$ 27,000	\$ 42,000	5
Solids Dewatering/Treatment	T-12LCP02 Panel,Local Control,Centrifuge 2, & PLC	Equipment - Electrical		2027		\$ 15,000	1.800	\$ 27,000	\$ 42,000	5
Sitewide	Provide seismic bracing for space heaters (approx. 8 locations)	Seismic Retrofits	20 MGD	2022						

VEOLIA COST FACTORING

System Name	Item	Type	Phase	Year In Service	QTY	Veolia Cost Estimate (Total Direct EQ Cost)	JSW Install & Burdens Multiply Factor	JSW OPCC for Installation & Burdens	GRAND TOTAL Veolia Cost + JSW Class 5 OPCC	Estimate Class
Electrical	Replace existing switchgear	Capacity Upgrades	20 MGD	2022						
Electrical	Replace existing transformer	Capacity Upgrades	20 MGD	2022	8	\$ 120,000	0.500	\$ 60,000	\$ 180,000	4
Electrical	Rewire existing system as necessary to support emergency power supply	Capacity Upgrades	20 MGD	2022						
Electrical	2MW emergency generator (sufficient to power plant through 30 MGD)	Capacity Upgrades	20 MGD	2022						
Electrical	T-99PCM01 PCM01, Admin Panel RM 103A	Industrial Control Network System		2017		\$ 30,000	1.400	\$ 42,000	\$ 72,000	4
Electrical	T-99PCM02 PCM02, Admin Electrical RM 106	Industrial Control Network System		2017		\$ 30,000	1.400	\$ 42,000	\$ 72,000	4
Electrical	T-99FILTERPLCB PCM 5 PLC B	Industrial PLC System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99FILTERPLCC PCM 5 PLC C	Industrial PLC System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99PCM03 PCM03,Ozone Gallery	Industrial Control Network System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99PCM04 PCM04,WW Recovery	Industrial Control Network System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99PCM05 PCM05,Filter Gallery	Industrial Control Network System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99PCM06 PCM06,High Service Elec Room	Industrial Control Network System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99PLCA PCM 1 PLC A	Industrial PLC System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Electrical	T-99PLCA Backup PCM 1 PLC Back-up	Industrial PLC System		2017		\$ 15,000	1.400	\$ 21,000	\$ 36,000	4
Miscellaneous	T-30P01 Pump, Water Feature	Grounds System - Mechanical		2024		\$ 50,000	2.400	\$ 120,000	\$ 170,000	5
Miscellaneous	T-30P02 SPARE Pump, Water Feature	Grounds System - Mechanical		2035		\$ 30,000	3.500	\$ 105,000	\$ 135,000	5
Miscellaneous	T-30P02 Pump #1, Waste, Irrigation	Grounds System - Mechanical		2022		\$ 30,000	3.000	\$ 90,000	\$ 120,000	4
Miscellaneous	T-30P03 Pump #2, Waste Irrigation	Grounds System - Mechanical		2022		\$ 30,000	3.000	\$ 90,000	\$ 120,000	4
Miscellaneous	T-32YARD001 Company Truck	Support Vehicles System		2020		\$ 25,000	0.500	\$ 12,500	\$ 37,500	4
Miscellaneous	T-32YARD002 Mule Kawasaki 550	Support Vehicles System		2017		\$ 10,000	0.500	\$ 5,000	\$ 15,000	4
Miscellaneous	T-18FACP01 Fire Alarm System- Yearly Maintenance + Parts	Fire and Security Monitoring System		2017		\$ 4,000	0.750	\$ 3,000	\$ 7,000	4
Miscellaneous	T-18FASS01 Sprinkler System, Fire Alarm- Yearly Maintenance + Parts	Fire and Security Monitoring System		2017		\$ 2,500	0.750	\$ 1,875	\$ 4,375	4
Miscellaneous	T-18SECU01 Security Monitoring System	Fire and Security Monitoring System		2017		\$ 10,000	1.350	\$ 13,500	\$ 23,500	4
Miscellaneous	T-32YARD015 Signs, Safety and Warning	Grounds System		2017		\$ 10,000	0.500	\$ 5,000	\$ 15,000	4
Miscellaneous	T-33TOOLS08 Fire Extinguishers	Safety Equipment System		2022		\$ 10,000	0.500	\$ 5,000	\$ 15,000	4
Miscellaneous	T-18HVAC01 HVAC Unit #1, Rooftop,Admin, Confer.Rm	Admin Bldg System - Mechanical		2027		\$ 20,000	2.350	\$ 47,000	\$ 67,000	5
Miscellaneous	T-18HVAC02 HVAC Unit #2, Rooftop,Admin, Control Rm	Admin Bldg System - Mechanical		2027		\$ 20,000	2.350	\$ 47,000	\$ 67,000	5
Miscellaneous	T-18HVAC03 HVAC Unit #3, Rooftop,Admin, Lab	Admin Bldg System - Bldg 18		2027		\$ 15,000	2.350	\$ 35,250	\$ 50,250	5
						\$ 7,022,700		\$ 11,914,595	\$ 18,662,295	



PROJECT MEMORANDUM

WRWTP – 2017 MPU

Date: March 30, 2018

Project No.: 10721.A00

Client Name

Prepared By: Meghann Chell

Reviewed By: Jude Grounds

Subject: Modification to OPCC and Cost Factoring Workbook

MWH Constructors prepared a Class 4/5 opinion of probably construction cost (OPCC) for capital improvement projects (CIPs) associated with the Willamette River Water Treatment Plant (WRWTP) 2017 Master Plan Update (2017 MPU). During the 2017 MPU review, there were several changes requested by the City of Wilsonville, plant operations staff (Veolia), or the project engineer (Carollo Engineers, Inc.) that required revisions to the OPCC.

The changes in the CIP table (Appendix E) that deviate from the OPCC are listed below. Note that Task #s indicated below are captured in the CIP Table; WBS #s indicated below are captured in the OPCC; CFW indicates that the item was estimated in the cost factoring workbook.

Additions

- Task # 173 (temporary pump station) was added to the 30 mgd expansion CIP for drinking water supply resiliency. Cost was estimated using the cost for two 15 mgd pumps and assuming no permanent structures would be necessary.
- Task #174 (tracer study) was added to the 20 mgd expansion CIP for support of the ozone coalition waiver. Cost was estimated at \$50,000 based on pricing for previous tracer studies performed at WRWTP.
- Tasks #141 through 172 (CFW) are assumed yearly maintenance assumptions for the fire alarm and sprinkler system, so they are applied annually in the repair and replace CIP.

Revisions

- Task #11 (CFW) was updated to reflect operator comment that the streaming current analyzer needs to be relocated to be used for chemical dosing. The equipment cost was multiplied by 3 to account for installation fees.
- Task #14 (WBS 69) was reduced by half to reflect operator input that one flash mix pump was recently replaced.
- Task #83 (WBS 22) was reduced by one-third to reflect operator comment that only two pumps (not three pumps) have Robocon VFDs.

Appendix E
CIP WORKBOOK

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK

CIP SUMMARY TABLE																	
CIP Project Stage #	CIP Project Stage	Type of Cost Projection	Estimated Construction Cost	Design + Admin Cost	Total Estimated Project Cost ⁽¹⁾	Project Completion Year	ENR @ Project Year	Future Value in Project Year - Escalation	Project Duration (Years)	Project Duration (Years)	Project Start Year	Design Duration (Months)	Construction Duration (Months)	Schedule Float (Months)	Design Start	Construction Start	Actual Project Cost
1	20 MGD Expansion	Escalation	\$ 12,580,000	\$ 3,150,000	\$ 15,730,000	2021		\$ 17,710,000	3	0	2018	12	18	6	2018	2019	\$ -
2	Life-Safety Repairs	Escalation	\$ 570,000	\$ 60,000	\$ 630,000	2022		\$ 720,000	2	0	2020	6	6	3	2020	2021	\$ -
3	Seismic Retrofits	Escalation	\$ 930,000	\$ 240,000	\$ 1,170,000	2022		\$ 1,340,000	2	0	2020	6	6	3	2020	2021	\$ -
4	30 MGD Expansion	Escalation	\$ 30,920,000	\$ 7,730,000	\$ 38,650,000	2034		\$ 63,870,000	3	0	2031	12	18	6	2031	2032	\$ -
TOTAL COSTS			\$ 45,020,000	\$ 11,170,000	\$ 56,190,000												

Notes:
 (1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration costs.
 (2) All costs in the CIP Summary table are rounded up to nearest \$10,000. For more detailed costs, see the CIP Full table.

Ongoing Repair and Replacement Activities Summary (by Project Completion Year)										
Type of Cost Projection		Escalation								
Construction Duration (months)		6								
Schedule Float (months)		6								
CIP Project Stage #	CIP Project Stage	Year	ENR @ Project Year	Estimated Construction Cost	Estimated Administrative Cost	Estimated Task Cost ⁽¹⁾	Future Value in Project Year - Escalation	Admin Cost in Project Year - Escalation	Construction Cost in Project Year - Escalation	Actual Project Cost
5	Repair & Replace - Year 1	2019		\$ 1,360,000	\$ 140,000	\$ 1,500,000	\$ 1,590,000	\$ 160,000	\$ 1,430,000	\$ -
5	Repair & Replace - Year 2	2020		\$ 1,450,000	\$ 150,000	\$ 1,600,000	\$ 1,740,000	\$ 180,000	\$ 1,560,000	\$ -
5	Repair & Replace - Year 3	2021		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 4	2022		\$ 3,110,000	\$ 320,000	\$ 3,430,000	\$ 3,970,000	\$ 400,000	\$ 3,570,000	\$ -
5	Repair & Replace - Year 5	2023		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 6	2024		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 7	2025		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 8	2026		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 9	2027		\$ 4,740,000	\$ 480,000	\$ 5,220,000	\$ 7,010,000	\$ 710,000	\$ 6,300,000	\$ -
5	Repair & Replace - Year 10	2028		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 11	2029		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 12	2030		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 13	2031		\$ 20,000	\$ 10,000	\$ 30,000	\$ 20,000	\$ 10,000	\$ 10,000	\$ -
5	Repair & Replace - Year 14	2032		\$ 2,260,000	\$ 230,000	\$ 2,490,000	\$ 3,860,000	\$ 390,000	\$ 3,470,000	\$ -
5	Repair & Replace - Year 15	2033		\$ 20,000	\$ 10,000	\$ 30,000	\$ 30,000	\$ 10,000	\$ 20,000	\$ -
5	Repair & Replace - Year 16	2034		\$ 20,000	\$ 10,000	\$ 30,000	\$ 30,000	\$ 10,000	\$ 20,000	\$ -
5	Repair & Replace - Year 17	2035		\$ 20,000	\$ 10,000	\$ 30,000	\$ 30,000	\$ 10,000	\$ 20,000	\$ -
5	Repair & Replace - Year 18	2036		\$ 3,090,000	\$ 310,000	\$ 3,400,000	\$ 5,960,000	\$ 600,000	\$ 5,360,000	\$ -
5	Repair & Replace Total			\$ 16,130,000	\$ 1,610,000	\$ 17,740,000	\$ 24,320,000	\$ 2,210,000	\$ -	\$ -

Notes:
 (1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration
 (2) All costs in the CIP Summary table are rounded up to nearest \$10,000. For more detailed costs, see the CIP Full table.

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK

DETAIL CIP SUMMARY

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Type of Cost Projection	Estimated Design Cost	Estimated Administrative Cost	Estimated Total Cost ⁽¹⁾	Project Completion Year	ENR @ Project Year	Future Value in Project Year - Escalation	Future Design Cost - Escalation	Future Administrative Cost - Escalation	Design Duration (Months)	Construction Duration (Months)	Schedule Float (Months)	Design Start	Construction Start
1	20 MGD Expansion	Actiflo™	Install second flash mix pump to give system installed redundancy (1+1) rather than shelf spare.	\$ 169,791	Yes	Escalation	\$ 25,469	\$ 16,979	\$ 212,239	2021	0	\$ 238,877	\$ 28,665	\$ 19,110	12	18	6	2018	2019
2	20 MGD Expansion	Actiflo™	Purchase additional shelf spare solid pump	\$ 42,275	Yes	Escalation	\$ 6,341	\$ 4,228	\$ 52,844	2021	0	\$ 59,476	\$ 7,137	\$ 4,758	12	18	6	2018	2019
3	30 MGD Expansion	Actiflo™	Construct an additional Actiflo basin for the 30 MGD capacity upgrade. With the addition of a third basin, the WRWTP will have three 10 MGD basins and can run two basins at 15 MGD in the event one basin requires maintenance.	\$ 4,864,843	Yes	Escalation	\$ 729,726	\$ 486,484	\$ 6,081,054	2034	0	\$ 10,051,055	\$ 1,206,127	\$ 804,084	12	18	6	2031	2032
4	Life-Safety Repairs	Actiflo™	Exterior stair guardrail height is less than 42" and has no dedicated handrail. Replace with current code-compliant installation. (LS3)	\$ 6,427	No	Escalation	\$ -	\$ 643	\$ 7,070	2022	0	\$ 8,196	\$ -	\$ 745	6	6	3	2020	2021
5	Life-Safety Repairs	Actiflo™	Active leaks observed in the ozone gallery, creating a slip hazard. Pressure inject hydrophobic sealant into ozone leaks. Leaking joints may require negative side joint covers. (LS9)	\$ 36,136	No	Escalation	\$ -	\$ 3,614	\$ 39,750	2022	0	\$ 46,081	\$ -	\$ 4,189	6	6	3	2020	2021
6	Life-Safety Repairs	Actiflo™	The rated electrical service is 1200 amps or greater requiring two exits with panic hardware. Install panic hardware on doors. (LS4)	\$ 7,011	No	Escalation	\$ -	\$ 701	\$ 7,712	2022	0	\$ 8,940	\$ -	\$ 813	6	6	3	2020	2021
7	Life-Safety Repairs	Actiflo™	The west guardrail on top of the Actiflo™ tanks does not have continuous kickplates. Install new kickplates as required. (LS8)	\$ 2,305	No	Escalation	\$ -	\$ 231	\$ 2,536	2022	0	\$ 2,939	\$ -	\$ 267	6	6	3	2020	2021
8	Life-Safety Repairs	Actiflo™	Electrical outlets on gallery walls are in a wet area. Replace with GFCI protected outlets. (LS10)	\$ 2,425	No	Escalation	\$ -	\$ 243	\$ 2,668	2022	0	\$ 3,092	\$ -	\$ 281	6	6	3	2020	2021
9	Life-Safety Repairs	Actiflo™	The doors were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required at Actiflo™ building. (LS7)	\$ 33,171	No	Escalation	\$ -	\$ 3,317	\$ 36,488	2022	0	\$ 42,300	\$ -	\$ 3,845	6	6	3	2020	2021
10	Repair & Replace	Actiflo™	Replace the four hydrocyclones installed in the two existing Actiflo Basins	\$ 318,000	No	Escalation	\$ -	\$ 31,800	\$ 349,800	2020	0	\$ 382,236	\$ -	\$ 34,749	0	6	6	2019	2019
11	20 MGD Expansion	Actiflo™	Replace and reinstall existing streaming current analyzer on Actiflo inlet so it can be used for chemical dosing	\$ 70,500	Yes	Escalation	\$ 10,575	\$ 7,050	\$ 88,125	2020	0	\$ 96,297	\$ 11,556	\$ 7,704	12	18	6	2017	2018
12	Repair & Replace	Actiflo™	Replace lamella settling tubes in the two existing Actiflo basins, which are damaged due to UV exposure.	\$ 245,656	No	Escalation	\$ -	\$ 24,566	\$ 270,222	2020	0	\$ 295,278	\$ -	\$ 26,843	0	6	6	2019	2019
13	Repair & Replace	Actiflo™	Upgrade vendor PLC components in the two existing Actiflo basins	\$ 62,108	No	Escalation	\$ -	\$ 6,211	\$ 68,319	2022	0	\$ 79,200	\$ -	\$ 7,200	0	6	6	2021	2021
14	Repair & Replace	Actiflo™	Replace the two flash mix pumps (installed and standby)	\$ 188,760	No	Escalation	\$ -	\$ 18,876	\$ 207,636	2020	0	\$ 226,889	\$ -	\$ 20,626	0	6	6	2019	2019
15	Repair & Replace	Actiflo™	Replace the six mixers installed in the two existing Actiflo Basins	\$ 302,400	No	Escalation	\$ -	\$ 30,240	\$ 332,640	2022	0	\$ 385,621	\$ -	\$ 35,056	0	6	6	2021	2021
16	Repair & Replace	Actiflo™	Replace the two sample pumps installed in the two existing Actiflo Basins	\$ 46,051	No	Escalation	\$ -	\$ 4,605	\$ 50,656	2022	0	\$ 58,724	\$ -	\$ 5,339	0	6	6	2021	2021
17	Repair & Replace	Actiflo™	Replace original dry polymer batching system (T-13ME01)	\$ 198,750	No	Escalation	\$ -	\$ 19,875	\$ 218,625	2027	0	\$ 293,814	\$ -	\$ 26,710	0	6	6	2026	2026
18	Repair & Replace	Actiflo™	PLC upgrade for Actiflo Local Control Panels	\$ 84,000	No	Escalation	\$ -	\$ 8,400	\$ 92,400	2027	0	\$ 124,178	\$ -	\$ 11,289	0	6	6	2026	2026
19	Repair & Replace	Actiflo™	Replace existing streaming current analyzer on Actiflo inlet	\$ 23,500	No	Escalation	\$ -	\$ 2,350	\$ 25,850	2036	0	\$ 45,328	\$ -	\$ 4,121	0	6	6	2035	2035
20	Repair & Replace	Actiflo™	Replace the five solids pumps (installed and standby) on the existing Actiflo basins	\$ 640,000	No	Escalation	\$ -	\$ 64,000	\$ 704,000	2036	0	\$ 1,234,468	\$ -	\$ 112,224	0	6	6	2035	2035
21	30 MGD Expansion	Actiflo™	Replace the two installed flash mix pumps	\$ 378,229	Yes	Escalation	\$ 56,734	\$ 37,823	\$ 472,786	2034	0	\$ 781,444	\$ 93,773	\$ 62,515	12	18	6	2031	2032
22	Repair & Replace	Actiflo™	Replace the six mixers installed in the two existing Actiflo Basins	\$ 302,400	No	Escalation	\$ -	\$ 30,240	\$ 332,640	2036	0	\$ 583,286	\$ -	\$ 53,026	0	6	6	2035	2035
23	Repair & Replace	Actiflo™	Replace the four hydrocyclones installed in the two existing Actiflo Basins	\$ 369,000	No	Escalation	\$ -	\$ 36,900	\$ 405,900	2036	0	\$ 711,748	\$ -	\$ 64,704	0	6	6	2035	2035
24	20 MGD Expansion	Chemical Storage/Ozone Generation	Existing chemical lines are inaccessible south of the utilidor and cannot be inspected or replaced. Abandon existing lines in-place, extend utilidor to the southern end of the plant, and install chemical lines in the extended utilidor.	\$ 566,752	Yes	Escalation	\$ 85,013	\$ 56,675	\$ 708,440	2022	0	\$ 821,276	\$ 98,553	\$ 65,702	12	18	6	2019	2020
25	30 MGD Expansion	Chemical Storage/Ozone Generation	Replace existing 6,000 gallon LOX storage tank with larger tank (12,000 to 15,000 gallons) to ensure sufficient storage with 20 MGD plant capacity. Recommend purchasing LOX tank (rather than leasing from vendor) so LOX can be purchased from different vendors.	\$ 262,500	Yes	Escalation	\$ 39,375	\$ 26,250	\$ 328,125	2034	0	\$ 542,341	\$ 65,081	\$ 43,387	12	18	6	2031	2032
26	20 MGD Expansion	Chemical Storage/Ozone Generation	On existing hypochlorite system, add ventilation line that returns to tank to prevent offgassing to atmosphere.	\$ 7,144	Yes	Escalation	\$ 1,072	\$ 714	\$ 8,930	2021	0	\$ 10,051	\$ 1,206	\$ 804	12	18	6	2018	2019
27	20 MGD Expansion	Chemical Storage/Ozone Generation	On all existing chemical systems, add wye or basket strainers to all pump suction lines	\$ 10,978	Yes	Escalation	\$ 1,647	\$ 1,098	\$ 13,723	2021	0	\$ 15,445	\$ 1,853	\$ 1,236	12	18	6	2018	2019
28	30 MGD Expansion	Chemical Storage/Ozone Generation	Install a second dry polymer feeder to provide redundancy to plant chemical operations	\$ 240,000	Yes	Escalation	\$ 36,000	\$ 24,000	\$ 300,000	2034	0	\$ 495,854	\$ 59,503	\$ 39,668	12	18	6	2031	2032
29	30 MGD Expansion	Chemical Storage/Ozone Generation	Install a third 400 PPD ozone generator to support plant capacity expansion	\$ 1,193,917	Yes	Escalation	\$ 179,088	\$ 119,392	\$ 1,492,396	2034	0	\$ 2,466,704	\$ 296,004	\$ 197,336	12	18	6	2031	2032
30	30 MGD Expansion	Chemical Storage/Ozone Generation	Convert hypochlorite system from liquid chemical storage to dry sodium hypochlorite process system for increased storage capacity and plant resiliency.	\$ 637,883	Yes	Escalation	\$ 95,682	\$ 63,788	\$ 797,354	2034	0	\$ 1,317,904	\$ 158,149	\$ 105,432	12	18	6	2031	2032
31	30 MGD Expansion	Chemical Storage/Ozone Generation	Modify existing Chemical Storage Room to increase usable space for existing chemical systems. Recommendations include installation of roll-up door, removal of aqueous ammonia system, modifications necessary to expand hypochlorite system, and modifications to chemical containment to allow additional tanks.	\$ 160,350	Yes	Escalation	\$ 24,053	\$ 16,035	\$ 200,438	2034	0	\$ 331,293	\$ 39,755	\$ 26,503	12	18	6	2031	2032
32	Life-Safety Repairs	Chemical Storage/Ozone Generation	The chemical pipes that run through the center of the Chemical Storage Room are not seismically braced. Ozone and LOX piping in the Ozone Generation Room are not seismically braced. Provide seismic bracing for these lines. (LS19, LS20)	\$ 36,926	No	Escalation	\$ -	\$ 3,693	\$ 40,619	2022	0	\$ 47,088	\$ -	\$ 4,281	6	6	3	2020	2021
33	Life-Safety Repairs	Chemical Storage/Ozone Generation	Color-coded NFPA placards have faded. Replace all faded NFPA placards (LS2)	\$ 9,205	No	Escalation	\$ -	\$ 921	\$ 10,126	2022	0	\$ 11,738	\$ -	\$ 1,067	6	6	3	2020	2021
34	Life-Safety Repairs	Chemical Storage/Ozone Generation	Chemical Storage and Ozone Generation Rooms are Group H occupancy or rated electrical service of 1200 A. Install panic hardware on three exit doors in the chemical storage and ozone generation building. (LS4; LS5)	\$ 10,517	No	Escalation	\$ -	\$ 1,052	\$ 11,569	2022	0	\$ 13,411	\$ -	\$ 1,219	6	6	3	2020	2021
35	Life-Safety Repairs	Chemical Storage/Ozone Generation	Change swing direction on exit door between the ozone generation and administration building (LS5)	\$ 5,067	No	Escalation	\$ -	\$ 507	\$ 5,574	2022	0	\$ 6,461	\$ -	\$ 587	6	6	3	2020	2021
36	Life-Safety Repairs	Chemical Storage/Ozone Generation	Chemical lines pass above egress routes. Add containment pans to chemical conveyance lines that are located above doorways in the chemical storage and ozone generation building (LS6)	\$ 11,985	No	Escalation	\$ -	\$ 1,199	\$ 13,184	2022	0	\$ 15,283	\$ -	\$ 1,389	6	6	3	2020	2021

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK

DETAIL CIP SUMMARY

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Type of Cost Projection	Estimated Design Cost	Estimated Administrative Cost	Estimated Total Cost ⁽¹⁾	Project Completion Year	ENR @ Project Year	Future Value in Project Year - Escalation	Future Design Cost - Escalation	Future Administrative Cost - Escalation	Design Duration (Months)	Construction Duration (Months)	Schedule Float (Months)	Design Start	Construction Start
37	Life-Safety Repairs	Chemical Storage/Ozone Generation	Install emergency shut-off at the two other exits in the Ozone Generation Room exits (LS15)	\$ 11,664	No	Escalation	\$ -	\$ 1,166	\$ 12,830	2022	0	\$ 14,874	\$ -	\$ 1,352	6	6	3	2020	2021
38	Repair & Replace	Chemical Storage/Ozone Generation	Upgrade vendor PLC components in the existing dry polymer blending unit	\$ 22,060	No	Escalation	\$ -	\$ 2,206	\$ 24,266	2022	0	\$ 28,131	\$ -	\$ 2,557	0	6	6	2021	2021
40	Repair & Replace	Chemical Storage/Ozone Generation	Replate two existing 300 PPD ozone generators with 400 PPD units	\$ 1,752,000	No	Escalation	\$ -	\$ 175,200	\$ 1,927,200	2022	0	\$ 2,234,153	\$ -	\$ 203,105	0	6	6	2021	2021
41	20 MGD Expansion	Chemical Storage/Ozone Generation	Replace existing 4,400 gallon XLPE sodium hypochlorite tank with a 3,900 gallon tank	\$ 52,500	Yes	Escalation	\$ 7,875	\$ 5,250	\$ 65,625	2021	0	\$ 73,862	\$ 8,863	\$ 5,909	12	18	6	2018	2019
42	Repair & Replace	Chemical Storage/Ozone Generation	Inspect existing alum tank and repair as needed	\$ 52,500	No	Escalation	\$ -	\$ 5,250	\$ 57,750	2022	0	\$ 66,948	\$ -	\$ 6,086	0	6	6	2021	2021
43	Repair & Replace	Chemical Storage/Ozone Generation	Inspect existing caustic soda tank and repair as needed	\$ 52,500	No	Escalation	\$ -	\$ 5,250	\$ 57,750	2022	0	\$ 66,948	\$ -	\$ 6,086	0	6	6	2021	2021
44	Repair & Replace	Chemical Storage/Ozone Generation	Replace the LOX evaporator equipment	\$ 112,500	No	Escalation	\$ -	\$ 11,250	\$ 123,750	2036	0	\$ 216,996	\$ -	\$ 19,727	0	6	6	2035	2035
46	20 MGD Expansion	Electrical	Install 15 KV/1,200 A metering/distribution switchgear	\$ 4,147,606	Yes	Escalation	\$ 622,141	\$ 414,761	\$ 5,184,508	2021	0	\$ 5,835,209	\$ 700,225	\$ 466,817	12	18	6	2018	2019
47	20 MGD Expansion	Electrical	Install new 5,000 KVA transformer to control power distribution to raw and finished water pumps	\$ 180,000	Yes	Escalation	\$ 27,000	\$ 18,000	\$ 225,000	2021	0	\$ 253,239	\$ 30,389	\$ 20,259	12	18	6	2018	2019
48	20 MGD Expansion	Electrical	Rewire existing electrical system to install new switchgear and transformer, connect all raw and finished water pumps to new transformer, connect new 2 MW emergency generator to switchgear, and upgrade existing electrical connections as needed to support new layout.	\$ 285,988	Yes	Escalation	\$ 42,898	\$ 28,599	\$ 357,485	2021	0	\$ 402,353	\$ 48,282	\$ 32,188	12	18	6	2018	2019
49	20 MGD Expansion	Electrical	Replace existing 1 MW generator with 2 MW generator	\$ 4,014,088	Yes	Escalation	\$ 602,113	\$ 401,409	\$ 5,017,610	2021	0	\$ 5,647,364	\$ 677,684	\$ 451,789	12	18	6	2018	2019
60	30 MGD Expansion	Filters	Construct two new media filters to support plant expansion to 30 MGD	\$ 4,185,194	Yes	Escalation	\$ 627,779	\$ 418,519	\$ 5,231,493	2034	0	\$ 8,646,860	\$ 1,037,623	\$ 691,749	12	18	6	2031	2032
61	Life-Safety Repairs	Filters	Exterior stair guardrail height is less than 42" and has no dedicated handrail. Replace with current code-compliant installation. (LS3)	\$ 6,427	No	Escalation	\$ -	\$ 643	\$ 7,070	2022	0	\$ 8,196	\$ -	\$ 745	6	6	3	2020	2021
62	Life-Safety Repairs	Filters	Active leaks observed in the ozone gallery, creating a slip hazard. Pressure inject hydrophobic sealant into active leaks. Leaking joints may require negative side joint covers. (LS9)	\$ 34,854	No	Escalation	\$ -	\$ 3,485	\$ 38,339	2022	0	\$ 44,446	\$ -	\$ 4,041	6	6	3	2020	2021
63	Life-Safety Repairs	Filters	The west guardrail on top of the the Filter ladder pit does not have continuous kickplates. Install new kickplates as required. (LS8)	\$ 2,305	No	Escalation	\$ -	\$ 231	\$ 2,536	2022	0	\$ 2,939	\$ -	\$ 267	6	6	3	2020	2021
64	Life-Safety Repairs	Filters	Electrical outlets on gallery walls are in a wet area. Replace with GFCI protected outlets. (LS10)	\$ 4,851	No	Escalation	\$ -	\$ 485	\$ 5,336	2022	0	\$ 6,186	\$ -	\$ 562	6	6	3	2020	2021
65	Life-Safety Repairs	Filters	Add a fire-rated door at the bottom of the filter gallery stairs and add signage to existing ladder pit door to clarify that it is not an exit. (LS12)	\$ 3,505	No	Escalation	\$ -	\$ 351	\$ 3,856	2022	0	\$ 4,470	\$ -	\$ 406	6	6	3	2020	2021
66	Life-Safety Repairs	Filters	The doors for various rooms were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required in the air scour blower room. (LS7)	\$ 43,493	No	Escalation	\$ -	\$ 4,349	\$ 47,842	2022	0	\$ 55,462	\$ -	\$ 5,042	6	6	3	2020	2021
68	Repair & Replace	Filters	Replace existing air scour blowers and motors on existing media filtration system	\$ 351,000	No	Escalation	\$ -	\$ 35,100	\$ 386,100	2022	0	\$ 447,596	\$ -	\$ 40,691	0	6	6	2021	2021
69	20 MGD Expansion	Filters	Upgrade electrical wiring as necessary to support plant-wide electrical upgrades	\$ 238,323	Yes	Escalation	\$ 35,748	\$ 23,832	\$ 297,904	2021	0	\$ 335,293	\$ 40,235	\$ 26,823	12	18	6	2018	2019
73	Repair & Replace	Filters	Replace aging MCC in existing filter gallery	\$ 70,000	No	Escalation	\$ -	\$ 7,000	\$ 77,000	2036	0	\$ 135,020	\$ -	\$ 12,275	0	6	6	2035	2035
74	Repair & Replace	Filters	Replace air scour blowers and motors on existing media filtration system	\$ 402,000	No	Escalation	\$ -	\$ 40,200	\$ 442,200	2036	0	\$ 775,400	\$ -	\$ 70,491	0	6	6	2035	2035
75	20 MGD Expansion	Finished Water Pump Station	Replace existing 4 MGD pump with 7.5 MGD pump to ensure plant meets 20 MGD firm capacity. Alternately, install a fifth pump that is at least 5 MGD.	\$ 1,212,081	Yes	Escalation	\$ 181,812	\$ 121,208	\$ 1,515,101	2021	0	\$ 1,705,260	\$ 204,631	\$ 136,421	12	18	6	2018	2019
76	30 MGD Expansion	Finished Water Pump Station	Upgrade three existing 7.5 MGD finished water pumps with three 12 MGD pumps	\$ 4,896,098	Yes	Escalation	\$ 734,415	\$ 489,610	\$ 6,120,123	2034	0	\$ 10,115,630	\$ 1,213,876	\$ 809,250	12	18	6	2031	2032
77	30 MGD Expansion	Finished Water Pump Station	Install a fifth finished water pump as part of the 30 MGD upgrade. Recommend 7.5 MGD pump (only valid if not installed during 20 MGD expansion)	\$ 1,185,023	Yes	Escalation	\$ 177,753	\$ 118,502	\$ 1,481,279	2034	0	\$ 2,448,328	\$ 293,799	\$ 195,866	12	18	6	2031	2032
79	Life-Safety Repairs	Finished Water Pump Station	The cable trays lack longitudinal bracing. Add bracing to existing cable trays. (LS18)	\$ 14,553	No	Escalation	\$ -	\$ 1,455	\$ 16,008	2022	0	\$ 18,558	\$ -	\$ 1,687	6	6	3	2020	2021
80	Life-Safety Repairs	Finished Water Pump Station	The rated electrical service is 1200 amps or greater requiring two exits with panic hardware. Install panic hardware on doors. (LS4)	\$ 7,011	No	Escalation	\$ -	\$ 701	\$ 7,712	2022	0	\$ 8,940	\$ -	\$ 813	6	6	3	2020	2021
81	Life-Safety Repairs	Finished Water Pump Station	The doors for various rooms were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required in the finished water pump station. (LS7)	\$ 81,982	No	Escalation	\$ -	\$ 8,198	\$ 90,180	2022	0	\$ 104,544	\$ -	\$ 9,504	6	6	3	2020	2021
82	Life-Safety Repairs	Finished Water Pump Station	Switchgear Room has rated electrical service is 1200 amps or greater requiring two exits with panic hardware. Install panic hardware on doors. (LS4)	\$ 7,011	No	Escalation	\$ -	\$ 701	\$ 7,712	2022	0	\$ 8,940	\$ -	\$ 813	6	6	3	2020	2021
83	Repair & Replace	Finished Water Pump Station	Replace VFDs on three Finished Water Pumps	\$ 596,336	No	Escalation	\$ -	\$ 59,634	\$ 655,970	2019	0	\$ 695,918	\$ -	\$ 63,265	0	6	6	2018	2018
84	Repair & Replace	Finished Water Pump Station	Replace existing soft-start controller on High Service Pump 3	\$ 84,000	No	Escalation	\$ -	\$ 8,400	\$ 92,400	2027	0	\$ 124,178	\$ -	\$ 11,289	0	6	6	2026	2026
85	Repair & Replace	Finished Water Pump Station	Replace two existing backwash supply pumps in the Wastewater Equalization Basin	\$ 1,980,000	No	Escalation	\$ -	\$ 198,000	\$ 2,178,000	2032	0	\$ 3,393,253	\$ -	\$ 308,478	0	6	6	2031	2031
86	Seismic Retrofits	Finished Water Pump Station	The roof joist wall anchorage along the east and west walls of the High Service PS have a DCR of 1.55. Add new wall anchorage along the east and west walls between the existing roof joists. (S3)	\$ 144,364	Yes	Escalation	\$ 21,655	\$ 14,436	\$ 180,455	2022	0	\$ 209,197	\$ 25,104	\$ 16,736	6	6	3	2020	2021
87	Seismic Retrofits	Finished Water Pump Station	The roof diaphragm shear at the High Service PS has a DCR of 1.82 to 2.25. Replace existing deficient deck sections with 16 GA corrugated steel decking. (S4)	\$ 125,618	Yes	Escalation	\$ 18,843	\$ 12,562	\$ 157,023	2022	0	\$ 182,032	\$ 21,844	\$ 14,563	6	6	3	2020	2021

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK

DETAIL CIP SUMMARY

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Type of Cost Projection	Estimated Design Cost	Estimated Administrative Cost	Estimated Total Cost ⁽¹⁾	Project Completion Year	ENR @ Project Year	Future Value in Project Year - Escalation	Future Design Cost - Escalation	Future Administrative Cost - Escalation	Design Duration (Months)	Construction Duration (Months)	Schedule Float (Months)	Design Start	Construction Start
88	Seismic Retrofits	Finished Water Pump Station	Tension capacity of the diaphragm chords at the High Service PS has a DCR of 1.20 at connections at the east windows. Strengthen chord splices as required. (S5)	\$ 12,159	Yes	Escalation	\$ 1,824	\$ 1,216	\$ 15,199	2022	0	\$ 17,620	\$ 2,114	\$ 1,410	6	6	3	2020	2021
89	Seismic Retrofits	Finished Water Pump Station	Roof deck shear transfer to interior wall ledger bolts at the High Service PS have DCR's of 3.20 to 3.90. Add new top plate over exterior shear wall and install epoxied anchors. (S6)	\$ 87,647	Yes	Escalation	\$ 13,147	\$ 8,765	\$ 109,559	2022	0	\$ 127,009	\$ 15,241	\$ 10,161	6	6	3	2020	2021
92	Repair & Replace	Miscellaneous	Replace the existing safety and warning signs throughout the site	\$ 15,000	No	Escalation	\$ -	\$ 1,500	\$ 16,500	2022	0	\$ 19,128	\$ -	\$ 1,739	0	6	6	2021	2021
93	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2020	0	\$ 8,414	\$ -	\$ 765	0	6	6	2019	2019
94	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2020	0	\$ 5,259	\$ -	\$ 478	0	6	6	2019	2019
95	Repair & Replace	Miscellaneous	Upgrade site security monitoring system camera and computer	\$ 23,500	No	Escalation	\$ -	\$ 2,350	\$ 25,850	2020	0	\$ 28,247	\$ -	\$ 2,568	0	6	6	2019	2019
96	Repair & Replace	Miscellaneous	Replace sitewide fire extinguishers	\$ 15,000	No	Escalation	\$ -	\$ 1,500	\$ 16,500	2022	0	\$ 19,128	\$ -	\$ 1,739	0	6	6	2021	2021
97	Repair & Replace	Miscellaneous	Replace the two existing irrigation waste pumps (T-30P01/2)	\$ 340,000	No	Escalation	\$ -	\$ 34,000	\$ 374,000	2022	0	\$ 433,569	\$ -	\$ 39,415	0	6	6	2021	2021
98	Repair & Replace	Miscellaneous	Replace the two existing water feature pumps (T-30P01/2)	\$ 340,000	No	Escalation	\$ -	\$ 34,000	\$ 374,000	2027	0	\$ 502,625	\$ -	\$ 45,693	0	6	6	2026	2026
99	20 MGD Expansion	Miscellaneous	Replace two existing rooftop HVAC units in the Administration Building (Conference Room and Control Room) and repair ventilation in Laboratory (T-18HVAC01 through 3)	\$ 184,250	Yes	Escalation	\$ 27,638	\$ 18,425	\$ 230,313	2019	0	\$ 244,339	\$ 29,321	\$ 19,547	12	18	6	2016	2017
100	20 MGD Expansion	Ozonation	Replace the diffusers in the two existing ozone basins to support 30 MGD capacity expansion	\$ 73,000	Yes	Escalation	\$ 10,950	\$ 7,300	\$ 91,250	2021	0	\$ 102,703	\$ 12,324	\$ 8,216	12	18	6	2018	2019
101	30 MGD Expansion	Ozonation	Construct a third ozone basin and gallery to support 30 MGD expansion	\$ 3,420,955	Yes	Escalation	\$ 513,143	\$ 342,096	\$ 4,276,194	2034	0	\$ 7,067,897	\$ 848,148	\$ 565,432	12	18	6	2031	2032
102	Life-Safety Repairs	Ozonation	The ozone destruct pipe on the top side is not seismically braced or marked. Add chemical service label and provide seismic bracing down to the concrete deck. (LS17)	\$ 11,809	No	Escalation	\$ -	\$ 1,181	\$ 12,990	2022	0	\$ 15,059	\$ -	\$ 1,369	6	6	3	2020	2021
103	Life-Safety Repairs	Ozonation	Exterior stair guardrail height is less than 42" and has no dedicated handrail. Replace with current code-compliant installation. (LS3)	\$ 6,427	No	Escalation	\$ -	\$ 643	\$ 7,070	2022	0	\$ 8,196	\$ -	\$ 745	6	6	3	2020	2021
104	Life-Safety Repairs	Ozonation	Active leaks observed in the ozone gallery, creating a slip hazard. Pressure inject hydrophobic sealant into active leaks. Leaking joints may require negative side joint covers. (LS9)	\$ 44,468	No	Escalation	\$ -	\$ 4,447	\$ 48,915	2022	0	\$ 56,706	\$ -	\$ 5,155	6	6	3	2020	2021
105	Life-Safety Repairs	Ozonation	Electrical outlets on gallery walls are in a wet area. Replace with GFCI protected outlets. (LS10)	\$ 2,425	No	Escalation	\$ -	\$ 243	\$ 2,668	2022	0	\$ 3,092	\$ -	\$ 281	6	6	3	2020	2021
106	Life-Safety Repairs	Ozonation	The south stairwell does not have any ventilation system serving it directly. Investigate and repair as required. (LS11)	\$ 10,499	No	Escalation	\$ -	\$ 1,050	\$ 11,549	2022	0	\$ 13,388	\$ -	\$ 1,217	6	6	3	2020	2021
107	20 MGD Expansion	Raw Water Pump Station	Replace existing 4 MGD pump with 7.5 MGD pump to ensure plant meets 20 MGD firm capacity with three dedicated pumps	\$ 665,000	Yes	Escalation	\$ 99,750	\$ 66,500	\$ 831,250	2021	0	\$ 935,579	\$ 112,270	\$ 74,846	12	18	6	2018	2019
108	30 MGD Expansion	Raw Water Pump Station	Replace two existing 7.5 MGD pumps with 15 MGD pumps	\$ 1,772,847	Yes	Escalation	\$ 265,927	\$ 177,285	\$ 2,216,059	2034	0	\$ 3,662,807	\$ 439,537	\$ 293,025	12	18	6	2031	2032
109	Repair & Replace	Raw Water Pump Station	Replace existing raw water sump pump	\$ 100,000	No	Escalation	\$ -	\$ 10,000	\$ 110,000	2020	0	\$ 120,200	\$ -	\$ 10,927	0	6	6	2019	2019
110	Repair & Replace	Raw Water Pump Station	Replace obsolete Robocon VFDs on three Raw Water Pumps	\$ 97,375	No	Escalation	\$ -	\$ 9,738	\$ 107,113	2019	0	\$ 113,636	\$ -	\$ 10,331	0	6	6	2018	2018
111	Repair & Replace	Raw Water Pump Station	Replace two existing Air Burst Compressors	\$ 395,000	No	Escalation	\$ -	\$ 39,500	\$ 434,500	2027	0	\$ 583,932	\$ -	\$ 53,085	0	6	6	2026	2026
112	Repair & Replace	Raw Water Pump Station	Replace existing air burst control panel PLC and local control panel	\$ 42,375	No	Escalation	\$ -	\$ 4,238	\$ 46,613	2027	0	\$ 62,643	\$ -	\$ 5,695	0	6	6	2026	2026
113	Repair & Replace	Raw Water Pump Station	Replace the existing constant-speed 7.5 MGD pump with a VFD-controlled pump	\$ 682,500	No	Escalation	\$ -	\$ 68,250	\$ 750,750	2036	0	\$ 1,316,445	\$ -	\$ 119,677	0	6	6	2035	2035
114	20 MGD Expansion	Sitewide	Sitewide lighting upgrade to support continued nighttime operations. For purpose of cost estimate, assuming that sitewide external lighting is replaced with high efficiency LED system.	\$ 156,532	Yes	Escalation	\$ 23,480	\$ 15,653	\$ 195,665	2021	0	\$ 220,223	\$ 26,427	\$ 17,618	12	18	6	2018	2019
115	Life-Safety Repairs	Sitewide	The space heaters throughout the plant are laterally braced above their center of gravity. The space heaters at the Switchgear Room are not braced. Provide additional seismic bracing to approximately eight locations. (LS16)	\$ 11,827	No	Escalation	\$ -	\$ 1,183	\$ 13,010	2022	0	\$ 15,082	\$ -	\$ 1,371	6	6	3	2020	2021
116	Life-Safety Repairs	Sitewide	Tread plate hatches do not have provisions for installing temporary fall protection barriers. Install sleeves or other hardware for temporary fall protection. (LS1)	\$ 42,284	No	Escalation	\$ -	\$ 4,228	\$ 46,512	2022	0	\$ 53,921	\$ -	\$ 4,902	6	6	3	2020	2021
117	Repair & Replace	Sitewide	Replace obsolete ABB magnetic flow meters installed throughout the WRWTP and at Wilsonville Road	\$ 662,400	No	Escalation	\$ -	\$ 66,240	\$ 728,640	2019	0	\$ 773,014	\$ -	\$ 70,274	0	6	6	2018	2018
118	30 MGD Expansion	Solids - Dewatering	Install a third 60 GPM centrifuge and solids transfer pump to support the 30 MGD plant expansion	\$ 1,665,316	Yes	Escalation	\$ 249,797	\$ 166,532	\$ 2,081,645	2034	0	\$ 3,440,642	\$ 412,877	\$ 275,251	12	18	6	2031	2032
119	Life-Safety Repairs	Solids - Dewatering	The Solids Handling Building roof does not appear to have an overflow scupper. Provide an overflow scupper with downspout. (LS14)	\$ 8,855	No	Escalation	\$ -	\$ 886	\$ 9,741	2022	0	\$ 11,292	\$ -	\$ 1,027	6	6	3	2020	2021
120	Repair & Replace	Solids - Dewatering	Replace the existing dewatered sludge screw conveyor in the Solids Handling Building	\$ 87,000	No	Escalation	\$ -	\$ 8,700	\$ 95,700	2022	0	\$ 110,943	\$ -	\$ 10,086	0	6	6	2021	2021
121	Repair & Replace	Solids - Dewatering	Replace two existing 60 GPM centrifuges and transfer pumps	\$ 3,500,000	No	Escalation	\$ -	\$ 350,000	\$ 3,850,000	2027	0	\$ 5,174,078	\$ -	\$ 470,371	0	6	6	2026	2026
122	Repair & Replace	Solids - Dewatering	Replace existing PLC and local control panel for two dewatering centrifuges	\$ 84,000	No	Escalation	\$ -	\$ 8,400	\$ 92,400	2027	0	\$ 124,178	\$ -	\$ 11,289	0	6	6	2026	2026
123	Repair & Replace	Solids - Dewatering	Replace two existing 60 GPM solids transfer pumps	\$ 316,059	No	Escalation	\$ -	\$ 31,606	\$ 347,665	2036	0	\$ 609,633	\$ -	\$ 55,421	0	6	6	2035	2035
124	Seismic Retrofits	Solids - Dewatering	The Solids Handling Building has no lateral load resisting system in the transverse direction at the lower level. Provide structural bracing in the east-west direction by installation of shear wall extensions or exterior steel bracing. (S7)	\$ 47,722	Yes	Escalation	\$ 7,158	\$ 4,772	\$ 59,653	2022	0	\$ 69,154	\$ 8,298	\$ 5,532	6	6	3	2020	2021
125	Seismic Retrofits	Solids - Dewatering	The roof joist wall anchorage along the east and west walls of the Solids Handling Building have a DCR of 1.17. Add new wall anchorage along the east and west walls between the existing roof joists. (S8)	\$ 62,761	Yes	Escalation	\$ 9,414	\$ 6,276	\$ 78,451	2022	0	\$ 90,947	\$ 10,914	\$ 7,276	6	6	3	2020	2021
126	Seismic Retrofits	Solids - Dewatering	The foundation elements at the Solids Handling Building do not have adequate ties. The floor slab is not doweled into the walls or the footings. Tie the existing slab to the walls with stainless steel angles and epoxy anchors. (S9)	\$ 24,672	Yes	Escalation	\$ 3,701	\$ 2,467	\$ 30,840	2022	0	\$ 35,752	\$ 4,290	\$ 2,860	6	6	3	2020	2021

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK

DETAIL CIP SUMMARY


P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Type of Cost Projection	Estimated Design Cost	Estimated Administrative Cost	Estimated Total Cost ⁽¹⁾	Project Completion Year	ENR @ Project Year	Future Value in Project Year - Escalation	Future Design Cost - Escalation	Future Administrative Cost - Escalation	Design Duration (Months)	Construction Duration (Months)	Schedule Float (Months)	Design Start	Construction Start
127	20 MGD Expansion	Solids - Gravity Thickener	To increase solids mixing redundancy, recommend purchasing and installing a second mixing pump to give 1+1 configuration	\$ 104,385	Yes	Escalation	\$ 15,658	\$ 10,439	\$ 130,481	2021	0	\$ 146,858	\$ 17,623	\$ 11,749	12	18	6	2018	2019
128	30 MGD Expansion	Solids - Gravity Thickener	Construct a second 35-ft diameter gravity thickener to support the 30 MGD plant expansion and provide solids handling redundancy	\$ 870,475	Yes	Escalation	\$ 130,571	\$ 87,048	\$ 1,088,094	2034	0	\$ 1,798,453	\$ 215,814	\$ 143,876	12	18	6	2031	2032
129	Repair & Replace	Solids - Gravity Thickener	Replace two existing sludge mixing pumps (one installed, one shelf spare)	\$ 260,000	No	Escalation	\$ -	\$ 26,000	\$ 286,000	2020	0	\$ 312,520	\$ -	\$ 28,411	0	6	6	2019	2019
130	Repair & Replace	Solids - Gravity Thickener	Replace the two existing sludge mixing pumps	\$ 260,000	No	Escalation	\$ -	\$ 26,000	\$ 286,000	2032	0	\$ 445,579	\$ -	\$ 40,507	0	6	6	2031	2031
131	Repair & Replace	Solids - Gravity Thickener	Replace the existing gravity thickener drive	\$ 114,264	No	Escalation	\$ -	\$ 11,426	\$ 125,690	2036	0	\$ 220,399	\$ -	\$ 20,036	0	6	6	2035	2035
132	30 MGD Expansion	WWEQ Basin	Install fourth washwater recycle pump for additional redundancy at 30 MGD expansion	\$ 281,250	Yes	Escalation	\$ 42,188	\$ 28,125	\$ 351,563	2034	0	\$ 581,079	\$ 69,730	\$ 46,486	12	18	6	2031	2032
133	Life-Safety Repairs	WWEQ Basin	Verify how fall restraint is provided when using the ladder into the waste washwater equalization basin and provide additional hardware as required. (LS13)	\$ 7,546	No	Escalation	\$ -	\$ 755	\$ 8,301	2022	0	\$ 9,623	\$ -	\$ 875	6	6	3	2020	2021
134	Life-Safety Repairs	WWEQ Basin	The doors for various rooms were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required at waste washwater equalization basin. (LS7)	\$ 35,168	No	Escalation	\$ -	\$ 3,517	\$ 38,685	2022	0	\$ 44,846	\$ -	\$ 4,077	6	6	3	2020	2021
135	Repair & Replace	WWEQ Basin	Replace three existing filter waste washwater recycle pumps	\$ 300,000	No	Escalation	\$ -	\$ 30,000	\$ 330,000	2020	0	\$ 360,600	\$ -	\$ 32,782	0	6	6	2019	2019
136	20 MGD Expansion	WWEQ Basin	Modifications necessary to support chemical pipelines along western WWEQ Basin wall	\$ 300,000	Yes	Escalation	\$ 45,000	\$ 30,000	\$ 375,000	2022	0	\$ 434,728	\$ 52,167	\$ 34,778	12	18	6	2019	2020
137	Repair & Replace	WWEQ Basin	Replace three existing filter waste washwater recycle pumps	\$ 43,036	No	Escalation	\$ -	\$ 4,304	\$ 47,340	2036	0	\$ 83,010	\$ -	\$ 7,546	0	6	6	2035	2035
138	Seismic Retrofits	WWEQ Basin	Waste Washwater EQ Basin North & South Walls: Horizontal reinforcing steel at east corners (#8 @ 12" OC) have a DCR of 1.53 for soil seismic loads. Recommend adding additional reinforced shotcrete to wall or adding three concrete/steel braces across the basin. (S1)	\$ 219,386	Yes	Escalation	\$ 32,908	\$ 21,939	\$ 274,233	2022	0	\$ 317,911	\$ 38,149	\$ 25,433	6	6	3	2020	2021
139	Seismic Retrofits	WWEQ Basin	Waste Washwater EQ Basin North & South Walls: Wall shear at the concrete beam has a DCR of 1.67 for soil seismic loads. Recommend addition of reinforced shotcrete to wall or addition of concrete/steel braces across the basin. (S2)	\$ 197,164	Yes	Escalation	\$ 29,575	\$ 19,716	\$ 246,455	2022	0	\$ 285,709	\$ 34,285	\$ 22,857	6	6	3	2020	2021
140	20 MGD Expansion	Chemical Storage/Ozone Generation	Replace 6,000-gallon rented LOX tank with larger tank	\$ 88,917	Yes	Escalation	\$ 13,338	\$ 8,892	\$ 111,146	2021	0	\$ 125,096	\$ 15,012	\$ 10,008	12	18	6	2018	2019
141	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2021	0	\$ 8,666	\$ -	\$ 788	0	6	6	2020	2020
142	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2021	0	\$ 5,417	\$ -	\$ 492	0	6	6	2020	2020
143	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2022	0	\$ 8,926	\$ -	\$ 811	0	6	6	2021	2021
144	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2022	0	\$ 5,579	\$ -	\$ 507	0	6	6	2021	2021
145	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2023	0	\$ 9,194	\$ -	\$ 836	0	6	6	2022	2022
146	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2023	0	\$ 5,746	\$ -	\$ 522	0	6	6	2022	2022
147	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2024	0	\$ 9,470	\$ -	\$ 861	0	6	6	2023	2023
148	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2024	0	\$ 5,919	\$ -	\$ 538	0	6	6	2023	2023
149	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2025	0	\$ 9,754	\$ -	\$ 887	0	6	6	2024	2024
150	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2025	0	\$ 6,096	\$ -	\$ 554	0	6	6	2024	2024
151	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2026	0	\$ 10,047	\$ -	\$ 913	0	6	6	2025	2025
152	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2026	0	\$ 6,279	\$ -	\$ 571	0	6	6	2025	2025
153	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2027	0	\$ 10,348	\$ -	\$ 941	0	6	6	2026	2026
154	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2027	0	\$ 6,468	\$ -	\$ 588	0	6	6	2026	2026
155	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2028	0	\$ 10,659	\$ -	\$ 969	0	6	6	2027	2027
156	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2028	0	\$ 6,662	\$ -	\$ 606	0	6	6	2027	2027
157	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2029	0	\$ 10,978	\$ -	\$ 998	0	6	6	2028	2028
158	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2029	0	\$ 6,861	\$ -	\$ 624	0	6	6	2028	2028
159	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2030	0	\$ 11,308	\$ -	\$ 1,028	0	6	6	2029	2029
160	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2030	0	\$ 7,067	\$ -	\$ 642	0	6	6	2029	2029
161	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2031	0	\$ 11,647	\$ -	\$ 1,059	0	6	6	2030	2030
162	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2031	0	\$ 7,279	\$ -	\$ 662	0	6	6	2030	2030
163	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2032	0	\$ 11,996	\$ -	\$ 1,091	0	6	6	2031	2031
164	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2032	0	\$ 7,498	\$ -	\$ 682	0	6	6	2031	2031
165	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2033	0	\$ 12,356	\$ -	\$ 1,123	0	6	6	2032	2032
166	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2033	0	\$ 7,723	\$ -	\$ 702	0	6	6	2032	2032
167	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2034	0	\$ 12,727	\$ -	\$ 1,157	0	6	6	2033	2033
168	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2034	0	\$ 7,954	\$ -	\$ 723	0	6	6	2033	2033
169	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2035	0	\$ 13,109	\$ -	\$ 1,192	0	6	6	2034	2034
170	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2035	0	\$ 8,193	\$ -	\$ 745	0	6	6	2034	2034
171	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	Escalation	\$ -	\$ 700	\$ 7,700	2036	0	\$ 13,502	\$ -	\$ 1,227	0	6	6	2035	2035
172	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	Escalation	\$ -	\$ 438	\$ 4,813	2036	0	\$ 8,439	\$ -	\$ 767	0	6	6	2035	2035
173	30 MGD Expansion	Finished Water Pump Station	Temporary pump station to supply 15 MGD from the WWSP Treatment Plant to the WRWTP distribution system in the event of a service disruption.	\$ 4,896,098	Yes	Escalation	\$ 734,415	\$ 489,610	\$ 6,120,123	2034	0	\$ 10,115,630	\$ 1,213,876	\$ 809,250	12	18	6	2031	2032
174	20 MGD Expansion	Finished Water Pump Station	Conduct tracer study in support of receiving OHA ozonation waiver	\$ 50,000	Yes	Escalation	\$ 7,500	\$ 5,000	\$ 62,500	2021	0	\$ 70,344	\$ 8,441	\$ 5,628	12	18	6	2018	2019
TOTAL COSTS				\$ 56,193,027					\$67,738,302										

Notes:
(1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration costs.

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 1

Project Title 20 MGD Expansion
Project Category Capacity Improvement
Project Description The existing treatment processes will be updated for the 20 mgd WRWTP expansion. For the primary treatment processes, the uprating will include the following:

- Increasing the Actiflo® flow rate from 7.5 mgd per basin to 10 mgd per basin.
- Increasing the ozonation basin flow rate from 7.5 mgd per basin to 10 mgd per basin. This will decrease the ozone contact time from 15 to 11 minutes, which still allows sufficient contact time for 1-log Cryptosporidium inactivation, provided increased levels of ozone can be dosed in the contactor.
- Increasing the filtration rate to a nominal rate of 5.7 gpm/sf and a maximum rate of 7.5 gpm/sf when one filter is off-line, and to a nominal rate of 7.5 gpm/sf and a maximum rate of 10 gpm/sf when one basin is offline. This increased filtration rate will require approval from OHA prior to increasing plant capacity. To support OHA approval, a full scale pilot study should be conducted in which the filtration rate is gradually increased and water quality is closely monitored.
- To meet the 2022 site capacity of nominally 20 mgd, the plant's electrical supply and distribution system will need significant upgrades. Preliminary engineering for the capacity expansion will require detailed analysis of electrical supply alternatives, including backup power requirements. Improving the "backbone" of electrical and standby power is recommended in parallel with the expansion project.



WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 1

Project Summary Table


P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Total Cost⁽¹⁾	Future Value in Project Year - Escalation	Actual Construction Cost
1	20 MGD Expansion	Actiflo™	Install second flash mix pump to give system installed redundancy (1+1) rather than shelf spare.	\$ 169,791	Yes	\$ 212,239	\$ 238,877	
2	20 MGD Expansion	Actiflo™	Purchase additional shelf spare solid pump	\$ 42,275	Yes	\$ 52,844	\$ 59,476	
11	20 MGD Expansion	Actiflo™	Replace and reinstall existing streaming current analyzer on Actiflo inlet so it can be used for chemical dosing	\$ 70,500	Yes	\$ 88,125	\$ 96,297	
24	20 MGD Expansion	Chemical Storage/Ozone Generation	Existing chemical lines are inaccessible south of the utilidor and cannot be inspected or replaced. Abandon existing lines in-place, extend utilidor to the southern end of the plant, and install chemical lines in the extended utilidor.	\$ 566,752	Yes	\$ 708,440	\$ 821,276	
26	20 MGD Expansion	Chemical Storage/Ozone Generation	On existing hypochlorite system, add ventilation line that returns to tank to prevent offgassing to atmosphere.	\$ 7,144	Yes	\$ 8,930	\$ 10,051	
27	20 MGD Expansion	Chemical Storage/Ozone Generation	On all existing chemical systems, add wye or basket strainers to all pump suction lines	\$ 10,978	Yes	\$ 13,723	\$ 15,445	
41	20 MGD Expansion	Chemical Storage/Ozone Generation	Replace existing 4,400 gallon XLPE sodium hypochlorite tank with a 3,900 gallon tank	\$ 52,500	Yes	\$ 65,625	\$ 73,862	
46	20 MGD Expansion	Electrical	Install 15 KV/1,200 A metering/distribution switchgear	\$ 4,147,606	Yes	\$5,184,508	\$ 5,835,209	
47	20 MGD Expansion	Electrical	Install new 5,000 KVA transformer to control power distribution to raw and finished water pumps	\$ 180,000	Yes	\$ 225,000	\$ 253,239	
48	20 MGD Expansion	Electrical	Rewire existing electrical system to install new switchgear and transformer, connect all raw and finished water pumps to new transformer, connect new 2 MW emergency generator to switchgear, and upgrade existing electrical connections as needed to support new layout.	\$ 285,988	Yes	\$ 357,485	\$ 402,353	
49	20 MGD Expansion	Electrical	Replace existing 1 MW generator with 2 MW generator	\$ 4,014,088	Yes	\$5,017,610	\$ 5,647,364	
69	20 MGD Expansion	Filters	Upgrade electrical wiring as necessary to support plant-wide electrical upgrades	\$ 238,323	Yes	\$ 297,904	\$ 335,293	
75	20 MGD Expansion	Finished Water Pump Station	Replace existing 4 MGD pump with 7.5 MGD pump to ensure plant meets 20 MGD firm capacity. Alternately, install a fifth pump that is at least 5 MGD.	\$ 1,212,081	Yes	\$1,515,101	\$ 1,705,260	
99	20 MGD Expansion	Miscellaneous	Replace two existing rooftop HVAC units in the Administration Building (Conference Room and Control Room) and repair ventilation in Laboratory (T-18HVAC01 through 3)	\$ 184,250	Yes	\$ 230,313	\$ 244,339	
100	20 MGD Expansion	Ozonation	Replace the diffusers in the two existing ozone basins to support 30 MGD capacity expansion	\$ 73,000	Yes	\$ 91,250	\$ 102,703	
107	20 MGD Expansion	Raw Water Pump Station	Replace existing 4 MGD pump with 7.5 MGD pump to ensure plant meets 20 MGD firm capacity with three dedicated pumps	\$ 665,000	Yes	\$ 831,250	\$ 935,579	
114	20 MGD Expansion	Sitewide	Sitewide lighting upgrade to support continued nighttime operations. For purpose of cost estimate, assuming that sitewide external lighting is replaced with high efficiency LED system.	\$ 156,532	Yes	\$ 195,665	\$ 220,223	
127	20 MGD Expansion	Solids - Gravity Thickener	To increase solids mixing redundancy, recommend purchasing and installing a second mixing pump to give 1+1 configuration	\$ 104,385	Yes	\$ 130,481	\$ 146,858	
136	20 MGD Expansion	WWEQ Basin	Modifications necessary to support chemical pipelines along western WWEQ Basin wall	\$ 300,000	Yes	\$ 375,000	\$ 434,728	
140	20 MGD Expansion	Chemical Storage/Ozone Generation	Replace 6,000-gallon rented LOX tank with larger tank	\$ 88,917	Yes	\$ 111,146	\$ 125,096	
174	20 MGD Expansion	Finished Water Pump Station	Conduct tracer study in support of receiving OHA ozonation waiver	\$ 50,000	Yes	\$ 62,500	\$ 70,344	

Notes:

(1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration costs.

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 2

Project Title Life-Safety Repairs
Project Category Renewal and Replacement
Project Description The preliminary life-safety analysis identified issues about building code compliance and structural improvements. This 2017 MPU recommends modifications to support worker safety after a catastrophic seismic event.



**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 2**

Project Summary Table

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost⁽¹⁾	Future Value in Project Year - Escalation	Actual Construction Cost
4	Life-Safety Repairs	Actiflo™	Exterior stair guardrail height is less than 42" and has no dedicated handrail. Replace with current code-compliant installation. (LS3)	\$ 6,427	No	\$ 7,070	\$ 8,196	
5	Life-Safety Repairs	Actiflo™	Active leaks observed in the ozone gallery, creating a slip hazard. Pressure inject hydrophobic sealant into active leaks. Leaking joints may require negative side joint covers. (LS9)	\$ 36,136	No	\$ 39,750	\$ 46,081	
6	Life-Safety Repairs	Actiflo™	The rated electrical service is 1200 amps or greater requiring two exits with panic hardware. Install panic hardware on doors. (LS4)	\$ 7,011	No	\$ 7,712	\$ 8,940	
7	Life-Safety Repairs	Actiflo™	The west guardrail on top of the Actiflo™ tanks does not have continuous kickplates. Install new kickplates as required. (LS8)	\$ 2,305	No	\$ 2,536	\$ 2,939	
8	Life-Safety Repairs	Actiflo™	Electrical outlets on gallery walls are in a wet area. Replace with GFCI protected outlets. (LS10)	\$ 2,425	No	\$ 2,668	\$ 3,092	
9	Life-Safety Repairs	Actiflo™	The doors were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required at Actiflo™ building. (LS7)	\$ 33,171	No	\$ 36,488	\$ 42,300	
32	Life-Safety Repairs	Chemical Storage/ Ozone Generation	The chemical pipes that run through the center of the Chemical Storage Room are not seismically braced. Ozone and LOX piping in the Ozone Generation Room are not seismically braced. Provide seismic bracing for these lines. (LS19, LS20)	\$ 36,926	No	\$ 40,619	\$ 47,088	
33	Life-Safety Repairs	Chemical Storage/ Ozone Generation	Color-coded NFPA placards have faded. Replace all faded NFPA placards (LS2)	\$ 9,205	No	\$ 10,126	\$ 11,738	
34	Life-Safety Repairs	Chemical Storage	Chemical Storage and Ozone Generation Rooms are Group H occupancy or rated electrical service of 1200 A. Install panic hardware on three exit doors in the chemical storage and ozone generation building. (LS4; LS5)	\$ 10,517	No	\$ 11,569	\$ 13,411	
35	Life-Safety Repairs	Chemical Storage	Change swing direction on exit door between the ozone generation and administration building (LS5)	\$ 5,067	No	\$ 5,574	\$ 6,461	
36	Life-Safety Repairs	Chemical Storage	Chemical lines pass above egress routes. Add containment pans to chemical conveyance lines that are located above doorways in the chemical storage and ozone generation building (LS6)	\$ 11,985	No	\$ 13,184	\$ 15,283	
37	Life-Safety Repairs	Chemical Storage	Install emergency shut-off at the two other exits in the Ozone Generation Room exits (LS15)	\$ 11,664	No	\$ 12,830	\$ 14,874	
61	Life-Safety Repairs	Filters	Exterior stair guardrail height is less than 42" and has no dedicated handrail. Replace with current code-compliant installation. (LS3)	\$ 6,427	No	\$ 7,070	\$ 8,196	
62	Life-Safety Repairs	Filters	Active leaks observed in the ozone gallery, creating a slip hazard. Pressure inject hydrophobic sealant into active leaks. Leaking joints may require negative side joint covers. (LS9)	\$ 34,854	No	\$ 38,339	\$ 44,446	
63	Life-Safety Repairs	Filters	The west guardrail on top of the the Filter ladder pit does not have continuous kickplates. Install new kickplates as required. (LS8)	\$ 2,305	No	\$ 2,536	\$ 2,939	
64	Life-Safety Repairs	Filters	Electrical outlets on gallery walls are in a wet area. Replace with GFCI protected outlets. (LS10)	\$ 4,851	No	\$ 5,336	\$ 6,186	
65	Life-Safety Repairs	Filters	Add a fire-rated door at the bottom of the filter gallery stairs and add signage to existing ladder pit door to clarify that it is not an exit. (LS12)	\$ 3,505	No	\$ 3,856	\$ 4,470	
66	Life-Safety Repairs	Filters	The doors for various rooms were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required in the air scour blower room. (LS7)	\$ 43,493	No	\$ 47,842	\$ 55,462	
79	Life-Safety Repairs	Finished Water Pump Station	The cable trays lack longitudinal bracing. Add bracing to existing cable trays. (LS18)	\$ 14,553	No	\$ 16,008	\$ 18,558	


WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 2

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost⁽¹⁾	Future Value in Project Year - Escalation	Actual Construction Cost
80	Life-Safety Repairs	Finished Water Pump Station	The rated electrical service is 1200 amps or greater requiring two exits with panic hardware. Install panic hardware on doors. (LS4)	\$ 7,011	No	\$ 7,712	\$ 8,940	
81	Life-Safety Repairs	Finished Water Pump Station	The doors for various rooms were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required in the finished water pump station. (LS7)	\$ 81,982	No	\$ 90,180	\$ 104,544	
82	Life-Safety Repairs	Finished Water Pump Station	Switchgear Room has rated electrical service is 1200 amps or greater requiring two exits with panic hardware. Install panic hardware on doors. (LS4)	\$ 7,011	No	\$ 7,712	\$ 8,940	
102	Life-Safety Repairs	Ozonation	The ozone destruct pipe on the top side is not seismically braced or marked. Add chemical service label and provide seismic bracing down to the concrete deck. (LS17)	\$ 11,809	No	\$ 12,990	\$ 15,059	
103	Life-Safety Repairs	Ozonation	Exterior stair guardrail height is less than 42" and has no dedicated handrail. Replace with current code-compliant installation. (LS3)	\$ 6,427	No	\$ 7,070	\$ 8,196	
104	Life-Safety Repairs	Ozonation	Active leaks observed in the ozone gallery, creating a slip hazard. Pressure inject hydrophobic sealant into active leaks. Leaking joints may require negative side joint covers. (LS9)	\$ 44,468	No	\$ 48,915	\$ 56,706	
105	Life-Safety Repairs	Ozonation	Electrical outlets on gallery walls are in a wet area. Replace with GFCI protected outlets. (LS10)	\$ 2,425	No	\$ 2,668	\$ 3,092	
106	Life-Safety Repairs	Ozonation	The south stairwell does not have any ventilation system serving it directly. Investigate and repair as required. (LS11)	\$ 10,499	No	\$ 11,549	\$ 13,388	
115	Life-Safety Repairs	Sitewide	The space heaters throughout the plant are laterally braced above their center of gravity. The space heaters at the Switchgear Room are not braced. Provide additional seismic bracing to approximately eight locations. (LS16)	\$ 11,827	No	\$ 13,010	\$ 15,082	
116	Life-Safety Repairs	Sitewide	Tread plate hatches do not have provisions for installing temporary fall protection barriers. Install sleeves or other hardware for temporary fall protection. (LS1)	\$ 42,284	No	\$ 46,512	\$ 53,921	
119	Life-Safety Repairs	Solids - Dewatering	The Solids Handling Building roof does not appear to have an overflow scupper. Provide an overflow scupper with downspout. (LS14)	\$ 8,855	No	\$ 9,741	\$ 11,292	
133	Life-Safety Repairs	WWEQ Basin	Verify how fall restraint is provided when using the ladder into the waste washwater equalization basin and provide additional hardware as required. (LS13)	\$ 7,546	No	\$ 8,301	\$ 9,623	
134	Life-Safety Repairs	WWEQ Basin	The doors for various rooms were propped open and appear to be their normal position. Suspect that ventilation in the room is not adequate. Investigate ventilation and correct as required at waste washwater equalization basin. (LS7)	\$ 35,168	No	\$ 38,685	\$ 44,846	

Notes:
(1) In 09/17 dollars. Assuming 10% for legal and administration costs.

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 3

Project Title Seismic Retrofits
Project Category Risk Mitigation
Project Description The preliminary structural analysis identified both structural and non-structural vulnerabilities that may affect plant performance in a regional catastrophic seismic event. We recommend including seismic retrofits to minimize infrastructure downtime and ensure plant performance after a catastrophic event.



**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 3**


Project Summary Table

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost⁽¹⁾	Future Value in Project Year - Escalation	Actual Construction Cost
86	Seismic Retrofits	Finished Water Pump Station	The roof joist wall anchorage along the east and west walls of the High Service PS have a DCR of 1.55. Add new wall anchorage along the east and west walls between the existing roof joists. (S3)	\$ 144,364	Yes	\$ 180,455	\$ 209,197	
87	Seismic Retrofits	Finished Water Pump Station	The roof diaphragm shear at the High Service PS has a DCR of 1.82 to 2.25. Replace existing deficient deck sections with 16 GA corrugated steel decking. (S4)	\$ 125,618	Yes	\$ 157,023	\$ 182,032	
88	Seismic Retrofits	Finished Water Pump Station	Tension capacity of the diaphragm chords at the High Service PS has a DCR of 1.20 at connections at the east windows. Strengthen chord splices as required. (S5)	\$ 12,159	Yes	\$ 15,199	\$ 17,620	
89	Seismic Retrofits	Finished Water Pump Station	Roof deck shear transfer to interior wall ledger bolts at the High Service PS have DCR's of 3.20 to 3.90. Add new top plate over exterior shear wall and install epoxied anchors. (S6)	\$ 87,647	Yes	\$ 109,559	\$ 127,009	
124	Seismic Retrofits	Solids - Dewatering	The Solids Handling Building has no lateral load resisting system in the transverse direction at the lower level. Provide structural bracing in the east-west direction by installation of shear wall extensions or exterior steel bracing. (S7)	\$ 47,722	Yes	\$ 59,653	\$ 69,154	
125	Seismic Retrofits	Solids - Dewatering	The roof joist wall anchorage along the east and west walls of the Solids Handling Building have a DCR of 1.17. Add new wall anchorage along the east and west walls between the existing roof joists. (S8)	\$ 62,761	Yes	\$ 78,451	\$ 90,947	
126	Seismic Retrofits	Solids - Dewatering	The foundation elements at the Solids Handling Building do not have adequate ties. The floor slab is not doweled into the walls or the footings. Tie the existing slab to the walls with stainless steel angles and epoxy anchors. (S9)	\$ 24,672	Yes	\$ 30,840	\$ 35,752	
138	Seismic Retrofits	WWEQ Basin	Waste Washwater EQ Basin North & South Walls: Horizontal reinforcing steel at east corners (#8 @ 12" OC) have a DCR of 1.53 for soil seismic loads. Recommend adding additional reinforced shotcrete to wall or adding three concrete/steel braces across the basin. (S1)	\$ 219,386	Yes	\$ 274,233	\$ 317,911	
139	Seismic Retrofits	WWEQ Basin	Waste Washwater EQ Basin North & South Walls: Wall shear at the concrete beam has a DCR of 1.67 for soil seismic loads. Recommend addition of reinforced shotcrete to wall or addition of concrete/steel braces across the basin. (S2)	\$ 197,164	Yes	\$ 246,455	\$ 285,709	
Notes:								
(1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration costs.								

**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 4**

Project Title 30 MGD Expansion
Project Category Capacity Improvement
Project Description To maximize the available space at the WRWTP with the goal of achieving a total capacity of 60 mgd in the existing site boundary, the 30-mgd capacity expansion will be designed based on updated process design criteria for the 20-mgd capacity expansion. This will allow the plant to maximize the available space at the WRWTP with the intention of achieving a total capacity of 60 mgd within the existing site boundary. Additionally, using the updated criteria will allow the WRWTP to deliver high-quality finished water to the cities of Wilsonville, Sherwood, and any potential distribution partners while minimizing rate increases. The 30 mgd expansion requires the following major construction projects:

- One Actiflo® basin.
- One ozonation basin.
- Two filters.
- One 35-foot diameter gravity thickener.



**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN WORKBOOK
PROJECT NO. 4**

Project Summary Table

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost ⁽¹⁾	Future Value in Project Year - Escalation	Actual Construction Cost
3	30 MGD Expansion	Actiflo™	Construct an additional Actiflo basin for the 30 MGD capacity upgrade. With the addition of a third basin, the WRWTP will have three 10 MGD basins and can run two basins at 15 MGD in the event one basin requires maintenance.	\$ 4,864,843	Yes	\$ 6,081,054	\$ 10,051,055	
21	30 MGD Expansion	Actiflo™	Replace the two installed flash mix pumps	\$ 378,229	Yes	\$ 472,786	\$ 781,444	
25	30 MGD Expansion	Chemical Storage/Ozone Generation	Replace existing 6,000 gallon LOX storage tank with larger tank (12,000 to 15,000 gallons) to ensure sufficient storage with 20 MGD plant capacity. Recommend purchasing LOX tank (rather than leasing from vendor) so LOX can be purchased from different vendors.	\$ 262,500	Yes	\$ 328,125	\$ 542,341	
28	30 MGD Expansion	Chemical Storage/Ozone Generation	Install a second dry polymer feeder to provide redundancy to plant chemical operations	\$ 240,000	Yes	\$ 300,000	\$ 495,854	
29	30 MGD Expansion	Chemical Storage/Ozone Generation	Install a third 400 PPD ozone generator to support plant capacity expansion	\$ 1,193,917	Yes	\$ 1,492,396	\$ 2,466,704	
30	30 MGD Expansion	Chemical Storage/Ozone Generation	Convert hypochlorite system from liquid chemical storage to dry sodium hypochlorite process system for increased storage capacity and plant resiliency.	\$ 637,883	Yes	\$ 797,354	\$ 1,317,904	
31	30 MGD Expansion	Chemical Storage/Ozone Generation	Modify existing Chemical Storage Room to increase usable space for existing chemical systems. Recommendations include installation of roll-up door, removal of aqueous ammonia system, modifications necessary to expand hypochlorite system, and modifications to chemical containment to allow additional tanks.	\$ 160,350	Yes	\$ 200,438	\$ 331,293	
60	30 MGD Expansion	Filters	Construct two new media filters to support plant expansion to 30 MGD	\$ 4,185,194	Yes	\$ 5,231,493	\$ 8,646,860	
76	30 MGD Expansion	Finished Water Pump Station	Upgrade three existing 7.5 MGD finished water pumps with three 12 MGD pumps	\$ 4,896,098	Yes	\$ 6,120,123	\$ 10,115,630	
77	30 MGD Expansion	Finished Water Pump Station	Install a fifth finished water pump as part of the 30 MGD upgrade. Recommend 7.5 MGD pump (only valid if not installed during 20 MGD expansion)	\$ 1,185,023	Yes	\$ 1,481,279	\$ 2,448,328	
101	30 MGD Expansion	Ozonation	Construct a third ozone basin and gallery to support 30 MGD expansion	\$ 3,420,955	Yes	\$ 4,276,194	\$ 7,067,897	
108	30 MGD Expansion	Raw Water Pump Station	Replace two existing 7.5 MGD pumps with 15 MGD pumps	\$ 1,772,847	Yes	\$ 2,216,059	\$ 3,662,807	
118	30 MGD Expansion	Solids - Dewatering	Install a third 60 GPM centrifuge and solids transfer pump to support the 30 MGD plant expansion	\$ 1,665,316	Yes	\$ 2,081,645	\$ 3,440,642	
128	30 MGD Expansion	Solids - Gravity Thickener	Construct a second 35-ft diameter gravity thickener to support the 30 MGD plant expansion and provide solids handling redundancy	\$ 870,475	Yes	\$ 1,088,094	\$ 1,798,453	
132	30 MGD Expansion	WWEQ Basin	Install fourth washwater recycle pump for additional redundancy at 30 MGD expansion	\$ 281,250	Yes	\$ 351,563	\$ 581,079	
173	30 MGD Expansion	Finished Water Pump Station	Temporary pump station to supply 15 MGD from the WWSP Treatment Plant to the WRWTP distribution system in the event of a service disruption.	\$ 4,896,098	Yes	\$ 6,120,123	\$ 10,115,630	
Notes:								
(1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration costs.								

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN UPDATE
PROJECT NO. 5

Project Title Operations - Repair & Replace
Project Category Renewal and Replacement
Project Description The WRWTP requires ongoing maintenance/repair and replacement (R&R) of its existing infrastructure to meet service goals. This 2017 MPU summarizes repair and replacement projects for the next 20 years.

Project Summary Table

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost ⁽¹⁾	Project Completion Year	Future Value in Project Year - Escalation	Actual Construction Cost
10	Repair & Replace	Actiflo™	Replace the four hydrocyclones installed in the two existing Actiflo Basins	\$ 318,000	No	\$ 349,800	2020	\$ 382,236	
12	Repair & Replace	Actiflo™	Replace lamella settling tubes in the two existing Actiflo basins, which are damaged due to UV exposure.	\$ 245,656	No	\$ 270,222	2020	\$ 295,278	
13	Repair & Replace	Actiflo™	Upgrade vendor PLC components in the two existing Actiflo basins	\$ 62,108	No	\$ 68,319	2022	\$ 79,200	
14	Repair & Replace	Actiflo™	Replace the two flash mix pumps (installed and standby)	\$ 188,760	No	\$ 207,636	2020	\$ 226,889	
15	Repair & Replace	Actiflo™	Replace the six mixers installed in the two existing Actiflo Basins	\$ 302,400	No	\$ 332,640	2022	\$ 385,621	
16	Repair & Replace	Actiflo™	Replace the two sample pumps installed in the two existing Actiflo Basins	\$ 46,051	No	\$ 50,656	2022	\$ 58,724	
17	Repair & Replace	Actiflo™	Replace original dry polymer batching system (T-13ME01)	\$ 198,750	No	\$ 218,625	2027	\$ 293,814	
18	Repair & Replace	Actiflo™	PLC upgrade for Actiflo Local Control Panels	\$ 84,000	No	\$ 92,400	2027	\$ 124,178	
19	Repair & Replace	Actiflo™	Replace existing streaming current analyzer on Actiflo inlet	\$ 23,500	No	\$ 25,850	2036	\$ 45,328	
20	Repair & Replace	Actiflo™	Replace the five solids pumps (installed and standby) on the existing Actiflo basins	\$ 640,000	No	\$ 704,000	2036	\$ 1,234,468	
22	Repair & Replace	Actiflo™	Replace the six mixers installed in the two existing Actiflo Basins	\$ 302,400	No	\$ 332,640	2036	\$ 583,286	
23	Repair & Replace	Actiflo™	Replace the four hydrocyclones installed in the two existing Actiflo Basins	\$ 369,000	No	\$ 405,900	2036	\$ 711,748	
38	Repair & Replace	Chemical Storage/ Ozone Generation	Upgrade vendor PLC components in the existing dry polymer blending unit	\$ 22,060	No	\$ 24,266	2022	\$ 28,131	
40	Repair & Replace	Chemical Storage/ Ozone Generation	Replate two existing 300 PPD ozone generators with 400 PPD units	\$ 1,752,000	No	\$ 1,927,200	2022	\$ 2,234,153	
42	Repair & Replace	Chemical Storage/ Ozone Generation	Inspect existing alum tank and repair as needed	\$ 52,500	No	\$ 57,750	2022	\$ 66,948	
43	Repair & Replace	Chemical Storage/ Ozone Generation	Inspect existing caustic soda tank and repair as needed	\$ 52,500	No	\$ 57,750	2022	\$ 66,948	
44	Repair & Replace	Chemical Storage/ Ozone Generation	Replace the LOX evaporator equipment	\$ 112,500	No	\$ 123,750	2036	\$ 216,996	
68	Repair & Replace	Filters	Replace existing air scour blowers and motors on existing media filtration system	\$ 351,000	No	\$ 386,100	2022	\$ 447,596	
73	Repair & Replace	Filters	Replace aging MCC in existing filter gallery	\$ 70,000	No	\$ 77,000	2036	\$ 135,020	
74	Repair & Replace	Filters	Replace air scour blowers and motors on existing media filtration system	\$ 402,000	No	\$ 442,200	2036	\$ 775,400	

**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN UPDATE
PROJECT NO. 5**

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost ⁽¹⁾	Project Completion Year	Future Value in Project Year - Escalation	Actual Construction Cost
83	Repair & Replace	Finished Water Pump Station	Replace VFDs on three Finished Water Pumps	\$ 596,336	No	\$ 655,970	2019	\$ 695,918	
84	Repair & Replace	Finished Water Pump Station	Replace existing soft-start controller on High Service Pump 3	\$ 84,000	No	\$ 92,400	2027	\$ 124,178	
85	Repair & Replace	Finished Water Pump Station	Replace two existing backwash supply pumps in the Wastewater Equalization Basin	\$ 1,980,000	No	\$ 2,178,000	2032	\$ 3,393,253	
92	Repair & Replace	Miscellaneous	Replace the existing safety and warning signs throughout the site	\$ 15,000	No	\$ 16,500	2022	\$ 19,128	
93	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2020	\$ 8,414	
94	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2020	\$ 5,259	
95	Repair & Replace	Miscellaneous	Upgrade site security monitoring system camera and computer	\$ 23,500	No	\$ 25,850	2020	\$ 28,247	
96	Repair & Replace	Miscellaneous	Replace sitewide fire extinguishers	\$ 15,000	No	\$ 16,500	2022	\$ 19,128	
97	Repair & Replace	Miscellaneous	Replace the two existing irrigation waste pumps (T-30P01/2)	\$ 340,000	No	\$ 374,000	2022	\$ 433,569	
98	Repair & Replace	Miscellaneous	Replace the two existing water feature pumps (T-30P01/2)	\$ 340,000	No	\$ 374,000	2027	\$ 502,625	
109	Repair & Replace	Raw Water Pump Station	Replace existing raw water sump pump	\$ 100,000	No	\$ 110,000	2020	\$ 120,200	
110	Repair & Replace	Raw Water Pump Station	Replace obsolete Robocon VFDs on three Raw Water Pumps	\$ 97,375	No	\$ 107,113	2019	\$ 113,636	
111	Repair & Replace	Raw Water Pump Station	Replace two existing Air Burst Compressors	\$ 395,000	No	\$ 434,500	2027	\$ 583,932	
112	Repair & Replace	Raw Water Pump Station	Replace existing air burst control panel PLC and local control panel	\$ 42,375	No	\$ 46,613	2027	\$ 62,643	
113	Repair & Replace	Raw Water Pump Station	Replace the existing constant-speed 7.5 MGD pump with a VFD-controlled pump	\$ 682,500	No	\$ 750,750	2036	\$ 1,316,445	
117	Repair & Replace	Sitewide	Replace obsolete ABB magnetic flow meters installed throughout the WRWTP and at Wilsonville Road	\$ 662,400	No	\$ 728,640	2019	\$ 773,014	
120	Repair & Replace	Solids - Dewatering	Replace the existing dewatered sludge screw conveyor in the Solids Handling Building	\$ 87,000	No	\$ 95,700	2022	\$ 110,943	
121	Repair & Replace	Solids - Dewatering	Replace two existing 60 GPM centrifuges and transfer pumps	\$ 3,500,000	No	\$ 3,850,000	2027	\$ 5,174,078	
122	Repair & Replace	Solids - Dewatering	Replace existing PLC and local control panel for two dewatering centrifuges	\$ 84,000	No	\$ 92,400	2027	\$ 124,178	
123	Repair & Replace	Solids - Dewatering	Replace two existing 60 GPM solids transfer pumps	\$ 316,059	No	\$ 347,665	2036	\$ 609,633	
129	Repair & Replace	Solids - Gravity Thickener	Replace two existing sludge mixing pumps (one installed, one shelf spare)	\$ 260,000	No	\$ 286,000	2020	\$ 312,520	
130	Repair & Replace	Solids - Gravity Thickener	Replace the two existing sludge mixing pumps	\$ 260,000	No	\$ 286,000	2032	\$ 445,579	
131	Repair & Replace	Solids - Gravity Thickener	Replace the existing gravity thickener drive	\$ 114,264	No	\$ 125,690	2036	\$ 220,399	
135	Repair & Replace	WWEQ Basin	Replace three existing filter waste washwater recycle pumps	\$ 300,000	No	\$ 330,000	2020	\$ 360,600	
137	Repair & Replace	WWEQ Basin	Replace three existing filter waste washwater recycle pumps	\$ 43,036	No	\$ 47,340	2036	\$ 83,010	

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
 CAPITAL IMPROVEMENT PLAN UPDATE
 PROJECT NO. 5

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost ⁽¹⁾	Project Completion Year	Future Value in Project Year - Escalation	Actual Construction Cost
141	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2021	\$ 8,666	
142	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2021	\$ 5,417	
143	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2022	\$ 8,926	
144	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2022	\$ 5,579	
145	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2023	\$ 9,194	
146	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2023	\$ 5,746	
147	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2024	\$ 9,470	
148	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2024	\$ 5,919	
149	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2025	\$ 9,754	
150	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2025	\$ 6,096	
151	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2026	\$ 10,047	
152	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2026	\$ 6,279	
153	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2027	\$ 10,348	
154	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2027	\$ 6,468	
155	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2028	\$ 10,659	
156	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2028	\$ 6,662	
157	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2029	\$ 10,978	
158	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2029	\$ 6,861	
159	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2030	\$ 11,308	
160	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2030	\$ 7,067	
161	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2031	\$ 11,647	
162	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2031	\$ 7,279	
163	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2032	\$ 11,996	
164	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2032	\$ 7,498	
165	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2033	\$ 12,356	

WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
 CAPITAL IMPROVEMENT PLAN UPDATE
 PROJECT NO. 5

P#	CIP Project Stage	System Name	CIP - Task Description	Estimated Construction Cost	Design Project?	Estimated Task Cost ⁽¹⁾	Project Completion Year	Future Value in Project Year - Escalation	Actual Construction Cost
166	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2033	\$ 7,723	
167	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2034	\$ 12,727	
168	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2034	\$ 7,954	
169	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2035	\$ 13,109	
170	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2035	\$ 8,193	
171	Repair & Replace	Miscellaneous	Annual maintenance on the existing site fire alarm	\$ 7,000	No	\$ 7,700	2036	\$ 13,502	
172	Repair & Replace	Miscellaneous	Annual maintenance on the existing site sprinkler system	\$ 4,375	No	\$ 4,813	2036	\$ 8,439	
Notes: (1) In 09/17 dollars. Assuming 15% contingency for Design and 10% for legal and administration costs.									

**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN UPDATE**

Financial Summary - CIP Costs in \$2017													
PROJECT	FY	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
20 MGD Expansion													
Design	\$	-	\$ 1,885,517	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ 419,004	\$ 419,004	\$ 419,004	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ 6,285,055	\$ 6,285,055	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ 2,304,520	\$ 6,704,059	\$ 6,704,059	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Life-Safety Repairs													
Design	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ -	\$ 28,007	\$ 28,007	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ -	\$ -	\$ 560,139	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ -	\$ -	\$ 28,007	\$ 588,146	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Seismic Retrofits													
Design	\$	-	\$ -	\$ -	\$ 138,224	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ -	\$ 46,075	\$ 46,075	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ -	\$ -	\$ 921,493	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ -	\$ -	\$ 184,299	\$ 967,568	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
30 MGD Expansion													
Design	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Repair & Replace													
Design	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ 135,611	\$ 144,729	\$ 1,138	\$ 310,899	\$ 1,138	\$ 1,138	\$ 1,138	\$ 1,138	\$ 473,950	\$ 1,138
Construction	\$	-	\$ -	\$ 1,356,111	\$ 1,447,291	\$ 11,375	\$ 3,108,994	\$ 11,375	\$ 11,375	\$ 11,375	\$ 11,375	\$ 4,739,500	\$ 11,375
Total	\$	-	\$ -	\$ 1,491,722	\$ 1,592,020	\$ 12,513	\$ 3,419,893	\$ 12,513	\$ 12,513	\$ 12,513	\$ 12,513	\$ 5,213,450	\$ 12,513
Total	\$	-	\$ 2,304,520	\$ 8,195,781	\$ 8,508,384	\$ 1,568,226	\$ 3,419,893	\$ 12,513	\$ 12,513	\$ 12,513	\$ 12,513	\$ 5,213,450	\$ 12,513
Stakeholders Resp.													
City of Wilsonville	\$	-	\$ 1,537,115	\$ 5,466,586	\$ 5,675,092	\$ 1,046,007	\$ 2,281,069	\$ 8,346	\$ 8,346	\$ 8,346	\$ 8,346	\$ 3,477,371	\$ 8,346
20 MGD Expansion	66.7%	\$ -	\$ 1,537,115	\$ 4,471,607	\$ 4,471,607	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Life Safety Repairs	66.7%	\$ -	\$ -	\$ -	\$ 18,681	\$ 392,293	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Seismic Retrofits	66.7%	\$ -	\$ -	\$ -	\$ 122,927	\$ 645,368	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
30 MGD Expansion	67.7%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Repair & Replace	66.7%	\$ -	\$ -	\$ 994,979	\$ 1,061,877	\$ 8,346	\$ 2,281,069	\$ 8,346	\$ 8,346	\$ 8,346	\$ 8,346	\$ 3,477,371	\$ 8,346
City of Sherwood	\$	-	\$ 767,405	\$ 2,729,195	\$ 2,833,292	\$ 522,219	\$ 1,138,825	\$ 4,167	\$ 4,167	\$ 4,167	\$ 4,167	\$ 1,736,079	\$ 4,167
20 MGD Expansion	33.3%	\$ -	\$ 767,405	\$ 2,232,452	\$ 2,232,452	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Life Safety Repairs	33.3%	\$ -	\$ -	\$ -	\$ 9,326	\$ 195,853	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Seismic Retrofits	33.3%	\$ -	\$ -	\$ -	\$ 61,371	\$ 322,200	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
30 MGD Expansion	32.3%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Repair & Replace	33.3%	\$ -	\$ -	\$ 496,743	\$ 530,143	\$ 4,167	\$ 1,138,825	\$ 4,167	\$ 4,167	\$ 4,167	\$ 4,167	\$ 1,736,079	\$ 4,167

Notes

- 1 For 20 MGD Expansion, Life Safety Repairs, Seismic Retrofits, and 30 MGD Expansion projects, all design costs were assumed to be in the first year of the project and the construction costs were split over the remaining project years.
- 2 For the Repair and Replace projects, the design and construction costs were assumed to be in the project completion year.

**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN UPDATE**

Financial Summary - CIP Costs in \$2017																			
PROJECT	FY	2029	2030	2031	2032	2033	2034	2035	2036		TOTAL								
20 MGD Expansion																			
Design	\$	-	\$	-	\$	-	\$	-	\$	-	\$	1,885,517							
Administration	\$	-	\$	-	\$	-	\$	-	\$	-	\$	1,257,011							
Construction	\$	-	\$	-	\$	-	\$	-	\$	-	\$	12,570,110							
Total	\$	-	\$	-	\$	-	\$	-	\$	-	\$	15,712,638							
Life-Safety Repairs																			
Design	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-							
Administration	\$	-	\$	-	\$	-	\$	-	\$	-	\$	56,014							
Construction	\$	-	\$	-	\$	-	\$	-	\$	-	\$	560,139							
Total	\$	-	\$	-	\$	-	\$	-	\$	-	\$	616,153							
Seismic Retrofits																			
Design	\$	-	\$	-	\$	-	\$	-	\$	-	\$	138,224							
Administration	\$	-	\$	-	\$	-	\$	-	\$	-	\$	92,149							
Construction	\$	-	\$	-	\$	-	\$	-	\$	-	\$	921,493							
Total	\$	-	\$	-	\$	-	\$	-	\$	-	\$	1,151,866							
30 MGD Expansion																			
Design	\$	-	\$	-	\$	4,636,647	\$	-	\$	-	\$	4,636,647							
Administration	\$	-	\$	-	\$	1,030,366	\$	1,030,366	\$	1,030,366	\$	3,091,098							
Construction	\$	-	\$	-	\$	15,455,489	\$	15,455,489	\$	-	\$	30,910,978							
Total	\$	-	\$	-	\$	5,667,013	\$	16,485,855	\$	16,485,855	\$	38,638,723							
Repair & Replace																			
Design	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-							
Administration	\$	1,138	\$	1,138	\$	1,138	\$	225,138	\$	1,138	\$	1,138	\$	308,663					
Construction	\$	11,375	\$	11,375	\$	11,375	\$	2,251,375	\$	11,375	\$	11,375	\$	3,086,634					
Total	\$	12,513	\$	12,513	\$	12,513	\$	2,476,513	\$	12,513	\$	12,513	\$	3,395,297					
Total	\$	12,513	\$	12,513	\$	5,679,525	\$	18,962,367	\$	16,498,367	\$	12,513	\$	12,513	\$	3,395,297	\$	73,858,425	
Stakeholders																			
	Resp.																		
City of Wilsonville		\$	8,346	\$	8,346	\$	3,844,913	\$	12,812,758	\$	11,169,270	\$	8,346	\$	8,346	\$	2,264,663	\$	48,112,842
20 MGD Expansion	66.7%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	8,943,214
Life Safety Repairs	66.7%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	410,974
Seismic Retrofits	66.7%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	768,295
30 MGD Expansion	67.7%	\$	-	\$	-	\$	3,836,568	\$	11,160,924	\$	11,160,924	\$	-	\$	-	\$	-	\$	26,158,415
Repair & Replace	66.7%	\$	8,346	\$	8,346	\$	8,346	\$	1,651,834	\$	8,346	\$	8,346	\$	8,346	\$	2,264,663	\$	11,831,943
City of Sherwood		\$	4,167	\$	4,167	\$	1,834,612	\$	6,149,610	\$	5,329,098	\$	4,167	\$	4,167	\$	1,130,634	\$	23,441,063
20 MGD Expansion	33.3%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	4,464,903
Life Safety Repairs	33.3%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	205,179
Seismic Retrofits	33.3%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	383,571
30 MGD Expansion	32.3%	\$	-	\$	-	\$	1,830,445	\$	5,324,931	\$	5,324,931	\$	-	\$	-	\$	-	\$	12,480,307
Repair & Replace	33.3%	\$	4,167	\$	4,167	\$	4,167	\$	824,679	\$	4,167	\$	4,167	\$	4,167	\$	1,130,634	\$	5,907,102
Notes																			
1 For 20 MGD Expansion, Life Safety Repair																			
2 For the Repair and Replace projects, the d																			

**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN UPDATE**

Financial Summary - CIP Costs in \$2017													
PROJECT	FY	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
20 MGD Expansion													
Design	\$	-	\$ 1,885,517	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ 419,004	\$ 419,004	\$ 419,004	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ 6,285,055	\$ 6,285,055	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ 2,304,520	\$ 6,704,059	\$ 6,704,059	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Life-Safety Repairs													
Design	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ -	\$ 28,007	\$ 28,007	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ -	\$ -	\$ 560,139	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ -	\$ -	\$ 28,007	\$ 588,146	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Seismic Retrofits													
Design	\$	-	\$ -	\$ -	\$ 138,224	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ -	\$ 46,075	\$ 46,075	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ -	\$ -	\$ 921,493	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ -	\$ -	\$ 184,299	\$ 967,568	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
30 MGD Expansion													
Design	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Construction	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Repair & Replace													
Design	\$	-	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Administration	\$	-	\$ -	\$ 135,611	\$ 144,729	\$ 1,138	\$ 310,899	\$ 1,138	\$ 1,138	\$ 1,138	\$ 1,138	\$ 473,950	\$ 1,138
Construction	\$	-	\$ -	\$ 1,356,111	\$ 1,447,291	\$ 11,375	\$ 3,108,994	\$ 11,375	\$ 11,375	\$ 11,375	\$ 11,375	\$ 4,739,500	\$ 11,375
Total	\$	-	\$ -	\$ 1,491,722	\$ 1,592,020	\$ 12,513	\$ 3,419,893	\$ 12,513	\$ 12,513	\$ 12,513	\$ 12,513	\$ 5,213,450	\$ 12,513
Total	\$	-	\$ 2,304,520	\$ 8,195,781	\$ 8,508,384	\$ 1,568,226	\$ 3,419,893	\$ 12,513	\$ 12,513	\$ 12,513	\$ 12,513	\$ 5,213,450	\$ 12,513
Stakeholders Resp.													
City of Wilsonville	\$	-	\$ 1,537,115	\$ 5,466,586	\$ 5,675,092	\$ 1,046,007	\$ 2,281,069	\$ 8,346	\$ 8,346	\$ 8,346	\$ 8,346	\$ 3,477,371	\$ 8,346
20 MGD Expansion	66.7%	\$ -	\$ 1,537,115	\$ 4,471,607	\$ 4,471,607	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Life Safety Repairs	66.7%	\$ -	\$ -	\$ -	\$ 18,681	\$ 392,293	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Seismic Retrofits	66.7%	\$ -	\$ -	\$ -	\$ 122,927	\$ 645,368	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
30 MGD Expansion	67.7%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Repair & Replace	66.7%	\$ -	\$ -	\$ 994,979	\$ 1,061,877	\$ 8,346	\$ 2,281,069	\$ 8,346	\$ 8,346	\$ 8,346	\$ 8,346	\$ 3,477,371	\$ 8,346
City of Sherwood	\$	-	\$ 767,405	\$ 2,729,195	\$ 2,833,292	\$ 522,219	\$ 1,138,825	\$ 4,167	\$ 4,167	\$ 4,167	\$ 4,167	\$ 1,736,079	\$ 4,167
20 MGD Expansion	33.3%	\$ -	\$ 767,405	\$ 2,232,452	\$ 2,232,452	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Life Safety Repairs	33.3%	\$ -	\$ -	\$ -	\$ 9,326	\$ 195,853	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Seismic Retrofits	33.3%	\$ -	\$ -	\$ -	\$ 61,371	\$ 322,200	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
30 MGD Expansion	32.3%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Repair & Replace	33.3%	\$ -	\$ -	\$ 496,743	\$ 530,143	\$ 4,167	\$ 1,138,825	\$ 4,167	\$ 4,167	\$ 4,167	\$ 4,167	\$ 1,736,079	\$ 4,167


Notes

- 1 For 20 MGD Expansion, Life Safety Repairs, Seismic Retrofits, and 30 MGD Expansion projects, all design costs were assumed to be in the first year of the project and the construction costs were split over the remaining project years.
- 2 For the Repair and Replace projects, the design and construction costs were assumed to be in the project completion year.


**WILLAMETTE RIVER WATER TREATMENT PLANT - 2017 MASTER PLAN UPDATE
CAPITAL IMPROVEMENT PLAN UPDATE**

Financial Summary - CIP Costs in \$2017											
PROJECT	FY	2029	2030	2031	2032	2033	2034	2035	2036		TOTAL
20 MGD Expansion											
Design	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	1,885,517
Administration	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	1,257,011
Construction	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	12,570,110
Total	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	15,712,638
Life-Safety Repairs											
Design	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
Administration	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	56,014
Construction	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	560,139
Total	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	616,153
Seismic Retrofits											
Design	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	138,224
Administration	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	92,149
Construction	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	921,493
Total	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	1,151,866
30 MGD Expansion											
Design	\$	- \$	- \$	4,636,647	- \$	- \$	- \$	- \$	- \$	- \$	4,636,647
Administration	\$	- \$	- \$	1,030,366	1,030,366	1,030,366	- \$	- \$	- \$	- \$	3,091,098
Construction	\$	- \$	- \$	- \$	15,455,489	15,455,489	- \$	- \$	- \$	- \$	30,910,978
Total	\$	- \$	- \$	5,667,013	16,485,855	16,485,855	- \$	- \$	- \$	- \$	38,638,723
Repair & Replace											
Design	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
Administration	\$	1,138	1,138	1,138	225,138	1,138	1,138	1,138	308,663	- \$	1,612,641
Construction	\$	11,375	11,375	11,375	2,251,375	11,375	11,375	11,375	3,086,634	- \$	16,126,405
Total	\$	12,513	12,513	12,513	2,476,513	12,513	12,513	12,513	3,395,297	- \$	17,739,046
Total	\$	12,513	12,513	5,679,525	18,962,367	16,498,367	12,513	12,513	3,395,297	- \$	73,858,425
Stakeholders	Resp.										
City of Wilsonville		\$ 8,346	\$ 8,346	\$ 3,844,913	\$ 12,812,758	\$ 11,169,270	\$ 8,346	\$ 8,346	\$ 2,264,663		\$ 48,112,842
20 MGD Expansion	66.7%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		\$ 8,943,214
Life Safety Repairs	66.7%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		\$ 410,974
Seismic Retrofits	66.7%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		\$ 768,295
30 MGD Expansion	67.7%	\$ -	\$ -	\$ 3,836,568	\$ 11,160,924	\$ 11,160,924	\$ -	\$ -	\$ -		\$ 26,158,415
Repair & Replace	66.7%	\$ 8,346	\$ 8,346	\$ 8,346	\$ 1,651,834	\$ 8,346	\$ 8,346	\$ 8,346	\$ 2,264,663		\$ 11,831,943
City of Sherwood		\$ 4,167	\$ 4,167	\$ 1,834,612	\$ 6,149,610	\$ 5,329,098	\$ 4,167	\$ 4,167	\$ 1,130,634		\$ 23,441,063
20 MGD Expansion	33.3%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		\$ 4,464,903
Life Safety Repairs	33.3%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		\$ 205,179
Seismic Retrofits	33.3%	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		\$ 383,571
30 MGD Expansion	32.3%	\$ -	\$ -	\$ 1,830,445	\$ 5,324,931	\$ 5,324,931	\$ -	\$ -	\$ -		\$ 12,480,307
Repair & Replace	33.3%	\$ 4,167	\$ 4,167	\$ 4,167	\$ 824,679	\$ 4,167	\$ 4,167	\$ 4,167	\$ 1,130,634		\$ 5,907,102
Notes											
1 For 20 MGD Expansion, Life Safety Repair											
2 For the Repair and Replace projects, the d											


WRWTP 2017 MPU - Near Term CIP (By Project)




WRWTP 2017 MPU -
Total CIP (By Project)




WRWTP 2017 MPU - Near Term CIP (By Partner)




WRWTP 2017 MPU -
Total CIP (By Partner)




WRWTP 2017 MPU -
Near Term CIP (City of Wilsonville)



WRWTP 2017 MPU - Total CIP (City of Wilsonville)



WRWTP 2017 MPU - Near Term CIP (City of Sherwood)



WRWTP 2017 MPU -
Total CIP (City of Sherwood)

